

400/220/110/66 kV TRANSMISSION OUTAGES : 18.08.2020 to 24.08.2020

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	18-Aug-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	18:46 (19.07.0.2020)			LINE OPEN:LINE CLEAR AVALIED
2	18-Aug-20	BAGALKOT	110	110/11KV, HV1	YELPARAHATTI_110	12:18	12:49	00:31	LINE CLAE AVALIED
3	18-Aug-20	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	15:58	17:43	01:45	LINE CLAE AVALIED
4	18-Aug-20	BAGALKOT	110	110/11KV, HV1	SIDDAPUR_110	10:34	10:37	00:03	LINE CLAE AVALIED
5	18-Aug-20	BAGALKOT	110	110/11KV, HV1	VAJRAMATTI_110	11:41	13:34	01:53	LINE CLAE AVALIED
6	18-Aug-20	BAGALKOT	110	110/11KV, HV1	VAJRAMATTI_110	13:42	17:40	03:58	TRANSFORMER FAULT
7	18-Aug-20	BAGALKOT	110	110/11KV, HV1	SHIROL_110	12:41	14:58	02:17	LINE CLAE AVALIED
8	18-Aug-20	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	13:37	18:45	05:08	LINE CLAE AVALIED
9	18-Aug-20	BAGALKOT	110	110/11KV,HV1	BEDI_110	11:23	12:40	01:17	LINE CLAE AVALIED
10	18-Aug-20	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	10:04	11:24	01:20	LINE CLAE AVALIED
11	18-Aug-20	BAGALKOT	110	110/11KV,HV2	HIDIKAL_110	14:02	14:23	00:21	LINE CLAE AVALIED
12	18-Aug-20	BAGALKOT	110	110/33KV,HV2	ANKOLA_110,MASTIKATTA_33,SEABIR D 33	10:27	16:15	05:48	LINE CLAE AVALIED
13	18-Aug-20	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
14	18-Aug-20	BAGALKOT	110	220/110KV, LV2	RANEENNUR_220	11:04 (18.08.2020)			TRANSFORMER OPEN: LINE CLEAR AVALIED
15	18-Aug-20	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	00:11	09:06	08:55	HAND TRIPPED
16	18-Aug-20	BAGALKOT	110	AB-SOLAR-BELLATTI	BELLATTI_110	06:16	19:20	13:04	LINE CLAE AVALIED
17	18-Aug-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN:LINE CLEAR AVALIED
18	18-Aug-20	BAGALKOT	110	ENERCON2-BELLATTI	BELLATTI_110	06:16	19:42	13:26	LINE CLAE AVALIED
19	18-Aug-20	BAGALKOT	110	GADAG220-LAXMESHWAR	LAXMESHWAR_110	06:14	18:54	12:40	NFBC ISSUED
20	18-Aug-20	BAGALKOT	110	GADAG220-SHIRAHATTI	SHIRAHATTI_110	06:02	18:59	12:57	NFBC ISSUED
21	18-Aug-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN:LINE CLEAR AVALIED
22	18-Aug-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:0 (21.07.2020)			LINE OPEN:LINE CLEAR AVALIED
23	18-Aug-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
24	18-Aug-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN:LINE CLEAR AVALIED
25	18-Aug-20	BAGALKOT	110	MAHALINGAPUR220- JAMKHANDI	JAMKHANDI_110	17:09	17:26	00:17	LINE CLAE AVALIED
26	18-Aug-20	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30 (01.08.2020)			LINE OPEN:LINE CLEAR AVALIED
27	18-Aug-20	BAGALKOT	110	VAJRAMATTI220- VAJRAMATTI	VAJRAMATTI_110	11:41	11:45	00:04	HAND TRIPPED
28	18-Aug-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN:LINE CLEAR AVALIED
29	18-Aug-20	BAGALKOT	110	VISHWANATH SUGAR- HUKKERI	HUKKERI_110	15:34	17:10	01:36	LINE CLAE AVALIED
30	18-Aug-20	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	12:49	20:42	07:53	LINE FAULT
31	18-Aug-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN: LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
32	18-Aug-20	BAGALKOT	220	BAGEWADI-ATRIA 2	STATION NOT AFFECTED BAGEWADI_220	16:26 (17.08.2020)			LINE OPEN:LINE CLEAR AVAILED
33	18-Aug-20	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	17:26 (24.07.2020)			LOAD CURTAILMENT
34	18-Aug-20	BAGALKOT	220	BELGAUM- CHIKKODI2	BELGAUM_220	21:12 (17.08.2020)	11:31 (18.08.2020)	14:19	LINE CHARGED
35	18-Aug-20	BAGALKOT	220	BELGAUM- NARENDRA2 (KANABARGI2)	STATION NOT AFFECTED BELGAUM_220	22:18 (04.08.2020)			LINE OPEN:LINE CLEAR AVAILED
36	18-Aug-20	BAGALKOT	220	BELLIGAVI (SHIRALKOPPA)- RANEENNUR	RANEENNUR_220	11:07	18:54	07:47	LINE CLAE AVALIED
37	18-Aug-20	BAGALKOT	220	BIDNAL-NARENDRA	BIDNAL_220	12:02	14:56	02:54	NFBC ISSUED
38	18-Aug-20	BAGALKOT	220	GADAG-HARTHI1	GADAG_220	12:19 (17.08.2020)			LOAD CURTAILMENT
39	18-Aug-20	BAGALKOT	220	GUTTUR- RANEENNUR	RANEENNUR_220	11:20	18:52	07:32	LINE CLAE AVALIED
40	18-Aug-20	BAGALKOT	220	GUTTUR2-NARENDRA	HAVERI_220	13:17	13:48	00:31	HAND TRIPPED
41	18-Aug-20	BAGALKOT	220	GUTTUR2-NARENDRA	HAVERI_220	22:18	23:47	01:29	LINE CLAE AVALIED
42	18-Aug-20	BAGALKOT	220	HAVERI- NARENDRA	HAVERI_220	11:26 (18.08.2020)			LINE OPEN:LINE CLEAR AVAILED
43	18-Aug-20	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	16:57 (10.08.2020)			LINE OPEN:LINE CLEAR AVAILED
44	18-Aug-20	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	18:35 (07.08.2020)			LINE OPEN: LINE FAULT
45	18-Aug-20	BAGALKOT	220	MK HUBLI220-NARENDRA1	STATION NOT AFFECTED MK HUBLI_220	22:57 (15.08.2020)	10:41 (18.08.2020)	11:44	LOAD CURTAILMENT
46	18-Aug-20	BAGALKOT	400	DHONI-GUDDADAHALLI	DHONI_400	3:25 (16.08.2020)			LOAD CURTAILMENT
47	18-Aug-20	BENGALURU	220	HV2	SOMANAHALLI 220	10:25	10:45	00:20	LOAD CHANGE OVER
48	18-Aug-20	BENGALURU	220	HV2	SOMANAHALLI 220	17:30	17:34	00:04	LOAD CHANGE OVER
49	18-Aug-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN: LINE FAULT
50	18-Aug-20	BENGALURU	220	SOMANAHALLI 220 - HSR LAYOUT 220	NO STATION AFFECTED	06:54	14:16	07:22	LINE FAULT
51	18-Aug-20	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 1 & 2	NO STATION AFFECTED	10:16(17/08/2020)			LINE OPEN:LINE CLEAR AVAILED
52	18-Aug-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
53	18-Aug-20	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	16:56	17:06	00:10	LINE FAULT
54	18-Aug-20	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	10:18	11:36	01:18	LINE FAULT
55	18-Aug-20	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	15:52	16:19	00:27	LINE FAULT
56	18-Aug-20	BENGALURU	66	HV1	HANUMANTHNAGARA	18:14	18:18	00:04	TRANSFORMER FAULT
57	18-Aug-20	BENGALURU	66	HV1	MEI LAYOUT	12:04	12:36	00:32	TRANSFORMER FAULT
58	18-Aug-20	BENGALURU	66	HV1	KANAKAPURA 66	11:02	11:05	00:02	LINE CLAE AVALIED
59	18-Aug-20	BENGALURU	66	HV2	SIDDALAGATTA	13:58	14:21	00:22	LINE CLAE AVALIED
60	18-Aug-20	BENGALURU	66	HV3	NELEMANGALA 66	11:36	12:14	00:38	LINE CLAE AVALIED
61	18-Aug-20	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	15:50	15:54	00:04	LOAD CHANGE OVER
62	18-Aug-20	BENGALURU	66	NANDINI LAYOUT - SRS 220	NANDINI LAYOUT	14:10	14:23	00:13	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
63	18-Aug-20	BENGALURU	66	NIMHANS 220 - BMTc	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN: LINE FAULT
64	18-Aug-20	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	SOUTH CITY	10:25	10:50	00:25	LOAD CHANGE OVER
65	18-Aug-20	BENGALURU	66	SOMANAHALLI 220 - JIGANI 1	SOUTH CITY	17:15	17:40	00:25	LOAD CHANGE OVER
66	18-Aug-20	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	10:25	10:50	00:25	LOAD CHANGE OVER
67	18-Aug-20	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	17:15	17:40	00:25	LOAD CHANGE OVER
68	18-Aug-20	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	10:25	10:50	00:25	LOAD CHANGE OVER
69	18-Aug-20	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	17:15	17:40	00:25	LOAD CHANGE OVER
70	18-Aug-20	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	ISKON, SUBRAMANYAPURA 66	10:25	10:50	00:25	LOAD CHANGE OVER
71	18-Aug-20	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	ISKON, SUBRAMANYAPURA 66	17:15	17:40	00:25	LOAD CHANGE OVER
72	18-Aug-20	BENGALURU	66	SRS PEENYA 220 - NANDINI LAYOUT	NO STATION AFFECTED	14:10	15:40	01:30	LINE FAULT
73	18-Aug-20	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 1	HALAGUR,HONNIGANAHALLI	10:37	10:53	00:16	LINE FAULT
74	18-Aug-20	BENGALURU	66	YELDUR - DALASNUR	YELDUR	10:00	13:59	03:59	LINE CLAE AVAILED
75	18-Aug-20	GULBARGA	66	HV1	GUDEKOTE_66	11:40	13:55	02:15	LINE CLAE AVAILED
76	18-Aug-20	GULBARGA	66	HV1	HANASI_66	13:40	14:40	01:00	LINE CLAE AVAILED
77	18-Aug-20	GULBARGA	110	CHINCHOLI-MANEKHALLI	CHINCHOLI_110	16:30	17:40	01:10	LINE CLAE AVAILED
78	18-Aug-20	GULBARGA	110	HV1	MANVI_110	20:05	20:26	00:21	LINE CLAE AVAILED
79	18-Aug-20	GULBARGA	110	KUSTAGI-KUSTAGISOLAR_IPP	KUSTAGI_220	06:00	06:35	00:35	LINE FAULT
80	18-Aug-20	GULBARGA	110	RAICHUR-SHAHBAD1	GABUR_110, DEODURGA_110	00:20	01:10	00:50	LINE CLAE AVAILED
81	18-Aug-20	GULBARGA	110	SHAHPUR-KHANAPUR	KHANAPUR_110, SAIDAPUR_110, WADAGERA_110, SANNATI_110, NALWAR_110	04:05	04:17	00:12	LINE FAULT
82	18-Aug-20	GULBARGA	110	SHAHPUR-SHORAPUR	SHORAPUR_110	12:09	12:12	00:03	LINE CLAE AVAILED
83	18-Aug-20	GULBARGA	220	HUMNABAD-HULBARGA1	HALBURGA_220	05:59	06:18	00:19	LINE FAULT
84	18-Aug-20	GULBARGA	220	HV1	KUSTAGI_220	10:20	10:40	00:20	TRANSFORMER FAULT
85	18-Aug-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN:LINE CLEAR AVAILED
86	18-Aug-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN: LINE FAULT
87	18-Aug-20	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	18:20(17.8.2020)	12:10(18.8.2020)	17:50HRS	LINE CHARGED
88	18-Aug-20	HASSAN	110	HV2	BRAHMAVARA_110	11:25	11:44	00:19	HAND TRIPPED
89	18-Aug-20	HASSAN	110	HV2	KADUR_220	10:05	13:35	03:30	LINE CLAE AVAILED
90	18-Aug-20	HASSAN	110	HV3	SAGARA_110	00:16	01:17	01:01	TRANSFORMER FAULT
91	18-Aug-20	HASSAN	110	HV3	SAGARA_110	11:00	12:01	01:01	LINE CLAE AVAILED
92	18-Aug-20	HASSAN	110	HV4	MANIPAL_110	10:15	11:29	01:14	LINE CLAE AVAILED
93	18-Aug-20	HASSAN	110	JOG-NK2	NO STN AFFECTED	23:36 (7.08.2020)			LINE OPEN:LINE CLEAR AVAILED
94	18-Aug-20	HASSAN	110	KAVOOR-BAIKAMPADY	KAVOOR_220	16:13	16:17	00:04	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
95	18-Aug-20	HASSAN	110	MADHUV-KUNDAPURA	MADHUVANA_110	09:26	17:48	08:22	LINE CLAE AVAILED
96	18-Aug-20	HASSAN	110	NITUR110-MANIPAL	NITTUR_110	13:32	13:33	00:01	HAND TRIPPED
97	18-Aug-20	HASSAN	110	PUTTUR-KARAYA	PUTTUR_220	10:59	13:04	02:05	LINE CLAE AVAILED
98	18-Aug-20	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	18:07	18:56	00:49	MAIN SUPPLY FAILURE
99	18-Aug-20	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	18:07	18:56	00:49	MAIN SUPPLY FAILURE
100	18-Aug-20	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	18:07	18:56	00:49	MAIN SUPPLY FAILURE
101	18-Aug-20	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	18:07 (18.08.2020)			LINE OPEN: LINE FAULT
102	18-Aug-20	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	18:07 (18.08.2020)			LINE OPEN: LINE FAULT
103	18-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	22:37 (14.08.2020)	10:05 (18.08.2020)	83:28 hrs	LINE CHARGED
104	18-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:06 (18.08.2020)			LINE OPEN:LINE CLEAR AVAILED
105	18-Aug-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	16:42 (17.08.2020)			LINE OPEN:LINE CLEAR AVAILED
106	18-Aug-20	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	12:39	13:00	00:21	LINE FAULT
107	18-Aug-20	HASSAN	66	HASSN220-R R NAGAR	HASSAN_220	15:54	17:07	01:13	LINE CLAE AVAILED
108	18-Aug-20	HASSAN	66	HV1	DODDAKADANUR_66	13:30	16:10	02:40	LINE CLAE AVAILED
109	18-Aug-20	HASSAN	66	HV1	HIEMANGALUR_66	14:06	16:03	01:57	LINE CLAE AVAILED
110	18-Aug-20	HASSAN	66	HV2	HOLEHONNUR_66	12:24	14:09	01:45	LINE CLAE AVAILED
111	18-Aug-20	HASSAN	66	HV2	RAMNATHPURA_66	04:17	13:32	09:15	TRANSFORMER FAULT
112	18-Aug-20	MYSURU	66	NANJANGUDU-THANDYA	THANDYA_66	09:20	17:34	08:14	NFBC ISSUED
113	18-Aug-20	MYSURU	220	HV2	KUSHALNAGARA_220	15:06	15:44	00:38	LINE CLAE AVAILED
114	18-Aug-20	MYSURU	66	SINDUVALLIPURA-BEGUR 220KV	SINDHUVALLI_66	10:00	18:45	08:45	LINE CLAE AVAILED
115	18-Aug-20	MYSURU	66	DODDARAYAPETE-KUNTHUR	NO STATIONS INTERRUPTED	15:32	18:38	03:06	LINE CLAE AVAILED
116	18-Aug-20	MYSURU	66	HOOTAGALLI-BASTIPURA-1	NO STATIONS INTERRUPTED	10:29	14:31	04:02	LINE CLAE AVAILED
117	18-Aug-20	MYSURU	66	HV1	BASARALU_66	15:54	16:10	00:15	LINE CLAE AVAILED
118	18-Aug-20	MYSURU	66	HV1	HALAGUR_66	11:08	12:24	01:16	LINE CLAE AVAILED
119	18-Aug-20	MYSURU	66	HV1	KADAKOLA_220	10:20	11:45	01:25	LINE CLAE AVAILED
120	18-Aug-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
121	18-Aug-20	MYSURU	66	HV2	BASARALU_66	13:00	13:51	00:51	LINE CLAE AVAILED
122	18-Aug-20	MYSURU	66	HV2	BASARALU_66	15:54	16:10	00:15	LINE CLAE AVAILED
123	18-Aug-20	MYSURU	66	HV2	KADAKOLA_220	11:32	12:48	01:16	LINE CLAE AVAILED
124	18-Aug-20	MYSURU	66	HV2	SANTHEBACHALLI_66	12:17	12:26	00:08	HAND TRIPPED
125	18-Aug-20	MYSURU	66	HV2	SANTHEBACHALLI_66	13:02	13:10	00:08	HAND TRIPPED
126	18-Aug-20	MYSURU	66	HV2	SANTHEMARAHALLI_66	13:03	13:25	00:22	LINE CLAE AVAILED
127	18-Aug-20	MYSURU	66	KUSHALNAGARA 220-PERIYAPATNA-1	PERIYAPATNA_66 PONNAMPET_66 VIRAJPET_66 HANAGODU_66	07:17	07:30	00:13	LINE FAULT
128	18-Aug-20	MYSURU	66	KUSHALNAGARA 220-PERIYAPATNA-2	BYLUKUPPE_66	07:17	07:30	00:13	LINE FAULT
129	18-Aug-20	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS INTERRUPTED	07:52	08:06	00:14	LINE FAULT
130	18-Aug-20	MYSURU	66	NANJANGUDU-KADKOLA 1	NANJANGUDU_66	09:25	13:30	04:05	LINE CLAE AVAILED
131	18-Aug-20	MYSURU	66	NANJANGUDU-SINDHUVALIPURA	NANJANGUDU_66	09:09	15:35	06:25	LINE CLAE AVAILED
132	18-Aug-20	MYSURU	66	SATHEGALA-HEBBANI	SATHEGALA_66	10:05	17:36	07:31	LINE CLAE AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
133	18-Aug-20	MYSURU	66	SINDUVALLY-KADKOLA	NO STATIONS INTERRUPTED	7:40 (09.08.2020)	12:21	220:41 HRS	LINE CHARGED
134	18-Aug-20	MYSURU	66	HOOTAGALLI-VIJAYANAGARA	VAJAMANGALA_220 BANNIMANTAP_66	12:26 (17/08/2020)			LINE OPEN: LINE FAULT
135	18-Aug-20	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	YEDIYUR_66	13:42	13:52	00:09	LINE FAULT
136	18-Aug-20	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	13:15	13:28	00:13	HAND TRIPPED
137	18-Aug-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	18:28	18:34	00:06	LINE FAULT
138	18-Aug-20	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66, CHANNAGIRI_66, BASAVAPATNA_66	01:26	01:31	00:05	LINE FAULT
139	18-Aug-20	TUMKUR	66	MADHUGIRI 220KV- SIRA 1	SIRA_66, GULIGENAHALLI_66,	15:56	16:21	00:25	HAND TRIPPED
140	18-Aug-20	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	16:17	16:21	00:04	HAND TRIPPED
141	18-Aug-20	TUMKUR	66	NEELAGUNDA 220KV-HULUVAGALU	HALUVAGALU_66	04:57	05:17	00:20	LINE FAULT
142	18-Aug-20	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66, HDPURA_66, RAMAGIRI_66	14:59	15:18	00:18	LINE FAULT
143	18-Aug-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
144	18-Aug-20	TUMKUR	66	TR-2	GARAGA_66	05:14	07:07	01:52	TRANSFORMER FAULT
145	18-Aug-20	TUMKUR	110	TR-1	KGTEMPLE_110	10:58	11:00	00:02	LINE CLAE AVAILED
146	18-Aug-20	TUMKUR	110	TR-1	KGTEMPLE_110	12:34	13:25	00:50	LINE CLAE AVAILED
147	18-Aug-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT
148	18-Aug-20	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	04:57	12:45	07:47	LINE FAULT
149	18-Aug-20	TUMKUR	220	NEELAGUNDA220KV- GUTTUR 220KV	NEELAGUNDA_220	04:57	12:36	07:39	LINE FAULT
150	18-Aug-20	TUMKUR	220	TR-1	MADHUGIRI_220	12:14	13:25	01:10	LINE CLAE AVAILED
1	19-Aug-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020)			LINE OPEN:LINE CLEAR AVAILED
2	19-Aug-20	BAGALKOT	110	110/11KV, HV1	AREMALLAPUR_110,	15:30	15:45	00:15	TRANSFORMER FAULT
3	19-Aug-20	BAGALKOT	110	110/11KV, HV1	VAJRAMATTI_110	17:37	18:15	00:38	LINE CLAE AVAILED
4	19-Aug-20	BAGALKOT	110	110/11KV, HV1	VAJRAMATTI_110	17:37	18:15	00:38	LINE CLAE AVAILED
5	19-Aug-20	BAGALKOT	110	110/11KV, HV1	NANADI_110	13:44	14:59	01:15	LINE CLAE AVAILED
6	19-Aug-20	BAGALKOT	110	110/11KV, HV1	GADAG_110	05:31	07:58	02:27	LINE CLAE AVAILED
7	19-Aug-20	BAGALKOT	110	110/11KV, HV2	MK HUBLI_110	14:25	14:35	00:10	HAND TRIPPED
8	19-Aug-20	BAGALKOT	110	110/11KV, HV4(HV3)	MK HUBLI_110	14:57	15:00	00:03	HAND TRIPPED
9	19-Aug-20	BAGALKOT	110	110/33KV, HV1	STATION NOT EFFECTED BELGUAM_110, FORT_33, RM2_33, SADASHIVANAGAR_33 & KLE_33	15:29	16:21	00:52	LINE CLAE AVAILED
10	19-Aug-20	BAGALKOT	110	110/33KV, HV2	STATION NOT EFFECTED BELGUAM_110, FORT_33, RM2_33, SADASHIVANAGAR_33 & KLE_33	16:22	17:14	00:52	LINE CLAE AVAILED
11	19-Aug-20	BAGALKOT	110	110/33KV, HV3	AREMALLAPUR_110, CHALAGERI_33	15:30	15:45	00:15	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
12	19-Aug-20	BAGALKOT	110	110/33KV,HV1&HV2	MURDESHWAR_110,BATKAL_33,KASARKOD_33	10:43	12:16	01:33	LINE CLAE AVAILED
13	19-Aug-20	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
14	19-Aug-20	BAGALKOT	110	220/110,LV1	MK HUBLI_220	23:08 (19.08.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
15	19-Aug-20	BAGALKOT	110	220/110,LV2	MK HUBLI_220	21:22 (19.08.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
16	19-Aug-20	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED RANEENNUR_220	11:04 (18.08.2020)	18:53 (18.08.2020)	07:49	TRANSFORMER CHARGED
17	19-Aug-20	BAGALKOT	110	AMBEWADI-SUPA1&2	AMBEWADI_220	09:23	10:11	00:48	LINE CLAE AVAILED
18	19-Aug-20	BAGALKOT	110	BELAGAVI220-KANABARGI LAYOUT	KANABARGI LAYOUT_110	09:30	09:33	00:03	LINE CLAE AVAILED
19	19-Aug-20	BAGALKOT	110	BELGAUM220-KANABARGI LAYOUT	KANABARGI LAYOUT_110	10:50	12:54	02:04	LINE CLAE AVAILED
20	19-Aug-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)	10:40 (19:08:2020)	19:24	LINE CHARGED
21	19-Aug-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN:LINE CLEAR AVAILED
22	19-Aug-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN:LINE CLEAR AVAILED
23	19-Aug-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:0 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
24	19-Aug-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
25	19-Aug-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
26	19-Aug-20	BAGALKOT	110	RANEENNUR-BYADAGI	BYADAGI_110	12:25	12:49	00:24	LINE CLAE AVAILED
27	19-Aug-20	BAGALKOT	110	RANEENNUR-SAVANUR	SAVANUR_110	05:20	05:39	00:19	LINE FAULT
28	19-Aug-20	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
29	19-Aug-20	BAGALKOT	110	SULTANPUR(HIDIKAL)-ITNAL	ITNAL_110	12:25	12:38	00:13	LINE FAULT
30	19-Aug-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
31	19-Aug-20	BAGALKOT	220	220/110,HV1,LV1	MK HUBLI_220	00:42	09:22	08:40	HAND TRIPPED
32	19-Aug-20	BAGALKOT	220	220/110,HV2,LV2	MK HUBLI_220	15:40	20:09	04:29	LINE CLAE AVAILED
33	19-Aug-20	BAGALKOT	220	AMBEWADI-BIDNAL	BIDNAL_220	15:13	16:55	01:42	LINE CLAE AVAILED
34	19-Aug-20	BAGALKOT	220	AMBEWADI-NARENDRA 1&2	AMBEWADI_220	10:04	15:05	05:01	LINE CLAE AVAILED
35	19-Aug-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN: LINE FAULT
36	19-Aug-20	BAGALKOT	220	BAGEWADI-ATRIA 2	STATION NOT AFFECTED BAGEWADI_220	16:26 (17.08.2020)			LINE OPEN:LINE CLEAR AVAILED
37	19-Aug-20	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	17:26 (24.07.2020)			LOAD CURTAILMENT
38	19-Aug-20	BAGALKOT	220	BAGEWADI-LINGASUR1	BAGEWADI_220	13:57	14:00	00:03	LINE FAULT
39	19-Aug-20	BAGALKOT	220	BELGAUM- NARENDRA2 (KANABARGI2)	STATION NOT AFFECTED BELGAUM_220	22:18 (04.08.2020)			LINE OPEN:LINE CLEAR AVAILED
40	19-Aug-20	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	00:14 (19.08.2020)			LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
41	19-Aug-20	BAGALKOT	220	CHIKKODI-BELGAUM	CHIKKODI_220	23:44 (19.08.2020)			LOAD CURTAILMENT
42	19-Aug-20	BAGALKOT	220	GADAG-HARTHI1	GADAG_220	12:19 (17.08.2020)			LOAD CURTAILMENT
43	19-Aug-20	BAGALKOT	220	HAVERI- NARENDRA	HAVERI_220	11:26 (18.08.2020)	17:51 (19.08.2020)	06:25	LINE CHARGED
44	19-Aug-20	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	16:57 (10.08.2020)			LINE OPEN:LINE CLEAR AVALIED
45	19-Aug-20	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	18:35 (07.08.2020)			LINE OPEN: LINE FAULT
46	19-Aug-20	BAGALKOT	400	DHONI-GUDDADAHALLI	DHONI_400	3:25 (16.08.2020)	9:33 (19.08.2020)	06:08	LOAD CURTAILMENT
47	19-Aug-20	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 1 & 2	NO STATION AFFECTED	10:16(17/08/2020)			LINE OPEN:LINE CLEAR AVALIED
48	19-Aug-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
49	19-Aug-20	BENGALURU	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSURU RAMAPURA, NITRALLI	12:36	13:13	00:37	MAIN SUPPLY FAILURE
50	19-Aug-20	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	KODIGENAHALLI, ID HALLI	12:36	13:13	00:37	MAIN SUPPLY FAILURE
51	19-Aug-20	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKALLU, D PALYA, GUDIBANDE, SOMENAHALLI	12:36	13:13	00:37	MAIN SUPPLY FAILURE
52	19-Aug-20	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	11:21	11:30	00:08	LOAD CHANGE OVER
53	19-Aug-20	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	12:04	12:10	00:06	LOAD CHANGE OVER
54	19-Aug-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	06:03	07:00	00:56	LINE FAULT
55	19-Aug-20	BENGALURU	66	HOSUR RAMAPURA - GOWRIBIDANUR 220	HOSURU RAMAPURA, NITRALLI	12:30	13:08	00:38	MAIN SUPPLY FAILURE
56	19-Aug-20	BENGALURU	66	HV1	KADUBISANAHALLI	13:15	15:50	02:35	LINE CLAE AVALIED
57	19-Aug-20	BENGALURU	66	HV1	MITTEMARI 220	17:14	17:55	00:40	TRANSFORMER FAULT
58	19-Aug-20	BENGALURU	66	HV1	BAIRAKURU	12:30	15:20	02:50	LINE CLAE AVALIED
59	19-Aug-20	BENGALURU	66	HV2	AREHALLI	14:44	14:47	00:03	LINE CLAE AVALIED
60	19-Aug-20	BENGALURU	66	HV2	KADUGODI	12:15	12:22	00:07	LINE CLAE AVALIED
61	19-Aug-20	BENGALURU	66	HV2	KADUGODI	16:48	17:35	00:47	LINE CLAE AVALIED
62	19-Aug-20	BENGALURU	66	HV2	KADUBISANAHALLI	13:15	13:39	00:24	LINE CLAE AVALIED
63	19-Aug-20	BENGALURU	66	HV2	BANGARPETE	10:47	12:10	01:23	LINE CLAE AVALIED
64	19-Aug-20	BENGALURU	66	HV2	BANGARPETE	13:20	17:40	04:20	LINE CLAE AVALIED
65	19-Aug-20	BENGALURU	66	HV2	MULBAGLU	11:32	11:45	00:12	LINE CLAE AVALIED
66	19-Aug-20	BENGALURU	66	HV2	BAIRAKURU	15:20	15:25	00:05	LINE CLAE AVALIED
67	19-Aug-20	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	13:10	13:20	00:10	LOAD CHANGE OVER
68	19-Aug-20	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	10:50	10:55	00:05	LOAD CHANGE OVER
69	19-Aug-20	BENGALURU	66	MELLAHALLI - ADANI SOLAR (IPP)	NO STATION AFFECTED	05:00	06:16	01:16	LINE FAULT
70	19-Aug-20	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN: LINE FAULT
71	19-Aug-20	BENGALURU	66	RAMANAGARA - KOTIPURA 220	RAMANAGARA	12:58	14:14	01:16	LINE CLAE AVALIED
72	19-Aug-20	BENGALURU	66	TK HALLI 220 - SHIMSHA 1	T K HALLI 220	18:49	19:04	00:15	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
73	19-Aug-20	BENGALURU	220	HV3	GOWRIBIDANUR 220	12:36	13:13	00:37	TRANSFORMER FAULT
74	19-Aug-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN: LINE FAULT
75	19-Aug-20	GULBARGA	110	HALBURAGA-SANTHAPUR	SANTHAPUR_110, DONGARGOAN_110, KAMALNAGAR_110	18:43	18:49	00:06	LINE FAULT
76	19-Aug-20	GULBARGA	110	HALBURGA-KAMTHANA	KAMTHANA_110, HABSIKOTE_110	01:47	05:07	03:20	LINE FAULT
77	19-Aug-20	GULBARGA	110	HALBURGA-KAMTHANA	KAMTHANA_110, HABSIKOTE_110	06:40	07:05	00:25	LINE FAULT
78	19-Aug-20	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	04:40	05:31	00:51	LINE FAULT
79	19-Aug-20	GULBARGA	110	HV1	DEODURGA_110	12:05	13:35	01:30	LINE CLAE AVAILED
80	19-Aug-20	GULBARGA	110	HV1	KURKUNTA_110	17:35	17:50	00:15	LINE CLAE AVAILED
81	19-Aug-20	GULBARGA	110	SEDAM-GURUMITAKAL	GURUMITAKAL_110, KONKAL_110	00:08	00:16	00:08	LINE FAULT
82	19-Aug-20	GULBARGA	110	SEDAM-VICATSGAR CEMENTS	SEDAM-VICATSAGAR CEMENTS_IPP	23:08	23:16	00:08	LINE FAULT
83	19-Aug-20	GULBARGA	220	HUMNABAD-SEDAM1	HUMNABAD_220	04:40	04:58	00:18	LINE FAULT
84	19-Aug-20	GULBARGA	220	HUMNABAD-SEDAM2	HUMNABAD_220	04:40	05:26	00:46	LINE FAULT
85	19-Aug-20	GULBARGA	220	HV1, HV2	HUMNABAD_220	04:52	05:12	00:20	LINE CLAE AVAILED
86	19-Aug-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN:LINE CLEAR AVAILED
87	19-Aug-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN: LINE FAULT
88	19-Aug-20	GULBARGA	220	RAICHUR-JURALA2	RAICHUR_220	5:56(19.8.2020)			LINE OPEN: LINE FAULT
89	19-Aug-20	GULBARGA	220	RAICHUR-RTPS1	RAICHUR_220	13:57(19.8.2020)			LINE OPEN: LINE FAULT
90	19-Aug-20	HASSAN	66	CHANNARA-SHETTIHALLY	CHANNARAYAPATNA_66	12:01	12:44	00:43	LINE CLAE AVAILED
91	19-Aug-20	HASSAN	66	HV1	HANBALU_66	14:40	15:08	00:28	LINE CLAE AVAILED
92	19-Aug-20	HASSAN	66	HV1	HANBALU_66	16:33	17:12	00:39	LINE CLAE AVAILED
93	19-Aug-20	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	12:35	15:12	02:37	LINE CLAE AVAILED
94	19-Aug-20	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	12:06	15:12	03:06	LINE CLAE AVAILED
95	19-Aug-20	HASSAN	110	HALADY11-HIRIYADKA	HALADY_110	14:17	15:02	00:45	LINE CLAE AVAILED
96	19-Aug-20	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	14:19	15:02	00:43	NFBC ISSUED
97	19-Aug-20	HASSAN	110	HV1	SAGARA_110	21:42(19.08.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
98	19-Aug-20	HASSAN	110	HV1	KONAJE_110	10:12	14:34	04:22	LINE CLAE AVAILED
99	19-Aug-20	HASSAN	110	HV2	KONAJE_110	10:29	10:33	00:04	HAND TRIPPED
100	19-Aug-20	HASSAN	110	HV2	KONAJE_110	14:29	14:34	00:05	HAND TRIPPED
101	19-Aug-20	HASSAN	110	HV3	KONAJE_110	10:29	10:32	00:03	HAND TRIPPED
102	19-Aug-20	HASSAN	110	HV3	KONAJE_110	14:29	14:39	00:10	HAND TRIPPED
103	19-Aug-20	HASSAN	110	JOG-NK2	NO STN AFFECTED	23:36 (7.08.2020)			LINE OPEN:LINE CLEAR AVAILED
104	19-Aug-20	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	11:38	13:03	01:25	LINE CLAE AVAILED
105	19-Aug-20	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	11:39	12:54	01:15	NFBC ISSUED
106	19-Aug-20	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	10:47	14:18	03:31	LINE CLAE AVAILED
107	19-Aug-20	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	06:14	08:28	02:14	LINE FAULT
108	19-Aug-20	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	18:07 (18.08.2020)	14:56 (19.08.2020)	20:48 hrs	LINE CHARGED
109	19-Aug-20	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	18:07 (18.08.2020)	14:56 (19.08.2020)	20:48 hrs	LINE CHARGED
110	19-Aug-20	HASSAN	400	HASSAN40-TLGP400	SHANTHIGRAMA_400	10:34	16:42	06:08	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
111	19-Aug-20	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	10:34	16:42	06:08	LINE CLAE AVAILED
112	19-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:06 (18.08.2020)	7:07 (19.08.2020)	8:00 hrs	LINE CHARGED
113	19-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:44 (19.8.2020)			LINE OPEN:LINE CLEAR AVAILED
114	19-Aug-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	16:42 (17.08.2020)			LINE OPEN:LINE CLEAR AVAILED
115	19-Aug-20	MYSURU	66	BOGADHI-GIS	KALAMANDIRA_66	13:19	15:45	02:25	LINE FAULT
116	19-Aug-20	MYSURU	66	DK MAIDANA-KADKOLA	NO STATIONS EFFECTED	09:13	11:13	02:00	HAND TRIPPED
117	19-Aug-20	MYSURU	66	HARADANAHALLI (JAK)-LAXJEET	NO STATIONS EFFECTED	10:46	10:50	00:03	HAND TRIPPED
118	19-Aug-20	MYSURU	66	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	08:55	19:22	10:27	LINE CLAE AVAILED
119	19-Aug-20	MYSURU	66	HOOTAGALLI-HUNSUR	NO STATIONS EFFECTED	08:49	19:21	10:32	LINE CLAE AVAILED
120	19-Aug-20	MYSURU	66	HOOTAGALLI-KHB	NO STATIONS EFFECTED	08:55	19:15	10:20	LINE CLAE AVAILED
121	19-Aug-20	MYSURU	66	HOOTAGALLI-VIJAYANAGARA	VAJAMANGALA_220 BANNIMANTAP_66	12:26 (17/08/2020)	20:00	55:34 HRS	LINE CHARGED
122	19-Aug-20	MYSURU	66	HV1	HEBBAL_66	10:52	11:08	00:15	LINE CLAE AVAILED
123	19-Aug-20	MYSURU	66	HV1	HONNALLY_MYS_66	12:07	14:30	02:23	LINE CLAE AVAILED
124	19-Aug-20	MYSURU	66	HV1	KADAKOLA_220	09:54	09:58	00:04	TRANSFORMER FAULT
125	19-Aug-20	MYSURU	66	HV1	KADAKOLA_220	13:04	13:11	00:07	TRANSFORMER FAULT
126	19-Aug-20	MYSURU	66	HV1	K_HONNALGERE_66	11:15	12:35	01:20	LINE CLAE AVAILED
127	19-Aug-20	MYSURU	66	HV1	KUSHALNAGARA_220	15:15	15:52	00:36	LINE CLAE AVAILED
128	19-Aug-20	MYSURU	66	HV1	SATHEGALA_66	12:17	12:23	00:06	HAND TRIPPED
129	19-Aug-20	MYSURU	66	HV1	SFCSHIVA_66	18:49	19:10	00:20	TRANSFORMER FAULT
130	19-Aug-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
131	19-Aug-20	MYSURU	66	HV2	HANNUR_66	04:01	04:45	00:44	TRANSFORMER FAULT
132	19-Aug-20	MYSURU	66	HV2	HANNUR_66	14:25	16:00	01:35	LINE CLAE AVAILED
133	19-Aug-20	MYSURU	66	HV2	K_HONNALGERE_66	12:24	13:45	01:20	LINE CLAE AVAILED
134	19-Aug-20	MYSURU	66	HV2	KMDODDI_66	17:45	18:34	00:49	LINE CLAE AVAILED
135	19-Aug-20	MYSURU	66	HV2	SATHEGALA_66	12:06	12:16	00:09	HAND TRIPPED
136	19-Aug-20	MYSURU	66	HV2	SFCSHIVA_66	18:49	19:10	00:20	TRANSFORMER FAULT
137	19-Aug-20	MYSURU	66	HV3	SFCSHIVA_66	18:49	19:05	00:15	TRANSFORMER FAULT
138	19-Aug-20	MYSURU	66	HV4	SFCSHIVA_66	18:49	19:10	00:20	TRANSFORMER FAULT
139	19-Aug-20	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	NO STATIONS EFFECTED	08:46	13:29	04:43	HAND TRIPPED
140	19-Aug-20	MYSURU	66	KADAKOLA-DK MAIDANA	NO STATIONS EFFECTED	09:54	10:16	00:22	LINE FAULT
141	19-Aug-20	MYSURU	66	KADAKOLA-DK MAIDANA	NO STATIONS EFFECTED	13:04	13:11	00:06	LINE FAULT
142	19-Aug-20	MYSURU	66	KADAKOLA-MYSORE SOUTH	NO STATIONS EFFECTED	08:41	13:26	04:45	HAND TRIPPED
143	19-Aug-20	MYSURU	66	KADAKOLA-NANJANDUGU 1	NO STATIONS EFFECTED	11:11	13:32	02:21	HAND TRIPPED
144	19-Aug-20	MYSURU	66	KADAKOLA-RK NAGARA	NO STATIONS EFFECTED	08:35	13:27	04:52	HAND TRIPPED
145	19-Aug-20	MYSURU	66	KUNTHUR-DODDRAIPETE	JANNUR_66 MUGUR_66 THAYURU_66 TNARASIPURA_66 SANTHEMARAHALLI_66	06:00	06:11	00:10	LINE FAULT
146	19-Aug-20	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	06:28	06:33	00:05	LINE FAULT
147	19-Aug-20	MYSURU	66	SFC SIVA-10MW	NO STATIONS EFFECTED	18:55 (19.08.2020)			LINE OPEN: LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
148	19-Aug-20	MYSURU	66	SFC SIVA-5MW	NO STATIONS EFFECTED	18:55 (19.08.2020)			LINE OPEN: LINE FAULT
149	19-Aug-20	MYSURU	66	SFC SIVA-HEBBANI-9	NO STATIONS EFFECTED	18:49	19:28	00:39	LINE FAULT
150	19-Aug-20	MYSURU	66	SFC SIVA-PGL	NO STATIONS EFFECTED	18:49	19:05	00:15	LINE FAULT
151	19-Aug-20	MYSURU	66	THANDYA-NANJANGUDU	NO STATIONS EFFECTED	11:11	13:33	02:22	HAND TRIPPED
152	19-Aug-20	MYSURU	66	TUBINKERE-MC-2	NO STATIONS EFFECTED	06:08	06:15	00:06	LINE FAULT
153	19-Aug-20	MYSURU	66	TUBINKERE-MC-4	NO STATIONS EFFECTED	07:20	07:25	00:05	LINE FAULT
154	19-Aug-20	MYSURU	220	HV1	KADAKOLA_220	09:38	11:23	01:45	LINE CLAE AVAILED
155	19-Aug-20	MYSURU	220	HV2	KADAKOLA_220	11:24	13:15	01:50	LINE CLAE AVAILED
156	19-Aug-20	MYSURU	220	HV3	HOOTAGALLY_220	11:00	19:09	08:09	LINE CLAE AVAILED
157	19-Aug-20	TUMKUR	66	ANTHRASANAHALI 220KV-MELEKOTE	DODDASARANGI_66,MELKOTE_66, BADDIHALI_66, HONNUDIKE_66, HIREHALLY_66	05:39	07:27	01:48	LINE FAULT
158	19-Aug-20	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	06:25	06:31	00:06	LINE FAULT
159	19-Aug-20	TUMKUR	66	TR-1	HDPURA_66	06:25	06:27	00:01	TRANSFORMER FAULT
160	19-Aug-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
161	19-Aug-20	TUMKUR	66	TR-3	HARIYABBE_66	07:16	07:26	00:09	LINE CLAE AVAILED
162	19-Aug-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT
163	19-Aug-20	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	03:20	03:24	00:03	TRANSFORMER FAULT
164	20-Aug-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020)			LINE OPEN:LINE CLEAR AVAILED
165	20-Aug-20	BAGALKOT	110	110/11KV, HV1	KALADAGI_110	22:28	22:41	00:13	TRANSFORMER FAULT
166	20-Aug-20	BAGALKOT	110	110/11KV,HV 2	BAGALKOT_110	19:46	20:15	00:29	TRANSFORMER FAULT
167	20-Aug-20	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, KARADI_33, AMINGAD_33	18:34	18:43	00:09	TRANSFORMER FAULT
168	20-Aug-20	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
169	20-Aug-20	BAGALKOT	110	220/110,LV1	MK HUBLI_220	23:08 (19.08.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
170	20-Aug-20	BAGALKOT	110	220/110,LV2	MK HUBLI_220	21:22 (19.08.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
171	20-Aug-20	BAGALKOT	110	220/110KV, LV 1	ATHANI_220	03:35	03:57	00:22	TRANSFORMER FAULT
172	20-Aug-20	BAGALKOT	110	ATHANI22-ATHANI	ATHANI_110	15:18	15:53	00:35	LINE CLAE AVAILED
173	20-Aug-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN:LINE CLEAR AVAILED
174	20-Aug-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN:LINE CLEAR AVAILED
175	20-Aug-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:0 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
176	20-Aug-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
177	20-Aug-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
178	20-Aug-20	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	21:38 (20.08.2020)			LINE OPEN: LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
179	20-Aug-20	BAGALKOT	110	RANEBENNUR- (RATTIHALLI) TUMMINKATTI	TUMMINKATTI_110	16:03	18:01	01:58	LINE CLAE AVAILED
180	20-Aug-20	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
181	20-Aug-20	BAGALKOT	110	SIRSI- SIDDAPUR	SIDDAPUR_110	22:09	22:52	00:43	HAND TRIPPED
182	20-Aug-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
183	20-Aug-20	BAGALKOT	220	220/110KV,HV1& LV 1	ATHANI_220	11:45	14:22	02:37	LINE CLAE AVAILED
184	20-Aug-20	BAGALKOT	220	220/110KV,HV3& LV 3	MAHALINGAPUR_220	21:38	22:11	00:33	TRANSFORMER FAULT
185	20-Aug-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN: LINE FAULT
186	20-Aug-20	BAGALKOT	220	BAGEWADI-ATRIA 2	STATION NOT AFFECTED BAGEWADI_220	16:26 (17.08.2020)			LINE OPEN:LINE CLEAR AVAILED
187	20-Aug-20	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	17:26 (24.07.2020)			LOAD CURTAILMENT
188	20-Aug-20	BAGALKOT	220	BELGAUM- NARENDRA2 (KANABARGI2)	STATION NOT AFFECTED BELGAUM_220	22:18 (04.08.2020)			LINE OPEN:LINE CLEAR AVAILED
189	20-Aug-20	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	00:14 (19.08.2020)	10:31 (20.08.2020)	10:27	LOAD CURTAILMENT
190	20-Aug-20	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	22:55			LOAD CURTAILMENT
191	20-Aug-20	BAGALKOT	220	CHIKKODI-BELGAUM2	CHIKKODI_220	23:44 (19.08.2020)			LOAD CURTAILMENT
192	20-Aug-20	BAGALKOT	220	GADAG-HARTHI1	GADAG_220	12:19 (17.08.2020)			LOAD CURTAILMENT
193	20-Aug-20	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	16:57 (10.08.2020)	10:49 (20.08.2020)	17:52	LINE CHARGED
194	20-Aug-20	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	14:09 (20.08.2020)			LINE OPEN:LINE CLEAR AVAILED
195	20-Aug-20	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	18:35 (07.08.2020)	10:49 (20.08.2020)	16:14	LINE CHARGED
196	20-Aug-20	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	14:09 (20.08.2020)			LINE OPEN:LINE CLEAR AVAILED
197	20-Aug-20	BAGALKOT	220	NARENDRA- HAVERI	NARENDRA_220	12:29	13:40	01:11	LINE FAULT
198	20-Aug-20	BAGALKOT	220	SHARAVATHY1- SIRSI	SIRSI_220	10:49	14:07	03:18	LINE CLAE AVAILED
199	20-Aug-20	BAGALKOT	220	SHARAVATHY2- SIRSI	SIRSI_220	07:11	14:09	06:58	LINE CLAE AVAILED
200	20-Aug-20	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 1 & 2	NO STATION AFFECTED	10:16(17/08/2020)			LINE OPEN:LINE CLEAR AVAILED
201	20-Aug-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
202	20-Aug-20	BENGALURU	66	HV1	THAYALUR	14:32	15:51	01:18	TRANSFORMER CHARGED
203	20-Aug-20	BENGALURU	66	HV1	ELECTRONIC CITY P2 S2	16:38	17:57	01:18	TRANSFORMER FAULT
204	20-Aug-20	BENGALURU	66	HV1	PATH PALYA	14:00	14:20	00:20	LINE CLAE AVAILED
205	20-Aug-20	BENGALURU	66	HV1	RANGANDODDI	17:41	17:53	00:12	LINE CLAE AVAILED
206	20-Aug-20	BENGALURU	66	HV1	SULIBELE	16:57	18:06	01:09	TRANSFORMER FAULT
207	20-Aug-20	BENGALURU	66	HV2	KADUGODI	13:03	13:31	00:28	LINE CLAE AVAILED
208	20-Aug-20	BENGALURU	66	HV2	THAYALUR	11:40	14:32	02:52	LINE CLAE AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
209	20-Aug-20	BENGALURU	66	HV2	RANGANDODDI	17:41	17:53	00:12	LINE CLAE AVAILED
210	20-Aug-20	BENGALURU	66	HV2	HOSUR RAMAPURA	21:25:00(20/08/2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
211	20-Aug-20	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	17:21	17:46	00:25	LINE CLAE AVAILED
212	20-Aug-20	BENGALURU	66	NIMHANS 220 - BMTc	NO STATION AFFECTED	17:27(12/06/2020)	14:35(20.08.20)	1653 hrs	LINE CHARGED
213	20-Aug-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN: LINE FAULT
214	20-Aug-20	GULBARGA	66	ITTAGI-HIREHADAGALLI1	HIREHADAGALLI_66	13:23	14:01	00:38	LINE CLAE AVAILED
215	20-Aug-20	GULBARGA	110	HALBARGA-CHIDRI1,2	CHIDRI_110,KAMTHANA_110,HABSIK OTE_110	12:35	18:07	05:32	LINE CLAE AVAILED
216	20-Aug-20	GULBARGA	110	HV1	BEVOOR_110	12:25	13:28	01:03	LINE CLAE AVAILED
217	20-Aug-20	GULBARGA	110	HV3	DEODURGA_110	10:23	10:40	00:17	LINE CLAE AVAILED
218	20-Aug-20	GULBARGA	110	KAMPLI-SINDHANOOR	KAMPLI_110	12:30	16:20	03:50	LINE CLAE AVAILED
219	20-Aug-20	GULBARGA	110	KAMPLI-SINDHANOOR	KAMPLI_110	17:11	17:20	00:09	LINE CLAE AVAILED
220	20-Aug-20	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110,VALKAMDINNI_110	20:10	20:20	00:10	LINE FAULT
221	20-Aug-20	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110,VALKAMDINNI_110	21:05	21:15	00:10	LINE FAULT
222	20-Aug-20	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110,VALKAMDINNI_110	22:05	22:15	00:10	LINE FAULT
223	20-Aug-20	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110,VALKAMDINNI_110	22:50	23:00	00:10	LINE FAULT
224	20-Aug-20	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPURA_110,MANVI_110	12:17	13:26	01:09	LINE CLAE AVAILED
225	20-Aug-20	GULBARGA	110	RAICHUR-SHAHAPUR1	GABUR_110,DEODURGA_110	20:26	20:36	00:10	LINE FAULT
226	20-Aug-20	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	20:26	20:36	00:10	LINE FAULT
227	20-Aug-20	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110	12:20	16:43	04:23	LINE CLAE AVAILED
228	20-Aug-20	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,ASKI_110,HUNSAGI_ 110,UGAR SUGAR IPP	03:15	03:20	00:05	LINE FAULT
229	20-Aug-20	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	00:48	01:45	00:57	LINE FAULT
230	20-Aug-20	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	02:15	04:45	02:30	LINE CLAE AVAILED
231	20-Aug-20	GULBARGA	220	ITTAGI-LINGAPUR	ITTAGI_220	12:56	13:18	00:22	LINE FAULT
232	20-Aug-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN:LINE CLEAR AVAILED
233	20-Aug-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN: LINE FAULT
234	20-Aug-20	GULBARGA	220	RAICHUR-JURALLA1(IDLE LINE)	RAICHUR_220	10:35	17:57	07:22	LINE CLAE AVAILED
235	20-Aug-20	GULBARGA	220	RAICHUR-JURALLA2	RAICHUR_220	5:56(19.8.2020)			LINE OPEN: LINE FAULT
236	20-Aug-20	GULBARGA	220	RAICHUR-RTPS1	RAICHUR_220	13:57(19.8.2020)			LINE OPEN: LINE FAULT
237	20-Aug-20	HASSAN	66	HV1	DIDIGA_66	12:52	13:16	00:24	LINE CLAE AVAILED
238	20-Aug-20	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	18:08	18:35	00:27	LINE FAULT
239	20-Aug-20	HASSAN	110	HV1	SAGARA_110	21:42(19.08.2020)	2:59 (20.08.2020)	5:16 hrs	LINE CHARGED
240	20-Aug-20	HASSAN	110	HV1	BAIKAMPADI_110	10:35	16:32	05:57	LINE CLAE AVAILED
241	20-Aug-20	HASSAN	110	HV1	BIRUR_110	01:41	17:26	15:45	LINE CLAE AVAILED
242	20-Aug-20	HASSAN	110	HV2	ALKOLA_110	13:30	14:00	00:30	LINE CLAE AVAILED
243	20-Aug-20	HASSAN	110	HV2	BIRUR_110	09:53	17:26	07:33	LINE CLAE AVAILED
244	20-Aug-20	HASSAN	110	HV2	NANDIKUR_110	15:03	17:46	02:43	LINE CLAE AVAILED
245	20-Aug-20	HASSAN	110	JOG-JLT4	mghejog_gen	22:09	22:13	00:04	LINE FAULT
246	20-Aug-20	HASSAN	110	JOG-JST1	mghejog_gen	22:09	22:13	00:04	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
247	20-Aug-20	HASSAN	110	JOG-NK2	NO STN AFFECTED	23:36 (7.08.2020)			LINE OPEN:LINE CLEAR AVAILED
248	20-Aug-20	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	16:03	20:31	04:28	LINE CLAE AWAILED
249	20-Aug-20	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	03:25	13:10	09:45	LINE FAULT
250	20-Aug-20	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	03:25	03:55	00:30	LINE FAULT
251	20-Aug-20	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	09:00	13:10	04:10	LINE CLAE AWAILED
252	20-Aug-20	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	16:06	20:33	04:27	LINE CLAE AWAILED
253	20-Aug-20	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	07:11	14:10	06:59	LINE FAULT
254	20-Aug-20	HASSAN	220	SHRVTY-SIRISI 1	sharavathy_gen	10:58	14:09	03:11	HAND TRIPPED
255	20-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:44 (19.8.2020)	6:50 (20.08.2020)	7:05 hrs	LINE CHARGED
256	20-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:53 (20.08.2020)			LINE OPEN:LINE CLEAR AVAILED
257	20-Aug-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	16:42 (17.08.2020)			LINE OPEN:LINE CLEAR AVAILED
258	20-Aug-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	10:03 (20.08.2020)			LINE OPEN:LINE CLEAR AVAILED
259	20-Aug-20	MYSURU	66	HV1	BGNAGARA_66	10:15	16:16	06:01	LINE CLAE AWAILED
260	20-Aug-20	MYSURU	66	HV1	MADHUVANAHALLI_220	11:50	11:53	00:03	TRANSFORMER FAULT
261	20-Aug-20	MYSURU	66	HV1	VAJAMANGALA_220	10:00	17:27	07:27	LINE CLAE AWAILED
262	20-Aug-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
263	20-Aug-20	MYSURU	66	HV2	BGNAGARA_66	10:15	16:16	06:01	LINE CLAE AWAILED
264	20-Aug-20	MYSURU	66	HV2	MADIKERI_66	13:58	14:23	00:24	TRANSFORMER FAULT
265	20-Aug-20	MYSURU	66	HV2	VAJAMANGALA_220	10:00	17:27	07:27	LINE CLAE AWAILED
266	20-Aug-20	MYSURU	66	KUNTHUR-DODDRAIPETE	SANTHEMARAHALLI_66	12:15	14:54	02:39	LINE CLAE AWAILED
267	20-Aug-20	MYSURU	66	KUNTHUR-MADHUVANAHALLI	NO STATIONS EFFECTED	17:04	17:10	00:05	LINE FAULT
268	20-Aug-20	MYSURU	66	MADHUVANAHALLI-HANNUR1	NO STATIONS EFFECTED	11:19	17:07	05:48	LINE CLAE AWAILED
269	20-Aug-20	MYSURU	66	MADHUVANAHALLI-HANNUR2	NO STATIONS EFFECTED	15:55	17:07	01:12	HAND TRIPPED
270	20-Aug-20	MYSURU	66	PONNAMPETE-VIRAJPETE	VIRAJPET_66	14:13	14:32	00:19	LINE CLAE AWAILED
271	20-Aug-20	MYSURU	66	SFC SIVA-10MW	NO STATIONS EFFECTED	18:55 (19.08.2020)	06:40	11:45 HRS	LINE CHARGED
272	20-Aug-20	MYSURU	66	SFC SIVA-5MW	NO STATIONS EFFECTED	18:55 (19.08.2020)	06:15	11:20 HRS	LINE CHARGED
273	20-Aug-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
274	20-Aug-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT
1	21-Aug-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN: LINE FAULT
2	21-Aug-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
3	21-Aug-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
4	21-Aug-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
5	21-Aug-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
6	21-Aug-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020)			LINE OPEN:LINE CLEAR AVAILED
7	21-Aug-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:0 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
8	21-Aug-20	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	17:26 (24.07.2020)			LOAD CURTAILMENT
9	21-Aug-20	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
10	21-Aug-20	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
11	21-Aug-20	BAGALKOT	220	BELGAUM- NARENDRA2 (KANABARGI)	STATION NOT AFFECTED BELGAUM_220	22:18 (04.08.2020)			LINE OPEN:LINE CLEAR AVAILED
12	21-Aug-20	BAGALKOT	220	BAGEWADI-ATRIA 2	STATION NOT AFFECTED BAGEWADI_220	16:26 (17.08.2020)			LINE OPEN:LINE CLEAR AVAILED
13	21-Aug-20	BAGALKOT	220	GADAG-HARTHI1	GADAG_220	12:19 (17.08.2020)			LOAD CURTAILMENT
14	21-Aug-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN:LINE CLEAR AVAILED
15	21-Aug-20	BAGALKOT	220	CHIKKODI-BELGAUM2	CHIKKODI_220	23:44 (19.08.2020)			LOAD CURTAILMENT
16	21-Aug-20	BAGALKOT	110	220/110,LV2	MK HUBLI_220	21:22 (19.08.2020)	9:54 (20.08.2020)	11:32hrs	TRANSFORMER CHARGED
17	21-Aug-20	BAGALKOT	110	220/110,LV1	MK HUBLI_220	23:08 (19.08.2020)	6:20 (20.08.2020)	7:12hrs	TRANSFORMER CHARGED
18	21-Aug-20	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	10:55:00 PM (20.08.2020)	9:12 (21.08.2020)	22:17hrs	LOAD CURTAILMENT
19	21-Aug-20	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	21:38 (20.08.2020)	10:50 (21.08.2020)	13:22hrs	LINE CHARGED
20	21-Aug-20	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	14:09 (20.08.2020)			LINE OPEN:LINE CLEAR AVAILED
21	21-Aug-20	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	14:09 (20.08.2020)			LINE OPEN:LINE CLEAR AVAILED
22	21-Aug-20	BAGALKOT	110	VAJRAMATTI220- MANTUR (MUDHOL)	MUDHOL_110	11:02	11:07	0:05	HAND TRIPPED
23	21-Aug-20	BAGALKOT	110	220/110KV, LV3	HUBLI_220	10:57	15:13	4:16	LINE CLAE AVAILED
24	21-Aug-20	BAGALKOT	110	HUBLI- RAMANKOPPA	RAMANKOPPA_110	14:26	14:36	0:10	HAND TRIPPED
25	21-Aug-20	BAGALKOT	110	HUBLI-BIDNAL2	HUBLI_220	9:49	12:08	2:19	LINE CLAE AVAILED
26	21-Aug-20	BAGALKOT	110	110/11KV,HV4	SADALAGA_110	6:58	10:57	3:59	TRANSFORMER FAULT
27	21-Aug-20	BAGALKOT	110	110/11KV, HV1	MKHUBLI_110	15:51	16:02	0:11	LINE CLAE AVAILED
28	21-Aug-20	BAGALKOT	110	110/11KV, HV1	MKHUBLI_110	15:25	15:31	0:06	LINE CLAE AVAILED
29	21-Aug-20	BAGALKOT	110	MK HUBLI- KITTUR	KITTUR_110	15:26	15:31	0:05	LINE CLAE AVAILED
30	21-Aug-20	BAGALKOT	110	MAMDAPUR(B)- SHIRBUR	SHIRBUR_110	6:37	6:51	0:14	HAND TRIPPED
31	21-Aug-20	BAGALKOT	110	110/33KV, HV3	MAMDAPUR)B_110, DEVARGENNUR_33, LINGADALLI LIS_33	6:37	7:01	0:24	TRANSFORMER FAULT
32	21-Aug-20	BAGALKOT	110	RANNABELAGALI- UTTUR	UTTUR_110	10:29	10:52	0:23	LINE FAULT
33	21-Aug-20	BAGALKOT	110	RANNABELAGALI- UTTUR	UTTUR_110	11:05	14:02	2:57	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
34	21-Aug-20	BAGALKOT	110	BAGEWADI- MAMADAPUR(B)	MAMADAPUR(B)_110	6:21	6:35	0:14	LINE FAULT
35	21-Aug-20	BAGALKOT	110	110/11KV, HV1	GULEDGUDDA_110	16:12	16:18	0:06	TRANSFORMER FAULT
36	21-Aug-20	BAGALKOT	110	HAVERI-SAVANUR	SAVANUR_110	9:21	11:28	2:07	LINE FAULT
37	21-Aug-20	BAGALKOT	110	110/11KV,HV1	HIDIKAL_110	16:07	17:31	1:24	TRANSFORMER FAULT
38	21-Aug-20	BAGALKOT	110	110/11KV,HV1A&HV2A	JAMAKHANDI_110	15:00	15:59	0:59	LINE CLAE AVAILED
39	21-Aug-20	BENGALURU	220	VRISHBHAVATHI 220 - TATAGUNI 220 (EHT)	VRISHBHAVATHI 220	11:52	12:29	00:37	LINE FAULT
40	21-Aug-20	BENGALURU	220	VRISHBHAVATHI 220 - TATAGUNI 220 (EHT)	VRISHBHAVATHI 220	15:35	17:15	01:40	LINE FAULT
41	21-Aug-20	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	15:16	15:22	00:06	LOAD CHANGE OVER
42	21-Aug-20	BENGALURU	66	TK HALLI 220 - SHIMSHA	NO STATION AFFECTED	07:49	08:40	00:50	LINE CLAE AVAILED
43	21-Aug-20	BENGALURU	66	VRISHBHAVATHI 220 - BANASHANKARI	BANASHANKARI	11:54	12:13	00:18	MAIN SUPPLY FAILURE
44	21-Aug-20	BENGALURU	66	VRISHBHAVATHI 220 - BANASHANKARI	BANASHANKARI	15:35	15:48	00:13	MAIN SUPPLY FAILURE
45	21-Aug-20	BENGALURU	66	KENGERI SATELLITE TOWN - KUMBALAGODU	KENGERI SATELLITE TOWN	13:18	13:21	00:03	LOAD CHANGE OVER
46	21-Aug-20	BENGALURU	66	KENGERI SATELLITE TOWN - KUMBALAGODU	KENGERI SATELLITE TOWN	17:40	17:45	00:05	LOAD CHANGE OVER
47	21-Aug-20	BENGALURU	66	KENGERI SATELLITE TOWN - SIR MV LAYOUT	KENGERI SATELLITE TOWN	11:51	12:26	00:35	MAIN SUPPLY FAILURE
48	21-Aug-20	BENGALURU	66	KENGERI SATELLITE TOWN - SIR MV LAYOUT	KENGERI SATELLITE TOWN	15:37	16:09	00:32	MAIN SUPPLY FAILURE
49	21-Aug-20	BENGALURU	66	SIR MV LAYOUT - VRISHBHAVATHI 220	SIR MV LAYOUT	11:51	12:40	00:49	MAIN SUPPLY FAILURE
50	21-Aug-20	BENGALURU	66	SIR MV LAYOUT - VRISHBHAVATHI 220	SIR MV LAYOUT	15:37	17:20	01:43	MAIN SUPPLY FAILURE
51	21-Aug-20	BENGALURU	220	HOODY 220 - MALUR 220	NO STATION AFFECTED	11:17	15:30	04:12	LINE FAULT
52	21-Aug-20	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	09:41	09:43	00:02	LOAD CHANGE OVER
53	21-Aug-20	BENGALURU	66	NELAMANGALA 66 - ALUR	NELAMANGALA 66	09:35	09:45	00:10	LINE CLAE AVAILED
54	21-Aug-20	BENGALURU	66	REMCO - VRISHBHAVATHI 220	REMCO	11:51	12:40	00:49	MAIN SUPPLY FAILURE
55	21-Aug-20	BENGALURU	66	REMCO - VRISHBHAVATHI 220	REMCO	15:36	16:21	00:45	MAIN SUPPLY FAILURE
56	21-Aug-20	BENGALURU	66	REMCO - NRS	REMCO	21:40	22:05	00:25	LOAD CHANGE OVER
57	21-Aug-20	BENGALURU	220	HV1	VRISHBHAVATHI 220	11:52	12:29	00:37	MAIN SUPPLY FAILURE
58	21-Aug-20	BENGALURU	220	HV2	VRISHBHAVATHI 220	15:35	17:15	01:40	MAIN SUPPLY FAILURE
59	21-Aug-20	BENGALURU	220	HV1	VRISHBHAVATHI 220	11:52	12:29	00:37	MAIN SUPPLY FAILURE
60	21-Aug-20	BENGALURU	220	HV2	VRISHBHAVATHI 220	15:35	17:15	01:40	MAIN SUPPLY FAILURE
61	21-Aug-20	BENGALURU	66	CHANDRALAYOUT - VRISHBHAVATHI 220	CHANDRA LAYOUT	11:51	12:36	00:45	MAIN SUPPLY FAILURE
62	21-Aug-20	BENGALURU	66	CHANDRALAYOUT - VRISHBHAVATHI 220	CHANDRA LAYOUT	15:35	15:37	00:02	MAIN SUPPLY FAILURE
63	21-Aug-20	BENGALURU	66	CHANDRALAYOUT - NRS 220		21:36	21:41	00:05	LOAD CHANGE OVER
64	21-Aug-20	BENGALURU	66	HV1	VIJAYANAGARA	11:51	12:06	00:15	MAIN SUPPLY FAILURE
65	21-Aug-20	BENGALURU	66	HV1	VIJAYANAGARA	15:35	16:20	00:45	MAIN SUPPLY FAILURE
66	21-Aug-20	BENGALURU	66	HV1	VIJAYANAGARA	22:06	22:35	00:29	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
67	21-Aug-20	BENGALURU	66	HV2	NRS 220	22:36	22:40	00:04	LOAD CHANGE OVER
68	21-Aug-20	BENGALURU	220	SOMANAHALLI 220 - TATAGUNI(EHT)	NO STATION AFFECTED	11:51	12:04	00:13	LINE FAULT
69	21-Aug-20	BENGALURU	220	SOMANAHALLI 220 - TATAGUNI(EHT)	NO STATION AFFECTED	12:38	17:30	04:52	LINE FAULT
70	21-Aug-20	BENGALURU	66	RMV - GOKULA	RMV	13:28	13:33	00:05	LINE CLAE AVAILED
71	21-Aug-20	BENGALURU	66	HV1	BANGARPETE	13:55	14:07	00:12	TRANSFORMER FAULT
72	21-Aug-20	BENGALURU	66	HV1	BANGARPETE	14:55	15:06	00:11	TRANSFORMER FAULT
73	21-Aug-20	BENGALURU	66	HV1	SIDDLAGHATTA	14:49	15:19	00:30	LINE CLAE AVAILED
74	21-Aug-20	BENGALURU	66	HV2	HOSUR RAMAPURA	21:25:00(20/08/2020)	12:06(21/08/2020)	14:41HRS	TRANSFORMER CHARGED
75	21-Aug-20	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 1 & 2	NO STATION AFFECTED	10:16(17/08/2020)			LINE OPEN:LINE CLEAR AVAILED
76	21-Aug-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
77	21-Aug-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN: LINE FAULT
78	21-Aug-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN: LINE FAULT
79	21-Aug-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN:LINE CLEAR AVAILED
80	21-Aug-20	GULBARGA	220	RAICHUR-JURALLA2	RAICHUR_220	5:56(19.8.2020)			LINE OPEN: LINE FAULT
81	21-Aug-20	GULBARGA	400	BTPSG-HIRIYUR1	HIRIYUR_400	1:03(21.08.2020)			LINE OPEN:LINE CLEAR AVAILED
89	21-Aug-20	GULBARGA	220	RAICHUR-RTPS1	RAICHUR_220	13:57(19.8.2020)	11:44(21.8.2020)	21:47HRS	LINE CHARGED
90	21-Aug-20	GULBARGA	220	HV1	KUSHTAGI_220	12:28	12:53	00:25	TRANSFORMER FAULT
91	21-Aug-20	GULBARGA	220	HV2	KUSHTAGI_220	13:19	13:38	00:19	TRANSFORMER FAULT
92	21-Aug-20	GULBARGA	110	KUSHTAGI-KANAKAGIRI	KANAKAGIRI_110,GANADAL_110	13:18	13:47	00:29	LINE FAULT
93	21-Aug-20	GULBARGA	110	HATTI-SMNMRD_JPP	HATTI_110	05:48	06:36	00:48	LINE FAULT
94	21-Aug-20	GULBARGA	110	HV3	HATTI_110	05:48	06:15	00:27	TRANSFORMER FAULT
95	21-Aug-20	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110	05:07	05:21	00:14	LINE FAULT
96	21-Aug-20	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSLSUGSARFACTORY_I PP,CHOWDAPUR_110	05:56	06:09	00:13	LINE FAULT
97	21-Aug-20	GULBARGA	110	KUSHTAGI-HANUMANAL	HANUMANAL_110	13:20	13:50	00:30	MAIN SUPPLY FAILURE
98	21-Aug-20	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	00:48	06:00	05:12	LINE FAULT
99	21-Aug-20	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	20:15	20:35	00:20	LINE CLAE AVAILED
100	21-Aug-20	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	23:10(21.08.2020)			LINE OPEN: LINE FAULT
101	21-Aug-20	GULBARGA	110	SINDHANOOR-PGLR_WIND	SINDHANOOR_220	03:55	04:20	00:25	LINE FAULT
102	21-Aug-20	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	05:06	05:21	00:15	LINE FAULT
103	21-Aug-20	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSLSUGSARFACTORY_I PP,CHOWDAPUR_110	05:56	06:08	00:12	LINE FAULT
104	21-Aug-20	GULBARGA	66	HV2	TAMBRAHALLI_66	11:23	13:10	01:47	LINE CLAE AVAILED
105	21-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:53 (20.08.2020)	7:02 (21.8.2020)	7:08 hrs	LINE CHARGED
106	21-Aug-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	16:42 (17.08.2020)	7:25 (21.08.2020)	86:42 hrs	LINE CHARGED
107	21-Aug-20	HASSAN	110	JOG-NK2	NO STN AFFECTED	23:36 (7.08.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
108	21-Aug-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	10:03 (20.08.2020)			LINE OPEN:LINE CLEAR AVAILED
109	21-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	22:32 (21.08.2020)			LINE OPEN:LINE CLEAR AVAILED
110	21-Aug-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:09 (21.08.2020)			LINE OPEN:LINE CLEAR AVAILED
111	21-Aug-20	HASSAN	110	HV	PUTTUR_220	10:43	13:15	02:32	LINE CLAE AVAILED
112	21-Aug-20	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	11:26	12:42	01:16	LINE CLAE AVAILED
113	21-Aug-20	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	11:39	11:54	00:15	MAIN SUPPLY FAILURE
114	21-Aug-20	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	11:39	11:42	00:03	MAIN SUPPLY FAILURE
115	21-Aug-20	HASSAN	66	HV1	DIDIGA_66	07:46	07:57	00:11	TRANSFORMER FAULT
116	21-Aug-20	MYSURU	66	HV1	CHUNCHUNKATTE_66	12:12	13:27	1:15	LINE CLAE AVAILED
117	21-Aug-20	MYSURU	66	HV1	HALAGUR_66	12:20	15:00	2:40	LINE CLAE AVAILED
118	21-Aug-20	MYSURU	66	KUSHALNAGARA 220-SUNTIKOPPA	NO STATIONS EFFECTED	5:51	5:56	0:05	LINE FAULT
119	21-Aug-20	MYSURU	66	HV1	MADIKERI_66	11:20	11:30	0:09	HAND TRIPPED
120	21-Aug-20	MYSURU	66	HV2	MADIKERI_66	9:06	11:19	2:12	TRANSFORMER FAULT
121	21-Aug-20	MYSURU	66	SFC SIVA-PGL	NO STATIONS EFFECTED	6:40	6:44	0:03	LINE FAULT
122	21-Aug-20	MYSURU	66	SFC SIVA-HEBBANI-7	NO STATIONS EFFECTED	6:40	7:00	0:20	LINE FAULT
123	21-Aug-20	MYSURU	66	PARINAMIPURA-TALKADU	THALAKADU_66 CHANDALLI_66	6:03	6:08	0:05	LINE FAULT
124	21-Aug-20	MYSURU	66	TUBINKERE-MC-4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66 ADDIHALLI_66 BASARALU_66	6:33	6:43	0:10	LINE FAULT
125	21-Aug-20	MYSURU	66	TUBINKERE-NAGMANGALA 1	HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 VADERALLI_66	8:50	8:58	0:07	LINE FAULT
126	21-Aug-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
127	21-Aug-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT
128	21-Aug-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
129	21-Aug-20	TUMKUR	220	TR-3	HIRIYUR_220	14:12	14:20	0:08	TRANSFORMER FAULT
130	21-Aug-20	TUMKUR	220	THALLAK 220KV-CHITRADURGA	THALLAKK_220	11:17	17:55	6:38	LINE CLAE AVAILED
131	21-Aug-20	TUMKUR	220	THALLAK 220KV- SEI DIAMOND SOLAR IPP_66	SEL DIAMOND SOLAR_IPP_66	13:17	14:21	1:03	LINE CLAE AVAILED
132	21-Aug-20	TUMKUR	110	TR-1	DODDAGUNI_110	14:08	14:27	0:19	LINE CLAE AVAILED
133	21-Aug-20	TUMKUR	110	TR-1	KGTEMPLE_110	16:01	16:10	0:09	LINE CLAE AVAILED
134	21-Aug-20	TUMKUR	66	TR-1	DAVANAGERE_66	12:36	13:29	0:52	LINE CLAE AVAILED
135	21-Aug-20	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	22:53	23:21	0:27	LINE FAULT
136	21-Aug-20	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	22:53	23:16	0:23	LINE FAULT
137	21-Aug-20	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	14:19	14:26	0:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
138	21-Aug-20	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	11:05	11:17	0:12	HAND TRIPPED
139	21-Aug-20	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	14:19	14:25	0:05	HAND TRIPPED
140	21-Aug-20	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	14:18	14:25	0:07	HAND TRIPPED
141	21-Aug-20	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	13:43	13:50	0:06	HAND TRIPPED
142	21-Aug-20	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	14:18	14:56	0:37	HAND TRIPPED
143	21-Aug-20	TUMKUR	66	TR-2	HULIYURDURGA_66	11:50	13:49	1:58	LINE CLAE AVAILED
144	21-Aug-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:04	12:10	0:05	LINE FAULT
145	21-Aug-20	TUMKUR	66	THALLAK 220kV -BGKERE 1	BGKERE_66	12:44	12:56	0:11	HAND TRIPPED
146	22-Aug-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN: LINE FAULT
147	22-Aug-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
148	22-Aug-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
149	22-Aug-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
150	22-Aug-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN:LINE CLEAR AVAILED
151	22-Aug-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020)			LINE OPEN:LINE CLEAR AVAILED
152	22-Aug-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:0 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
153	22-Aug-20	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	17:26 (24.07.2020)			LOAD CURTAILMENT
154	22-Aug-20	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
155	22-Aug-20	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
156	22-Aug-20	BAGALKOT	220	BELGAUM- NARENDRA2 (KANABARGI)	STATION NOT AFFECTED BELGAUM_220	22:18 (04.08.2020)			LINE OPEN:LINE CLEAR AVAILED
157	22-Aug-20	BAGALKOT	220	BAGEWADI-ATRIA 2	STATION NOT AFFECTED BAGEWADI_220	16:26 (17.08.2020)			LINE OPEN:LINE CLEAR AVAILED
158	22-Aug-20	BAGALKOT	220	GADAG-HARTHI1	GADAG_220	12:19 (17.08.2020)			LOAD CURTAILMENT
159	22-Aug-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN:LINE CLEAR AVAILED
160	22-Aug-20	BAGALKOT	220	CHIKKODI-BELGAUM2	CHIKKODI_220	23:44 (19.08.2020)			LOAD CURTAILMENT
161	22-Aug-20	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	14:09 (20.08.2020)			LINE OPEN:LINE CLEAR AVAILED
162	22-Aug-20	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	14:09 (20.08.2020)			LINE OPEN:LINE CLEAR AVAILED
163	22-Aug-20	BAGALKOT	110	110/33KV,HV2	HUNGUND-110 & KARADI,AMINAGAD_33	11:09	11:15	0:06	TRANSFORMER FAULT
164	22-Aug-20	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	16:15 (22.08.2020)			LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
165	22-Aug-20	BAGALKOT	110	220/110,LV1	MK HUBLI_220	14:56 (22.08.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
166	22-Aug-20	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	NO STATION AFFECTED	14:36	21:05	06:29	LINE FAULT
167	22-Aug-20	BENGALURU	220	HV2	SOMANAHALLI 220	14:36	15:33	00:57	TRANSFORMER FAULT
168	22-Aug-20	BENGALURU	220	HV3	SOMANAHALLI 220	14:36	15:10	00:34	TRANSFORMER FAULT
169	22-Aug-20	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	14:36	15:11	00:35	LINE CLAE AVAILED
170	22-Aug-20	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 1 & 2	NO STATION AFFECTED	10:16(17/08/2020)			LINE OPEN:LINE CLEAR AVAILED
171	22-Aug-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
172	22-Aug-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN: LINE FAULT
173	22-Aug-20	GULBARGA	400	BTPSG-HIRIYUR1	HIRIYUR_400	1:03(21.8.2020)	9:08(22.8.2020)	32:05HRS	LINE CHARGED
174	22-Aug-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN: LINE FAULT
175	22-Aug-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN:LINE CLEAR AVAILED
176	22-Aug-20	GULBARGA	220	RAICHUR-JURALLA2	RAICHUR_220	5:56(19.8.2020)			LINE OPEN: LINE FAULT
177	22-Aug-20	GULBARGA	220	RAICHUR-RTPS2	RAICHUR_220	10:22	22:50	12:28	LINE CLAE AVAILED
178	22-Aug-20	GULBARGA	220	HV1	KUSHTAGI_220	09:47	09:51	00:04	TRANSFORMER FAULT
179	22-Aug-20	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	07:00	18:25	11:25	LINE CLAE AVAILED
180	22-Aug-20	GULBARGA	110	HV1	KURKUNTA_110	16:05	17:10	01:05	LINE CLAE AVAILED
181	22-Aug-20	GULBARGA	110	HV3	DEODURGA_110	11:15	11:20	00:05	LINE CLAE AVAILED
182	22-Aug-20	GULBARGA	110	CHINCHOLI-SEDAM	CHINCHOLI_110	06:45	07:05	00:20	LINE FAULT
183	22-Aug-20	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	23:10(21.8.2020)	00:06	0:56HRS	LINE CHARGED
184	22-Aug-20	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	02:04	02:15	00:11	LINE FAULT
185	22-Aug-20	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	23:15	23:21	00:06	LINE FAULT
186	22-Aug-20	GULBARGA	110	HUMNABAD-BIDAR1	HALIKHED_110	11:11	11:18	00:07	LINE FAULT
187	22-Aug-20	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPURA_110,MANVI_110,KURDI CROSS_110	05:32	05:48	00:16	LINE FAULT
188	22-Aug-20	GULBARGA	110	RAICHUR-SHAHAPUR1	DEODURGA_110,GABUR_110	01:21	01:30	00:09	LINE FAULT
189	22-Aug-20	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	01:21	01:30	00:09	LINE FAULT
190	22-Aug-20	GULBARGA	110	RAICHUR-SINDHANOOR1	VALKAMDINNI_110	06:19	06:30	00:11	LINE FAULT
191	22-Aug-20	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	22:59	23:08	00:09	LINE FAULT
192	22-Aug-20	GULBARGA	66	ITTAGGI-HUVINAHADAGALLI	HUVINA_HADAGALLI_66	07:36	07:44	00:08	LINE FAULT
193	22-Aug-20	GULBARGA	66	ITTAGGI-SUZLON1	ITTAGI_220	15:14	15:22	00:08	LINE FAULT
194	22-Aug-20	GULBARGA	66	ITTAGGI-SUZLON1	ITTAGI_220	18:00	18:39	00:39	LINE FAULT
195	22-Aug-20	GULBARGA	66	ITTAGGI-SUZLON1	ITTAGI_220	21:26	21:33	00:07	LINE FAULT
196	22-Aug-20	GULBARGA	66	ITTAGGI-KUDLIGI2	KUDLIGI_66,CJHALLI_66,HANASI_66,H OSAHALLI_66,BANAVEKAL_66,CHORN OOR_66,GUDEKOTE_66	19:22	19:30	00:08	LINE FAULT
197	22-Aug-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:09 (21.08.2020)	9:03 (22.08.2020)	10:53 hrs	LINE CHARGED
198	22-Aug-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:19 (22.08.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
199	22-Aug-20	HASSAN	110	JOG-NK2	NO STN AFFECTED	23:36 (7.08.2020)			LINE OPEN:LINE CLEAR AVALIED
200	22-Aug-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	10:03 (20.08.2020)			LINE OPEN:LINE CLEAR AVALIED
201	22-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	22:32 (21.08.2020)			LINE OPEN:LINE CLEAR AVALIED
202	22-Aug-20	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	10:07	11:03	00:56	HAND TRIPPED
203	22-Aug-20	HASSAN	110	MRSSHM-BADRAVATY2	MRSMSG_220	10:07	11:03	00:56	HAND TRIPPED
204	22-Aug-20	HASSAN	110	NANDIKU-ISTR	NANDIKUR_110	14:15	14:38	00:23	LINE FAULT
205	22-Aug-20	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	07:51	07:59	00:08	LINE FAULT
206	22-Aug-20	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	11:23	12:20	00:57	LINE CLAE AVALIED
207	22-Aug-20	HASSAN	66	KIADB H-RAMESWARNAGAR	KIADB_66	07:21	07:30	00:09	LINE FAULT
208	22-Aug-20	MYSURU	66	VAJMANGALA-KADKOLA 2	NO STATIONS EFFECTED	18:33	18:38	0:05	LINE FAULT
209	22-Aug-20	MYSURU	66	KADKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66 ANTHARSANTHE_66 HDKOTE_66,	14:25	14:30	0:05	LINE FAULT
210	22-Aug-20	MYSURU	66	KADKOLA-DK MAIDANA	DKMAIDANA_66	17:13	17:17	0:04	LINE FAULT
211	22-Aug-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
212	22-Aug-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT
213	22-Aug-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
214	22-Aug-20	TUMKUR	66	BANUVALLI- NANDUGUDI	BANUVALLI_66	10:46	10:52	0:06	LINE FAULT
215	22-Aug-20	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	0:14	1:34	1:20	HAND TRIPPED
216	22-Aug-20	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	3:09	3:31	0:21	HAND TRIPPED
217	22-Aug-20	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	5:06	6:28	1:22	HAND TRIPPED
218	22-Aug-20	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	0:14	1:11	0:56	HAND TRIPPED
219	22-Aug-20	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	3:09	3:24	0:14	HAND TRIPPED
220	22-Aug-20	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	5:06	5:26	0:19	HAND TRIPPED
221	22-Aug-20	TUMKUR	66	TR-2	HARIYABBE_66	3:09	3:27	0:17	TRANSFORMER FAULT
222	22-Aug-20	TUMKUR	66	TR-2	HARIYABBE_66	5:06	6:23	1:16	TRANSFORMER FAULT
223	22-Aug-20	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUN DA_66	7:44	7:57	0:13	LINE FAULT
224	22-Aug-20	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	9:26	9:35	0:08	LINE FAULT
225	22-Aug-20	TUMKUR	66	PAVAGADA-NAGALAMADIKE	PAVAGADA_220	19:00	19:06	0:05	LINE FAULT
226	22-Aug-20	TUMKUR	66	RAMPURA66-WELSPUN SOLAR	WELSPUN SOLAR_IPP_66	11:48	11:55	0:06	LINE FAULT
227	22-Aug-20	TUMKUR	66	TR-1	RANGANATHAPURA_66	7:45	8:35	0:49	LINE CLAE AVALIED
228	22-Aug-20	TUMKUR	66	THALLAK 220kV -BGKERE 1	BGKERE_66	10:13	11:05	0:52	LINE FAULT
229	22-Aug-20	TUMKUR	66	THALLAK 220kV- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	10:13	10:21	0:07	HAND TRIPPED
230	22-Aug-20	TUMKUR	66	THALLAK 220kV- GOWRASAMUDRA	GOWRASAMUDRA_66	10:13	10:26	0:13	HAND TRIPPED
231	22-Aug-20	TUMKUR	66	TR-1(LV SIDE)	THALLAKK_220	10:06	10:31	0:25	TRANSFORMER FAULT
232	22-Aug-20	TUMKUR	66	THALLAK 220kV- SEI DIAMOND SOLAR IPP_66	SEL DIAMOND SOLAR_IPP_66	10:13	10:26	0:13	HAND TRIPPED
233	22-Aug-20	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:27	15:22	4:54	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
234	22-Aug-20	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	12:32	15:22	2:50	HAND TRIPPED
235	22-Aug-20	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUNSOLAR1_IPP_66	10:13	10:31	0:18	HAND TRIPPED
236	23-Aug-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN: LINE FAULT
237	23-Aug-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
238	23-Aug-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
239	23-Aug-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
240	23-Aug-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN:LINE CLEAR AVAILED
241	23-Aug-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020)			LINE OPEN:LINE CLEAR AVAILED
242	23-Aug-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:0 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
243	23-Aug-20	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	17:26 (24.07.2020)			LOAD CURTAILMENT
244	23-Aug-20	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
245	23-Aug-20	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
246	23-Aug-20	BAGALKOT	220	BELGAUM- NARENDRA2 (KANABARGI)	STATION NOT AFFECTED BELGAUM_220	22:18 (04.08.2020)			LINE OPEN:LINE CLEAR AVAILED
247	23-Aug-20	BAGALKOT	220	BAGEWADI-ATRIA 2	STATION NOT AFFECTED BAGEWADI_220	16:26 (17.08.2020)			LINE OPEN:LINE CLEAR AVAILED
248	23-Aug-20	BAGALKOT	220	GADAG-HARTHI1	GADAG_220	12:19 (17.08.2020)			LOAD CURTAILMENT
249	23-Aug-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN:LINE CLEAR AVAILED
250	23-Aug-20	BAGALKOT	220	CHIKKODI-BELGAUM2	CHIKKODI_220	23:44 (19.08.2020)			LOAD CURTAILMENT
251	23-Aug-20	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	14:09 (20.08.2020)			LINE OPEN:LINE CLEAR AVAILED
252	23-Aug-20	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	14:09 (20.08.2020)			LINE OPEN:LINE CLEAR AVAILED
253	23-Aug-20	BAGALKOT	110	220/110,LV1	MK HUBLI_220	14:56 (22.08.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
254	23-Aug-20	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	16:15 (22.08.2020)			LOAD CURTAILMENT
255	23-Aug-20	BAGALKOT	110	110/11KV, HV1	UCHAGOAN_110	9:45	14:21	4:36	TRANSFORMER FAULT
256	23-Aug-20	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	18:31	19:15	0:44	LINE CLAE AVAILED
257	23-Aug-20	BAGALKOT	220	HUBLI- SIRSI1&2	HUBLI_220	17:28 (23.08.2020)			LOAD CURTAILMENT
258	23-Aug-20	BAGALKOT	110	BIJAPUR-ENERCON(BAGEWADI)	BIJAPUR_220	15:13	15:25	0:12	LINE FAULT
259	23-Aug-20	BAGALKOT	110	HAVERI-HAVERI 110	HAVERI_110	11:00	11:42	0:42	LINE CLAE AVAILED
260	23-Aug-20	BAGALKOT	110	110/33KV,HV2	HUNGUND-110 & KARADI,AMINAGAD_33	16:20	16:26	0:06	TRANSFORMER FAULT
261	23-Aug-20	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	13:42	13:45	0:03	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
262	23-Aug-20	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	15:28	15:31	0:03	TRANSFORMER FAULT
263	23-Aug-20	BAGALKOT	110	ATHARGA-KN SOLAR	ATHRGA_110	18:55	20:06	1:11	LINE FAULT
264	23-Aug-20	BAGALKOT	110	220/110, LV2	MK HUBLI_220	12:43 (23.08.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
265	23-Aug-20	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	11:06	13:27	02:20	LINE CLAE AVAILED
266	23-Aug-20	BENGALURU	66	HV1	HEJJALA	16:22	16:30	00:08	TRANSFORMER FAULT
267	23-Aug-20	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 1 & 2	NO STATION AFFECTED	10:16(17/08/2020)			LINE OPEN:LINE CLEAR AVAILED
268	23-Aug-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
269	23-Aug-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN: LINE FAULT
270	23-Aug-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN: LINE FAULT
271	23-Aug-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN:LINE CLEAR AVAILED
272	23-Aug-20	GULBARGA	220	RAICHUR-JURALLA2	RAICHUR_220	5:56(19.8.2020)			LINE OPEN: LINE FAULT
273	23-Aug-20	GULBARGA	220	LINGAPUR-SINDHANOOR	LINGAPUR_220	23:04	23:55	00:51	LINE FAULT
274	23-Aug-20	GULBARGA	220	HUMNABAD-SEDAM1	HUMNABAD_220	12:13	12:41	00:28	LINE FAULT
275	23-Aug-20	GULBARGA	220	HV2	ITTAGI_220	11:37	11:45	00:08	TRANSFORMER FAULT
276	23-Aug-20	GULBARGA	220	HV1	ITTAGI_220	11:37	11:45	00:08	LINE CLAE AVAILED
277	23-Aug-20	GULBARGA	220	HV1	ITTAGI_220	13:53	13:55	00:02	LINE CLAE AVAILED
278	23-Aug-20	GULBARGA	220	HV2	KUSHTAGI_220	14:58	15:03	00:05	TRANSFORMER FAULT
279	23-Aug-20	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATTI_110	19:57	20:27	00:30	LINE FAULT
280	23-Aug-20	GULBARGA	110	KUSHTAGI-KANAKAGIRI	KANAKAGIRI_110,GANADAL_110	14:59	15:07	00:08	LINE FAULT
281	23-Aug-20	GULBARGA	110	HIREGONNAGAR-HANUMANAL	HANUMANAL_110	14:45	15:10	00:25	MAIN SUPPLY FAILURE
282	23-Aug-20	GULBARGA	110	HATTI-SMNMRD_IPP	HATTI_110	06:25	06:50	00:25	MAIN SUPPLY FAILURE
283	23-Aug-20	GULBARGA	110	WARDHA-RAJESHWAR	RAJESHWAR_110	12:15	12:45	00:30	LINE CLAE AVAILED
284	23-Aug-20	GULBARGA	110	MALLAT-VALKAMDINI	VALKAMDINI_110	19:51	20:02	00:11	MAIN SUPPLY FAILURE
285	23-Aug-20	GULBARGA	110	HV2	TAMBRAHALLI_66	14:03	15:21	01:18	LINE CLAE AVAILED
286	23-Aug-20	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITGUPPA_110,NIRNA_110	12:15	12:45	00:30	MAIN SUPPLY FAILURE
287	23-Aug-20	GULBARGA	66	LV1	ITTAGI_220	11:37	16:34	04:57	LINE CLAE AVAILED
288	23-Aug-20	GULBARGA	66	ITTAGGI-HIREHADAGALLI2	HIREHADAGALLI_66,SOVENAHALLI_66,GIRIYAPUR_66,MAGALA_66	09:30	09:44	00:14	LINE FAULT
289	23-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	22:32 (21.08.2020)	6:14 (23.08.2020)	31:41 hrs	LINE CHARGED
290	23-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:09 (23.08.2020)			LINE OPEN:LINE CLEAR AVAILED
291	23-Aug-20	HASSAN	110	JOG-NK2	NO STN AFFECTED	23:36 (7.08.2020)			LINE OPEN:LINE CLEAR AVAILED
292	23-Aug-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	10:03 (20.08.2020)			LINE OPEN:LINE CLEAR AVAILED
293	23-Aug-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:19 (22.08.2020)			LINE OPEN:LINE CLEAR AVAILED
294	23-Aug-20	HASSAN	220	KEMAR-Varahi1	KEMAR220	10:28	13:51	03:23	LINE FAULT
295	23-Aug-20	HASSAN	220	VARAHI-KEMAR1	varahi_gen	10:28	13:52	03:24	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
296	23-Aug-20	HASSAN	110	HV2	BAIKAMPADI_110	10:07	16:03	05:56	LINE CLAE AVAILED
297	23-Aug-20	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	07:45	09:52	02:07	LINE CLAE AVAILED
298	23-Aug-20	HASSAN	110	HV2	BARANGI_110	21:40	23:40	02:00	TRANSFORMER FAULT
299	23-Aug-20	HASSAN	110	PUTTUR-KARAYA	PUTTUR_220	06:14	06:26	00:12	LINE FAULT
300	23-Aug-20	HASSAN	66	HV1	DIDIGA_66	09:24	09:44	00:20	TRANSFORMER FAULT
301	23-Aug-20	MYSURU	66	RK NAGARA-MANTGALLI	NO STATIONS EFFECTED	6:23	18:45	12:22	LINE CLAE AVAILED
302	23-Aug-20	MYSURU	66	KADKOLA-MYSORE SOUTH	NO STATIONS EFFECTED	6:37	18:33	11:56	LINE CLAE AVAILED
303	23-Aug-20	MYSURU	66	KADKOLA-DK MAIDANA	NO STATIONS EFFECTED	13:26	18:33	5:07	LINE CLAE AVAILED
304	23-Aug-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
305	23-Aug-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT
306	23-Aug-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
307	23-Aug-20	TUMKUR	110	TR-1	TURUVEKERE_110	11:29	12:13	0:44	TRANSFORMER FAULT
308	23-Aug-20	TUMKUR	66	TR-2	BENKIKERE_66	13:55	14:30	0:35	LINE CLAE AVAILED
309	23-Aug-20	TUMKUR	66	TR-2	CHITRADURGA_66	16:35	16:43	0:07	TRANSFORMER FAULT
310	23-Aug-20	TUMKUR	66	HIRIYUR 220KV- CHITRADURGA(SIRA)	HIRIYUR_220	10:48	11:06	0:17	HAND TRIPPED
311	23-Aug-20	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	6:20	6:30	0:09	LINE FAULT
312	23-Aug-20	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	10:48	10:51	0:02	HAND TRIPPED
313	23-Aug-20	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	12:21	16:19	3:58	LINE FAULT
1	21-Aug-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN: LINE FAULT
2	21-Aug-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
3	21-Aug-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
4	21-Aug-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
5	21-Aug-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN:LINE CLEAR AVAILED
6	21-Aug-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020)			LINE OPEN:LINE CLEAR AVAILED
7	21-Aug-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:0 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
8	21-Aug-20	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	17:26 (24.07.2020)			LOAD CURTAILMENT
9	21-Aug-20	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
10	21-Aug-20	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
11	21-Aug-20	BAGALKOT	220	BELGAUM- NARENDRA2 (KANABARGI)	STATION NOT AFFECTED BELGAUM_220	22:18 (04.08.2020)			LINE OPEN:LINE CLEAR AVAILED
12	21-Aug-20	BAGALKOT	220	BAGEWADI-ATRIA 2	STATION NOT AFFECTED BAGEWADI_220	16:26 (17.08.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
13	21-Aug-20	BAGALKOT	220	GADAG-HARTHI1	GADAG_220	12:19 (17.08.2020)			LOAD CURTAILMENT
14	21-Aug-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN:LINE CLEAR AVAILED
15	21-Aug-20	BAGALKOT	220	CHIKKODI-BELGAUM2	CHIKKODI_220	23:44 (19.08.2020)			LOAD CURTAILMENT
16	21-Aug-20	BAGALKOT	110	220/110,LV2	MK HUBLI_220	21:22 (19.08.2020)	9:54 (20.08.2020)	11:32hrs	TRANSFORMER CHARGED
17	21-Aug-20	BAGALKOT	110	220/110,LV1	MK HUBLI_220	23:08 (19.08.2020)	6:20 (20.08.2020)	7:12hrs	TRANSFORMER CHARGED
18	21-Aug-20	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	10:55:00 PM (20.08.2020)	9:12 (21.08.2020)	22:17hrs	LOAD CURTAILMENT
19	21-Aug-20	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	21:38 (20.08.2020)	10:50 (21.08.2020)	13:22hrs	LINE CHARGED
20	21-Aug-20	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	14:09 (20.08.2020)			LINE OPEN:LINE CLEAR AVAILED
21	21-Aug-20	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	14:09 (20.08.2020)			LINE OPEN:LINE CLEAR AVAILED
22	21-Aug-20	BAGALKOT	110	VAJRAMATTI220- MANTUR (MUDHOL)	MUDHOL_110	11:02	11:07	0:05	HAND TRIPPED
23	21-Aug-20	BAGALKOT	110	220/110KV, LV3	HUBLI_220	10:57	15:13	4:16	LINE CLAE AVAILED
24	21-Aug-20	BAGALKOT	110	HUBLI- RAMANKOPPA	RAMANKOPPA_110	14:26	14:36	0:10	HAND TRIPPED
25	21-Aug-20	BAGALKOT	110	HUBLI-BIDNAL2	HUBLI_220	9:49	12:08	2:19	LINE CLAE AVAILED
26	21-Aug-20	BAGALKOT	110	110/11KV,HV4	SADALAGA_110	6:58	10:57	3:59	TRANSFORMER FAULT
27	21-Aug-20	BAGALKOT	110	110/11KV, HV1	MKHUBLI_110	15:51	16:02	0:11	LINE CLAE AVAILED
28	21-Aug-20	BAGALKOT	110	110/11KV, HV1	MKHUBLI_110	15:25	15:31	0:06	LINE CLAE AVAILED
29	21-Aug-20	BAGALKOT	110	MK HUBLI- KITTUR	KITTUR_110	15:26	15:31	0:05	LINE CLAE AVAILED
30	21-Aug-20	BAGALKOT	110	MAMDAPUR(B)- SHIRBUR	SHIRBUR_110	6:37	6:51	0:14	HAND TRIPPED
31	21-Aug-20	BAGALKOT	110	110/33KV, HV3	MAMDAPUR(B)_110, DEVARGENNUR_33, LINGADALLI LIS 33	6:37	7:01	0:24	TRANSFORMER FAULT
32	21-Aug-20	BAGALKOT	110	RANNABELAGALI- UTTUR	UTTUR_110	10:29	10:52	0:23	LINE FAULT
33	21-Aug-20	BAGALKOT	110	RANNABELAGALI- UTTUR	UTTUR_110	11:05	14:02	2:57	HAND TRIPPED
34	21-Aug-20	BAGALKOT	110	BAGEWADI- MAMADAPUR(B)	MAMADAPUR(B)_110	6:21	6:35	0:14	LINE FAULT
35	21-Aug-20	BAGALKOT	110	110/11KV, HV1	GULEDGUDDA_110	16:12	16:18	0:06	TRANSFORMER FAULT
36	21-Aug-20	BAGALKOT	110	HAVERI-SAVANUR	SAVANUR_110	9:21	11:28	2:07	LINE FAULT
37	21-Aug-20	BAGALKOT	110	110/11KV,HV1	HIDIKAL_110	16:07	17:31	1:24	TRANSFORMER FAULT
38	21-Aug-20	BAGALKOT	110	110/11KV,HV1A&HV2A	JAMAKHANDI_110	15:00	15:59	0:59	LINE CLAE AVAILED
39	21-Aug-20	BENGALURU	220	VRISHBHAVATHI 220 - TATAGUNI 220 (EHT)	VRISHBHAVATHI 220	11:52	12:29	00:37	LINE FAULT
40	21-Aug-20	BENGALURU	220	VRISHBHAVATHI 220 - TATAGUNI 220 (EHT)	VRISHBHAVATHI 220	15:35	17:15	01:40	LINE FAULT
41	21-Aug-20	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	15:16	15:22	00:06	LOAD CHANGE OVER
42	21-Aug-20	BENGALURU	66	TK HALLI 220 - SHIMSHA	NO STATION AFFECTED	07:49	08:40	00:50	LINE CLAE AVAILED
43	21-Aug-20	BENGALURU	66	VRISHBHAVATHI 220 - BANASHANKARI	BANASHANKARI	11:54	12:13	00:18	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
44	21-Aug-20	BENGALURU	66	VRISHBHAVATHI 220 - BANASHANKARI	BANASHANKARI	15:35	15:48	00:13	MAIN SUPPLY FAILURE
45	21-Aug-20	BENGALURU	66	KENGERI SATELLITE TOWN - KUMBALAGODU	KENGERI SATELLITE TOWN	13:18	13:21	00:03	LOAD CHANGE OVER
46	21-Aug-20	BENGALURU	66	KENGERI SATELLITE TOWN - KUMBALAGODU	KENGERI SATELLITE TOWN	17:40	17:45	00:05	LOAD CHANGE OVER
47	21-Aug-20	BENGALURU	66	KENGERI SATELLITE TOWN - SIR MV LAYOUT	KENGERI SATELLITE TOWN	11:51	12:26	00:35	MAIN SUPPLY FAILURE
48	21-Aug-20	BENGALURU	66	KENGERI SATELLITE TOWN - SIR MV LAYOUT	KENGERI SATELLITE TOWN	15:37	16:09	00:32	MAIN SUPPLY FAILURE
49	21-Aug-20	BENGALURU	66	SIR MV LAYOUT - VRISHBHAVATHI 220	SIR MV LAYOUT	11:51	12:40	00:49	MAIN SUPPLY FAILURE
50	21-Aug-20	BENGALURU	66	SIR MV LAYOUT - VRISHBHAVATHI 220	SIR MV LAYOUT	15:37	17:20	01:43	MAIN SUPPLY FAILURE
51	21-Aug-20	BENGALURU	220	HOODY 220 - MALUR 220	NO STATION AFFECTED	11:17	15:30	04:12	LINE FAULT
52	21-Aug-20	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	09:41	09:43	00:02	LOAD CHANGE OVER
53	21-Aug-20	BENGALURU	66	NELAMANGALA 66 - ALUR	NELAMANGALA 66	09:35	09:45	00:10	LINE CLAE AVAILED
54	21-Aug-20	BENGALURU	66	REMCO - VRISHBHAVATHI 220	REMCO	11:51	12:40	00:49	MAIN SUPPLY FAILURE
55	21-Aug-20	BENGALURU	66	REMCO - VRISHBHAVATHI 220	REMCO	15:36	16:21	00:45	MAIN SUPPLY FAILURE
56	21-Aug-20	BENGALURU	66	REMCO - NRS	REMCO	21:40	22:05	00:25	LOAD CHANGE OVER
57	21-Aug-20	BENGALURU	220	HV1	VRISHBHAVATHI 220	11:52	12:29	00:37	MAIN SUPPLY FAILURE
58	21-Aug-20	BENGALURU	220	HV2	VRISHBHAVATHI 220	15:35	17:15	01:40	MAIN SUPPLY FAILURE
59	21-Aug-20	BENGALURU	220	HV1	VRISHBHAVATHI 220	11:52	12:29	00:37	MAIN SUPPLY FAILURE
60	21-Aug-20	BENGALURU	220	HV2	VRISHBHAVATHI 220	15:35	17:15	01:40	MAIN SUPPLY FAILURE
61	21-Aug-20	BENGALURU	66	CHANDRALAYOUT - VRISHBHAVATHI 220	CHANDRA LAYOUT	11:51	12:36	00:45	MAIN SUPPLY FAILURE
62	21-Aug-20	BENGALURU	66	CHANDRALAYOUT - VRISHBHAVATHI 220	CHANDRA LAYOUT	15:35	15:37	00:02	MAIN SUPPLY FAILURE
63	21-Aug-20	BENGALURU	66	CHANDRALAYOUT - NRS 220		21:36	21:41	00:05	LOAD CHANGE OVER
64	21-Aug-20	BENGALURU	66	HV1	VIJAYANAGARA	11:51	12:06	00:15	MAIN SUPPLY FAILURE
65	21-Aug-20	BENGALURU	66	HV1	VIJAYANAGARA	15:35	16:20	00:45	MAIN SUPPLY FAILURE
66	21-Aug-20	BENGALURU	66	HV1	VIJAYANAGARA	22:06	22:35	00:29	LOAD CHANGE OVER
67	21-Aug-20	BENGALURU	66	HV2	NRS 220	22:36	22:40	00:04	LOAD CHANGE OVER
68	21-Aug-20	BENGALURU	220	SOMANAHALLI 220 - TATAGUNI(EHT)	NO STATION AFFECTED	11:51	12:04	00:13	LINE FAULT
69	21-Aug-20	BENGALURU	220	SOMANAHALLI 220 - TATAGUNI(EHT)	NO STATION AFFECTED	12:38	17:30	04:52	LINE FAULT
70	21-Aug-20	BENGALURU	66	RMV - GOKULA	RMV	13:28	13:33	00:05	LINE CLAE AVAILED
71	21-Aug-20	BENGALURU	66	HV1	BANGARPETE	13:55	14:07	00:12	TRANSFORMER FAULT
72	21-Aug-20	BENGALURU	66	HV1	BANGARPETE	14:55	15:06	00:11	TRANSFORMER FAULT
73	21-Aug-20	BENGALURU	66	HV1	SIDDLAGHATTA	14:49	15:19	00:30	LINE CLAE AVAILED
74	21-Aug-20	BENGALURU	66	HV2	HOSUR RAMAPURA	21:25:00(20/08/2020)	12:06(21/08/2020)	14:41HRS	TRANSFORMER CHARGED
75	21-Aug-20	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 1 & 2	NO STATION AFFECTED	10:16(17/08/2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
76	21-Aug-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
77	21-Aug-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN: LINE FAULT
78	21-Aug-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN: LINE FAULT
79	21-Aug-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN:LINE CLEAR AVAILED
80	21-Aug-20	GULBARGA	220	RAICHUR-JURALLA2	RAICHUR_220	5:56(19.8.2020)			LINE OPEN: LINE FAULT
81	21-Aug-20	GULBARGA	400	BTPSG-HIRIYUR1	HIRIYUR_400	1:03(21.08.2020)			LINE OPEN:LINE CLEAR AVAILED
89	21-Aug-20	GULBARGA	220	RAICHUR-RTPS1	RAICHUR_220	13:57(19.8.2020)	11:44(21.8.2020)	21:47HRS	LINE CHARGED
90	21-Aug-20	GULBARGA	220	HV1	KUSHTAGI_220	12:28	12:53	00:25	TRANSFORMER FAULT
91	21-Aug-20	GULBARGA	220	HV2	KUSHTAGI_220	13:19	13:38	00:19	TRANSFORMER FAULT
92	21-Aug-20	GULBARGA	110	KUSHTAGI-KANAKAGIRI	KANAKAGIRI_110,GANADAL_110	13:18	13:47	00:29	LINE FAULT
93	21-Aug-20	GULBARGA	110	HATTI-SMNMRD_IPP	HATTI_110	05:48	06:36	00:48	LINE FAULT
94	21-Aug-20	GULBARGA	110	HV3	HATTI_110	05:48	06:15	00:27	TRANSFORMER FAULT
95	21-Aug-20	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110	05:07	05:21	00:14	LINE FAULT
96	21-Aug-20	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSLSUGSARFACTORY_I PP,CHOWDAPUR_110	05:56	06:09	00:13	LINE FAULT
97	21-Aug-20	GULBARGA	110	KUSHTAGI-HANUMANAL	HANUMANAL_110	13:20	13:50	00:30	MAIN SUPPLY FAILURE
98	21-Aug-20	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	00:48	06:00	05:12	LINE FAULT
99	21-Aug-20	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	20:15	20:35	00:20	LINE CLAE AVAILED
100	21-Aug-20	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	23:10(21.08.2020)			LINE OPEN: LINE FAULT
101	21-Aug-20	GULBARGA	110	SINDHANOOR-PGLR_WIND	SINDHANOOR_220	03:55	04:20	00:25	LINE FAULT
102	21-Aug-20	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	05:06	05:21	00:15	LINE FAULT
103	21-Aug-20	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSLSUGSARFACTORY_I PP,CHOWDAPUR_110	05:56	06:08	00:12	LINE FAULT
104	21-Aug-20	GULBARGA	66	HV2	TAMBRAHALLI_66	11:23	13:10	01:47	LINE CLAE AVAILED
105	21-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:53 (20.08.2020)	7:02 (21.8.2020)	7:08 hrs	LINE CHARGED
106	21-Aug-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	16:42 (17.08.2020)	7:25 (21.08.2020)	86:42 hrs	LINE CHARGED
107	21-Aug-20	HASSAN	110	JOG-NK2	NO STN AFFECTED	23:36 (7.08.2020)			LINE OPEN:LINE CLEAR AVAILED
108	21-Aug-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	10:03 (20.08.2020)			LINE OPEN:LINE CLEAR AVAILED
109	21-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	22:32 (21.08.2020)			LINE OPEN:LINE CLEAR AVAILED
110	21-Aug-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:09 (21.08.2020)			LINE OPEN:LINE CLEAR AVAILED
111	21-Aug-20	HASSAN	110	HV	PUTTUR_220	10:43	13:15	02:32	LINE CLAE AVAILED
112	21-Aug-20	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	11:26	12:42	01:16	LINE CLAE AVAILED
113	21-Aug-20	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	11:39	11:54	00:15	MAIN SUPPLY FAILURE
114	21-Aug-20	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	11:39	11:42	00:03	MAIN SUPPLY FAILURE
115	21-Aug-20	HASSAN	66	HV1	DIDIGA_66	07:46	07:57	00:11	TRANSFORMER FAULT
116	21-Aug-20	MYSURU	66	HV1	CHUNCHUNKATTE_66	12:12	13:27	1:15	LINE CLAE AVAILED
117	21-Aug-20	MYSURU	66	HV1	HALAGUR_66	12:20	15:00	2:40	LINE CLAE AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
118	21-Aug-20	MYSURU	66	KUSHALNAGARA 220-SUNTIKOPPA	NO STATIONS EFFECTED	5:51	5:56	0:05	LINE FAULT
119	21-Aug-20	MYSURU	66	HV1	MADIKERI_66	11:20	11:30	0:09	HAND TRIPPED
120	21-Aug-20	MYSURU	66	HV2	MADIKERI_66	9:06	11:19	2:12	TRANSFORMER FAULT
121	21-Aug-20	MYSURU	66	SFC SIVA-PGL	NO STATIONS EFFECTED	6:40	6:44	0:03	LINE FAULT
122	21-Aug-20	MYSURU	66	SFC SIVA-HEBBANI-7	NO STATIONS EFFECTED	6:40	7:00	0:20	LINE FAULT
123	21-Aug-20	MYSURU	66	PARINAMIPURA-TALKADU	THALAKADU_66 CHANDALLI_66	6:03	6:08	0:05	LINE FAULT
124	21-Aug-20	MYSURU	66	TUBINKERE-MC-4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66 ADDIHALLI_66 BASARALU_66	6:33	6:43	0:10	LINE FAULT
125	21-Aug-20	MYSURU	66	TUBINKERE-NAGMANGALA 1	HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 VADERALLI_66	8:50	8:58	0:07	LINE FAULT
126	21-Aug-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
127	21-Aug-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT
128	21-Aug-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
129	21-Aug-20	TUMKUR	220	TR-3	HIRIYUR_220	14:12	14:20	0:08	TRANSFORMER FAULT
130	21-Aug-20	TUMKUR	220	THALLAK 220kV-CHITRADURGA	THALLAKK_220	11:17	17:55	6:38	LINE CLAE AVAILED
131	21-Aug-20	TUMKUR	220	THALLAK 220kV- SEI DIAMOND SOLAR IPP_66	SEL DIAMOND SOLAR_IPP_66	13:17	14:21	1:03	LINE CLAE AVAILED
132	21-Aug-20	TUMKUR	110	TR-1	DODDAGUNI_110	14:08	14:27	0:19	LINE CLAE AVAILED
133	21-Aug-20	TUMKUR	110	TR-1	KGTEMPLE_110	16:01	16:10	0:09	LINE CLAE AVAILED
134	21-Aug-20	TUMKUR	66	TR-1	DAVANAGERE_66	12:36	13:29	0:52	LINE CLAE AVAILED
135	21-Aug-20	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	22:53	23:21	0:27	LINE FAULT
136	21-Aug-20	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	22:53	23:16	0:23	LINE FAULT
137	21-Aug-20	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	14:19	14:26	0:07	LINE FAULT
138	21-Aug-20	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	11:05	11:17	0:12	HAND TRIPPED
139	21-Aug-20	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	14:19	14:25	0:05	HAND TRIPPED
140	21-Aug-20	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	14:18	14:25	0:07	HAND TRIPPED
141	21-Aug-20	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	13:43	13:50	0:06	HAND TRIPPED
142	21-Aug-20	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	14:18	14:56	0:37	HAND TRIPPED
143	21-Aug-20	TUMKUR	66	TR-2	HULIYURDURGA_66	11:50	13:49	1:58	LINE CLAE AVAILED
144	21-Aug-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:04	12:10	0:05	LINE FAULT
145	21-Aug-20	TUMKUR	66	THALLAK 220kV -BGKERE 1	BGKERE_66	12:44	12:56	0:11	HAND TRIPPED
146	22-Aug-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN: LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
147	22-Aug-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
148	22-Aug-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
149	22-Aug-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
150	22-Aug-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN:LINE CLEAR AVAILED
151	22-Aug-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020)			LINE OPEN:LINE CLEAR AVAILED
152	22-Aug-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:0 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
153	22-Aug-20	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	17:26 (24.07.2020)			LOAD CURTAILMENT
154	22-Aug-20	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
155	22-Aug-20	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
156	22-Aug-20	BAGALKOT	220	BELGAUM- NARENDRA2 (KANABARGI)	STATION NOT AFFECTED BELGAUM_220	22:18 (04.08.2020)			LINE OPEN:LINE CLEAR AVAILED
157	22-Aug-20	BAGALKOT	220	BAGEWADI-ATRIA 2	STATION NOT AFFECTED BAGEWADI_220	16:26 (17.08.2020)			LINE OPEN:LINE CLEAR AVAILED
158	22-Aug-20	BAGALKOT	220	GADAG-HARTHI1	GADAG_220	12:19 (17.08.2020)			LOAD CURTAILMENT
159	22-Aug-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN:LINE CLEAR AVAILED
160	22-Aug-20	BAGALKOT	220	CHIKKODI-BELGAUM2	CHIKKODI_220	23:44 (19.08.2020)			LOAD CURTAILMENT
161	22-Aug-20	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	14:09 (20.08.2020)			LINE OPEN:LINE CLEAR AVAILED
162	22-Aug-20	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	14:09 (20.08.2020)			LINE OPEN:LINE CLEAR AVAILED
163	22-Aug-20	BAGALKOT	110	110/33KV,HV2	HUNGUND-110 & KARADI,AMINAGAD_33	11:09	11:15	0:06	TRANSFORMER FAULT
164	22-Aug-20	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	16:15 (22.08.2020)			LOAD CURTAILMENT
165	22-Aug-20	BAGALKOT	110	220/110,LV1	MK HUBLI_220	14:56 (22.08.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
166	22-Aug-20	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	NO STATION AFFECTED	14:36	21:05	06:29	LINE FAULT
167	22-Aug-20	BENGALURU	220	HV2	SOMANAHALLI 220	14:36	15:33	00:57	TRANSFORMER FAULT
168	22-Aug-20	BENGALURU	220	HV3	SOMANAHALLI 220	14:36	15:10	00:34	TRANSFORMER FAULT
169	22-Aug-20	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	14:36	15:11	00:35	LINE CLAE AVAILED
170	22-Aug-20	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 1 & 2	NO STATION AFFECTED	10:16(17/08/2020)			LINE OPEN:LINE CLEAR AVAILED
171	22-Aug-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
172	22-Aug-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN: LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
173	22-Aug-20	GULBARGA	400	BTPSG-HIRIYUR1	HIRIYUR_400	1:03(21.8.2020)	9:08(22.8.2020)	32:05HRS	LINE CHARGED
174	22-Aug-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN: LINE FAULT
175	22-Aug-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN:LINE CLEAR AVAILED
176	22-Aug-20	GULBARGA	220	RAICHUR-JURALLA2	RAICHUR_220	5:56(19.8.2020)			LINE OPEN: LINE FAULT
177	22-Aug-20	GULBARGA	220	RAICHUR-RTPS2	RAICHUR_220	10:22	22:50	12:28	LINE CLAE AVOIDED
178	22-Aug-20	GULBARGA	220	HV1	KUSHTAGI_220	09:47	09:51	00:04	TRANSFORMER FAULT
179	22-Aug-20	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	07:00	18:25	11:25	LINE CLAE AVOIDED
180	22-Aug-20	GULBARGA	110	HV1	KURKUNTA_110	16:05	17:10	01:05	LINE CLAE AVOIDED
181	22-Aug-20	GULBARGA	110	HV3	DEODURGA_110	11:15	11:20	00:05	LINE CLAE AVOIDED
182	22-Aug-20	GULBARGA	110	CHINCHOLI-SEDAM	CHINCHOLI_110	06:45	07:05	00:20	LINE FAULT
183	22-Aug-20	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	23:10(21.8.2020)	00:06	0:56HRS	LINE CHARGED
184	22-Aug-20	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	02:04	02:15	00:11	LINE FAULT
185	22-Aug-20	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	23:15	23:21	00:06	LINE FAULT
186	22-Aug-20	GULBARGA	110	HUMNABAD-BIDAR1	HALIKHED_110	11:11	11:18	00:07	LINE FAULT
187	22-Aug-20	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPURA_110,MANVI_110,KURDI CROSS_110	05:32	05:48	00:16	LINE FAULT
188	22-Aug-20	GULBARGA	110	RAICHUR-SHAHAPUR1	DEODURGA_110,GABUR_110	01:21	01:30	00:09	LINE FAULT
189	22-Aug-20	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	01:21	01:30	00:09	LINE FAULT
190	22-Aug-20	GULBARGA	110	RAICHUR-SINDHANOOR1	VALKAMDINNI_110	06:19	06:30	00:11	LINE FAULT
191	22-Aug-20	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	22:59	23:08	00:09	LINE FAULT
192	22-Aug-20	GULBARGA	66	ITTAGGI-HUVINAHADAGALLI	HUVINA_HADAGALLI_66	07:36	07:44	00:08	LINE FAULT
193	22-Aug-20	GULBARGA	66	ITTAGGI-SUZLON1	ITTAGI_220	15:14	15:22	00:08	LINE FAULT
194	22-Aug-20	GULBARGA	66	ITTAGGI-SUZLON1	ITTAGI_220	18:00	18:39	00:39	LINE FAULT
195	22-Aug-20	GULBARGA	66	ITTAGGI-SUZLON1	ITTAGI_220	21:26	21:33	00:07	LINE FAULT
196	22-Aug-20	GULBARGA	66	ITTAGGI-KUDLIGI2	KUDLIGI_66,CJHALLI_66,HANASI_66,H OSAHALLI_66,BANAVEKAL_66,CHORN OOR_66,GUDEKOTE_66	19:22	19:30	00:08	LINE FAULT
197	22-Aug-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:09 (21.08.2020)	9:03 (22.08.2020)	10:53 hrs	LINE CHARGED
198	22-Aug-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:19 (22.08.2020)			LINE OPEN:LINE CLEAR AVAILED
199	22-Aug-20	HASSAN	110	JOG-NK2	NO STN AFFECTED	23:36 (7.08.2020)			LINE OPEN:LINE CLEAR AVAILED
200	22-Aug-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	10:03 (20.08.2020)			LINE OPEN:LINE CLEAR AVAILED
201	22-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	22:32 (21.08.2020)			LINE OPEN:LINE CLEAR AVAILED
202	22-Aug-20	HASSAN	110	MRSSHM-BADRAVATY1	MRS MG_220	10:07	11:03	00:56	HAND TRIPPED
203	22-Aug-20	HASSAN	110	MRSSHM-BADRAVATY2	MRS MG_220	10:07	11:03	00:56	HAND TRIPPED
204	22-Aug-20	HASSAN	110	NANDIKU-ISTR	NANDIKUR_110	14:15	14:38	00:23	LINE FAULT
205	22-Aug-20	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	07:51	07:59	00:08	LINE FAULT
206	22-Aug-20	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	11:23	12:20	00:57	LINE CLAE AVOIDED
207	22-Aug-20	HASSAN	66	KIADB H-RAMESWARNAGAR	KIADB_66	07:21	07:30	00:09	LINE FAULT
208	22-Aug-20	MYSURU	66	VAJMANGALA-KADKOLA 2	NO STATIONS EFFECTED	18:33	18:38	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
209	22-Aug-20	MYSURU	66	KADKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66 ANTHARSANTHE_66 HDKOTE_66,	14:25	14:30	0:05	LINE FAULT
210	22-Aug-20	MYSURU	66	KADKOLA-DK MAIDANA	DKMAIDANA_66	17:13	17:17	0:04	LINE FAULT
211	22-Aug-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
212	22-Aug-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT
213	22-Aug-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
214	22-Aug-20	TUMKUR	66	BANUVALLI- NANDUGUDI	BANUVALLI_66	10:46	10:52	0:06	LINE FAULT
215	22-Aug-20	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	0:14	1:34	1:20	HAND TRIPPED
216	22-Aug-20	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	3:09	3:31	0:21	HAND TRIPPED
217	22-Aug-20	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	5:06	6:28	1:22	HAND TRIPPED
218	22-Aug-20	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	0:14	1:11	0:56	HAND TRIPPED
219	22-Aug-20	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	3:09	3:24	0:14	HAND TRIPPED
220	22-Aug-20	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	5:06	5:26	0:19	HAND TRIPPED
221	22-Aug-20	TUMKUR	66	TR-2	HARIYABBE_66	3:09	3:27	0:17	TRANSFORMER FAULT
222	22-Aug-20	TUMKUR	66	TR-2	HARIYABBE_66	5:06	6:23	1:16	TRANSFORMER FAULT
223	22-Aug-20	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUN DA_66	7:44	7:57	0:13	LINE FAULT
224	22-Aug-20	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	9:26	9:35	0:08	LINE FAULT
225	22-Aug-20	TUMKUR	66	PAVAGADA-NAGALAMADIKE	PAVAGADA_220	19:00	19:06	0:05	LINE FAULT
226	22-Aug-20	TUMKUR	66	RAMPURA66-WELSPUN SOLAR	WELSPUN SOLAR_IPP_66	11:48	11:55	0:06	LINE FAULT
227	22-Aug-20	TUMKUR	66	TR-1	RANGANATHAPURA_66	7:45	8:35	0:49	LINE CLAE AVAILED
228	22-Aug-20	TUMKUR	66	THALLAK 220kv -BGKERE 1	BGKERE_66	10:13	11:05	0:52	LINE FAULT
229	22-Aug-20	TUMKUR	66	THALLAK 220kv- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	10:13	10:21	0:07	HAND TRIPPED
230	22-Aug-20	TUMKUR	66	THALLAK 220kv- GOWRASAMUDRA	GOWRASAMUDRA_66	10:13	10:26	0:13	HAND TRIPPED
231	22-Aug-20	TUMKUR	66	TR-1(LV SIDE)	THALLAKK_220	10:06	10:31	0:25	TRANSFORMER FAULT
232	22-Aug-20	TUMKUR	66	THALLAK 220kv- SEI DIAMOND SOLAR_IPP_66	SEL DIAMOND SOLAR_IPP_66	10:13	10:26	0:13	HAND TRIPPED
233	22-Aug-20	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	10:27	15:22	4:54	HAND TRIPPED
234	22-Aug-20	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	12:32	15:22	2:50	HAND TRIPPED
235	22-Aug-20	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR2	WELSPUNSOLAR1_IPP_66	10:13	10:31	0:18	HAND TRIPPED
236	23-Aug-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN: LINE FAULT
237	23-Aug-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
238	23-Aug-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
239	23-Aug-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
240	23-Aug-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN:LINE CLEAR AVAILED
241	23-Aug-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
242	23-Aug-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:0 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
243	23-Aug-20	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	17:26 (24.07.2020)			LOAD CURTAILMENT
244	23-Aug-20	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
245	23-Aug-20	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
246	23-Aug-20	BAGALKOT	220	BELGAUM- NARENDRA2 (KANABARGI)	STATION NOT AFFECTED BELGAUM_220	22:18 (04.08.2020)			LINE OPEN:LINE CLEAR AVAILED
247	23-Aug-20	BAGALKOT	220	BAGEWADI-ATRIA 2	STATION NOT AFFECTED BAGEWADI_220	16:26 (17.08.2020)			LINE OPEN:LINE CLEAR AVAILED
248	23-Aug-20	BAGALKOT	220	GADAG-HARTHI1	GADAG_220	12:19 (17.08.2020)			LOAD CURTAILMENT
249	23-Aug-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN:LINE CLEAR AVAILED
250	23-Aug-20	BAGALKOT	220	CHIKKODI-BELGAUM2	CHIKKODI_220	23:44 (19.08.2020)			LOAD CURTAILMENT
251	23-Aug-20	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	14:09 (20.08.2020)			LINE OPEN:LINE CLEAR AVAILED
252	23-Aug-20	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	14:09 (20.08.2020)			LINE OPEN:LINE CLEAR AVAILED
253	23-Aug-20	BAGALKOT	110	220/110,LV1	MK HUBLI_220	14:56 (22.08.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
254	23-Aug-20	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	16:15 (22.08.2020)			LOAD CURTAILMENT
255	23-Aug-20	BAGALKOT	110	110/11KV, HV1	UCHAGOAN_110	9:45	14:21	4:36	TRANSFORMER FAULT
256	23-Aug-20	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	18:31	19:15	0:44	LINE CLAE AVAILED
257	23-Aug-20	BAGALKOT	220	HUBLI- SIRSI1&2	HUBLI_220	17:28 (23.08.2020)			LOAD CURTAILMENT
258	23-Aug-20	BAGALKOT	110	BIJAPUR-ENERCON(BAGEWADI)	BIJAPUR_220	15:13	15:25	0:12	LINE FAULT
259	23-Aug-20	BAGALKOT	110	HAVERI-HAVERI 110	HAVERI_110	11:00	11:42	0:42	LINE CLAE AVAILED
260	23-Aug-20	BAGALKOT	110	110/33KV,HV2	HUNGUND-110 & KARADI,AMINAGAD 33	16:20	16:26	0:06	TRANSFORMER FAULT
261	23-Aug-20	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	13:42	13:45	0:03	TRANSFORMER FAULT
262	23-Aug-20	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	15:28	15:31	0:03	TRANSFORMER FAULT
263	23-Aug-20	BAGALKOT	110	ATHARGA-KN SOLAR	ATHRGA_110	18:55	20:06	1:11	LINE FAULT
264	23-Aug-20	BAGALKOT	110	220/110,LV2	MK HUBLI_220	12:43 (23.08.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
265	23-Aug-20	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	11:06	13:27	02:20	LINE CLAE AVAILED
266	23-Aug-20	BENGALURU	66	HV1	HEJJALA	16:22	16:30	00:08	TRANSFORMER FAULT
267	23-Aug-20	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 1 & 2	NO STATION AFFECTED	10:16(17/08/2020)			LINE OPEN:LINE CLEAR AVAILED
268	23-Aug-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
269	23-Aug-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN: LINE FAULT
270	23-Aug-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN: LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
271	23-Aug-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN:LINE CLEAR AVAILED
272	23-Aug-20	GULBARGA	220	RAICHUR-JURALLA2	RAICHUR_220	5:56(19.8.2020)			LINE OPEN: LINE FAULT
273	23-Aug-20	GULBARGA	220	LINGAPUR-SINDHANOOR	LINGAPUR_220	23:04	23:55	00:51	LINE FAULT
274	23-Aug-20	GULBARGA	220	HUMNABAD-SEDAM1	HUMNABAD_220	12:13	12:41	00:28	LINE FAULT
275	23-Aug-20	GULBARGA	220	HV2	ITTAGI_220	11:37	11:45	00:08	TRANSFORMER FAULT
276	23-Aug-20	GULBARGA	220	HV1	ITTAGI_220	11:37	11:45	00:08	LINE CLAE AVAILED
277	23-Aug-20	GULBARGA	220	HV1	ITTAGI_220	13:53	13:55	00:02	LINE CLAE AVAILED
278	23-Aug-20	GULBARGA	220	HV2	KUSHTAGI_220	14:58	15:03	00:05	TRANSFORMER FAULT
279	23-Aug-20	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATTI_110	19:57	20:27	00:30	LINE FAULT
280	23-Aug-20	GULBARGA	110	KUSHTAGI-KANAKAGIRI	KANAKAGIRI_110,GANADAL_110	14:59	15:07	00:08	LINE FAULT
281	23-Aug-20	GULBARGA	110	HIREGONNAGAR-HANUMANAL	HANUMANAL_110	14:45	15:10	00:25	MAIN SUPPLY FAILURE
282	23-Aug-20	GULBARGA	110	HATTI-SMNMRD_IPP	HATTI_110	06:25	06:50	00:25	MAIN SUPPLY FAILURE
283	23-Aug-20	GULBARGA	110	WARDHA-RAJESHWAR	RAJESHWAR_110	12:15	12:45	00:30	LINE CLAE AVAILED
284	23-Aug-20	GULBARGA	110	MALLAT-VALKAMDINI	VALKAMDINI_110	19:51	20:02	00:11	MAIN SUPPLY FAILURE
285	23-Aug-20	GULBARGA	110	HV2	TAMBRAHALLI_66	14:03	15:21	01:18	LINE CLAE AVAILED
286	23-Aug-20	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITGUPPA_110,NIRNA_110	12:15	12:45	00:30	MAIN SUPPLY FAILURE
287	23-Aug-20	GULBARGA	66	LV1	ITTAGI_220	11:37	16:34	04:57	LINE CLAE AVAILED
288	23-Aug-20	GULBARGA	66	ITTAGGI-HIREHADAGALLI2	HIREHADAGALLI_66,SOVENAHALLI_66,GIRIYAPUR_66,MAGALA_66	09:30	09:44	00:14	LINE FAULT
289	23-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	22:32 (21.08.2020)	6:14 (23.08.2020)	31:41 hrs	LINE CHARGED
290	23-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:09 (23.08.2020)			LINE OPEN:LINE CLEAR AVAILED
291	23-Aug-20	HASSAN	110	JOG-NK2	NO STN AFFECTED	23:36 (7.08.2020)			LINE OPEN:LINE CLEAR AVAILED
292	23-Aug-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	10:03 (20.08.2020)			LINE OPEN:LINE CLEAR AVAILED
293	23-Aug-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:19 (22.08.2020)			LINE OPEN:LINE CLEAR AVAILED
294	23-Aug-20	HASSAN	220	KEMAR-Varahi1	KEMAR220	10:28	13:51	03:23	LINE FAULT
295	23-Aug-20	HASSAN	220	VARAHI-KEMAR1	varahi_gen	10:28	13:52	03:24	LINE FAULT
296	23-Aug-20	HASSAN	110	HV2	BAIKAMPADI_110	10:07	16:03	05:56	LINE CLAE AVAILED
297	23-Aug-20	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	07:45	09:52	02:07	LINE CLAE AVAILED
298	23-Aug-20	HASSAN	110	HV2	BARANGI_110	21:40	23:40	02:00	TRANSFORMER FAULT
299	23-Aug-20	HASSAN	110	PUTTUR-KARAYA	PUTTUR_220	06:14	06:26	00:12	LINE FAULT
300	23-Aug-20	HASSAN	66	HV1	DIDIGA_66	09:24	09:44	00:20	TRANSFORMER FAULT
301	23-Aug-20	MYSURU	66	RK NAGARA-MANTGALLI	NO STATIONS EFFECTED	6:23	18:45	12:22	LINE CLAE AVAILED
302	23-Aug-20	MYSURU	66	KADKOLA-MYSORE SOUTH	NO STATIONS EFFECTED	6:37	18:33	11:56	LINE CLAE AVAILED
303	23-Aug-20	MYSURU	66	KADKOLA-DK MAIDANA	NO STATIONS EFFECTED	13:26	18:33	5:07	LINE CLAE AVAILED
304	23-Aug-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
305	23-Aug-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
306	23-Aug-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
307	23-Aug-20	TUMKUR	110	TR-1	TURUVEKERE_110	11:29	12:13	0:44	TRANSFORMER FAULT
308	23-Aug-20	TUMKUR	66	TR-2	BENKIKERE_66	13:55	14:30	0:35	LINE CLAE AVAILED
309	23-Aug-20	TUMKUR	66	TR-2	CHITRADURGA_66	16:35	16:43	0:07	TRANSFORMER FAULT
310	23-Aug-20	TUMKUR	66	HIRIYUR 220KV- CHITRADURGA(SIRA)	HIRIYUR_220	10:48	11:06	0:17	HAND TRIPPED
311	23-Aug-20	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	6:20	6:30	0:09	LINE FAULT
312	23-Aug-20	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	10:48	10:51	0:02	HAND TRIPPED
313	23-Aug-20	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	12:21	16:19	3:58	LINE FAULT