

### 400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 12.01.21 TO 18.01.2021

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	12-Jan-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN ,LINE FAULT
2	12-Jan-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
3	12-Jan-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
4	12-Jan-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR 220	13:16 (17.11.2020)			LINE OPEN ,LINE FAULT
5	12-Jan-2021	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI 110	9:18 (21.11.2020)			LINE OPEN, LINE CLEAR AVAILED
6	12-Jan-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM 110	1:05 (27.11.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
7	12-Jan-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG 220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVAILED
8	12-Jan-2021	BAGALKOT	110	KANABARGI LAYOUT- NEHARUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT 110	9:16 (03.01.2021)			LINE OPEN, LINE CLEAR AVAILED
9	12-Jan-2021	BAGALKOT	110	GADAG-ANNIGERI	GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
10	12-Jan-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA 110	15:24 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
11	12-Jan-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA 110	15:25 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
12	12-Jan-2021	BAGALKOT	110	NAVALGUND-KNRNGD(KONNUR)	STATION NOT AFFECTED NAVALGUND 110	15:29 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
13	12-Jan-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND 110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
14	12-Jan-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI 220	7:15 (07.01.2021)	2:44 (12.01.2021)	115:39HRS	LINE CHARGED
15	12-Jan-2021	BAGALKOT	110	110/33KV,HV2	UTTUR_110, YADWAD_33,ONTIGODI_33	6:33 (09.01.2021)			TRANSFORMER OPEN , TRANSFORMER FAULT
16	12-Jan-2021	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	20:10(11.01.2021)	6:55(12.01.2021)	10:45HRS	TRANSFORMER CHARGED
17	12-Jan-2021	BAGALKOT	220	AMBEWADI-NAGJIHARI1	STATION NOT AFFECTED AMBEWADI 220	01:28	04:29	3:01	HAND TRIPPED
18	12-Jan-2021	BAGALKOT	220	AMBEWADI-NARENDRA1	STATION NOT AFFECTED AMBEWADI 220	02:36	04:28	1:52	HAND TRIPPED
19	12-Jan-2021	BAGALKOT	220	BAGEWADI220-RBRK IPP	RBRK IPP_220	12:51	13:01	0:10	LINE FAULT
20	12-Jan-2021	BAGALKOT	220	BAGEWADI-LINGASUR2	STATION NOT AFFECTED BAGEWADI 220	14:03	15:00	0:57	LINE FAULT
21	12-Jan-2021	BAGALKOT	110	BAGEWADI220-UKKALI LIS	UKKALI LIS_110	0:41	0:54	0:13	LINE FAULT
22	12-Jan-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED ATHARGA 110	14:04	15:59	1:55	LINE CLEAR AVAILED
23	12-Jan-2021	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED ATHARGA 110	16:36	16:37	0:01	HAND TRIPPED
24	12-Jan-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED BANAHATTI 110	09:33	10:27	0:54	LINE CLEAR AVAILED
25	12-Jan-2021	BAGALKOT	110	110/11KV, HV1	GUTTAL 110	10:35	18:14	7:39	LINE CLEAR AVAILED
26	12-Jan-2021	BAGALKOT	110	110/11KV, HV2	GUTTAL_110	10:35	18:18	7:43	LINE CLEAR AVAILED
27	12-Jan-2021	BAGALKOT	110	110/33KV, HV3	GUTTAL_110, HOSARITTI_33	10:35	18:18	7:43	LINE CLEAR AVAILED
28	12-Jan-2021	BAGALKOT	110	110/33KV, HV4	GUTTAL_110, NEERALAGI_33	10:30	18:15	7:45	LINE CLEAR AVAILED
29	12-Jan-2021	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	22:03			LINE OPEN, LINE CLEAR AVAILED
30	12-Jan-2021	BAGALKOT	220	CHIKKODI-BELGAUM-2	CHIKKODI_220	22:04			LINE OPEN, LINE CLEAR AVAILED
31	12-Jan-2021	BAGALKOT	110	110/11KV,HV2	VAJRAMATTI_110	16:24	16:28	0:04	TRANSFORMER FAULT
32	12-Jan-2021	BAGALKOT	110	110/11KV,HV2	RATTIHALI_110	12:27	13:08	0:41	LINE CLEAR AVAILED
33	12-Jan-2021	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI 220	16:47	17:28	0:41	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
34	12-Jan-2021	BAGALKOT	220	HUBLI-NAGJHARI 3	STATION NOT AFFECTED HUBLI_220	09:27	22:16	12:49	LINE CLEAR AVAILED
35	12-Jan-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	11:05 (08.01.2021)	2:42 (12.01.2021)	87:37HRS	LINE CHARGED
36	12-Jan-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	4:32	22:08	17:36	LOAD CURTAILMENT
37	12-Jan-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	4:33	22:08	17:35	LOAD CURTAILMENT
38	12-Jan-2021	BAGALKOT	220	SIRSI- HUBLI 1	STATION NOT AFFECTED SIRSI_220	16:43	17:29	0:46	HAND TRIPPED
39	12-Jan-2021	BAGALKOT	220	SIRSI- HUBLI 1	STATION NOT AFFECTED SIRSI_220	22:09 (12.01.2021)			LOAD CURTAILMENT
40	12-Jan-2021	BENGALURU	66	HV1	GOKULA	11:40	12:52	01:12	LINE CLEAR AVAILED
41	12-Jan-2021	BENGALURU	66	HV1	NGEF	12:00	13:01	01:01	LINE CLEAR AVAILED
42	12-Jan-2021	BENGALURU	66	HV2	NIMHANS	11:38	11:42	00:04	LINE CLEAR AVAILED
43	12-Jan-2021	BENGALURU	66	HV1	NATIONAL COLLEGE	12:50	12:59	00:09	LINE CLEAR AVAILED
44	12-Jan-2021	BENGALURU	66	HV2	NATIONAL COLLEGE	09:42	09:45	00:03	LINE CLEAR AVAILED
45	12-Jan-2021	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	20:25	20:33	00:08	TRANSFORMER FAULT
46	12-Jan-2021	BENGALURU	66	HV2	DODDABELAVANGALA	13:19	13:27	00:08	TRANSFORMER FAULT
47	12-Jan-2021	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	17:51	18:01	00:10	MAIN SUPPLY FAILURE
48	12-Jan-2021	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	19:10	19:14	00:04	LOAD CHANGE OVER
49	12-Jan-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	BELL CERAMICS (EHT)	17:51	18:46	00:55	LINE FAULT
50	12-Jan-2021	BENGALURU	66	HV1	MANDIKAL	13:10	13:30	00:20	LINE CLEAR AVAILED
51	12-Jan-2021	BENGALURU	66	HV1	MANDIKAL	13:35	15:20	01:45	LINE CLEAR AVAILED
52	12-Jan-2021	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN, LINE CLEAR AVAILED
53	12-Jan-2021	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN, LINE CLEAR AVAILED
54	12-Jan-2021	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN ,LINE FAULT
55	12-Jan-2021	GULBARGA	400	JINDAL-GUTTUR	GUTTUR_400	1:47(7.1.2021)			LINE OPEN ,LINE FAULT
56	12-Jan-2021	GULBARGA	220	ALIPUR-RAGALPADU	RAGALPADU_IPP	13:07	19:16	06:09	LINE CLEAR AVAILED
57	12-Jan-2021	GULBARGA	220	HV2	KAPNOOR_220	11:03	13:05	02:02	LINE CLEAR AVAILED
58	12-Jan-2021	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	14:02	14:27	00:25	LINE FAULT
59	12-Jan-2021	GULBARGA	220	RTPS-SEDAM1	SEDAM_220	04:42	12:38	07:56	LINE FAULT
60	12-Jan-2021	GULBARGA	220	RTPS-SHAHAPUR2	SHAHAPUR_110	08:48	16:14	07:26	NFBC ISSUED
61	12-Jan-2021	GULBARGA	110	HV2	YELBURGA_110	11:03	18:28	07:25	LINE CLEAR AVAILED
62	12-Jan-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGARSUGAR_IPP	22:44	22:59	00:15	LINE FAULT
63	12-Jan-2021	GULBARGA	110	MALLAT-VALKAMDINNI	VALKAMDINNI_110	21:40	22:30	00:50	MAIN SUPPLY FAILURE
64	12-Jan-2021	GULBARGA	110	SINDHNOOR-RAICHUR2	MANVI_110,MADLAPUR_110,KURUDICROSS_1 10	20:44	20:51	00:07	LINE FAULT
65	12-Jan-2021	GULBARGA	110	SINDHNOOR-SINDHANOOR1	SINDHANOOR_110	21:45	22:01	00:16	LINE FAULT
66	12-Jan-2021	GULBARGA	110	SINDHNOOR-SINDHANOOR1	SINDHANOOR_110	22:04	22:21	00:17	LINE FAULT
67	12-Jan-2021	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
68	12-Jan-2021	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
69	12-Jan-2021	HASSAN	110	SORABA-SHR220	SORABA_110	11:22 (2.01.2021)			LINE OPEN, LINE CLEAR AVAILED
70	12-Jan-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	20:49 (5.01.2021)			LINE OPEN, LINE CLEAR AVAILED
71	12-Jan-2021	HASSAN	66	HV1	KANDLI_66	11:45(11.1.2021)			LINE OPEN, LINE CLEAR AVAILED
72	12-Jan-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	2:00 (12.01.2021)			LINE OPEN, LINE CLEAR AVAILED
73	12-Jan-2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:24 (12.01.2021)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
74	12-Jan-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	00:08	07:15	07:07	HAND TRIPPED
75	12-Jan-2021	HASSAN	220	HASSN22-NITTUR	HASSAN_220	13:17	13:55	00:38	LINE FAULT
76	12-Jan-2021	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	13:17	14:28	01:11	HAND TRIPPED
77	12-Jan-2021	HASSAN	66	HASSN22-BELUR	HASSAN_220	13:17	15:23	02:06	HAND TRIPPED
78	12-Jan-2021	HASSAN	66	HASSN22-HN PURA	HASSAN_220	13:17	15:02	01:45	HAND TRIPPED
79	12-Jan-2021	HASSAN	66	HASSN22-HSN66	HASSAN_220	13:17	14:06	00:49	HAND TRIPPED
80	12-Jan-2021	HASSAN	66	LV1	HASSAN_220	13:17	13:58	00:41	TRANSFORMER FAULT
81	12-Jan-2021	HASSAN	66	LV1	HASSAN_220	13:17	13:58	00:41	TRANSFORMER FAULT
82	12-Jan-2021	HASSAN	66	LV2	HASSAN_220	13:17	13:58	00:41	TRANSFORMER FAULT
83	12-Jan-2021	HASSAN	66	LV2	HASSAN_220	13:17	13:58	00:41	TRANSFORMER FAULT
84	12-Jan-2021	HASSAN	66	HASSN22-MALLALI	HASSAN_220	13:17	15:24	02:07	HAND TRIPPED
85	12-Jan-2021	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	13:17	14:08	00:51	HAND TRIPPED
86	12-Jan-2021	HASSAN	66	HASSN22-SKPURA	HASSAN_220	13:17	14:24	01:07	HAND TRIPPED
87	12-Jan-2021	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	13:17	14:13	00:56	HAND TRIPPED
88	12-Jan-2021	HASSAN	220	GERSOPA-TALGUPA2	GERSOPA	09:38	11:10	01:32	HAND TRIPPED
89	12-Jan-2021	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	03:41	09:07	05:26	LINE FAULT
90	12-Jan-2021	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	10:11	14:03	03:52	LINE CLEAR AVAILED
91	12-Jan-2021	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	03:41	09:07	05:26	LINE FAULT
92	12-Jan-2021	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	10:11	14:03	03:52	LINE CLEAR AVAILED
93	12-Jan-2021	HASSAN	110	NITUR11-MANIPAL	NITTUR_110	14:47	14:51	00:04	HAND TRIPPED
94	12-Jan-2021	HASSAN	110	HV2	PUTTUR_110	09:31	14:56	05:25	LINE CLEAR AVAILED
95	12-Jan-2021	HASSAN	110	HV1	HALADY_110	09:45	18:25	08:40	LINE CLEAR AVAILED
96	12-Jan-2021	HASSAN	110	HV2	HALADY_110	14:16	16:51	02:35	LINE CLEAR AVAILED
97	12-Jan-2021	HASSAN	110	HV1	ARASIKERE_110	12:14	12:40	00:26	LINE CLEAR AVAILED
98	12-Jan-2021	HASSAN	110	HV1	BARANGI_110	12:17	14:04	01:47	LINE CLEAR AVAILED
99	12-Jan-2021	HASSAN	110	HV2	BARANGI_110	16:16	16:31	00:15	LINE CLEAR AVAILED
100	12-Jan-2021	HASSAN	110	HV1	GANDSI_110	11:00	17:42	06:42	LINE CLEAR AVAILED
101	12-Jan-2021	HASSAN	110	HV2	GANDSI_110	11:04	17:01	05:57	LINE CLEAR AVAILED
102	12-Jan-2021	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	09:45	13:09	03:24	LINE CLEAR AVAILED
103	12-Jan-2021	HASSAN	110	HV3	KAVOOR_220	08:21	08:44	00:23	TRANSFORMER FAULT
104	12-Jan-2021	HASSAN	110	HV3	KAVOOR_220	08:52	09:46	00:54	TRANSFORMER FAULT
105	12-Jan-2021	HASSAN	110	KEMAR-Manipal2	KEMAR_220	09:09	17:50	08:41	LINE CLEAR AVAILED
106	12-Jan-2021	HASSAN	110	HV1	KULASHEKARA_110	04:55	08:19	03:24	LINE CLEAR AVAILED
107	12-Jan-2021	HASSAN	110	MADHUV-HIRIYADKA	MADHUVANA_110	09:48	13:32	03:44	NFBC ISSUED
108	12-Jan-2021	HASSAN	110	HV1	MADHUVANA_110	10:12	13:33	03:21	LINE CLEAR AVAILED
109	12-Jan-2021	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	09:27	13:12	03:45	LINE CLEAR AVAILED
110	12-Jan-2021	HASSAN	110	HV2	MOODABIDRE_110	09:43	17:23	07:40	LINE CLEAR AVAILED
111	12-Jan-2021	HASSAN	110	HV1	NAVUNDA_110	09:53	13:30	03:37	LINE CLEAR AVAILED
112	12-Jan-2021	HASSAN	110	HV2	SHIKARIPURA_110	10:17	18:29	08:12	LINE CLEAR AVAILED
113	12-Jan-2021	HASSAN	66	CHIKKAK-DUDDA	CHIKKAKONDAGOLA_66	14:12	14:26	00:14	HAND TRIPPED
114	12-Jan-2021	HASSAN	66	HV1	DUDDA_66	13:20	14:25	01:05	MAIN SUPPLY FAILURE
115	12-Jan-2021	HASSAN	66	HV1	HOLALUR_66	10:10	18:36	08:26	MAIN SUPPLY FAILURE
116	12-Jan-2021	HASSAN	66	HV2	HOLALUR_66	10:11	18:37	08:26	LINE CLEAR AVAILED
117	12-Jan-2021	HASSAN	66	HV1	MAGGE_66	13:20	14:28	01:08	MAIN SUPPLY FAILURE
118	12-Jan-2021	HASSAN	66	HV2	MAGGE_66	13:20	14:29	01:09	MAIN SUPPLY FAILURE
119	12-Jan-2021	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	12:00	13:30	01:30	LINE CLEAR AVAILED
120	12-Jan-2021	HASSAN	66	HV1	SALAGAME_66	11:14	12:47	01:33	LINE CLEAR AVAILED
121	12-Jan-2021	HASSAN	66	USSURKO-CHIKMANGLUR	UDDURKOPLU_66	13:41	13:57	00:16	HAND TRIPPED
122	12-Jan-2021	MYSURU	66	CR NAGARA-YALANDUR	YELANDUR_66	14:07	14:18	0:10	LINE FAULT
123	12-Jan-2021	MYSURU	66	DR PETE-KUNTHUR	SANTHEMARAHALLI_66 MUGUR_66 THAYURU_66 JANNUR_66 TNARASIPURA_66	21:58	22:08	0:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
124	12-Jan-2021	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	6:57	7:02	0:04	LINE FAULT
125	12-Jan-2021	MYSURU	66	HV1	RAMAPURA_MYS_66	17:26	17:37	0:11	HAND TRIPPED
126	12-Jan-2021	MYSURU	66	HV1	KOLLEGALA_66	9:07	9:46	0:38	TRANSFORMER FAULT
127	12-Jan-2021	MYSURU	66	HV1	PERIYAPATNA_66	12:22	13:24	1:01	LINE CLEAR AVAILED
128	12-Jan-2021	MYSURU	66	HV2	PERIYAPATNA_66	13:26	14:13	0:47	LINE CLEAR AVAILED
129	12-Jan-2021	MYSURU	66	HV1	SANIVARASANTHE_66	10:41	10:56	0:15	LINE CLEAR AVAILED
130	12-Jan-2021	MYSURU	66	SHANIVARSANTHE-YESSLUR	NO STATION EFFECTED	13:50	14:08	0:17	LINE CLEAR AVAILED
131	12-Jan-2021	MYSURU	66	HV1	ANEGOLAL_66	10:57 (11.01.2021)			TRANSFORMER OPEN ,LINE CLEAR AVAILED.
132	12-Jan-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE OPEN, LINE CLEAR AVAILED
133	12-Jan-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN, LINE CLEAR AVAILED
134	12-Jan-2021	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	9:45:16 PM(04.01.2020)			LINE OPEN, LINE CLEAR AVAILED
135	12-Jan-2021	TUMKUR	220	TR-2	MADHUGIRI_220	17:20	17:27	0:06	LINE CLEAR AVAILED
136	12-Jan-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	11:45	12:04	0:19	LINE FAULT
137	12-Jan-2021	TUMKUR	66	HIRIYURKV 220kv- SUZLON 2	SUZLON1_IPP_66	14:52	17:17	2:25	LINE CLEAR AVAILED
138	12-Jan-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	12:20	12:56	0:36	LINE FAULT
139	12-Jan-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	13:02	13:30	0:27	LINE FAULT
140	12-Jan-2021	TUMKUR	66	PAVAGADA-NAGALAMADIKE	NAGALMADIKE_66	14:07	14:12	0:05	LINE FAULT
141	13-Jan-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN ,LINE FAULT
142	13-Jan-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
143	13-Jan-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
144	13-Jan-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN ,LINE FAULT
145	13-Jan-2021	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN, LINE CLEAR AVAILED
146	13-Jan-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
147	13-Jan-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVAILED
148	13-Jan-2021	BAGALKOT	110	KANABARGI LAYOUT- NEHARUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN, LINE CLEAR AVAILED
149	13-Jan-2021	BAGALKOT	110	GADAG-ANNIGERI	GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
150	13-Jan-2021	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	15:24 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
151	13-Jan-2021	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA_110	15:25 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
152	13-Jan-2021	BAGALKOT	110	NAVALGUND-KNRNGD(KONNUR)	STATION NOT AFFECTED NAVALGUND_110	15:29 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
153	13-Jan-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
154	13-Jan-2021	BAGALKOT	110	110/33KV,HV2	UTTUR_110, YADWAD_33,ONTIGODI_33	6:33 (09.01.2021)			TRANSFORMER OPEN , TRANSFORMER FAULT
155	13-Jan-2021	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	22:03 (12.01.2021)	7:36 (13.01.2021)	9:33HRS	LINE CHARGED
156	13-Jan-2021	BAGALKOT	220	CHIKKODI-BELGAUM-2	CHIKKODI_220	22:04 (12.01.2021)	7:35 (13.01.2021)	9:31HRS	LINE CHARGED
157	13-Jan-2021	BAGALKOT	220	SIRSI- HUBLI 1	STATION NOT AFFECTED SIRSI_220	22:09 (12.01.2021)	5:58 (13.01.2021)	7:49HRS	LINE CHARGED
158	13-Jan-2021	BAGALKOT	110	110/11KV,HV1	ANKOLA_110	10:08	10:10	0:02	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
159	13-Jan-2021	BAGALKOT	110	ANKOLA-KUMATA (L2)	STATION NOT AFFECTED ANKOLA_110	11:38	12:58	1:20	HAND TRIPPED
160	13-Jan-2021	BAGALKOT	110	110/33KV,HV2	ANKOLA_110,MASTIKATTA_33,SEABIRD_33	8:50	08:56	0:06	TRANSFORMER FAULT
161	13-Jan-2021	BAGALKOT	110	BAGALKOT-NEERBUDIHAL( KATARKI F9)	NEERBUDIHAL_110	16:42	19:07	2:25	LINE CLEAR AVAILED
162	13-Jan-2021	BAGALKOT	220	BIDNAL-NAGJHARI 2	STATION NOT AFFECTED BIDNAL_220	9:06	17:34	8:28	LINE CLEAR AVAILED
163	13-Jan-2021	BAGALKOT	220	220/110KV,HV2 & LV2	BIJAPUR_220	06:20	17:43	11:23	TRANSFORMER FAULT
164	13-Jan-2021	BAGALKOT	110	GOPANAKOPA-NARGUND(BIDNAL-NAVALGUND)	GOPANAKOPPA_110 (STATION NOT AFFECTED)	13:29	14:29	1:00	HAND TRIPPED
165	13-Jan-2021	BAGALKOT	110	GOPANAKOPA-NARGUND(BIDNAL-NAVALGUND)	GOPANAKOPPA_110 (STATION NOT AFFECTED)	14:38	14:55	0:17	HAND TRIPPED
166	13-Jan-2021	BAGALKOT	220	BELGAUM-NARENDRA1(KANABARGI1)	BELGAUM_220	00:39	07:34	6:55	HAND TRIPPED
167	13-Jan-2021	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	22:03 (13.01.2021)			LOAD CURTAILMENT
168	13-Jan-2021	BAGALKOT	220	CHIKKOD-BELGAUM-2	CHIKKODI_220	22:03 (13.01.2021)			LOAD CURTAILMENT
169	13-Jan-2021	BAGALKOT	110	KERUR-KONNUR	KONNUR_110 (STATION NOT AFFECTED)	12:49	13:16	0:27	LINE FAULT
170	13-Jan-2021	BAGALKOT	220	400/220KV,ICT 1	DHONI_400	11:06	13:26	2:20	LINE CLEAR AVAILED
171	13-Jan-2021	BAGALKOT	220	NAGJHARI3- HUBLI	STATION NOT AFFECTED HUBLI_220	08:52	17:26	8:34	LINE CLEAR AVAILED
172	13-Jan-2021	BAGALKOT	220	HUBLI- SIRSI1	STATION NOT AFFECTED HUBLI_220	12:50	14:50	2:00	LINE CLEAR AVAILED
173	13-Jan-2021	BAGALKOT	110	SIRSI- KUMTA2	KUMTA_110	18:28	18:50	0:22	LINE FAULT
174	13-Jan-2021	BAGALKOT	220	SHARAVATHY1- SIRSI	STATION NOT AFFECTED SIRSI_220	5:58	6:09	0:11	LOAD CURTAILMENT
175	13-Jan-2021	BAGALKOT	220	SHARAVATHY2- SIRSI	STATION NOT AFFECTED SIRSI_220	5:58	6:09	0:11	LOAD CURTAILMENT
176	13-Jan-2021	BAGALKOT	220	SHARAVATHY1- SIRSI	STATION NOT AFFECTED SIRSI_220	6:20 (13.01.2020)			LOAD CURTAILMENT
177	13-Jan-2021	BAGALKOT	220	SHARAVATHY2- SIRSI	STATION NOT AFFECTED SIRSI_220	6:20 (13.01.2020)			LOAD CURTAILMENT
178	13-Jan-2021	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	6:09	6:12	0:03	LOAD CURTAILMENT
179	13-Jan-2021	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	6:09	6:12	0:03	LOAD CURTAILMENT
180	13-Jan-2021	BAGALKOT	110	KUMTA- SIRSI1	STATION NOT AFFECTED KUMTA_110	18:54 (13.01.2020)			LINE OPEN ,LINE FAULT
181	13-Jan-2021	BENGALURU	66	BANASHANKARI - VRISHBHAVATHI 220	BANASHANKARI	16:42	17:07	00:25	MAIN SUPPLY FAILURE
182	13-Jan-2021	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	19:57	20:02	00:05	LOAD CHANGE OVER
183	13-Jan-2021	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	17:48	18:00	00:12	MAIN SUPPLY FAILURE
184	13-Jan-2021	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	HENNUR CROSS	22:40	22:44	00:04	LOAD CHANGE OVER
185	13-Jan-2021	BENGALURU	66	VIDYANAGARA - BEGUR 220	VIDYANAGARA	17:48	18:10	00:22	LINE FAULT
186	13-Jan-2021	BENGALURU	66	VIDYANAGARA - HENNUR CROSS	NO STATION AFFECTED	17:48	22:29	04:41	LINE FAULT
187	13-Jan-2021	BENGALURU	66	HOODY 220 - POTTERY ROAD	NO STATION AFFECTED	07:07	07:30	00:23	LINE FAULT
188	13-Jan-2021	BENGALURU	66	HV2	LEELA VENTURE	02:43	02:58	00:15	TRANSFORMER FAULT
189	13-Jan-2021	BENGALURU	66	HV2	PRESTIGE SHANTINIKETHAN	14:31	15:24	00:53	LINE CLEAR AVAILED
190	13-Jan-2021	BENGALURU	66	SOBHA FOREST - SUBRAMANYAPURA 220	SHOBHA FOREST	10:07	10:23	00:16	LOAD CHANGE OVER
191	13-Jan-2021	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT), RR NAGAR	17:14	17:28	00:14	LINE CLEAR AVAILED
192	13-Jan-2021	BENGALURU	66	VRISHBHAVATHI 220 - BANASHANKARI	NO STATION AFFECTED	16:51	19:17	02:26	LINE FAULT
193	13-Jan-2021	BENGALURU	220	HV2	YARANDANAHALLI 220	22:32	22:48	00:16	TRANSFORMER FAULT
194	13-Jan-2021	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	22:32	22:56	00:24	LINE FAULT
195	13-Jan-2021	BENGALURU	66	BAGHMANE WORLD TECH PARK - HOODY 1	BAGHMANE WORLD TECH PARK, NGEF, NGEF (EHT)	11:30	11:40	00:10	LOAD CHANGE OVER
196	13-Jan-2021	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	12:22	13:01	00:39	MAIN SUPPLY FAILURE
197	13-Jan-2021	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	12:22	13:01	00:39	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
198	13-Jan-2021	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	12:22	13:01	00:39	MAIN SUPPLY FAILURE
199	13-Jan-2021	BENGALURU	66	HV2	TADIGOLU	12:01	13:00	00:58	LINE CLEAR AVAILED
200	13-Jan-2021	BENGALURU	66	HV1	TEKAL	13:21	17:01	03:39	TRANSFORMER FAULT
201	13-Jan-2021	BENGALURU	66	HV2	DODDABELAVANGALA	03:01	03:05	00:03	TRANSFORMER FAULT
202	13-Jan-2021	BENGALURU	66	HV2	DODDABELAVANGALA	10:03	10:16	00:13	TRANSFORMER FAULT
203	13-Jan-2021	BENGALURU	66	HV1	ANDERSONPET	12:25	13:05	00:40	LINE CLEAR AVAILED
204	13-Jan-2021	BENGALURU	66	IRGAMPALLI - DIBBURAHALLI	DIBBURAHALLI	17:15	17:20	00:05	MAIN SUPPLY FAILURE
205	13-Jan-2021	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)	14:45(13/01/2021)	935:25HRS	LINE CHARGED
206	13-Jan-2021	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)	12:40(13/01/2021)	932:46HRS	LINE CHARGED
207	13-Jan-2021	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)	13:50(13/01/2021)	5245:55HRS	LINE CHARGED
208	13-Jan-2021	GULBARGA	400	JINDAL-GUTTUR	GUTTUR_400	1:47(7.1.2021)	11:54(13.01.2021)	154:07HRS	LINE CHARGED
209	13-Jan-2021	GULBARGA	220	RTPS-RAICHUR1	RAICHUR_220	08:49	15:54	07:05	NFBC ISSUED
210	13-Jan-2021	GULBARGA	220	RTPS-RAICHUR2	RAICHUR_220	15:15	17:54	02:39	NFBC ISSUED
211	13-Jan-2021	GULBARGA	220	BMM ISPAT-LINGAPUR	LINGAPUR_220	08:49	13:56	05:07	NFBC ISSUED
212	13-Jan-2021	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	05:14	12:18	07:04	NFBC ISSUED
213	13-Jan-2021	GULBARGA	110	PDHALLI-CLNMAX	PD_HALLI_110	14:09	14:17	00:08	LINE CLEAR AVAILED
214	13-Jan-2021	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	00:21	00:35	00:14	LINE FAULT
215	13-Jan-2021	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	01:11	01:27	00:16	LINE FAULT
216	13-Jan-2021	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	04:43	05:00	00:17	LINE FAULT
217	13-Jan-2021	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	04:55	05:00	00:05	LINE FAULT
218	13-Jan-2021	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	06:19	06:29	00:10	LINE FAULT
219	13-Jan-2021	GULBARGA	110	MALLAT-KAVITAL	KAVITHAL_110	07:35	07:45	00:10	LINE FAULT
220	13-Jan-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI2	KBJNL_IPP	15:13	15:31	00:18	LINE FAULT
221	13-Jan-2021	GULBARGA	110	HV2	SINDHANOOR_110	09:22	09:32	00:10	TRANSFORMER FAULT
222	13-Jan-2021	GULBARGA	110	HV3	KEREHALLI_110	14:09	14:25	00:16	TRANSFORMER FAULT
223	13-Jan-2021	GULBARGA	110	HALBARGA-BHALKI	BHLAKI_110	02:31	02:38	00:07	LINE FAULT
224	13-Jan-2021	GULBARGA	110	HALBARGA-BHALKI	BHLAKI_110	06:27	06:33	00:06	LINE FAULT
225	13-Jan-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	02:48	02:58	00:10	LINE FAULT
226	13-Jan-2021	GULBARGA	66	ITTAGGI-HIREHADAGALLI2	HIREHADAGALLI_66,SOVENAHALLI_66,GIRIYAPURA_66,MAGALA_66,TBPCL_IPP	21:30(12.1.2021)	17:02(13.1.2021)	19:32 HRS	LINE CHARGED
227	13-Jan-2021	GULBARGA	66	ITTAGGI-RENEW SOLAR1,2	ITTAGGI_220	10:45	11:40	00:55	LINE CLEAR AVAILED
228	13-Jan-2021	GULBARGA	66	ITTAGGI-CLNMAX1,2	ITTAGGI_220	10:45	11:40	00:55	LINE CLEAR AVAILED
229	13-Jan-2021	GULBARGA	66	HV2	ITTAGGI_220	11:20	12:30	01:10	TRANSFORMER FAULT
230	13-Jan-2021	GULBARGA	66	HV3	ITTAGGI_220	11:20	11:51	00:31	LINE CLEAR AVAILED
231	13-Jan-2021	GULBARGA	66	ITTAGGI-SUZLON1,2	ITTAGGI_220	11:52	12:40	00:48	LINE CLEAR AVAILED
232	13-Jan-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	2:00 (12.01.2021)	7:19(13.01.2021)	28:19 hrs	LINE CHARGED
233	13-Jan-2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:24 (12.01.2021)	6:21 (13.01.2021)	6:56 hrs	LINE CHARGED
234	13-Jan-2021	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
235	13-Jan-2021	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
236	13-Jan-2021	HASSAN	110	SORABA-SHR220	SORABA_110	11:22 (2.01.2021)			LINE OPEN, LINE CLEAR AVAILED
237	13-Jan-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	20:49 (5.01.2021)			LINE OPEN, LINE CLEAR AVAILED
238	13-Jan-2021	HASSAN	66	HV1	KANDLI_66	11:45(11.1.2021)			LINE OPEN, LINE CLEAR AVAILED
239	13-Jan-2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:16 (13.01.2021)			LINE OPEN, LINE CLEAR AVAILED
240	13-Jan-2021	HASSAN	220	MRSSHM-VARAH11	MRSMG_220	22:27 (13.01.2021)			LINE OPEN ,LINE FAULT
241	13-Jan-2021	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	22:27 (13.01.2021)			LINE OPEN ,LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
242	13-Jan-2021	HASSAN	220	HASSN22-Shimoga	HASSAN_220	13:57	15:15	01:18	LINE FAULT
243	13-Jan-2021	HASSAN	110	HV1	HALADY_110	18:45	22:02	03:17	TRANSFORMER FAULT
244	13-Jan-2021	HASSAN	110	ANANDA-LPH(LST-4)	ANANDAPURA_110	11:31	12:11	00:40	LINE CLEAR AVAILED
245	13-Jan-2021	HASSAN	110	ANANDA-SHIMOGA	ANANDAPURA_110	10:41	12:01	01:20	LINE CLEAR AVAILED
246	13-Jan-2021	HASSAN	110	HV1	KARAYA_110	12:55	16:32	03:37	TRANSFORMER FAULT
247	13-Jan-2021	HASSAN	110	KAVOOR-EMAR	KAVOOR_220	10:16	14:36	04:20	LINE CLEAR AVAILED
248	13-Jan-2021	HASSAN	110	SAGARA-SS2	SAGARA_110	10:46	11:18	00:32	HAND TRIPPED
249	13-Jan-2021	HASSAN	110	HV1	BRAHMAVARA_110	11:12	11:19	00:07	LINE CLEAR AVAILED
250	13-Jan-2021	HASSAN	110	BRAHMAV-MANIPAL	BRAHMAVARA_110	10:05	14:30	04:25	LINE CLEAR AVAILED
251	13-Jan-2021	HASSAN	110	HV1	SHIVPURA_110	14:28	15:07	00:39	LINE CLEAR AVAILED
252	13-Jan-2021	HASSAN	66	BANDISH-ADANI	BANDISHETTYHALLI_66	10:00	10:05	00:05	LINE FAULT
253	13-Jan-2021	HASSAN	66	HV1	DUDDA_110	13:15	13:30	00:15	TRANSFORMER FAULT
254	13-Jan-2021	HASSAN	66	HV1	HANGARANAHALLY_66	13:45	13:55	00:10	LINE CLEAR AVAILED
255	13-Jan-2021	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	13:17	14:02	00:45	LINE CLEAR AVAILED
256	13-Jan-2021	HASSAN	66	HV1	SHANTHIGRAMMA_66	12:21	13:09	00:48	LINE CLEAR AVAILED
257	13-Jan-2021	HASSAN	66	HV2	SHANTHIGRAMMA_66	10:36	12:27	01:51	LINE CLEAR AVAILED
258	13-Jan-2021	MYSURU	66	TUBINKERE-G UKKADA	NO STATION EFFECTED	11:33	14:16	2:42	LINE CLEAR AVAILED
259	13-Jan-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66	15:23	17:20	1:56	LINE CLEAR AVAILED
260	13-Jan-2021	MYSURU	66	TUBINKERE-NAGAMANGALA 2	SHIVALLY_66	11:26	13:43	2:17	LINE CLEAR AVAILED
261	13-Jan-2021	MYSURU	66	TUBINKERE-PANDAVAPURA	DODDABYADARAHALLI_66	14:28	16:30	2:02	LINE CLEAR AVAILED
262	13-Jan-2021	MYSURU	66	G UKKADA-PANDAVAPURA	NO STATION EFFECTED	11:14	11:22	0:08	HAND TRIPPED
263	13-Jan-2021	MYSURU	66	G UKKADA-PANDAVAPURA	NO STATION EFFECTED	16:32	16:36	0:03	HAND TRIPPED
264	13-Jan-2021	MYSURU	66	HV1	KRPET_220	11:33	15:40	4:07	LINE CLEAR AVAILED
265	13-Jan-2021	MYSURU	66	HV2	KRPET_220	11:33	15:40	4:07	LINE CLEAR AVAILED
266	13-Jan-2021	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	9:40	9:48	0:07	LINE FAULT
267	13-Jan-2021	MYSURU	66	HOOTAGALLI-BARC2	NO STATION EFFECTED	14:02	14:13	0:10	LINE FAULT
268	13-Jan-2021	MYSURU	66	MANDYA -HAMPAPURA	CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI 66, KOPPA 66	6:51	6:59	0:07	LINE FAULT
269	13-Jan-2021	MYSURU	66	HV1	BASARALU_66	14:07	14:27	0:19	LINE CLEAR AVAILED
270	13-Jan-2021	MYSURU	66	HV2	HDKOTE_66	16:41	17:16	0:35	LINE CLEAR AVAILED
271	13-Jan-2021	MYSURU	66	SATHEGALA-HEBBANI	SATHEGALA_66	11:40	12:30	0:50	LINE CLEAR AVAILED
272	13-Jan-2021	MYSURU	66	SATHEGALA-BPCL	NO STATION EFFECTED	11:38	12:31	0:53	LINE CLEAR AVAILED
273	13-Jan-2021	MYSURU	66	SATHEGALA-KOLLEGALA	SATHEGALA_66	11:38	12:31	0:53	LINE CLEAR AVAILED
274	13-Jan-2021	MYSURU	66	HV2	JYOTHINAGARA_66	11:10	14:15	3:05	LINE CLEAR AVAILED
275	13-Jan-2021	MYSURU	66	HV1	ANEGOLAL_66	10:57 (11.01.2021)	15:00 (13.01.2021)	52:03 HRS	TRANSFORMER CHARGED
276	13-Jan-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE OPEN, LINE CLEAR AVAILED
277	13-Jan-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN, LINE CLEAR AVAILED
278	13-Jan-2021	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	21:45:16(04.01.2020)	15:54:56 (13.01.2021)	225:10HRS	LINE CHARGED
279	13-Jan-2021	TUMKUR	220	THALLAK 220KV- HIREMALLANAHOLE 1	THALLAK_220	11:21	17:21	5:59	LINE CLEAR AVAILED
280	13-Jan-2021	TUMKUR	66	TR-2	BELLAVI_66	12:22	13:14	0:52	LINE CLEAR AVAILED
281	13-Jan-2021	TUMKUR	66	BENKIKERE-NALLUR	BENKIKERE_66	10:54	11:21	0:26	LINE CLEAR AVAILED
282	13-Jan-2021	TUMKUR	66	TR-1	BENKIKERE_66	10:55	11:24	0:29	LINE CLEAR AVAILED
283	13-Jan-2021	TUMKUR	66	TR-2	BENKIKERE_66	10:55	11:22	0:27	LINE CLEAR AVAILED
284	13-Jan-2021	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	5:49	6:03	0:14	LINE FAULT
285	13-Jan-2021	TUMKUR	66	TR-1	HALURAMESHWARA_66	10:06	10:15	0:09	TRANSFORMER FAULT
286	13-Jan-2021	TUMKUR	66	TR-2	HOSADURGA_66	7:46	12:11	4:25	LINE CLEAR AVAILED
287	13-Jan-2021	TUMKUR	66	HOSADURGA-RAMAGIRI 1	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66	16:47	19:27	2:39	MAIN SUPPLY FAILURE
288	13-Jan-2021	TUMKUR	66	I D HALLI- CLEAN MAX SOLAR	CLEANMAXSOLAR_IPP_66	13:53	14:05	0:12	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
289	13-Jan-2021	TUMKUR	66	TR-1	MATHOD_66	19:10	19:12	0:01	LINE CLEAR AVAILED
290	13-Jan-2021	TUMKUR	66	TR-2	TUMKUR_66	7:40	9:39	1:58	LINE CLEAR AVAILED
291	13-Jan-2021	TUMKUR	66	YEDIYUR- BGNAGARA_66	YEDIYUR_66	15:22	17:21	1:59	HAND TRIPPED
292	14-Jan-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN ,LINE FAULT
293	14-Jan-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
294	14-Jan-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
295	14-Jan-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN ,LINE FAULT
296	14-Jan-2021	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN, LINE CLEAR AVAILED
297	14-Jan-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
298	14-Jan-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVAILED
299	14-Jan-2021	BAGALKOT	110	KANABARGI LAYOUT- NEHARUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN, LINE CLEAR AVAILED
300	14-Jan-2021	BAGALKOT	110	GADAG-ANNIGERI	GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
301	14-Jan-2021	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	15:24 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
302	14-Jan-2021	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA_110	15:25 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
303	14-Jan-2021	BAGALKOT	110	NAVALGUND-KNRNGD(KONNUR)	STATION NOT AFFECTED NAVALGUND_110	15:29 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
304	14-Jan-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
305	14-Jan-2021	BAGALKOT	110	110/33KV,HV2	UTTUR_110, YADWAD_33,ONTIGODI_33	6:33 (09.01.2021)	16:56 (14.01.2021)	130:23HRS	LINE CLEAR AVAILED
306	14-Jan-2021	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	22:03 (13.01.2021)	7:06 (14.01.2021)	9:03HRS	LINE CHARGED
307	14-Jan-2021	BAGALKOT	220	CHIKKOD-BELGAUM-2	CHIKKODI_220	22:03 (13.01.2021)	7:06 (14.01.2021)	9:03HRS	LINE CHARGED
308	14-Jan-2021	BAGALKOT	220	SHARAVATHY1- SIRSI	STATION NOT AFFECTED SIRSI_220	6:20 (13.01.2020)			LOAD CURTAILMENT
309	14-Jan-2021	BAGALKOT	220	SHARAVATHY2- SIRSI	STATION NOT AFFECTED SIRSI_220	6:20 (13.01.2020)			LOAD CURTAILMENT
310	14-Jan-2021	BAGALKOT	110	KUMTA- SIRSI1	STATION NOT AFFECTED KUMTA_110	18:54 (13.01.2020)	8:23 (14.01.2020)	13:29HRS	LINE CHARGED
311	14-Jan-2021	BAGALKOT	110	BANAHATTI-JAMAKHANDI	NAVALAGI_110	14:43	18:19	3:36	HAND TRIPPED
312	14-Jan-2021	BAGALKOT	220	220/110KV,HV2 &LV2	GADAG_220	10:38	18:28	7:50	LINE CLEAR AVAILED
313	14-Jan-2021	BAGALKOT	220	BELGAUM-NARENDRA1(KANABARGI1)	BELGAUM_220	01:23	07:05	5:42	HAND TRIPPED
314	14-Jan-2021	BAGALKOT	220	BELGAUM-NARENDRA1(KANABARGI1)	BELGAUM_220	21:04 (14.01.2021)			LINE OPEN, LINE CLEAR AVAILED
315	14-Jan-2021	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	21:39 (14.01.2021)			LINE OPEN, LINE CLEAR AVAILED
316	14-Jan-2021	BAGALKOT	220	CHIKKOD-BELGAUM-2	CHIKKODI_220	21:39 (14.01.2021)			LINE OPEN, LINE CLEAR AVAILED
317	14-Jan-2021	BAGALKOT	110	MAHALINGAPUR-JMAKHANDI	JAMAKHANDI_110 (STATION NOT AFFECTED)	15:01 (14.01.2021)			LINE OPEN, LINE CLEAR AVAILED
318	14-Jan-2021	BAGALKOT	110	KALAGHATGI-ASPL(KAVALWAD-HUBLI)	KALAGHATGI_110 (STATION NOT AFFECTED)	18:45	21:47	3:02	LINE CLEAR AVAILED
319	14-Jan-2021	BAGALKOT	220	NAGJHARI3- HUBLI	STATION NOT AFFECTED HUBLI_220	13:33	16:54	3:21	LINE CLEAR AVAILED
320	14-Jan-2021	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED HUBLI_220	10:18	14:39	4:21	LINE CLEAR AVAILED
321	14-Jan-2021	BAGALKOT	110	RON- HIREHAL	STATION NOT AFFECTED RON_110	20:32	21:14	0:42	LINE FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
322	14-Jan-2021	BAGALKOT	110	110/11KV, HV2	MUKARTIHAL_110	16:33	17:01	0:28	TRANSFORMER FAULT
323	14-Jan-2021	BAGALKOT	110	110/33KV, HV3	LOKAPUR_110, BATAKURKI_33	18:13	18:31	0:18	TRANSFORMER FAULT
324	14-Jan-2021	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	03:37	03:57	00:20	MAIN SUPPLY FAILURE
325	14-Jan-2021	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	06:50	06:57	00:07	LOAD CHANGE OVER
326	14-Jan-2021	BENGALURU	66	KORAMANGALA 220 - AUSTIN TOWN 1	NO STATION AFFECTED	16:35	18:38	02:03	LINE FAULT
327	14-Jan-2021	BENGALURU	220	NRS 220 - VRISHABHAVATHI 220	NO STATION AFFECTED	15:56	17:57	02:01	LINE FAULT
328	14-Jan-2021	BENGALURU	66	HV1	VIJAYANAGARA	10:13	10:24	00:11	LOAD CHANGE OVER
329	14-Jan-2021	BENGALURU	66	HV1	VIJAYANAGARA	16:25	16:33	00:08	LOAD CHANGE OVER
330	14-Jan-2021	BENGALURU	220	HV1	YARANDANAHALLI 220	03:37	08:13	04:36	TRANSFORMER FAULT
331	14-Jan-2021	BENGALURU	66	HV2	YARANDANAHALLI 220	03:37	03:54	00:17	LOAD CHANGE OVER
332	14-Jan-2021	BENGALURU	66	HV1	KIADB 220	09:15	09:58	00:43	LINE CLEAR AVAILED
333	14-Jan-2021	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	07:13	07:36	00:23	LINE FAULT
334	14-Jan-2021	BENGALURU	220	HV1	YARANDANAHALLI 220	21:30:00(14/01/2021)			TRANSFORMER OPEN , TRANSFORMER FAULT
335	14-Jan-2021	GULBARGA	220	HUMNABAD-SEDAM	HUMNABAD_220	04:38	06:48	02:10	LINE FAULT
336	14-Jan-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	04:58	14:22	09:24	LINE FAULT
337	14-Jan-2021	GULBARGA	220	SHAHAPUR-LINGSUGUR	SHAHAPUR_220	12:57	14:40	01:43	LINE CLEAR AVAILED
338	14-Jan-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	15:55	16:12	00:17	LINE CLEAR AVAILED
339	14-Jan-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	18:05	18:13	00:08	LINE CLEAR AVAILED
340	14-Jan-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	04:46	04:55	00:09	LINE FAULT
341	14-Jan-2021	GULBARGA	110	HV1	HALBARGA_220	18:10	18:25	00:15	TRANSFORMER FAULT
342	14-Jan-2021	GULBARGA	110	HV1	HALBARGA_220	18:25	18:50	00:25	LINE CLEAR AVAILED
343	14-Jan-2021	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALU_110,KUDITINI_110,KURUGOD_110,SHATAVAHANA_IPP,AGARWAL_IPP,SUZLON_IPP,KAMALAPUR_110,METRI_110	05:38	05:54	00:16	LINE FAULT
344	14-Jan-2021	GULBARGA	110	HV1	HANUMASAGAR_110	22:20(14.1.2021)			TRANSFORMER OPEN ,LINE CLEAR AVAILED.
345	14-Jan-2021	GULBARGA	110	HUMNABAD-MANEKHALI	MANEKHALI_110	17:20	17:25	00:05	LINE FAULT
346	14-Jan-2021	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	06:37	08:00	01:23	LINE FAULT
347	14-Jan-2021	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110	21:35	21:45	00:10	LINE FAULT
348	14-Jan-2021	GULBARGA	66	ITTAGGI-HIREHADAGALLI2	HIREHADAGALLI_66,SOVENAHALLI_66,GIRIYAPURA_66,MAGALA_66,TBPCL_IPP	06:33	06:45	00:12	LINE FAULT
349	14-Jan-2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:16 (13.01.2021)	6:52 (14.01.2021)	8:35 hrs	LINE CHARGED
350	14-Jan-2021	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	22:27 (13.01.2021)	20:20 (14.01.2021)	21:52 hrs	LINE CHARGED
351	14-Jan-2021	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	22:27 (13.01.2021)	20:20 (14.01.2021)	21:52 hrs	LINE CHARGED
352	14-Jan-2021	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
353	14-Jan-2021	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
354	14-Jan-2021	HASSAN	110	SORABA-SHR220	SORABA_110	11:22 (2.01.2021)			LINE OPEN, LINE CLEAR AVAILED
355	14-Jan-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	20:49 (5.01.2021)			LINE OPEN, LINE CLEAR AVAILED
356	14-Jan-2021	HASSAN	66	HV1	KANDLI_66	11:45(11.1.2021)			LINE OPEN, LINE CLEAR AVAILED
357	14-Jan-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:09 (14.01.2021)			LINE OPEN, LINE CLEAR AVAILED
358	14-Jan-2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:29 (14.01.2021)			LINE OPEN, LINE CLEAR AVAILED
359	14-Jan-2021	HASSAN	220	MRSSHM-VARAH2	MRSMSG_220	11:55	12:20	00:25	HAND TRIPPED
360	14-Jan-2021	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	11:55	12:20	00:25	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
361	14-Jan-2021	HASSAN	110	HV1	HALADY_110	21:09	21:25	00:16	TRANSFORMER FAULT
362	14-Jan-2021	HASSAN	110	SAGARA-LST4	SAGARA_110	11:30	13:41	02:11	LINE CLEAR AVAILED
363	14-Jan-2021	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTYHALLI_66	03:10	04:05	00:55	LINE FAULT
364	14-Jan-2021	HASSAN	66	BYACHAN-HNPURA	BYACHANAHALLI_66	03:46	04:06	00:20	MAIN SUPPLY FAILURE
365	14-Jan-2021	MYSURU	66	HV2	HOOTAGALLY_220	10:36	12:02	1:26	LINE CLEAR AVAILED
366	14-Jan-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020			LINE OPEN, LINE CLEAR AVAILED
367	14-Jan-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN, LINE CLEAR AVAILED
368	14-Jan-2021	TUMKUR	110	TR-1	BIDARE_110	10:04:17 PM(14.01.2021)			TRANSFORMER OPEN , TRANSFORMER FAULT
369	14-Jan-2021	TUMKUR	66	TR-1	HALURAMESHWARA_66	10:06	10:15	0:09	TRANSFORMER FAULT
370	14-Jan-2021	TUMKUR	66	TR-2	HARIHAR_66	16:25	17:02	0:36	LINE CLEAR AVAILED
371	14-Jan-2021	TUMKUR	66	TR-1	MYLANAHALLI_66	18:35	18:39	0:03	TRANSFORMER FAULT
372	14-Jan-2021	TUMKUR	66	TR-1	RANGANATHAPURA_66	17:09	17:45	0:35	LINE CLEAR AVAILED
1	15-Jan-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
2	15-Jan-2021	BAGALKOT	110	110/11KV, HV1	KHANAPUR_110	11:55	14:40	2:45	LINE CLEAR AVAILED
3	15-Jan-2021	BAGALKOT	110	110/11KV, HV2	RATTIHALI_110	9:47	9:53	0:06	TRANSFORMER FAULT
4	15-Jan-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM 110	1:05 (27.11.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
5	15-Jan-2021	BAGALKOT	110	110/11KV,HV1	ACHANUR_110	11:49	14:52	3:03	LINE CLEAR AVAILED
6	15-Jan-2021	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	09:49	09:52	0:03	TRANSFORMER FAULT
7	15-Jan-2021	BAGALKOT	110	110/33KV, HV2	UTTUR_110, YADAWAD_33, VONTAGODI_33	12:01	12:28	0:27	LINE CLEAR AVAILED
8	15-Jan-2021	BAGALKOT	110	110/33KV, HV2	SAVALAGI_110, HIREPADASALAGI_33, KALBALGI 33	12:00	12:31	0:31	LINE CLEAR AVAILED
9	15-Jan-2021	BAGALKOT	110	110/33KV,HV3	GAJENDRAGAD_110 & RRB3&4 IPP	11:05	11:33	0:28	LINE CLEAR AVAILED
10	15-Jan-2021	BAGALKOT	110	110/33KV,HV3	GAJENDRAGAD_110 & RRB3&4 IPP	16:13	17:42	1:29	TRANSFORMER FAULT
11	15-Jan-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED NAREGAL 110	11:06	12:17	1:11	LINE CLEAR AVAILED
12	15-Jan-2021	BAGALKOT	110	GADAG-ANNIGERI	GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
13	15-Jan-2021	BAGALKOT	110	GHATAPRABHA-GOKAK	GOKAK_110	15:50	17:08	1:18	LINE CLEAR AVAILED
14	15-Jan-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA 110	15:24 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
15	15-Jan-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA 110	15:25 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
16	15-Jan-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
17	15-Jan-2021	BAGALKOT	110	HAVERI220-BYADAGI	STATION NOT AFFECTED BYADAGI 110	12:52	14:59	2:07	LINE CLEAR AVAILED
18	15-Jan-2021	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI 110	17:35 (29.12.2020)			LINE OPEN, LINE CLEAR AVAILED
19	15-Jan-2021	BAGALKOT	110	KANABARGI LAYOUT- NEHARUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT 110	9:16 (03.01.2021)			LINE OPEN, LINE CLEAR AVAILED
20	15-Jan-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN ,LINE FAULT
21	15-Jan-2021	BAGALKOT	110	MAHALINGAPUR-JMAKHANDI	JAMAKHANDI_110 (STATION NOT AFFECTED)	15:01 (14.01.2021)	14:52 (15.01.2021)	23:51hrs	LINE CHARGED
22	15-Jan-2021	BAGALKOT	110	NAVALGUND-KNRNGD(KONNUR)	STATION NOT AFFECTED NAVALGUND 110	15:29 (05.01.2021)	11:08 (15.01.2020)	235:39 HRS	LINE CHARGED
23	15-Jan-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND 110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
24	15-Jan-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR 220	13:16 (17.11.2020)			LINE OPEN ,LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
25	15-Jan-2021	BAGALKOT	220	220/110KV,HV1&LV1	GADAG_220	11:08	17:43	6:35	LINE CLEAR AVAILED
26	15-Jan-2021	BAGALKOT	220	220/110KV,HV2&LV2	BIJAPUR_220	14:59	18:44	3:45	LINE CLEAR AVAILED
27	15-Jan-2021	BAGALKOT	220	220/110KV,HV2,LV2	NO STATION AFFECTED HAVERI_220	14:59	17:12	2:13	LINE CLEAR AVAILED
28	15-Jan-2021	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	21:39 (14.01.2021)	7:58 (15.01.2021)	10:19hrs	LINE CHARGED
29	15-Jan-2021	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	20:41 (15.01.2021)			LOAD CURTAILMENT
30	15-Jan-2021	BAGALKOT	220	BELGAUM-KANABARGI1 (NARENDRA1)	STATION NOT AFFECTED BELGAUM_220	20:49 (15.01.2021)			LOAD CURTAILMENT
31	15-Jan-2021	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM_220	12:46	13:08	0:22	LINE FAULT
32	15-Jan-2021	BAGALKOT	220	BELGAUM-NARENDRA1(KANABARGI1)	BELGAUM_220	21:04 (14.01.2021)	7:49 (15.01.2021)	10:45hrs	LINE CHARGED
33	15-Jan-2021	BAGALKOT	220	CHIKKOD-BELGAUM-1	CHIKKODI_220	21:39 (14.01.2021)	7:59 (15.01.2021)	10:20hrs	LINE CHARGED
34	15-Jan-2021	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	20:41 (15.01.2021)			LOAD CURTAILMENT
35	15-Jan-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVAILED
36	15-Jan-2021	BAGALKOT	220	NAGJHARI3- HUBLI	STATION NOT AFFECTED HUBLI_220	12:10	15:33	3:23	LINE CLEAR AVAILED
37	15-Jan-2021	BAGALKOT	220	NARENDRA-KANABARGI1 (BELGAUM1)	STATION NOT AFFECTED NARENDRA_220	12:46	13:09	0:23	LINE FAULT
38	15-Jan-2021	BAGALKOT	220	SHARAVATHY1- SIRSI	STATION NOT AFFECTED SIRSI_220	6:20 (13.01.2020)			LOAD CURTAILMENT
39	15-Jan-2021	BAGALKOT	220	SHARAVATHY2- SIRSI	STATION NOT AFFECTED SIRSI_220	6:20 (13.01.2020)			LOAD CURTAILMENT
40	15-Jan-2021	BENGALURU	66	ATTUR YELAHANKA - DG4	ATTUR YELAHANKA	13:03	13:05	00:02	LOAD CHANGE OVER
41	15-Jan-2021	BENGALURU	66	ATTUR YELAHANKA - YELAHANKA 220	ATTUR YELAHANKA	09:47	09:58	00:11	LINE FAULT
42	15-Jan-2021	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	06:50	06:57	00:07	LOAD CHANGE OVER
43	15-Jan-2021	BENGALURU	66	HV1	HULIMANGALA	11:34	16:38	05:04	LINE CLEAR AVAILED
44	15-Jan-2021	BENGALURU	66	HV1	MELLAHALLI	11:40	11:45	00:05	LINE CLEAR AVAILED
45	15-Jan-2021	BENGALURU	66	HV1	RAJANUKUNTE	11:35	11:40	00:05	LINE CLEAR AVAILED
46	15-Jan-2021	BENGALURU	66	HV1	L R BANDE	16:25	16:27	00:02	LINE CLEAR AVAILED
47	15-Jan-2021	BENGALURU	66	HV1	KAMASAMUDRA	12:23	12:35	00:08	LINE CLEAR AVAILED
48	15-Jan-2021	BENGALURU	66	HV1	MAASTHI	17:02	17:50	00:47	LINE CLEAR AVAILED
49	15-Jan-2021	BENGALURU	66	HV2	HULIMANGALA	11:58	12:10	00:12	LINE CLEAR AVAILED
50	15-Jan-2021	BENGALURU	66	HV2	BANASAWADI	15:09	15:20	00:11	LOAD CHANGE OVER
51	15-Jan-2021	BENGALURU	66	HV2	BANASAWADI	15:54	15:58	00:04	LOAD CHANGE OVER
52	15-Jan-2021	BENGALURU	66	HV2	RAJANUKUNTE	13:45	14:20	00:35	LINE CLEAR AVAILED
53	15-Jan-2021	BENGALURU	66	HV2	HOSKOTE 66	12:00	12:26	00:26	LINE CLEAR AVAILED
54	15-Jan-2021	BENGALURU	66	HV2	IRGAMPALLI	13:57	18:01	04:03	LINE CLEAR AVAILED
55	15-Jan-2021	BENGALURU	66	ITI 220 - BANASAWADI	NO STATION AFFECTED	15:13	15:41	00:28	LINE FAULT
56	15-Jan-2021	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	05:27	05:40	00:12	LINE CLEAR AVAILED
57	15-Jan-2021	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	12:18	12:33	00:15	LINE CLEAR AVAILED
58	15-Jan-2021	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	05:27	05:39	00:11	LINE CLEAR AVAILED
59	15-Jan-2021	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	12:18	12:33	00:15	LINE CLEAR AVAILED
60	15-Jan-2021	BENGALURU	66	RAJANKUNTE - DB PURA 220	RAJANUKUNTE	16:35	16:45	00:10	LOAD CHANGE OVER
61	15-Jan-2021	BENGALURU	66	RAJANUKUNTE - YELAHANKA 220	RAJANUKUNTE	13:45	14:20	00:35	LOAD CHANGE OVER
62	15-Jan-2021	BENGALURU	66	SOBHA FOREST - SOMANAHALLI 220	SOBHA FOREST	00:22	00:43	00:21	LOAD CHANGE OVER
63	15-Jan-2021	BENGALURU	220	DB PURA 220 - NELAMANGALA 1	NO STATION AFFECTED	16:41:00(15/01/2021)			LINE OPEN ,LINE FAULT
64	15-Jan-2021	BENGALURU	220	HV1	YARANDANAHALLI 220	21:30:00(14/01/2021)	6:41(15/01/2021)	9:11HRS	TRANSFORMER CHARGED
65	15-Jan-2021	GULBARGA	110	GURUMITKAL-KONKAL	KONKAL_110	20:22	20:29	00:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
66	15-Jan-2021	GULBARGA	110	HV1	HANUMASAGAR_110	22:20(14.1.2021)	13:10(15.1.2021)	14:50 HRS	TRANSFORMER CHARGED
67	15-Jan-2021	GULBARGA	110	HV1	NIRNA_110	11:00	11:05	00:05	TRANSFORMER FAULT
68	15-Jan-2021	GULBARGA	110	HV1	NIRNA_110	11:10	11:15	00:05	TRANSFORMER FAULT
69	15-Jan-2021	GULBARGA	110	HV1	NIRNA_110	15:00	15:05	00:05	TRANSFORMER FAULT
70	15-Jan-2021	GULBARGA	110	HV1	NIRNA_110	15:40	15:45	00:05	TRANSFORMER FAULT
71	15-Jan-2021	GULBARGA	110	HV1	GINIGERA_110	13:40	13:50	00:10	LINE CLEAR AVAILED
72	15-Jan-2021	GULBARGA	110	HV1,HV2	RAJESHWAR_110	15:25	15:40	00:15	LINE CLEAR AVAILED
73	15-Jan-2021	GULBARGA	110	HV2	SANKLAPUR_110	9:00(15.01.2021)			TRANSFORMER OPEN ,LINE CLEAR AVAILED.
74	15-Jan-2021	GULBARGA	110	HV3	GINIGERA_110	11:05	11:15	00:10	LINE CLEAR AVAILED
75	15-Jan-2021	GULBARGA	110	HV3	GULBARGAWEST_110	17:00	19:25	02:25	LINE CLEAR AVAILED
76	15-Jan-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	06:00	06:06	00:06	LINE FAULT
77	15-Jan-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	19:09	19:21	00:12	LINE FAULT
78	15-Jan-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	19:42	19:58	00:16	LINE FAULT
79	15-Jan-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	20:28	20:43	00:15	LINE FAULT
80	15-Jan-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	21:15	21:50	00:35	LINE FAULT
81	15-Jan-2021	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	03:53	04:03	00:10	LINE FAULT
82	15-Jan-2021	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	10:22	10:30	00:08	LINE CLEAR AVAILED
83	15-Jan-2021	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	10:35	10:45	00:10	LINE CLEAR AVAILED
84	15-Jan-2021	GULBARGA	110	SINDHANOOR-SIRIGUPPA	SIRIGUPPA_110,DHADESUGUR_110,TEKKALKOTE_110,NSL SUGAR IPP	11:05	11:15	00:10	LINE FAULT
85	15-Jan-2021	HASSAN	66	HV1	KANDLI_66	11:45(11.1.2021)	13:53 (15.01.2021)	26:07 hrs	LINE CHARGED
86	15-Jan-2021	HASSAN	66	HV1	HALEBEEDU_66	09:37	11:16	01:39	LINE CLEAR AVAILED
87	15-Jan-2021	HASSAN	66	HV1	HOLEHONNUR_66	15:25	20:07	04:42	LINE CLEAR AVAILED
88	15-Jan-2021	HASSAN	66	HV1	KANDLI_66	15:35	15:50	00:15	LINE CLEAR AVAILED
89	15-Jan-2021	HASSAN	66	HV1	KANDLI_66	18:15	19:30	01:15	LINE CLEAR AVAILED
90	15-Jan-2021	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	06:34	06:39	00:05	HAND TRIPPED
91	15-Jan-2021	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
92	15-Jan-2021	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
93	15-Jan-2021	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	01:26	01:42	00:16	LINE FAULT
94	15-Jan-2021	HASSAN	110	ALKOLA-MRS	ALKOLA_110	11:47	17:12	05:25	LINE CLEAR AVAILED
95	15-Jan-2021	HASSAN	110	HV	KITTADAHALLI_110	14:03	15:25	01:22	LINE CLEAR AVAILED
96	15-Jan-2021	HASSAN	110	HV1	HALADY_110	02:23	02:59	00:36	TRANSFORMER FAULT
97	15-Jan-2021	HASSAN	110	HV1	HALADY_110	09:49	10:12	00:23	TRANSFORMER FAULT
98	15-Jan-2021	HASSAN	110	HV1	HALADY_110	11:50	15:05	03:15	LINE CLEAR AVAILED
99	15-Jan-2021	HASSAN	110	HV2	PUTTUR_110	15:40(15.1.2021)			TRANSFORMER OPEN ,LINE CLEAR AVAILED.
100	15-Jan-2021	HASSAN	110	HV2	ARASIKERE_110	16:22	17:49	01:27	LINE CLEAR AVAILED
101	15-Jan-2021	HASSAN	110	MRSSHM-SS1	MRSMSG_220	11:46	15:35	03:49	LINE CLEAR AVAILED
102	15-Jan-2021	HASSAN	110	SHIVAPUR-BIRUR	SHIVPURA_110	13:46	16:27	02:41	LINE CLEAR AVAILED
103	15-Jan-2021	HASSAN	110	SORABA-SHR220	SORABA_110	11:22 (2.01.2021)			LINE OPEN, LINE CLEAR AVAILED
104	15-Jan-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:09 (14.01.2021)	7:55 (15.01.2021)	30:45 hrs	LINE CHARGED
105	15-Jan-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	20:49 (5.01.2021)			LINE OPEN, LINE CLEAR AVAILED
106	15-Jan-2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:29 (14.01.2021)	7:23 (15.01.2021)	7:53 hrs	LINE CHARGED
107	15-Jan-2021	MYSURU	66	BANNUR-VAJAMANGALA	NO STATION EFFECTED	14:30	14:46	0:16	LINE FAULT
108	15-Jan-2021	MYSURU	66	GUNDLUPETE-KABBALLY	NO STATION EFFECTED	15:53	17:28	1:35	LINE CLEAR AVAILED
109	15-Jan-2021	MYSURU	66	HAMAPAPURA-KODAKOLA	HAMPAPURA(K)_66	12:08	12:12	0:04	LINE FAULT
110	15-Jan-2021	MYSURU	66	HEBBANI-SHIMSHA	NO STATION EFFECTED	15:45	16:06	0:21	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
111	15-Jan-2021	MYSURU	66	HV1	MYSORESOUTH_66	12:44	14:11	1:27	LINE CLEAR AVAILED
112	15-Jan-2021	MYSURU	66	HV1	CRNAGAR_220	12:14	14:01	1:47	LINE CLEAR AVAILED
113	15-Jan-2021	MYSURU	66	HV2	MYSORESOUTH_66	14:13	14:35	0:21	LINE CLEAR AVAILED
114	15-Jan-2021	MYSURU	220	HOOTAGALLY-KODAKOLA	NO STATION EFFECTED	12:14	15:18	3:03	HAND TRIPPED
115	15-Jan-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	10:00	11:52	1:52	LINE CLEAR AVAILED
116	15-Jan-2021	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	03:28	03:31	0:02	LINE FAULT
117	15-Jan-2021	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	09:50	10:17	0:26	LINE FAULT
118	15-Jan-2021	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	09:05	13:10	4:04	LINE FAULT
119	15-Jan-2021	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	09:49	10:15	0:26	LINE FAULT
120	15-Jan-2021	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	09:49	10:15	0:26	LINE FAULT
121	15-Jan-2021	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	03:16	03:25	0:09	LINE FAULT
122	15-Jan-2021	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	21:35	21:52	0:16	LINE FAULT
123	15-Jan-2021	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	21:35	21:47	0:11	LINE FAULT
124	15-Jan-2021	TUMKUR	66	TR-1	MYLANAHALLI_66	08:05	08:10	0:04	TRANSFORMER FAULT
125	15-Jan-2021	TUMKUR	66	TR-1	PAVAGADA_220	05:15	05:19	0:04	TRANSFORMER FAULT
126	15-Jan-2021	TUMKUR	66	TR-1	PAVAGADA_220	15:21	15:24	0:03	TRANSFORMER FAULT
127	15-Jan-2021	TUMKUR	66	TR-1(LV SIDE)	HIRIYUR_220	09:11	09:50	0:39	TRANSFORMER FAULT
128	15-Jan-2021	TUMKUR	66	TR-2	BELLAVI_66	11:02	11:42	0:39	LINE CLEAR AVAILED
129	15-Jan-2021	TUMKUR	66	TR-2	BELLAVI_66	15:08	17:11	2:03	LINE CLEAR AVAILED
130	15-Jan-2021	TUMKUR	110	TR-1	BIDARE_110	22:04:17 (14.01.2021)	14:48:36 (15.01.2021)	16:44hrs	TRANSFORMER CHARGED
131	15-Jan-2021	TUMKUR	110	TR-1	BIDARE_110	14:56	18:31	3:34	LINE CLEAR AVAILED
132	15-Jan-2021	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	12:42	13:41	0:59	LINE FAULT
133	15-Jan-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE CLEAR AVAILED
134	15-Jan-2021	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	12:42	13:26	0:44	LINE FAULT
135	15-Jan-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN, LINE CLEAR AVAILED
136	15-Jan-2021	TUMKUR	220	TR-1	HIRIYUR_220	09:11	09:42	0:31	TRANSFORMER FAULT
137	15-Jan-2021	TUMKUR	220	TR-3	HIRIYUR_220	09:11	10:06	0:55	TRANSFORMER FAULT
138	16-Jan-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
139	16-Jan-2021	BAGALKOT	110	110/11KV, HV1	NAVANAGAR HUBLI_110	12:08	13:02	0:54	LINE CLEAR AVAILED
140	16-Jan-2021	BAGALKOT	110	110/11KV, HV2	VAJRAMATTI_110	15:44	16:12	0:28	LINE CLEAR AVAILED
141	16-Jan-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED RANNABELAGALI_110	07:48	10:14	2:26	HAND TRIPPED
142	16-Jan-2021	BAGALKOT	110	110/11KV, HV2	NAVANAGAR HUBLI_110	11:15	13:45	2:30	LINE CLEAR AVAILED
143	16-Jan-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
144	16-Jan-2021	BAGALKOT	110	110/33KV, HV2	STATION NOT AFFECTED HUBLI_220	16:41	18:29	1:48	LINE CLEAR AVAILED
145	16-Jan-2021	BAGALKOT	110	110/33KV,HV3	HIDIKAL DAM_110,RUSTUMPUR LIS_33,BELGAUM WATER SUPPLY1_33,BELGAUM WATER SUPPLY2&3	16:20	16:50	0:30	TRANSFORMER FAULT
146	16-Jan-2021	BAGALKOT	110	220/110KV,LV2	STATION NOT AFFECTED MK HUBLI_220	12:45	17:01	4:16	HAND TRIPPED
147	16-Jan-2021	BAGALKOT	110	ANANTPURAM SOLAR-KONNUR	STATION NOT AFFECTED KONNUR_110	18:03	22:54	4:51	LINE CLEAR AVAILED
148	16-Jan-2021	BAGALKOT	110	ANANTPURAM SOLAR-KONNUR	STATION NOT AFFECTED KONNUR_110	18:16	22:22	4:06	LINE CLEAR AVAILED
149	16-Jan-2021	BAGALKOT	110	BAGALKOT-KERUR	STATION NOT AFFECTED BAGALKOT_220	13:24	13:38	0:14	LINE FAULT
150	16-Jan-2021	BAGALKOT	110	BAGALKOT-KERUR	KERUR_110	13:34	13:39	0:05	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
151	16-Jan-2021	BAGALKOT	110	BAGEWADI-MATTIHAL	MATTIHAL_110	12:24	12:40	0:16	LINE FAULT
152	16-Jan-2021	BAGALKOT	110	BELGAUM220- VADAGOAN	STATION NOT AFFECTED VADAGOAN_110	17:20	18:45	1:25	HAND TRIPPED
153	16-Jan-2021	BAGALKOT	110	BELGAUM220- VADAGOAN	STATION NOT AFFECTED VADAGOAN_110	18:54	21:58	3:04	NFBC ISSUED
154	16-Jan-2021	BAGALKOT	110	GADAG-ANNIGERI	GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
155	16-Jan-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	15:24 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
156	16-Jan-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA_110	15:25 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
157	16-Jan-2021	BAGALKOT	110	GOPPANAKOPPA-NARGUND	STATION NOT AFFECTED NARGUND_110	23:19 (16.01.2021)			LINE OPEN ,LINE FAULT
158	16-Jan-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
159	16-Jan-2021	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	17:35 (29.12.2020)			LINE OPEN, LINE CLEAR AVAILED
160	16-Jan-2021	BAGALKOT	110	KANABARGI LAYOUT- NEHARUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN, LINE CLEAR AVAILED
161	16-Jan-2021	BAGALKOT	110	KERUR-BADAMI	BADAMI_110	13:24	14:10	0:46	HAND TRIPPED
162	16-Jan-2021	BAGALKOT	110	KERUR-KONNUR	STATION NOT AFFECTED KONNUR_110	13:35	13:39	0:04	HAND TRIPPED
163	16-Jan-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN ,LINE FAULT
164	16-Jan-2021	BAGALKOT	110	MK HUBLI-HIREBAGEWADI	STATION NOT AFFECTED HIREBAGEWADI_110	12:12	16:01	3:49	LINE FAULT
165	16-Jan-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
166	16-Jan-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN ,LINE FAULT
167	16-Jan-2021	BAGALKOT	110	SINDAGI-ALMEL(SHABAD)	ALMEL_110	15:27	15:36	0:09	LINE FAULT
168	16-Jan-2021	BAGALKOT	220	220/110KV,HV1,LV1	NO STATION AFFECTED GADAG_220	10:17	18:25	8:08	LINE CLEAR AVAILED
169	16-Jan-2021	BAGALKOT	220	AMBEWADI-NARENDRA 1	AMBEWADI_220	12:30	15:43	3:13	LINE FAULT
170	16-Jan-2021	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220 (STATION NOT AFFECTED)	16:28	16:41	0:13	LINE FAULT
171	16-Jan-2021	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	20:41 (15.01.2021)	8:20 (16.01.2021)	11:39 HRS	LINE CHARGED
172	16-Jan-2021	BAGALKOT	220	BELGAUM-KANABARGI1 (NARENDRA1)	STATION NOT AFFECTED BELGAUM_220	20:49 (15.01.2021)	8:19 (16.01.2021)	11:30 HRS	LINE CHARGED
173	16-Jan-2021	BAGALKOT	220	BELGAUM-NARENDRA1(KANABARGI1)	BELGAUM_220	13:57	15:45	1:48	LINE FAULT
174	16-Jan-2021	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	20:41 (15.01.2021)	8:19 (16.01.2021)	11:38 HRS	LINE CHARGED
175	16-Jan-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVAILED
176	16-Jan-2021	BAGALKOT	220	NAGJHARI3- HUBLI	STATION NOT AFFECTED HUBLI_220	12:24	18:16	5:52	LINE FAULT
177	16-Jan-2021	BAGALKOT	220	NARENDRA-AMBEWADI1	STATION NOT AFFECTED NARENDRA_220	12:16	15:44	3:28	LINE FAULT
178	16-Jan-2021	BAGALKOT	220	NARENDRA-KANABARGI1(BELGAUM1)	STATION NOT AFFECTED NARENDRA_220	13:57	15:46	1:49	LINE FAULT
179	16-Jan-2021	BAGALKOT	220	SHARAVATHY1- SIRSI	STATION NOT AFFECTED SIRSI_220	6:20 (13.01.2020)	20:03 (17.01.2021)	37:43 HRS	LINE CHARGED
180	16-Jan-2021	BAGALKOT	220	SHARAVATHY2- SIRSI	STATION NOT AFFECTED SIRSI_220	6:20 (13.01.2020)	20:03 (17.01.2021)	37:43 HRS	LINE CHARGED
181	16-Jan-2021	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	17:17	17:19	00:01	LINE CLEAR AVAILED
182	16-Jan-2021	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	01:35	01:46	00:11	MAIN SUPPLY FAILURE
183	16-Jan-2021	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	06:14	06:18	00:04	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
184	16-Jan-2021	BENGALURU	66	HBR LAYOUT-HOSKOTE 220	HBR LAYOUT, BELL CERAMICS (EHT)	03:01	03:10	00:09	MAIN SUPPLY FAILURE
185	16-Jan-2021	BENGALURU	66	HOSKOTE 220 - BIAL	NO STATION AFFECTED	11:05	11:16	00:11	LINE FAULT
186	16-Jan-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	02:55	04:50	01:54	LINE FAULT
187	16-Jan-2021	BENGALURU	66	HV1	HANUMANTHNAGARA	09:27	09:37	00:10	TRANSFORMER FAULT
188	16-Jan-2021	BENGALURU	66	HV1	ARMY WELFARE	10:53	11:03	00:10	TRANSFORMER FAULT
189	16-Jan-2021	BENGALURU	66	HV1	IRGAMPALLI	12:45	14:45	02:00	LINE CLEAR AVAILED
190	16-Jan-2021	BENGALURU	66	HV2	IRGAMPALLI	14:50	16:23	01:33	LINE CLEAR AVAILED
191	16-Jan-2021	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD	07:20	07:40	00:20	LINE FAULT
192	16-Jan-2021	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI LINK ROAD	17:49	20:27	02:38	LINE FAULT
193	16-Jan-2021	BENGALURU	220	DB PURA 220 - NELAMANGALA 1	NO STATION AFFECTED	16:41:00(15/01/2021)	15:17(16/01/2021)	22:36HRS	LINE CHARGED
194	16-Jan-2021	BENGALURU	220	HV1	YARANDANAHALLI 220	1:35(16/01/2021)			TRANSFORMER OPEN , TRANSFORMER FAULT
195	16-Jan-2021	GULBARGA	66	HV1	HAMPASAGAR_66	15:30	18:30	03:00	LINE CLEAR AVAILED
196	16-Jan-2021	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110	15:35	16:40	01:05	LINE CLEAR AVAILED
197	16-Jan-2021	GULBARGA	110	HALBARGA-SANTPUR	SANTPUR_110	15:25	16:40	01:15	LINE CLEAR AVAILED
198	16-Jan-2021	GULBARGA	110	ITTAGGI-HIREHADAGALLI2	HIREHADAGALLI_66,SOVENAHALLI_66,GIRIYAP URA_66,MAGALA_66,TBPCL IPP	12:10	13:42	01:32	LINE CLEAR AVAILED
199	16-Jan-2021	GULBARGA	110	NALWAR-WARDA SLR	NALWAR_110	18:25	22:35	04:10	LINE CLEAR AVAILED
200	16-Jan-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	03:53	04:05	00:12	LINE FAULT
201	16-Jan-2021	GULBARGA	110	SHAHAPUR-SURPUR	SURPUR_110	10:55	13:25	02:30	LINE CLEAR AVAILED
202	16-Jan-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	10:41	13:45	03:04	LINE CLEAR AVAILED
203	16-Jan-2021	GULBARGA	110	SINDNOOR-NIRLOOTI	SINDHANOOR_220	01:35	01:50	00:15	LINE FAULT
204	16-Jan-2021	GULBARGA	110	VALKAMDINNI-MALLAT	VALKAMDINNI_110	18:50	19:00	00:10	MAIN SUPPLY FAILURE
205	16-Jan-2021	HASSAN	66	DODDAHA-HOOTGALLI	DODDAHALLY_66	10:58	14:51	03:53	LINE CLEAR AVAILED
206	16-Jan-2021	HASSAN	66	HV1	JUTTANAHALLI_66	10:22	10:48	00:26	TRANSFORMER FAULT
207	16-Jan-2021	HASSAN	66	HV1	MAGGE_66	16:54	18:44	01:50	LINE CLEAR AVAILED
208	16-Jan-2021	HASSAN	66	HV2	MAGGE_66	16:54	20:18	03:24	LINE CLEAR AVAILED
209	16-Jan-2021	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
210	16-Jan-2021	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
211	16-Jan-2021	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	17:01	21:14	04:13	MAIN SUPPLY FAILURE
212	16-Jan-2021	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	17:01	17:42	00:41	MAIN SUPPLY FAILURE
213	16-Jan-2021	HASSAN	110	GURUVA-SLVPWR	GURUVAYANAKERE_110	17:04	17:46	00:42	MAIN SUPPLY FAILURE
214	16-Jan-2021	HASSAN	110	HV1	PUTTUR_110	10:19	11:11	00:52	LINE CLEAR AVAILED
215	16-Jan-2021	HASSAN	110	HV2	PUTTUR_110	15:40(15.1.2021)			LINE CLEAR AVAILED
216	16-Jan-2021	HASSAN	110	HV2	KUNDAPURA_110	17:12	17:53	00:41	LINE CLEAR AVAILED
217	16-Jan-2021	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	17:00	17:50	00:50	LINE FAULT
218	16-Jan-2021	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	17:50	21:14	03:24	LINE FAULT
219	16-Jan-2021	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	17:00	17:41	00:41	LINE FAULT
220	16-Jan-2021	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	10:33	12:42	02:09	LINE CLEAR AVAILED
221	16-Jan-2021	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	12:29	12:34	00:05	MAIN SUPPLY FAILURE
222	16-Jan-2021	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	12:15	12:19	00:04	MAIN SUPPLY FAILURE
223	16-Jan-2021	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	12:29	12:33	00:04	MAIN SUPPLY FAILURE
224	16-Jan-2021	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	12:15	12:29	00:14	MAIN SUPPLY FAILURE
225	16-Jan-2021	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	12:15	12:37	00:22	MAIN SUPPLY FAILURE
226	16-Jan-2021	HASSAN	110	SORABA-SHR220	SORABA_110	11:22 (2.01.2021)			LINE OPEN, LINE CLEAR AVAILED
227	16-Jan-2021	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	14:11	14:59	00:48	LINE FAULT
228	16-Jan-2021	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	15:36	18:53	03:17	LINE FAULT
229	16-Jan-2021	HASSAN	220	MRSSHM-CHMLR	MRSMSG_220	10:32	18:33	08:01	LINE CLEAR AVAILED
230	16-Jan-2021	HASSAN	220	MRSSHM-HSN4001	MRSMSG_220	10:29	18:33	08:04	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
231	16-Jan-2021	HASSAN	220	MRSSH-M-SHARAVATHY1	MRSMSG_220	15:36	18:53	03:17	LINE FAULT
232	16-Jan-2021	HASSAN	220	MRSSH-M-STRP1	MRSMSG_220	14:11	14:59	00:48	LINE FAULT
233	16-Jan-2021	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	12:31	13:19	00:48	LINE FAULT
234	16-Jan-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	02:04	06:30	04:26	HAND TRIPPED
235	16-Jan-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	20:49 (5.01.2021)			LINE OPEN, LINE CLEAR AVAILED
236	16-Jan-2021	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATION EFFECTED	9:49	9:57	0:07	LINE FAULT
237	16-Jan-2021	MYSURU	66	DUNDANALLY-HULIYURDURGA	DUNDANAHALLI_66	15:00	16:36	1:36	LINE CLEAR AVAILED
238	16-Jan-2021	MYSURU	66	HANNUR-AJJIPURA	AJJIPURA_66 BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66	18:09	18:17	0:07	LINE FAULT
239	16-Jan-2021	MYSURU	66	HOOTAGALLI-BELAGOLA	NO STATION EFFECTED	9:01	15:02	6:01	LOAD CHANGE OVER
240	16-Jan-2021	MYSURU	66	HOOTAGALLI-BOGADHI	NO STATION EFFECTED	9:12	14:52	5:39	LOAD CHANGE OVER
241	16-Jan-2021	MYSURU	66	HOOTAGALLI-DATTAGALLI	NO STATION EFFECTED	9:21	9:23	0:01	HAND TRIPPED
242	16-Jan-2021	MYSURU	66	HOOTAGALLI-DATTAGALLI	NO STATION EFFECTED	14:37	14:42	0:05	HAND TRIPPED
243	16-Jan-2021	MYSURU	66	HOOTAGALLI-DODDAKADNURU	KAGGERE HAMPAPURA_66	11:05	15:20	4:15	LINE CLEAR AVAILED
244	16-Jan-2021	MYSURU	66	HOOTAGALLI-VIJAYANAGARA	NO STATION EFFECTED	9:12	14:52	5:39	LOAD CHANGE OVER
245	16-Jan-2021	MYSURU	66	HV1	MANDGERE_66	5:05	5:16	0:11	MAIN SUPPLY FAILURE
246	16-Jan-2021	MYSURU	66	HV2	DEVANOORNGUDU_66	10:24	10:39	0:15	TRANSFORMER FAULT
247	16-Jan-2021	MYSURU	66	HV2	DEVANOORNGUDU_66	10:43	10:59	0:16	TRANSFORMER FAULT
248	16-Jan-2021	MYSURU	66	HV2	DEVANOORNGUDU_66	11:45	11:55	0:10	TRANSFORMER FAULT
249	16-Jan-2021	MYSURU	66	HV2	DEVANOORNGUDU_66	11:57	12:38	0:41	LINE CLEAR AVAILED
250	16-Jan-2021	MYSURU	66	HV2	PANDAVAPURA_66	12:39	14:12	1:32	LINE CLEAR AVAILED
251	16-Jan-2021	MYSURU	66	VAJAMANGALA-JYOTHINAGARA	FTS_66 JYOTHINAGARA_66	16:57	17:05	0:07	LINE FAULT
252	16-Jan-2021	MYSURU	220	HV2	HOOTAGALLY_220	10:07	14:27	4:19	LINE CLEAR AVAILED
253	16-Jan-2021	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	14:32	15:12	0:40	LINE FAULT
254	16-Jan-2021	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	13:06	18:19	5:12	LINE CLEAR AVAILED
255	16-Jan-2021	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	13:05	18:15	5:09	LINE CLEAR AVAILED
256	16-Jan-2021	TUMKUR	66	HIRIYUR 220KV- CHITRADURGA(SIRA)	HIRIYUR_220	12:11	16:39	4:27	LINE CLEAR AVAILED
257	16-Jan-2021	TUMKUR	66	HONNALLI 220KV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL EHT_66	23:14	23:22	0:08	LINE FAULT
258	16-Jan-2021	TUMKUR	66	HULIYURDURGA- DUNDANAHALLI	DUNDANAHALLI_66	14:30	16:14	1:44	LINE CLEAR AVAILED
259	16-Jan-2021	TUMKUR	66	THALLAK 220KV-BGKERE 1	BGKERE_66	11:51	12:01	0:09	HAND TRIPPED
260	16-Jan-2021	TUMKUR	66	THALLAK 220KV-BGKERE 2	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	11:51	12:01	0:09	HAND TRIPPED
261	16-Jan-2021	TUMKUR	66	THALLAK 220KV- GOWRASAMUDRA	GOWRASAMUDRA_66	11:51	12:01	0:09	HAND TRIPPED
262	16-Jan-2021	TUMKUR	66	THALLAK 220KV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	11:52	14:31	2:39	HAND TRIPPED
263	16-Jan-2021	TUMKUR	66	THALLAK 220KV- WELSPUN SOLAR2	WELSPUNSOLAR2_IPP_66	11:52	14:31	2:39	HAND TRIPPED
264	16-Jan-2021	TUMKUR	66	TR-1	BADAVANAHALLI_66	12:33	13:08	0:35	LINE CLEAR AVAILED
265	16-Jan-2021	TUMKUR	66	TR-2	BADAVANAHALLI_66	12:33	13:09	0:35	LINE CLEAR AVAILED
266	16-Jan-2021	TUMKUR	66	TR-2	CHANNAGIRI_66	06:20	06:21	0:01	TRANSFORMER FAULT
267	16-Jan-2021	TUMKUR	66	TR-2	HANAGAL_66	15:40	16:50	1:10	LINE CLEAR AVAILED
268	16-Jan-2021	TUMKUR	66	TR-2	URDIGERE_66	08:17	09:05	0:47	LINE CLEAR AVAILED
269	16-Jan-2021	TUMKUR	66	TR-2(LV SIDE)	THALLAKK_220	11:40	11:58	0:18	TRANSFORMER FAULT
270	16-Jan-2021	TUMKUR	110	TR-1	SHETYKERE_110	13:38	15:09	1:31	LINE CLEAR AVAILED
271	16-Jan-2021	TUMKUR	110	TR-2	TURUVEKERE_110	10:11	17:18	7:06	TRANSFORMER FAULT
272	16-Jan-2021	TUMKUR	110	TR-2	SHETYKERE_110	13:38	15:06	1:27	LINE CLEAR AVAILED
273	16-Jan-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE OPEN, LINE CLEAR AVAILED
274	16-Jan-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN, LINE CLEAR AVAILED
275	16-Jan-2021	TUMKUR	220	TR-1	HIRIYUR_220	19:44	21:27	1:43	LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
276	17-Jan-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
277	17-Jan-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM 110	1:05 (27.11.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
278	17-Jan-2021	BAGALKOT	110	110/11KV,HV2	AMBEWADI 220	12:04	12:21	0:17	HAND TRIPPED
279	17-Jan-2021	BAGALKOT	110	110/33KV,HV2	HUNGUND_110,AMINAGAD_33,KARADI_33,MY TRA SOLAR 33	00:26	00:33	0:07	TRANSFORMER FAULT
280	17-Jan-2021	BAGALKOT	110	110/33KV,HV3(HV4)	LAKAMANALLI_110,ALNAVAR_33	22:36	22:44	0:08	TRANSFORMER FAULT
281	17-Jan-2021	BAGALKOT	110	ASHOK IRON PLANT-MACHE	STATION NOT AFFECTED MACHE 110	9:35	16:33	6:58	LINE CLEAR AVAILED
282	17-Jan-2021	BAGALKOT	110	GADAG-ANNIGERI	GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
283	17-Jan-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA 110	15:24 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
284	17-Jan-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA 110	15:25 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
285	17-Jan-2021	BAGALKOT	110	GOPPANAKOPPA-NARGUND	STATION NOT AFFECTED NARGUND 110	23:19 (16.01.2021)	13:55 (17.01.2021)	14:36hrs	LINE CHARGED
286	17-Jan-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
287	17-Jan-2021	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI 110	17:35 (29.12.2020)			LINE OPEN, LINE CLEAR AVAILED
288	17-Jan-2021	BAGALKOT	110	KANABARGI LAYOUT- NEHARUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT 110	9:16 (03.01.2021)			LINE OPEN, LINE CLEAR AVAILED
289	17-Jan-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN ,LINE FAULT
290	17-Jan-2021	BAGALKOT	110	NARENDRA220-BELUR1	BELUR_110	10:06	17:21	7:15	LINE CLEAR AVAILED
291	17-Jan-2021	BAGALKOT	110	NARENDRA220-BELUR2	BELUR_110	10:57	17:01	6:04	LINE CLEAR AVAILED
292	17-Jan-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND 110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
293	17-Jan-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR 220	13:16 (17.11.2020)			LINE OPEN ,LINE FAULT
294	17-Jan-2021	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	19:51 (17.01.2021)			LOAD CURTAILMENT
295	17-Jan-2021	BAGALKOT	220	CHIKKODI -BELGAUM-2	CHIKKODI_220	19:51 (17.01.2021)			LOAD CURTAILMENT
296	17-Jan-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG 220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVAILED
297	17-Jan-2021	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	STATION NOT AFFECTED MAHALINGAPUR 220	18:16	20:11	1:55	LINE FAULT
298	17-Jan-2021	BAGALKOT	220	NAGJHARI3- HUBLI	STATION NOT AFFECTED HUBLI 220	11:05	17:48	6:43	LINE FAULT
299	17-Jan-2021	BAGALKOT	220	SHARAVATHY1- SIRSI	STATION NOT AFFECTED SIRSI 220	21:03 (17.01.2021)			LOAD CURTAILMENT
300	17-Jan-2021	BAGALKOT	220	SHARAVATHY2- SIRSI	STATION NOT AFFECTED SIRSI 220	21:03 (17.01.2021)			LOAD CURTAILMENT
301	17-Jan-2021	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI 220	18:16	20:11	1:55	LINE FAULT
302	17-Jan-2021	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	08:01	08:13	00:11	LINE FAULT
303	17-Jan-2021	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	12:55	14:00	01:05	LINE FAULT
304	17-Jan-2021	BENGALURU	66	HV1	A STATION	11:00	11:05	00:05	LINE CLEAR AVAILED
305	17-Jan-2021	BENGALURU	66	HV1	BYADRAHALLI	11:20	11:22	00:02	LINE CLEAR AVAILED
306	17-Jan-2021	BENGALURU	66	HV1	DABUSPET 220	17:32	18:00	00:28	TRANSFORMER FAULT
307	17-Jan-2021	BENGALURU	66	HV2	KADUBISANAHALLI	15:05	16:55	01:50	TRANSFORMER FAULT
308	17-Jan-2021	BENGALURU	66	JAYADEVA - ADUGODI 1	NO STATION AFFECTED	15:16	15:55	00:39	LINE FAULT
309	17-Jan-2021	BENGALURU	66	JIGANI 66 - JIGANI 220	JIGANI 66	11:35	11:45	00:10	LOAD CHANGE OVER
310	17-Jan-2021	BENGALURU	66	JIGANI 66 - JIGANI LINK ROAD	JIGANI 66	13:42	13:49	00:07	LOAD CHANGE OVER
311	17-Jan-2021	BENGALURU	66	KADUBISANAHALLI - CESSNA	KADUBISANAHALLI	15:10	15:15	00:05	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
312	17-Jan-2021	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	08:50	09:05	00:15	LINE FAULT
313	17-Jan-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	08:50	09:05	00:15	LINE FAULT
314	17-Jan-2021	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	08:50	09:05	00:15	MAIN SUPPLY FAILURE
315	17-Jan-2021	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	16:37	16:45	00:08	LINE FAULT
316	17-Jan-2021	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	16:35	16:50	00:15	LINE FAULT
317	17-Jan-2021	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	08:50	09:05	00:15	MAIN SUPPLY FAILURE
318	17-Jan-2021	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	10:42	11:55	01:13	LINE CLEAR AVAILED
319	17-Jan-2021	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	12:30	13:45	01:15	LINE CLEAR AVAILED
320	17-Jan-2021	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	08:50	09:05	00:15	MAIN SUPPLY FAILURE
321	17-Jan-2021	BENGALURU	220	HV1	KOLAR 220	08:50	09:03	00:13	TRANSFORMER FAULT
322	17-Jan-2021	BENGALURU	220	HV1	YARANDANAHALLI 220	1:35(16/01/2021)	6:40(17/01/2021)	29:05HRS	TRANSFORMER CHARGED
323	17-Jan-2021	BENGALURU	220	HV2	KOLAR 220	08:50	09:03	00:13	TRANSFORMER FAULT
324	17-Jan-2021	GULBARGA	66	ITTAGGI-HIREHADAGALLI1	HIREHADAGALLI_66	06:32	06:45	00:13	LINE FAULT
325	17-Jan-2021	GULBARGA	66	ITTAGGI-HIREHADAGALLI2	HIREHADAGALLI_66,SOVENAHALLI_66,GIRIYAPURA_66,MAGALA_66,TBPCL IPP	00:33	00:42	00:09	LINE FAULT
326	17-Jan-2021	GULBARGA	66	ITTAGGI-HIREHADAGALLI2	HIREHADAGALLI_66,SOVENAHALLI_66,GIRIYAPURA_66,MAGALA_66,TBPCL IPP	20:22	20:34	00:12	LINE FAULT
327	17-Jan-2021	GULBARGA	66	KUDLIGI-CHORNOOR	CHORNOOR_66	05:20	05:35	00:15	MAIN SUPPLY FAILURE
328	17-Jan-2021	GULBARGA	110	GUTTAL-MYLAR	MYLAR_110	06:25	06:50	00:25	MAIN SUPPLY FAILURE
329	17-Jan-2021	GULBARGA	110	HV2	BISIHALLI_110	15:55	16:14	00:19	TRANSFORMER FAULT
330	17-Jan-2021	GULBARGA	110	HV2	SANKLAPUR_110	9:00(15.01.2021)	13:15(17.01.2021)	52:15 HRS	TRANSFORMER CHARGED
331	17-Jan-2021	GULBARGA	110	HV2	BISIHALLI_110	15:55	16:14	00:19	TRANSFORMER FAULT
332	17-Jan-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	03:58	04:08	00:10	LINE FAULT
333	17-Jan-2021	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	13:05	17:15	04:10	LINE CLEAR AVAILED
334	17-Jan-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	12:54	17:05	04:11	LINE CLEAR AVAILED
335	17-Jan-2021	GULBARGA	110	SINDHANOOR-RAICHUR2	ADAVINA AMARESHWARA CAMP_110KURDICROSS_110	21:44	21:54	00:10	LINE FAULT
336	17-Jan-2021	HASSAN	66	CRPATNA-MATTANAVILE	CHANNARAYAPATNA_66	09:53	10:09	00:16	LINE FAULT
337	17-Jan-2021	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	10:41	12:54	02:13	LINE CLEAR AVAILED
338	17-Jan-2021	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
339	17-Jan-2021	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
340	17-Jan-2021	HASSAN	110	HV2	PUTTUR_110	15:40(15.1.2021)			TRANSFORMER OPEN ,LINE CLEAR AVAILED.
341	17-Jan-2021	HASSAN	110	HV3	KAVOOR_220	10:28	11:17	00:49	LINE CLEAR AVAILED
342	17-Jan-2021	HASSAN	110	SORABA-SHR220	SORABA_110	11:22 (2.01.2021)			LINE OPEN, LINE CLEAR AVAILED
343	17-Jan-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	01:30	06:47	05:17	HAND TRIPPED
344	17-Jan-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	20:49 (5.01.2021)			LINE OPEN, LINE CLEAR AVAILED
345	17-Jan-2021	MYSURU	66	HV1	KOLLEGALA_66	16:05	16:25	0:19	LINE CLEAR AVAILED
346	17-Jan-2021	MYSURU	66	HV2	MADIKERI_66	8:47	8:56	0:08	TRANSFORMER FAULT
347	17-Jan-2021	MYSURU	66	HV2	KOLLEGALA_66	16:25	16:46	0:21	LINE CLEAR AVAILED
348	17-Jan-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATION EFFECTED	13:06 (17/01/2021)			LINE OPEN, LINE CLEAR AVAILED
349	17-Jan-2021	MYSURU	66	MEGHALAPURA-HEBBANI	BGPURA_66 CHIDRAVALI_66 GARGESHWARI_66 THUMBLA_66 VYASRAJPURA_66	7:37	7:45	0:08	LINE FAULT
350	17-Jan-2021	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	09:10	09:19	0:09	LINE FAULT
351	17-Jan-2021	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	11:29	11:35	0:05	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
352	17-Jan-2021	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	12:33	16:10	3:37	LINE CLEAR AVAILED
353	17-Jan-2021	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	11:11	11:43	0:32	LINE CLEAR AVAILED
354	17-Jan-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	07:17	07:20	0:02	HAND TRIPPED
355	17-Jan-2021	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	01:57	02:07	0:10	LINE FAULT
356	17-Jan-2021	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	07:09	07:22	0:12	LINE FAULT
357	17-Jan-2021	TUMKUR	66	THALLAK 220KV- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	10:30	11:37	1:06	LINE CLEAR AVAILED
358	17-Jan-2021	TUMKUR	66	TR-1	CHALLAKERE_66	10:02	11:41	1:39	LINE CLEAR AVAILED
359	17-Jan-2021	TUMKUR	66	TR-1	MAVINAKATTE_66	17:53	18:02	0:08	TRANSFORMER FAULT
360	17-Jan-2021	TUMKUR	66	TR-3	HONNALLI_66	05:52	16:05	10:12	TRANSFORMER FAULT
361	17-Jan-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE OPEN, LINE CLEAR AVAILED
362	17-Jan-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN, LINE CLEAR AVAILED
363	17-Jan-2021	TUMKUR	220	TR-1	HIRIYUR_220	09:09	11:26	2:17	LINE CLEAR AVAILED
1	18-Jan-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN ,LINE FAULT
2	18-Jan-2021	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN, LINE CLEAR AVAILED
3	18-Jan-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN, LINE CLEAR AVAILED
4	18-Jan-2021	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN ,LINE FAULT
5	18-Jan-2021	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	17:35 (29.12.2020)			LINE OPEN, LINE CLEAR AVAILED
6	18-Jan-2021	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN , TRANSFORMER FAULT
7	18-Jan-2021	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN, LINE CLEAR AVAILED
8	18-Jan-2021	BAGALKOT	110	KANABARGI LAYOUT- NEHARUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN, LINE CLEAR AVAILED
9	18-Jan-2021	BAGALKOT	110	GADAG-ANNIGERI	GADAG_110	15:23 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
10	18-Jan-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	15:24 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
11	18-Jan-2021	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYANAGAR2	STATION NOT AFFECTED GOPPANAKOPPA_110	15:25 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
12	18-Jan-2021	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN, LINE CLEAR AVAILED
13	18-Jan-2021	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	19:51 (17.01.2021)	7:10 (18.01.2021)	11:19hrs	LINE CHARGED
14	18-Jan-2021	BAGALKOT	220	CHIKKODI -BELGAUM-2	CHIKKODI_220	19:51 (17.01.2021)	7:10 (18.01.2021)	11:19hrs	LINE CHARGED
15	18-Jan-2021	BAGALKOT	220	SHARAVATHY1- SIRSI	STATION NOT AFFECTED SIRSI_220	21:03 (17.01.2021)			LOAD CURTAILMENT
16	18-Jan-2021	BAGALKOT	220	SHARAVATHY2- SIRSI	STATION NOT AFFECTED SIRSI_220	21:03 (17.01.2021)			LOAD CURTAILMENT
17	18-Jan-2021	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	10:21	12:12	1:51	LINE CLEAR AVAILED
18	18-Jan-2021	BAGALKOT	110	GADAG-ANNIGERI	ANNIGERI_110	09:40	17:55	8:15	LINE CLEAR AVAILED
19	18-Jan-2021	BAGALKOT	110	110/11KV,HV1	ANNIGERI_110	12:05	17:30	5:25	LINE CLEAR AVAILED
20	18-Jan-2021	BAGALKOT	110	BELUR-NARENDRA2	STATION NOT AFFECTED BELUR_110	7:59	08:04	0:05	HAND TRIPPED
21	18-Jan-2021	BAGALKOT	110	BELUR-NARENDRA2	STATION NOT AFFECTED BELUR_110	10:36	10:40	0:04	HAND TRIPPED
22	18-Jan-2021	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110(BIDNAL220)	10:07	17:27	7:20	NFBC ISSUED
23	18-Jan-2021	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	10:18	17:31	7:13	LINE CLEAR AVAILED
24	18-Jan-2021	BAGALKOT	110	110/11KV, HV2	MUKARTIHAL_110	12:04	13:10	1:06	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
25	18-Jan-2021	BAGALKOT	220	NAGJHARI3- HUBLI	STATION NOT AFFECTED HUBLI_220	10:37	15:31	4:54	LINE CLEAR AVALIED
26	18-Jan-2021	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN, LINE CLEAR AVALIED
27	18-Jan-2021	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED KULIGOD_110	6:19	6:51	0:32	TRANSFORMER FAULT
28	18-Jan-2021	BAGALKOT	110	KUDALASANGAM-HUNAGUND	STATION NOT AFFECTED HUNAGUND_110	11:09	11:12	0:02	HAND TRIPPED
29	18-Jan-2021	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED GADAG_220	11:39	18:10	6:31	LINE CLEAR AVALIED
30	18-Jan-2021	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED GADAG_220	11:40	18:10	6:30	LINE CLEAR AVALIED
31	18-Jan-2021	BAGALKOT	110	CHIKKODI220-SANKESHWER	STATION NOT AFFECTED SANKESHWER_110	14:07	14:53	0:46	LINE FAULT
32	18-Jan-2021	BAGALKOT	220	BELAGUAM-KANABARGI1	STATION NOT AFFECTED BELAGAUM_220	00:24	07:09	6:45	LOAD CURTAILMENT
33	18-Jan-2021	BENGALURU	66	HV3	AUSTIN TOWN	12:08	12:28	00:20	LINE CLEAR AVALIED
34	18-Jan-2021	BENGALURU	66	HV1	BOODIGERE	10:14	10:20	00:06	LINE CLEAR AVALIED
35	18-Jan-2021	BENGALURU	66	HV2	BOODIGERE	12:45	12:50	00:05	LINE CLEAR AVALIED
36	18-Jan-2021	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	08:40	08:46	00:06	LOAD CHANGE OVER
37	18-Jan-2021	BENGALURU	66	KORAMANGALA 220 - ADUGODI 1	NO STATION AFFECTED	11:37	15:42	04:05	LINE FAULT
38	18-Jan-2021	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	12:28	12:34	00:06	TRANSFORMER FAULT
39	18-Jan-2021	BENGALURU	66	HV2	TELECOM LAYOUT	13:17	13:32	00:15	LINE CLEAR AVALIED
40	18-Jan-2021	BENGALURU	66	ATTUR YELAHANKA - DG3	ATTUR YELAHANKA, ABBIGERE	07:43	08:03	00:20	LINE FAULT
41	18-Jan-2021	BENGALURU	66	ATTUR YELAHANKA - DG4	ATTUR YELAHANKA, ABBIGERE	10:03	10:07	00:04	LOAD CHANGE OVER
42	18-Jan-2021	BENGALURU	66	HV1	BANGARPETE	13:03	14:13	01:10	LINE CLEAR AVALIED
43	18-Jan-2021	BENGALURU	66	CHIKKABALLAPURA I/A - DB PURA 1	CHIKKABALLAPURA I/A	08:25	08:50	00:25	LINE FAULT
44	18-Jan-2021	BENGALURU	66	CHIKKABALLAPURA I/A - DB PURA 1	CHIKKABALLAPURA I/A	08:50	10:30	01:40	LINE FAULT
45	18-Jan-2021	BENGALURU	66	CHIKKABALLAPURA I/A - DB PURA 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	09:40	10:35	00:55	LINE CLEAR AVALIED
46	18-Jan-2021	BENGALURU	220	HV2	CHINTAMANI 220	16:16	16:35	00:19	LINE CLEAR AVALIED
47	18-Jan-2021	BENGALURU	220	HV3	CHINTAMANI 220	16:16	16:35	00:19	LINE CLEAR AVALIED
48	18-Jan-2021	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	16:16	16:35	00:19	LINE CLEAR AVALIED
49	18-Jan-2021	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1 & 2	GANJIGUNTE , PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA,SOMENAHALLI	16:16	16:35	00:19	LINE CLEAR AVALIED
50	18-Jan-2021	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	16:16	16:35	00:19	LINE CLEAR AVALIED
51	18-Jan-2021	BENGALURU	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66, SM MANGALA	16:16	16:35	00:19	LINE CLEAR AVALIED
52	18-Jan-2021	BENGALURU	66	CHINTAMANI 220 - IRAGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	16:16	16:35	00:19	LINE CLEAR AVALIED
53	18-Jan-2021	BENGALURU	66	CHINTAMANI 220 - SRINIVASAPURA	SRINIVASAPURA, KODIHALLI	16:16	16:35	00:19	LINE CLEAR AVALIED
54	18-Jan-2021	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	16:16	16:35	00:19	LINE CLEAR AVALIED
55	18-Jan-2021	BENGALURU	66	CHINTAMANI 220 - YENIGADALE	YENIGADALE, CHELUR, CHAKAVELU	16:16	16:35	00:19	LINE CLEAR AVALIED
56	18-Jan-2021	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	16:16	16:35	00:19	LINE CLEAR AVALIED
57	18-Jan-2021	BENGALURU	66	HV2	DODDABELAVANGALA	14:00	14:11	00:11	TRANSFORMER FAULT
58	18-Jan-2021	BENGALURU	66	DB PURA 220 - TUBUGERE	TUBUGERE	08:30	08:39	00:09	LINE FAULT
59	18-Jan-2021	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	09:40	10:25	00:45	LINE CLEAR AVALIED
60	18-Jan-2021	BENGALURU	66	DB PURA 220 - TUBUGERE	TUBUGERE	09:40	10:25	00:45	LINE CLEAR AVALIED
61	18-Jan-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	07:05	07:50	00:45	LINE FAULT
62	18-Jan-2021	BENGALURU	220	SRS PEENYA 220 - SUBRAMANYAPURA 220	NO STATION AFFECTED	07:22	15:53	08:31	LINE FAULT
63	18-Jan-2021	GULBARGA	220	HV1	KUSTAGI_220	12:05	12:40	00:35	TRANSFORMER FAULT
64	18-Jan-2021	GULBARGA	220	HV2	KUSTAGI_220	12:05	12:27	00:22	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
65	18-Jan-2021	GULBARGA	220	LINGAPUR-JSVL2	LINGAPUR_220	08:40	17:37	08:57	LINE CLEAR AVAILED
66	18-Jan-2021	GULBARGA	110	KUSTAGI-YELBURGA	YELBURGA_110	12:05	13:20	01:15	LINE FAULT
67	18-Jan-2021	GULBARGA	110	KUSTAGI-YELBURGA	YELBURGA_110	13:20	17:52	04:32	LINE CLEAR AVAILED
68	18-Jan-2021	GULBARGA	110	GULBARGA UNIVERSITY-GULBARGA NORTH	GULBARGA UNIVERSITY_110	14:15	14:40	00:25	MAIN SUPPLY FAILURE
69	18-Jan-2021	GULBARGA	110	HV2	GINIGERA_110	06:30	07:20	00:50	TRANSFORMER FAULT
70	18-Jan-2021	GULBARGA	66	ITTAGGI-HIREHADAGALLI2	HIREHADAGALLI_66,SOVENAHALLI_66,GIRIYAP URA_66,MAGALA_66,TBPCL IPP	12:20	15:00	02:40	LINE CLEAR AVAILED
71	18-Jan-2021	GULBARGA	66	ITTAGGI-HB HALLI	UP HALLI_66,HB HALLI_66	09:30	12:45	03:15	LINE CLEAR AVAILED
72	18-Jan-2021	GULBARGA	66	ITTAGGI-HB HALLI	UP HALLI_66,HB HALLI_66	14:30	20:34	06:04	LINE FAULT
73	18-Jan-2021	GULBARGA	66	ITTAGGI-HB HALLI	UP HALLI_66,HB HALLI_66	20:37	20:45	00:08	LINE CLEAR AVAILED
74	18-Jan-2021	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
75	18-Jan-2021	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			LINE OPEN, LINE CLEAR AVAILED
76	18-Jan-2021	HASSAN	110	SORABA-SHR220	SORABA_110	11:22 (2.01.2021)			LINE OPEN, LINE CLEAR AVAILED
77	18-Jan-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	20:49 (5.01.2021)			LINE OPEN, LINE CLEAR AVAILED
78	18-Jan-2021	HASSAN	110	HV2	PUTTUR_110	15:40(15.1.2021)			TRANSFORMER OPEN ,LINE CLEAR AVAILED.
79	18-Jan-2021	HASSAN	220	MRSSHM-ANTRSNH	MRSMG_220	22:42 (18.01.2021)			LINE OPEN ,LINE FAULT
80	18-Jan-2021	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	02:46	03:01	00:15	LINE FAULT
81	18-Jan-2021	HASSAN	66	HASSN22-ARAKALGUD2	HASSAN_220	16:54	17:10	00:16	LINE FAULT
82	18-Jan-2021	HASSAN	66	GORUR-HASSAN	GORUR_66	16:54	17:14	00:20	LINE FAULT
83	18-Jan-2021	HASSAN	66	BASAVAG-DUDDA	BASAVAGHATTA_66	11:50	12:45	00:55	MAIN SUPPLY FAILURE
84	18-Jan-2021	MYSURU	66	CR NAGARA-HONNALLI	HONNALLY_MYS_66 ATTIGULIPURA_66	2:33	2:43	0:10	LINE FAULT
85	18-Jan-2021	MYSURU	66	HV1	HANGLA_66	10:18	13:09	2:51	LINE CLEAR AVAILED
86	18-Jan-2021	MYSURU	66	HV3	KUSHALANAGARA_66	15:28	16:31	1:03	LINE CLEAR AVAILED
87	18-Jan-2021	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATION EFFECTED	3:24	3:31	0:06	LINE FAULT
88	18-Jan-2021	MYSURU	66	SATHEGALA-BPCL	NO STATION EFFECTED	11:40	12:53	1:12	LINE CLEAR AVAILED
89	18-Jan-2021	MYSURU	66	SATHEGALA-HEBBANI	SATHEGALA_66	11:40	12:53	1:12	LINE CLEAR AVAILED
90	18-Jan-2021	MYSURU	66	SATHEGALA-KOLLEGALA	SATHEGALA_66	11:40	12:53	1:12	LINE CLEAR AVAILED
91	18-Jan-2021	MYSURU	66	HV1	THANDYA_66	19:57	20:11	0:13	TRANSFORMER FAULT
92	18-Jan-2021	MYSURU	66	TUBINKERE-MANDYA 2	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	13:31	13:42	0:11	LINE FAULT
93	18-Jan-2021	MYSURU	66	TUBINKERE-MANDYA 4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	13:31	13:42	0:11	LINE FAULT
94	18-Jan-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATION EFFECTED	13:06 (17/01/2021)			LINE OPEN, LINE CLEAR AVAILED
95	18-Jan-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE OPEN, LINE CLEAR AVAILED
96	18-Jan-2021	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN, LINE CLEAR AVAILED
97	18-Jan-2021	TUMKUR	220	TR-3	HIRIYUR_220	18:26	18:34	0:08	TRANSFORMER FAULT
98	18-Jan-2021	TUMKUR	110	HUNSEGHATTA- K B CROSS	HUNSEGHATTA_110	15:09	15:49	0:40	LINE CLEAR AVAILED
99	18-Jan-2021	TUMKUR	66	TR-2	AVAREGERE_66	14:07	15:32	1:25	LINE CLEAR AVAILED
100	18-Jan-2021	TUMKUR	66	BENNEHALLI-ITTAGI	BENNEHALLI_66	4:12	4:24	0:11	LINE FAULT
101	18-Jan-2021	TUMKUR	66	TR-2	BEVINAHALLI_66	15:16	15:20	0:03	LINE CLEAR AVAILED
102	18-Jan-2021	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	6:34	6:53	0:18	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
103	18-Jan-2021	TUMKUR	66	TR-1	DYAVARANAHALLI_66	10:47	11:25	0:37	LINE CLEAR AVAILED
104	18-Jan-2021	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	19:46	20:01	0:14	LINE FAULT
105	18-Jan-2021	TUMKUR	66	TR-3	HARIYABBE_66	14:10	14:15	0:05	TRANSFORMER FAULT
106	18-Jan-2021	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	18:47	18:52	0:04	MAIN SUPPLY FAILURE
107	18-Jan-2021	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	14:02	15:10	1:07	HAND TRIPPED
108	18-Jan-2021	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	9:53	15:09	5:15	HAND TRIPPED
109	18-Jan-2021	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	9:33	15:09	5:36	HAND TRIPPED
110	18-Jan-2021	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL EHT_66	17:28	17:39	0:10	LINE FAULT
111	18-Jan-2021	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	15:09	15:14	0:04	HAND TRIPPED
112	18-Jan-2021	TUMKUR	66	NAGASAMUDRA- RAMPURA	NAGASAMUDRA_66	19:50	20:03	0:12	MAIN SUPPLY FAILURE
113	18-Jan-2021	TUMKUR	66	TURUVANUR66-JAGALUR	JAGALUR_66,BIDARKERE_66,SOKKE_66	6:34	7:00	0:25	LINE FAULT