

**400/220/110/66 kV TRANSMISSION OUTAGES FROM : 13.04.21 TO 19.04.21**

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
1	13-Apr-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVOIDED
2	13-Apr-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED ATHANI_220	17:45	20:11	2:26	LINE CLEAR AVOIDED
3	13-Apr-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED BANAHATTI_110	7:02	9:16	2:14	LINE CLEAR AVOIDED
4	13-Apr-21	BAGALKOT	110	110/11KV, HV1	NIDAGUNDI_110	16:17	16:45	0:28	TRANSFORMER FAULT
5	13-Apr-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED AKSHAY COLONY_110	9:54	10:27	0:33	TRANSFORMER FAULT
6	13-Apr-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED AMBEWADI_220	15:55	16:00	0:05	TRANSFORMER FAULT
7	13-Apr-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED KALAGHATAGI_110	17:58	18:00	0:02	TRANSFORMER FAULT
8	13-Apr-21	BAGALKOT	110	110/33KV, HV2	KARUSHI_33, KERUR_33 STATION NOT AFFECTED CHIKKODI_110	19:52	20:01	0:09	TRANSFORMER FAULT
9	13-Apr-21	BAGALKOT	110	110/33KV, HV2	KUDCHI_110, CHINCHALI_33	14:36	14:47	0:11	TRANSFORMER FAULT
10	13-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, ALSANGI_33	3:13	3:22	0:09	TRANSFORMER FAULT
11	13-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, ALSANGI_33	4:13	4:30	0:17	TRANSFORMER FAULT
12	13-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, ALSANGI_33	4:45	4:56	0:11	TRANSFORMER FAULT
13	13-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, ALSANGI_33	9:20	10:13	0:53	TRANSFORMER FAULT
14	13-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, ALSANGI_33	12:03	12:06	0:03	TRANSFORMER FAULT
15	13-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, ALSANGI_33	12:25	12:30	0:05	TRANSFORMER FAULT
16	13-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, ALSANGI_33	14:14	14:17	0:03	TRANSFORMER FAULT
17	13-Apr-21	BAGALKOT	110	ANKOLA-KUMTA(L2)	STATION NOT AFFECTED ANKOLA_110	23:03 (12.04.2021)	13:52 (13.04.2021)	14:49hrs	LINE CHARGED
18	13-Apr-21	BAGALKOT	110	BAGEWADI- MUDEBIHAL	MUDEBIHAL_110	5:51	6:28	0:37	HAND TRIPPED
19	13-Apr-21	BAGALKOT	110	BELGAUM-UCHAGOAN( HUKKERI)	UCHAGOAN_110	18:04	18:17	0:13	LINE FAULT
20	13-Apr-21	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN: LINE CLEAR AVOIDED
21	13-Apr-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	16:18 (11.04.2021)			LINE OPEN: LINE CLEAR AVOIDED
22	13-Apr-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVOIDED
23	13-Apr-21	BAGALKOT	110	KERUR-KONNUR	KONNUR_110	11:26	11:29	0:03	HAND TRIPPED
24	13-Apr-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
25	13-Apr-21	BAGALKOT	110	KUMATA-SIRSI 1	KUMATA_110	12:22 (12.04.2021)			LINE OPEN: LINE CLEAR AVOIDED
26	13-Apr-21	BAGALKOT	110	MACHE- UDYAMBAG	STATION NOT AFFECTED MACHE_110	8:11 (12.04.2021)			LINE OPEN: LINE CLEAR AVOIDED
27	13-Apr-21	BAGALKOT	110	MAHALINGPUR220-TERDAL	TERDAL_110	16:20	16:53	0:33	LINE FAULT
28	13-Apr-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
29	13-Apr-21	BAGALKOT	110	RON- GAJENDRAGAD1	STATION NOT AFFECTED RON 110	21:31 (08.04.2021)			LINE OPEN: LINE CLEAR AVOIDED
30	13-Apr-21	BAGALKOT	110	RON- GAJENDRAGAD2	STATION NOT AFFECTED RON 110	21:31 (08.04.2021)			LINE OPEN: LINE FAULT
31	13-Apr-21	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI 110	10:57 (05.03.2021)			LINE OPEN: LINE CLEAR AVOIDED
32	13-Apr-21	BAGALKOT	110	SOUDATTI220- NARAGUND	STATION NOT AFFECTED NARAGUND 110	14:37 (12.04.2021)			LINE OPEN: LINE CLEAR AVOIDED
33	13-Apr-21	BAGALKOT	220	AMBEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI 220	17:18 (13.04.2021)			LINE OPEN: LINE FAULT
34	13-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	STATION NOT AFFECTED BELGAUM 220	6:57 (12.04.2021)			LINE OPEN: LINE CLEAR AVOIDED
35	13-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	STATION NOT AFFECTED BELGAUM 220	6:57 (12.04.2021)	18:12 (13.04.2021)	35:15hrs	LINE CHARGED
36	13-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI 2	STATION NOT AFFECTED BELGAUM 220	18:02	18:26	0:24	LINE FAULT
37	13-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM 220	10:31 (05.04.2021)			LINE OPEN: LINE CLEAR AVOIDED
38	13-Apr-21	BAGALKOT	220	CHIKKODI-BELAGAUM1	STATION NOT AFFECTED CHIKKODI 220	18:01	18:26	0:25	LINE FAULT
39	13-Apr-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG 220	10:48 (16.12.2020)			LINE OPEN: LINE CLEAR AVOIDED
40	13-Apr-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR 220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVOIDED
41	13-Apr-21	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	STATION NOT AFFECTED MAHALINGAPUR 220	9:38 (09.04.2021)			LOAD CURTAILMENT
42	13-Apr-21	BAGALKOT	220	NARENDRA- HAVERI1	STATION NOT AFFECTED NARENDRA 220	15:38 (13.04.2021)			LINE OPEN: LINE FAULT
43	13-Apr-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA 220	17:22 (30.03.2021)			LINE OPEN: LINE FAULT
44	13-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI 220	17:31 (10.04.2021)			LOAD CURTAILMENT
45	13-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI 220	18:08 (06.03.2021)			LOAD CURTAILMENT
46	13-Apr-21	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI 220	16:35 (11.04.2021)			LINE OPEN: LINE FAULT
47	13-Apr-21	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI 220	16:17 (23.02.2021)			LINE OPEN: LINE FAULT
48	13-Apr-21	BAGALKOT	220	VAJRAMATTI -MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI 220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVOIDED
49	13-Apr-21	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNA (EHT)	11:18	11:46	0:28	LINE FAULT
50	13-Apr-21	BENGALURU	66	HV1	VOLVO	7:50	8:23	0:33	TRANSFORMER FAULT
51	13-Apr-21	BENGALURU	66	HV1	ELECTRONIC CITY P2 S2	10:21	10:26	0:04	TRANSFORMER FAULT
52	13-Apr-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	11:20	11:23	0:03	LINE FAULT
53	13-Apr-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	11:20	11:33	0:13	LINE FAULT
54	13-Apr-21	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	13:07	13:12	0:05	LINE FAULT
55	13-Apr-21	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	17:06	17:15	0:09	LOAD CHANGE OVER
56	13-Apr-21	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	17:40	17:46	0:06	LOAD CHANGE OVER
57	13-Apr-21	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	17:07	17:16	0:09	LOAD CHANGE OVER
58	13-Apr-21	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	17:40	17:45	0:05	LOAD CHANGE OVER
59	13-Apr-21	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA,	17:06	17:14	0:08	LOAD CHANGE OVER

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
60	13-Apr-21	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA,	17:40	17:46	0:06	LOAD CHANGEOVER
61	13-Apr-21	BENGALURU	66	THAYLUR - NG HULKUR	NG HULKUR	6:32	7:05	0:33	LINE FAULT
62	13-Apr-21	BENGALURU	66	THAYLUR - NG HULKUR	NG HULKUR	7:30	7:45	0:15	LINE FAULT
63	13-Apr-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN: LINE FAULT
64	13-Apr-21	BENGALURU	220	HV2	MITTEMARI 220	17:08	17:11	0:03	LINE CLEAR AVAILED
65	13-Apr-21	GULBARGA	66	HV2	HANASI_66	17:30	17:40	0:10	TRANSFORMER FAULT
66	13-Apr-21	GULBARGA	110	BISIHALLI-ALIPUR	BISIHALLI_110	6:28	6:48	0:20	MAIN SUPPLY FAILURE
67	13-Apr-21	GULBARGA	110	BISIHALLI-ALIPUR	BISIHALLI_110	7:00	7:45	0:45	MAIN SUPPLY FAILURE
68	13-Apr-21	GULBARGA	110	BISIHALLI-ALIPUR	BISIHALLI_110	10:30	10:40	0:10	MAIN SUPPLY FAILURE
69	13-Apr-21	GULBARGA	110	GULBARGA UNIVERSITY-SHAHABAD1	GULBARGA UNIVERSITY_110	8:30(9.04.2021)			LINE OPEN: LINE CLEAR AVAILED
70	13-Apr-21	GULBARGA	110	GURUMITAKAL-SEDAM	GURUMITAKAL_110,KONKAL_110	19:34	20:16	0:42	MAIN SUPPLY FAILURE
71	13-Apr-21	GULBARGA	110	HALBARGA-CHIDRI	CHIDRI_110	17:44	17:50	0:06	LINE FAULT
72	13-Apr-21	GULBARGA	110	HALBARGA-KAMTHANA	KAMTHANA,HABSIKOTE_110	17:44	17:52	0:08	LINE FAULT
73	13-Apr-21	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110,DIGGI_110	14:45	15:05	0:20	LINE FAULT
74	13-Apr-21	GULBARGA	110	HV1	KADAGANCHI_110	14:23	14:27	0:04	TRANSFORMER FAULT
75	13-Apr-21	GULBARGA	110	HV1	NIRNA_110	20:49	21:00	0:11	TRANSFORMER FAULT
76	13-Apr-21	GULBARGA	110	HV1	NIRNA_110	21:15	21:21	0:06	TRANSFORMER FAULT
77	13-Apr-21	GULBARGA	110	HV1	NIRNA_110	21:41	22:00	0:19	TRANSFORMER FAULT
78	13-Apr-21	GULBARGA	110	HV3	HANUMASAGAR_110	9:40	9:50	0:10	TRANSFORMER FAULT
79	13-Apr-21	GULBARGA	110	HV3	HANUMASAGAR_110	10:00	10:10	0:10	TRANSFORMER FAULT
80	13-Apr-21	GULBARGA	110	HV3	CHINCHOLI_110	18:58	19:35	0:37	TRANSFORMER FAULT
81	13-Apr-21	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110	17:36	17:48	0:12	LINE FAULT
82	13-Apr-21	GULBARGA	110	PDHALLI-ALIPUR	PD_HALLI_110	6:28	6:47	0:19	MAIN SUPPLY FAILURE
83	13-Apr-21	GULBARGA	110	PDHALLI-ALIPUR	PD_HALLI_110	6:58	7:45	0:47	MAIN SUPPLY FAILURE
84	13-Apr-21	GULBARGA	110	PDHALLI-ALIPUR	PD_HALLI_110	10:27	10:40	0:13	MAIN SUPPLY FAILURE
85	13-Apr-21	GULBARGA	110	SEDAM-KURUKUNTA	KURKUNTA_110	19:30	20:10	0:40	MAIN SUPPLY FAILURE
86	13-Apr-21	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	21:22	21:40	0:18	LINE FAULT
87	13-Apr-21	GULBARGA	220	HV1 & HV2	SEDAM_220	19:30	20:40	1:10	TRANSFORMER FAULT
88	13-Apr-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	13:32(13.04.2021)			LINE OPEN: LINE FAULT
89	13-Apr-21	HASSAN	66	CRPATNA-SBELAGOLA2	CRPATNA_220	10:46	10:55	0:09	LINE FAULT
90	13-Apr-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
91	13-Apr-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
92	13-Apr-21	HASSAN	66	SAKALE-HANBAL	SAKLESH PURA_66	1:46	2:02	0:16	LINE FAULT
93	13-Apr-21	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	8:50(12.4.2021)			LINE OPEN: LINE CLEAR AVAILED
94	13-Apr-21	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLY_66	16:50	17:00	0:10	LINE FAULT
95	13-Apr-21	HASSAN	110	GURUPUR-MDBDRE	GURUPURA_110	16:49	16:52	0:03	MAIN SUPPLY FAILURE
96	13-Apr-21	HASSAN	110	GURUPUR-MDBDRE	GURUPURA_110	17:23	18:04	0:41	MAIN SUPPLY FAILURE
97	13-Apr-21	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	3:13	3:40	0:27	MAIN SUPPLY FAILURE
98	13-Apr-21	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	17:19	18:52	1:33	MAIN SUPPLY FAILURE
99	13-Apr-21	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	19:14	19:33	0:19	LINE CLEAR AVAILED
100	13-Apr-21	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	16:28(13.4.2021)			MAIN SUPPLY FAILURE
101	13-Apr-21	HASSAN	110	HV1	KEMAR_220	17:34	17:55	0:21	HAND TRIPPED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
102	13-Apr-21	HASSAN	110	HV1	GURUPURA_110	0:36	13:07	12:31	TRANSFORMER FAULT
103	13-Apr-21	HASSAN	110	HV1	YAGATI_110	10:21	10:34	0:13	TRANSFORMER FAULT
104	13-Apr-21	HASSAN	110	HV2	KEMAR_220	17:39	18:03	0:24	HAND TRIPPED
105	13-Apr-21	HASSAN	110	HV2	KUMSI_110	16:32	16:57	0:25	LINE CLEAR AVAILED
106	13-Apr-21	HASSAN	110	HV2	KUMSI_110	17:19	18:43	1:24	MAIN SUPPLY FAILURE
107	13-Apr-21	HASSAN	110	HV2	SAGARA_110	3:18	7:01	3:43	TRANSFORMER FAULT
108	13-Apr-21	HASSAN	110	KADUR-NGNHL	KADUR_220	10:13	10:23	0:10	HAND TRIPPED
109	13-Apr-21	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	0:06	8:12	8:06	LINE FAULT
110	13-Apr-21	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	3:13	3:40	0:27	LINE FAULT
111	13-Apr-21	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	17:18	19:01	1:43	LINE FAULT
112	13-Apr-21	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	19:14	19:32	0:18	HAND TRIPPED
113	13-Apr-21	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	16:28(13.4.21)			LINE OPEN: LINE FAULT
114	13-Apr-21	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	17:13	18:01	0:48	HAND TRIPPED
115	13-Apr-21	HASSAN	110	KEMAR-Manipal1	KEMAR_220	17:39	17:56	0:17	HAND TRIPPED
116	13-Apr-21	HASSAN	110	KEMAR-Manipal2	KEMAR_220	17:35	17:57	0:22	HAND TRIPPED
117	13-Apr-21	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	17:35	18:07	0:32	HAND TRIPPED
118	13-Apr-21	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	0:08	0:37	0:29	HAND TRIPPED
119	13-Apr-21	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	17:34	18:05	0:31	HAND TRIPPED
120	13-Apr-21	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	23:06(12.4.2021)	0:03(13.4.2021)	0:57hrs	LINE CHARGED
121	13-Apr-21	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	4:31	4:50	0:19	LINE FAULT
122	13-Apr-21	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	17:24	19:00	1:36	MAIN SUPPLY FAILURE
123	13-Apr-21	HASSAN	110	LV1	KEMAR_220	17:23	18:03	0:40	HAND TRIPPED
124	13-Apr-21	HASSAN	110	LV2	KEMAR_220	17:23	17:54	0:31	HAND TRIPPED
125	13-Apr-21	HASSAN	110	LV3	KEMAR_220	17:23	17:53	0:30	HAND TRIPPED
126	13-Apr-21	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	2:01	2:14	0:13	LINE FAULT
127	13-Apr-21	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	17:24	18:06	0:42	MAIN SUPPLY FAILURE
128	13-Apr-21	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	17:23	18:00	0:37	MAIN SUPPLY FAILURE
129	13-Apr-21	HASSAN	110	MANIPAL-NITTUR	MANIPAL_110	17:25	18:05	0:40	MAIN SUPPLY FAILURE
130	13-Apr-21	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	21:15(11.4.2021)			LINE OPEN: LINE FAULT
131	13-Apr-21	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	16:32	17:05	0:33	MAIN SUPPLY FAILURE
132	13-Apr-21	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	17:22	19:06	1:44	MAIN SUPPLY FAILURE
133	13-Apr-21	HASSAN	220	HV1	KEMAR_220	17:23	18:02	0:39	TRANSFORMER FAULT
134	13-Apr-21	HASSAN	220	HV2	KEMAR_220	17:23	17:53	0:30	TRANSFORMER FAULT
135	13-Apr-21	HASSAN	220	HV3	KEMAR_220	17:23	17:52	0:29	TRANSFORMER FAULT
136	13-Apr-21	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	17:26	17:51	0:25	MAIN SUPPLY FAILURE
137	13-Apr-21	HASSAN	220	KAVOOR-KEMR1	KAVOOR_220	17:26	17:55	0:29	MAIN SUPPLY FAILURE
138	13-Apr-21	HASSAN	220	KAVOOR-KEMR2	KAVOOR_220	17:26	17:56	0:30	MAIN SUPPLY FAILURE
139	13-Apr-21	HASSAN	220	KEMAR-BAIPE2	KEMAR_220	9:58	13:53	3:55	NFBC ISSUED
140	13-Apr-21	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	17:23	17:49	0:26	LINE FAULT
141	13-Apr-21	HASSAN	220	KEMAR-Kavoor2	KEMAR_220	17:23	17:50	0:27	LINE FAULT
142	13-Apr-21	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	17:18	18:52	1:34	LINE FAULT
143	13-Apr-21	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	17:18(13.4.2021))			LINE OPEN: LINE FAULT
144	13-Apr-21	HASSAN	220	KEMAR-UPCL1	KEMAR_220	17:23	17:45	0:22	LINE FAULT
145	13-Apr-21	HASSAN	220	KEMAR-UPCL2	KEMAR_220	17:23	17:45	0:22	LINE FAULT
146	13-Apr-21	HASSAN	220	KEMAR-Varahi1	KEMAR_220	17:23	17:46	0:23	LINE FAULT
147	13-Apr-21	HASSAN	220	KEMAR-Varahi2	KEMAR_220	17:23	17:46	0:23	LINE FAULT
148	13-Apr-21	HASSAN	220	KEMAR-Varahi3	KEMAR_220	17:23(13.4.2021)			LINE OPEN: LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
149	13-Apr-21	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	17:23	17:55	0:32	MAIN SUPPLY FAILURE
150	13-Apr-21	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	17:23	17:50	0:27	MAIN SUPPLY FAILURE
151	13-Apr-21	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	17:23	17:50	0:27	MAIN SUPPLY FAILURE
152	13-Apr-21	HASSAN	220	UPCL-KEMAR1	upcl_gen	17:41	17:44	0:03	HAND TRIPPED
153	13-Apr-21	HASSAN	220	UPCL-KEMAR2	upcl_gen	17:42	17:45	0:03	HAND TRIPPED
154	13-Apr-21	HASSAN	220	VARAHI-KEMAR1	varahi_gen	17:41	17:46	0:05	HAND TRIPPED
155	13-Apr-21	HASSAN	220	VARAHI-KEMAR2	varahi_gen	17:41	17:47	0:06	HAND TRIPPED
156	13-Apr-21	MYSURU	66	BANNIMANTAP-FTS	NO STATIONS EFFECTED	11:43 (12/04/2021)			LINE OPEN: LINE CLEAR AVAILED
157	13-Apr-21	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
158	13-Apr-21	MYSURU	66	HV2	DATTAGALLY_66	7:41	9:00	1:19	LINE CLEAR AVAILED
159	13-Apr-21	MYSURU	66	HV5	SFCSHIVA_66	8:19 (4/4/2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
160	13-Apr-21	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN: LINE CLEAR AVAILED
161	13-Apr-21	MYSURU	66	KR PETE 220-CR PATNA	ANEGOLAL_66 KRISHNAPURA_66	5:18	5:25	0:06	LINE FAULT
162	13-Apr-21	MYSURU	66	KUSHALNAGARA 220-SUNTIKOPPA	NO STATIONS EFFECTED	6:30	6:41	0:11	LINE FAULT
163	13-Apr-21	MYSURU	66	SUNTIKOPPA-KUSHALNAGARA	NO STATIONS EFFECTED	16:21	17:29	1:07	LINE CLEAR AVAILED
164	13-Apr-21	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	23:08	23:13	0:05	LINE FAULT
165	13-Apr-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BASARALU_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 KESLAGERE_66 VADERALLI_66	22:33	22:40	0:06	LINE FAULT
166	13-Apr-21	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	18:56	19:09	0:12	LINE FAULT
167	13-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	2:20	2:34	0:13	LINE FAULT
168	13-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	3:17	3:38	0:20	LINE FAULT
169	13-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	13:06	13:13	0:07	LINE FAULT
170	13-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	13:22	13:36	0:14	LINE FAULT
171	13-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	14:34	14:47	0:13	LINE FAULT
172	13-Apr-21	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	8:45	8:54	0:09	LINE FAULT
173	13-Apr-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	2:26	2:42	0:15	LINE FAULT
174	13-Apr-21	TUMKUR	66	LINGADAHALLI- NALLUR	LINGDHALLI_66	10:39	10:42	0:03	LINE FAULT
175	13-Apr-21	TUMKUR	66	SIRA- KALLAMBELLA	SIRA_66	6:16	6:29	0:12	LINE FAULT
176	13-Apr-21	TUMKUR	66	SIRA- MADHUGIRI 2	SIRA_66	6:16	6:27	0:11	LINE FAULT
177	13-Apr-21	TUMKUR	66	TR-1	HIRIYUR_66	11:36	11:38	0:01	TRANSFORMER FAULT
178	13-Apr-21	TUMKUR	66	TR-2	MELKOTE_66	15:04	15:10	0:06	TRANSFORMER FAULT
179	13-Apr-21	TUMKUR	66	TURUVANUR66-CHITRADURGA	TURUVANUR_66	18:56	19:12	0:15	MAIN SUPPLY FAILURE
180	13-Apr-21	TUMKUR	66	TURUVANUR66-JAGALUR	JAGALUR_66,BIDARKERE_66,SOKKE 66	18:56	19:11	0:15	MAIN SUPPLY FAILURE
181	13-Apr-21	TUMKUR	66	VENKATAPURA- IMAMI_SOLAR_IPP	IMAMI_SOLAR_IPP	12:45	13:26	0:40	LINE FAULT
182	13-Apr-21	TUMKUR	110	TR-1	K B CROSS_110	18:06	18:18	0:11	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
183	13-Apr-21	TUMKUR	110	TR-2	MAYASANDRA_110	17:08	20:45	3:37	LINE CLEAR AVAILED
184	13-Apr-21	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	10:06	19:13	9:06	LOAD CURTAILMENT
185	14-Apr-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
186	14-Apr-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED HOSAHONNATTI_110	20:20	20:30	0:10	TRANSFORMER FAULT
187	14-Apr-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED HOSAHONNATTI_110	21:35	21:40	0:05	TRANSFORMER FAULT
188	14-Apr-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED AMBEWADI_220	23:04	23:12	0:08	TRANSFORMER FAULT
189	14-Apr-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED KALAGHATAGI_110	10:19	10:20	0:01	TRANSFORMER FAULT
190	14-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, ALSANGI_33	9:31	9:36	0:05	TRANSFORMER FAULT
191	14-Apr-21	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN: LINE CLEAR AVAILED
192	14-Apr-21	BAGALKOT	110	BIDNAL- NAVALGUN	STATION NOT AFFECTED NAVALGUND_110	8:17 (14.04.2021)			LINE OPEN: LINE FAULT
193	14-Apr-21	BAGALKOT	110	BIDNAL-NAVALAGUND	NAVALGUND_110	6:05	11:05	5:00	LINE FAULT
194	14-Apr-21	BAGALKOT	110	CHIKKODI220-ANKALI	ANKALI_110	7:03	10:57	3:54	LINE FAULT
195	14-Apr-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	16:18 (11.04.2021)			LINE OPEN: LINE CLEAR AVAILED
196	14-Apr-21	BAGALKOT	110	GAJENDRAGAD-KUSTAGI	STATION NOT AFFECTED GAJENDRAGAD_110	9:43	14:41	4:58	MAIN SUPPLY FAILURE
197	14-Apr-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
198	14-Apr-21	BAGALKOT	110	KERUR-BADAMI	BADAMI_110	14:32	14:36	0:04	HAND TRIPPED
199	14-Apr-21	BAGALKOT	110	KERUR-BAGALKOT220	KERUR_110	14:18	14:32	0:14	HAND TRIPPED
200	14-Apr-21	BAGALKOT	110	KERUR-KONNUR	KONNUR_110	14:32	14:36	0:04	HAND TRIPPED
201	14-Apr-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
202	14-Apr-21	BAGALKOT	110	KNM SOLAR- MUDEBIHAL	MUDEBIHAL_110	14:51	15:15	0:24	LINE FAULT
203	14-Apr-21	BAGALKOT	110	KULAGERI CROSS-KERUR	KULAGERI CROSS_110	18:05 (24.02.2021)	7:20 (14.04.2021)	1165:15hrs	LINE CHARGED
204	14-Apr-21	BAGALKOT	110	KULAGERI CROSS-KONNUR	KULAGERI CROSS_110	7:17	7:24	0:07	HAND TRIPPED
205	14-Apr-21	BAGALKOT	110	KUMATA-SIRSI 1	KUMATA_110	12:22 (12.04.2021)			LINE OPEN: LINE CLEAR AVAILED
206	14-Apr-21	BAGALKOT	110	MACHE- UDYAMBAG	STATION NOT AFFECTED MACHE_110	8:11 (12.04.2021)			LINE OPEN: LINE CLEAR AVAILED
207	14-Apr-21	BAGALKOT	110	MAHALINGPUR220-HIDIKAL	HIDIKAL_110	5:59	6:19	0:20	HAND TRIPPED
208	14-Apr-21	BAGALKOT	110	MAHALINGPUR220-RABAKAVI	RABAKAVI_110	6:00	6:16	0:16	HAND TRIPPED
209	14-Apr-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
210	14-Apr-21	BAGALKOT	110	RON- GAJENDRAGAD1	STATION NOT AFFECTED RON_110	21:31 (08.04.2021)			LINE OPEN: LINE CLEAR AVAILED
211	14-Apr-21	BAGALKOT	110	RON- GAJENDRAGAD2	STATION NOT AFFECTED RON_110	21:31 (08.04.2021)			LINE OPEN: LINE FAULT
212	14-Apr-21	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:57 (05.03.2021)			LINE OPEN: LINE CLEAR AVAILED
213	14-Apr-21	BAGALKOT	110	SOUATTI220- NARAGUND	STATION NOT AFFECTED NARAGUND_110	14:37 (12.04.2021)	14:45 (14.04.2021)	48:08hrs	LINE CHARGED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
214	14-Apr-21	BAGALKOT	220	220/110KV,HV3 & LV3	STATION NOT AFFECTED MAHALINGPUR_220,HIDIKAL_110,I TANAL_110,RABAKAVI_110	5:41	6:21	0:40	TRANSFORMER FAULT
215	14-Apr-21	BAGALKOT	220	AMBEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI_220	17:18 (13.04.2021)	14:09 (14.04.2021)	20:51hrs	LINE CHARGED
216	14-Apr-21	BAGALKOT	220	AMBEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI_220	14:09 (14.04.2021)			LINE OPEN: LINE FAULT
217	14-Apr-21	BAGALKOT	220	BAGALKOT-ALAMATTI1	STATON NOT AFFECTED BAGALKOT_220	17:33	19:13	1:40	LINE CLEAR AVAILED
218	14-Apr-21	BAGALKOT	220	BAGALKOT-ALAMATTI2	STATON NOT AFFECTED BAGALKOT_220	14:23	19:13	4:50	LINE FAULT
219	14-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	STATION NOT AFFECTED BELGAUM_220	6:57 (12.04.2021)			LINE OPEN: LINE CLEAR AVAILED
220	14-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:31 (05.04.2021)			LINE OPEN: LINE CLEAR AVAILED
221	14-Apr-21	BAGALKOT	220	BIDNAL-HARTI 2	BIDNAL_220	21:31 (14.04.2021)			LINE OPEN: LINE FAULT
222	14-Apr-21	BAGALKOT	220	BIDNAL-NRNRD	BIDNAL_220	10:23	13:57	3:34	NFBC ISSUED
223	14-Apr-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN: LINE CLEAR AVAILED
224	14-Apr-21	BAGALKOT	220	HAVERI-GUTTURI	STATON NOT AFFECTED HAVERI_220	19:14 (14.04.2021)			LINE OPEN: LINE FAULT
225	14-Apr-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
226	14-Apr-21	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	STATION NOT AFFECTED MAHALINGAPUR_220	9:38 (09.04.2021)			LOAD CURTAILMENT
227	14-Apr-21	BAGALKOT	220	NARENDRA- HAVERI1	STATION NOT AFFECTED NARENDRA_220	15:38 (13.04.2021)	13:57 (14.04.2021)	22:19hrs	LINE CHARGED
228	14-Apr-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN: LINE FAULT
229	14-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	17:31 (10.04.2021)			LOAD CURTAILMENT
230	14-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)			LOAD CURTAILMENT
231	14-Apr-21	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI_220	16:35 (11.04.2021)			LINE OPEN: LINE FAULT
232	14-Apr-21	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN: LINE FAULT
233	14-Apr-21	BAGALKOT	220	VAJRAMATTI -MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
234	14-Apr-21	BENGALURU	66	CHAKAVELU - SOMANATHPURA	CHAKAVELU	13:35	14:45	1:10	LINE FAULT
235	14-Apr-21	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	22:05	22:12	0:07	LOAD CHANGEOVER
236	14-Apr-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	16:13	16:37	0:24	LINE FAULT
237	14-Apr-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	BELL CERAMICS (EHT)	16:37	18:15	1:38	LINE FAULT
238	14-Apr-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	BELL CERAMICS (EHT)	18:42	18:47	0:05	LINE CLEAR AVAILED
239	14-Apr-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	BELL CERAMICS (EHT)	18:47	19:10	0:23	LINE FAULT
240	14-Apr-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	BELL CERAMICS (EHT)	19:10	21:29	2:19	LINE FAULT
241	14-Apr-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	BELL CERAMICS (EHT)	21:29	21:56	0:27	LINE CLEAR AVAILED
242	14-Apr-21	BENGALURU	66	HV1	VIJAYAPURA	14:35	15:10	0:35	TRANSFORMER FAULT
243	14-Apr-21	BENGALURU	66	HV1	SIDDALAGATTA	15:51	16:42	0:50	LINE CLEAR AVAILED
244	14-Apr-21	BENGALURU	66	HV1	ISRO LAYOUT	12:15	13:10	0:55	LINE CLEAR AVAILED
245	14-Apr-21	BENGALURU	66	HV2	GUDIBANDE	10:30	10:40	0:10	LOAD CHANGEOVER

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
246	14-Apr-21	BENGALURU	66	ITI 220 - BAGHMANE WTP	BAGHMANE WORLD TECH PARK	7:35	8:05	0:30	LINE FAULT
247	14-Apr-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	14:50	14:57	0:07	LINE FAULT
248	14-Apr-21	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	7:58	8:04	0:06	LINE FAULT
249	14-Apr-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	14:50	14:56	0:06	LINE FAULT
250	14-Apr-21	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	23:55	23:59	0:04	LINE FAULT
251	14-Apr-21	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	14:52	14:59	0:07	LINE FAULT
252	14-Apr-21	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	15:05	15:10	0:05	LINE FAULT
253	14-Apr-21	BENGALURU	66	KORMANGALA 220 - AUSTIN TOWN 2	NO STATION AFFECTED	16:08	17:01	0:53	LINE FAULT
254	14-Apr-21	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	5:45	5:53	0:08	LINE FAULT
255	14-Apr-21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELUR, CHAKAVELU, YENIGADALE	13:35	14:45	1:10	LINE FAULT
256	14-Apr-21	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA,	14:54	15:01	0:07	LINE FAULT
257	14-Apr-21	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA,	15:16	15:24	0:08	LINE FAULT
258	14-Apr-21	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA,	17:18	17:26	0:08	LINE FAULT
259	14-Apr-21	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	7:59	8:25	0:26	LINE FAULT
260	14-Apr-21	BENGALURU	66	SOMENAHALLI - MITTEMARI 220	SOMENAHALLI, PERESANDRA	14:55	15:25	0:30	LINE FAULT
261	14-Apr-21	BENGALURU	66	SOMENAHALLI - MITTEMARI 220	SOMENAHALLI, PERESANDRA	14:55	15:25	0:30	LINE FAULT
262	14-Apr-21	BENGALURU	66	SOMENAHALLI - PERESANDRA	PERESANDRA	14:55	15:15	0:20	LINE FAULT
263	14-Apr-21	BENGALURU	66	SOMENAHALLI - PERESANDRA	PERESANDRA	15:15	15:45	0:30	LINE FAULT
264	14-Apr-21	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	20:44	21:19	0:34	LINE FAULT
265	14-Apr-21	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	6:20	6:26	0:06	LINE FAULT
266	14-Apr-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN: LINE FAULT
267	14-Apr-21	GULBARGA	66	GUDEKOTE-KUDLIGI	GUDEKOTE_66	20:06	20:47	0:41	LINE CLEAR AVAILED
268	14-Apr-21	GULBARGA	66	HV1	KOTTUR_66	21:56	21:59	0:03	TRANSFORMER FAULT
269	14-Apr-21	GULBARGA	66	HV1	GUDEKOTE_66	18:28	20:48	2:20	TRANSFORMER FAULT
270	14-Apr-21	GULBARGA	110	GULBARGA UNIVERSITY-SHAHABAD1	GULBARGA UNIVERSITY_110	8:30(9.04.2021)			LINE OPEN: LINE CLEAR AVAILED
271	14-Apr-21	GULBARGA	110	HV1	KADAGANCHI_110	15:30	15:35	0:05	TRANSFORMER FAULT
272	14-Apr-21	GULBARGA	110	HV1	KURKUNTA_110	4:45	4:55	0:10	TRANSFORMER FAULT
273	14-Apr-21	GULBARGA	110	HV1	SIRWAR_110	3:05	3:25	0:20	TRANSFORMER FAULT
274	14-Apr-21	GULBARGA	110	HV1	METRI_110	18:10	18:15	0:05	TRANSFORMER FAULT
275	14-Apr-21	GULBARGA	110	HV2	DEODURGA_110	7:25	7:40	0:15	TRANSFORMER FAULT
276	14-Apr-21	GULBARGA	110	HV2	SHAHAPUR_220	0:48	1:13	0:25	TRANSFORMER FAULT
277	14-Apr-21	GULBARGA	110	HV4	DEODURGA_110	6:15	6:50	0:35	TRANSFORMER FAULT
278	14-Apr-21	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	16:54	17:06	0:12	LINE FAULT
279	14-Apr-21	GULBARGA	110	SINDHNOOR-SINDHNOOR2	SINDHNOOR_110	17:10	17:45	0:35	LINE FAULT
280	14-Apr-21	GULBARGA	110	STAR METALLIC-MUNIRABAD	STAR METALLIC_IPP	19:30	20:15	0:45	LINE FAULT
281	14-Apr-21	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	14:20(14.4.21)			LINE OPEN: LINE CLEAR AVAILED
282	14-Apr-21	GULBARGA	110	YERADONA-BENUR	BENUR_110	17:10	17:45	0:35	MAIN SUPPLY FAILURE
283	14-Apr-21	GULBARGA	110	YERADONA-BENUR	BENUR_110	21:00	21:05	0:05	MAIN SUPPLY FAILURE
284	14-Apr-21	GULBARGA	220	LINGAPUR-KUSTAGI	KUSTAGI_220	10:25	10:33	0:08	HAND TRIPPED



SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
285	14-Apr-21	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	13:32(13.04.2021)	10:08(14.04.2021)	20:36 hrs	LINE CHARGED
286	14-Apr-21	HASSAN	66	CHMANGA-BALEHONNUR	CHIKMAGALUR_220	13:46	13:56	0:10	LINE FAULT
287	14-Apr-21	HASSAN	66	CHMANGA-BALEHONNUR	CHIKMAGALUR_220	14:09	17:53	3:44	LINE FAULT
288	14-Apr-21	HASSAN	66	HV1	DUDDA_66	19:41	19:51	0:10	TRANSFORMER FAULT
289	14-Apr-21	HASSAN	66	HV1	MAGGE_66	16:00	17:35	1:35	LINE CLEAR AVAILED
290	14-Apr-21	HASSAN	66	HV2	MAGGE_66	16:00	17:35	1:35	LINE CLEAR AVAILED
291	14-Apr-21	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	15:57	17:39	1:42	LINE CLEAR AVAILED
292	14-Apr-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
293	14-Apr-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
294	14-Apr-21	HASSAN	66	SAKALE-HASSAN1	SAKLESH PURA_66	16:08	17:38	1:30	NFBC ISSUED
295	14-Apr-21	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	8:50(12.4.2021)			LINE OPEN: LINE CLEAR AVAILED
296	14-Apr-21	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	9:06	19:55	10:49	LINE CLEAR AVAILED
297	14-Apr-21	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	16:28(13.4.2021)	21:36(14.4.2021)	29:08hrs	LINE CHARGED
298	14-Apr-21	HASSAN	110	JOG110-MGHE	JOG_110	9:41	14:46	5:05	LINE CLEAR AVAILED
299	14-Apr-21	HASSAN	110	JOG-JLT3	mghejog_gen	9:40	14:47	5:07	NFBC ISSUED
300	14-Apr-21	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	18:10	20:14	2:04	LINE FAULT
301	14-Apr-21	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	16:28(13.4.21)	21:36(14.4.2021)	29:08hrs	LINE CHARGED
302	14-Apr-21	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	21:15(11.4.2021)			LINE OPEN: LINE FAULT
303	14-Apr-21	HASSAN	220	KADUR-DABUSET	KADUR_220	9:09	15:20	6:11	LINE CLEAR AVAILED
304	14-Apr-21	HASSAN	220	KEMAR-BAIPE2	KEMAR_220	18:57(14.4.2021)			LINE OPEN: LINE FAULT
305	14-Apr-21	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	17:18(13.4.2021))			LINE OPEN: LINE FAULT
306	14-Apr-21	HASSAN	220	KEMAR-Varahi3	KEMAR_220	17:23(13.4.2021)	11:16(14.4.2021)	17:53hrs	LINE CHARGED
307	14-Apr-21	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	11:05	13:20	2:15	LINE FAULT
308	14-Apr-21	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	14:23	15:32	1:09	LINE FAULT
309	14-Apr-21	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	18:55(14.04.21)			LINE OPEN: LINE FAULT
310	14-Apr-21	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	11:05	13:20	2:15	LINE FAULT
311	14-Apr-21	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	14:23	15:32	1:09	LINE FAULT
312	14-Apr-21	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	14:56	17:26	2:30	LINE CLEAR AVAILED
313	14-Apr-21	MYSURU	66	BANNIMANTAP-FTS	NO STATIONS EFFECTED	11:43 (12/04/2021)			LINE OPEN: LINE CLEAR AVAILED
314	14-Apr-21	MYSURU	66	CR NAGARA-CHANDAKAWADI	CHANDAKAVADI_66	19:07	19:32	0:25	LINE FAULT
315	14-Apr-21	MYSURU	66	CR NAGARA-CHANDAKAWADI	CHANDAKAVADI_66	19:38	20:44	1:06	LINE FAULT
316	14-Apr-21	MYSURU	66	GUNDLUPETE-BOMMALAPURA	BOMMALAPURA_66	16:18	16:23	0:05	LINE FAULT
317	14-Apr-21	MYSURU	66	HUNSUR-ELWALA	ELAVALA_66 GAVADAGERE_66	19:10	19:25	0:15	LINE FAULT
318	14-Apr-21	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
319	14-Apr-21	MYSURU	66	HV2	MADIKERI_66	14:33	16:05	1:31	LINE CLEAR AVAILED
320	14-Apr-21	MYSURU	66	HV2	SANTHEMARAHALLI_66	12:07	12:25	0:17	LINE CLEAR AVAILED
321	14-Apr-21	MYSURU	66	HV2	THANDYA_66	21:03	21:19	0:16	TRANSFORMER FAULT
322	14-Apr-21	MYSURU	66	HV2	THANDYA_66	22:30	22:37	0:06	TRANSFORMER FAULT
323	14-Apr-21	MYSURU	66	HV5	SFCSHIVA_66	8:19 (4/4/2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
324	14-Apr-21	MYSURU	66	KADAKOLA-DK MAIDANA	NO STATIONS EFFECTED	3:47	4:02	0:15	LINE FAULT
325	14-Apr-21	MYSURU	66	KADAKOLA-DK MAIDANA	NO STATIONS EFFECTED	18:43 (14/04/2021)			LINE OPEN: LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
326	14-Apr-21	MYSURU	66	KM DODDI-TK HALLI	KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66	6:13	6:30	0:17	LINE FAULT
327	14-Apr-21	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN: LINE CLEAR AVAILED
328	14-Apr-21	MYSURU	66	SFC SIVA-PGL	NO STATIONS EFFECTED	20:26	20:29	0:03	LINE FAULT
329	14-Apr-21	MYSURU	66	SFC SIVA-PGL	NO STATIONS EFFECTED	20:42	20:54	0:11	LINE FAULT
330	14-Apr-21	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	0:37	0:42	0:05	LINE FAULT
331	14-Apr-21	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	1:58	2:03	0:05	LINE FAULT
332	14-Apr-21	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	4:15	4:20	0:05	LINE FAULT
333	14-Apr-21	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	5:30	5:35	0:05	LINE FAULT
334	14-Apr-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BASARALU_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 KESLAGERE_66 VADERALLI_66	13:54	13:59	0:04	LINE FAULT
335	14-Apr-21	MYSURU	66	TUBINKERE-PANDAVAPURA	DODDABYADARAHALLI_66 PANDAVAPURA_66	18:59	19:05	0:06	LINE FAULT
336	14-Apr-21	MYSURU	220	MADHUVANAHALLI-CR NAGARA 1	NO STATIONS EFFECTED	20:02	21:15	1:13	LINE CLEAR AVAILED
337	14-Apr-21	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	YEDIYUR_66	13:53	14:21	0:28	LINE FAULT
338	14-Apr-21	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	17:28	18:04	0:36	LINE FAULT
339	14-Apr-21	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	18:06	20:25	2:18	LINE CLEAR AVAILED
340	14-Apr-21	TUMKUR	66	BENNEHALLI-ITTAGI	BENNEHALLI_66	18:52	19:47	0:54	LINE FAULT
341	14-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	15:30	15:41	0:10	LINE FAULT
342	14-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	16:06	16:18	0:12	LINE FAULT
343	14-Apr-21	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	18:25	19:35	1:09	MAIN SUPPLY FAILURE
344	14-Apr-21	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	18:25	19:44	1:19	MAIN SUPPLY FAILURE
345	14-Apr-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	8:27	8:49	0:22	LINE FAULT
346	14-Apr-21	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	8:27	8:49	0:22	MAIN SUPPLY FAILURE
347	14-Apr-21	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	9:42	9:54	0:11	LINE FAULT
348	14-Apr-21	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66, BASAVAPATNA_66	13:19	13:24	0:05	LINE FAULT
349	14-Apr-21	TUMKUR	66	KALAMARANAHALLI- PR PURA	KALAMARANAHALLI_66	19:48	21:14	1:25	LINE FAULT
350	14-Apr-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	8:14	8:20	0:06	LINE FAULT
351	14-Apr-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:57	12:04	0:06	LINE FAULT
352	14-Apr-21	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	18:41	18:48	0:06	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
353	14-Apr-21	TUMKUR	66	PAVAGADA 220kV- MADHUGIRI 1	HEBBUR_66, BHAKTARAHALLI_66	18:21	18:25	0:04	LINE FAULT
354	14-Apr-21	TUMKUR	66	THALLAK 220kV -BGKERE 1	BGKERE_66	18:19	19:31	1:12	LINE FAULT
355	14-Apr-21	TUMKUR	66	THALLAK 220kV -BGKERE 2	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	18:19	19:38	1:18	LINE FAULT
356	14-Apr-21	TUMKUR	66	TR-1	MAVINAKATTE_66	10:29	10:32	0:03	TRANSFORMER FAULT
357	14-Apr-21	TUMKUR	66	TR-1	RAMPURA_66	11:22	12:20	0:57	LINE CLEAR AVAILED
358	14-Apr-21	TUMKUR	66	TR-2	HANAGAL_66	18:26	19:36	1:10	MAIN SUPPLY FAILURE
359	14-Apr-21	TUMKUR	66	TR-2	HOLALKERE_66	7:58	8:07	0:09	TRANSFORMER FAULT
360	14-Apr-21	TUMKUR	110	TR-1	GUNGURMALE_110	(14.04.2021)5:57:05 PM			TRANSFORMER OPEN: LINE CLEAR AVAILED
361	14-Apr-21	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	15:52	18:07	2:14	LINE FAULT
362	15-Apr-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
363	15-Apr-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SIRSI_110	4:24	8:00	3:36	TRANSFORMER FAULT
364	15-Apr-21	BAGALKOT	110	110/11KV,HV1	HUNAGUND_110	11:30	11:35	0:05	TRANSFORMER FAULT
365	15-Apr-21	BAGALKOT	110	110/11KV,HV2	THORVI_110	2:50	20:52	18:02	TRANSFORMER FAULT
366	15-Apr-21	BAGALKOT	110	110/33KV,HV2	HUNAGUND_110,KARADI_33,AMIN AGAD_33,MYTRA SOLAR	11:30	11:38	0:08	TRANSFORMER FAULT
367	15-Apr-21	BAGALKOT	110	AINAPUR SUGARS-AINAPUR	STATON NOT AFFECTED AINAPUR_110	23:59 (15.04.2021)			LINE OPEN: LINE FAULT
368	15-Apr-21	BAGALKOT	110	AMBEWADI(SIRSI)-KIRUVATTI	STATON NOT AFFECTED KIRUVATTI_110	16:36	17:19	0:43	LINE FAULT
369	15-Apr-21	BAGALKOT	110	AMBEWADI(SIRSI)-KIRUVATTI	STATON NOT AFFECTED KIRUVATTI_110	17:19	18:36	1:17	LINE FAULT
370	15-Apr-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	KAVALWADA_110	16:36	17:06	0:30	LINE FAULT
371	15-Apr-21	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN: LINE CLEAR AVAILED
372	15-Apr-21	BAGALKOT	110	BIDNAL- NAVALGUN	STATION NOT AFFECTED NAVALGUND_110	8:17 (14.04.2021)	10:41 (15.04.2021)	26:24 hrs	LINE CHARGED
373	15-Apr-21	BAGALKOT	110	BIDNAL-NAVALGUND	STATON NOT AFFECTED NAVALGUND_110	10:14	10:23	0:09	LINE CLEAR AVAILED
374	15-Apr-21	BAGALKOT	110	DAMBAL-MUNDARAGI	MUNDARAGI_110	10:06	11:27	1:21	LINE CLEAR AVAILED
375	15-Apr-21	BAGALKOT	110	DAMBAL-SUZLON1&2	DAMBAL_110	10:06	11:50	1:44	LINE CLEAR AVAILED
376	15-Apr-21	BAGALKOT	110	EILS(ENERCON)_DAMBAL	DAMBAL_110	10:06	11:49	1:43	LINE CLEAR AVAILED
377	15-Apr-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	16:18 (11.04.2021)			LINE OPEN: LINE CLEAR AVAILED
378	15-Apr-21	BAGALKOT	110	GADAG-DAMBAL	STATON NOT AFFECTED GADAG_220	9:51	14:21	4:30	LINE CLEAR AVAILED
379	15-Apr-21	BAGALKOT	110	GADAG-SAMBAPUR ROAD	STATON NOT AFFECTED GADAG_220	10:04	11:09	1:05	LINE CLEAR AVAILED
380	15-Apr-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
381	15-Apr-21	BAGALKOT	110	HUBLI220-KADANAKOPPA	KADANAKOPPA_110	16:45	17:06	0:21	LINE FAULT
382	15-Apr-21	BAGALKOT	110	HUBLI220-RAMANAKOPPA	RAMANAKOPPA_110	10:45	14:49	4:04	LINE CLEAR AVAILED
383	15-Apr-21	BAGALKOT	110	HUNGUNDB-BAGEWADI(KUDALSANGAM)	HUNAGUND_110	11:30	11:35	0:05	LINE FAULT
384	15-Apr-21	BAGALKOT	110	HUNGUND-ILKAL1&2	HUNAGUND_110	11:30	11:35	0:05	LINE FAULT
385	15-Apr-21	BAGALKOT	110	HUNGUND-JINDAL	HUNAGUND_110	11:30	11:37	0:07	LINE FAULT
386	15-Apr-21	BAGALKOT	110	KADANKOPPA-KAVALWADA	STATON NOT AFFECTED KADANKOPPA_110	17:09 (15.04.2021)			LINE OPEN: LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
387	15-Apr-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
388	15-Apr-21	BAGALKOT	110	KULIGOD-GAMESH	STATION NOT AFFECTED KULIGOD_110	11:08	15:44	4:36	LINE CLEAR AVAILED
389	15-Apr-21	BAGALKOT	110	KUMATA-SIRSI 1	STATION NOT AFFECTED KUMATA_110	12:22 (12.04.2021)			LINE OPEN: LINE CLEAR AVAILED
390	15-Apr-21	BAGALKOT	110	MACHE- UDYAMBAG	STATION NOT AFFECTED MACHE_110	8:11 (12.04.2021)			LINE OPEN: LINE CLEAR AVAILED
391	15-Apr-21	BAGALKOT	110	MAHALINGAPUR-RANNABELAGALI	RANNABELAGALI_110	6:10	6:43	0:33	LINE FAULT
392	15-Apr-21	BAGALKOT	110	MUDDEBIHAL-KN SOLAR(KNMSLR)	KN SOLAR_110 STATION NOT AFFECTED MUDDEBIHAL_110	18:50 (14.04.2021)	16:25 (15.04.2021)	22:10	LINE CHARGED
393	15-Apr-21	BAGALKOT	110	NAVALGUND-KONNUR (KNMSLR)	STATION NOT AFFECTED NAVALAGUND_110	10:41	15:40	4:59	LINE CLEAR AVAILED
394	15-Apr-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
395	15-Apr-21	BAGALKOT	110	RON- GAJENDRAGAD1	STATION NOT AFFECTED RON_110	21:31 (08.04.2021)	14:51 (15.04.2021)	160:44 hrs	LINE CHARGED
396	15-Apr-21	BAGALKOT	110	RON- GAJENDRAGAD2	STATION NOT AFFECTED RON_110	21:31 (08.04.2021)	14:51 (15.04.2021)	160:44 hrs	LINE CHARGED
397	15-Apr-21	BAGALKOT	110	SAMBAPUR-DAMBAL	SAMBAPUR ROAD_110	10:05	11:15	1:10	LINE CLEAR AVAILED
398	15-Apr-21	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:57 (05.03.2021)			LINE OPEN: LINE CLEAR AVAILED
399	15-Apr-21	BAGALKOT	110	SIRSI-JOG2	STATION NOT AFFECTED SIRSI_110	0:51	13:50	12:59	LINE FAULT
400	15-Apr-21	BAGALKOT	110	SIRSI-SIDDAPUR (JOG1)	SIDDAPUR_110	0:51	1:33	0:42	LINE FAULT
401	15-Apr-21	BAGALKOT	110	TADASINAKOPPA-KIADB GAMANAGATTI (KUD DHARWAD)	KIADB GAMANAGATTI_110	12:36	14:56	2:20	LINE CLEAR AVAILED
402	15-Apr-21	BAGALKOT	110	TARIHAL-KIADB GAMANGATTI	STATION NOT AFFECTED TARIHAL_110	12:11 (15.04.2021)			LINE OPEN: LINE CLEAR AVAILED
403	15-Apr-21	BAGALKOT	110	YADAWAD-IZRA SOLAR(ISEL)	YADAWAD_110, IZRA SOLAR_110	7:45	7:46	0:01	HAND TRIPPED
404	15-Apr-21	BAGALKOT	220	AMBEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI_220	14:09 (14.04.2021)			LINE OPEN: LINE FAULT
405	15-Apr-21	BAGALKOT	220	BAGALKOT-GADAG2	STATION NOT AFFECTED BAGALKOT_220	16:21 (15.04.2021)			LINE OPEN: LINE CLEAR AVAILED
406	15-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:31 (05.04.2021)			LINE OPEN: LINE CLEAR AVAILED
407	15-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:46 (15.04.2021)			LOAD CURTAILMENT
408	15-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	17:23	23:35	6:12	LINE CLEAR AVAILED
409	15-Apr-21	BAGALKOT	220	BELGAUM-NARENDRA2	STATION NOT AFFECTED BELGAUM_220	17:23	23:35	6:12	LINE FAULT
410	15-Apr-21	BAGALKOT	220	BIDNAL-HARTI 2	STATION NOT AFFECTED BIDNAL_220	21:31 (14.04.2021)	9:13 (15.04.2021)	11:42 hrs	LINE CHARGED
411	15-Apr-21	BAGALKOT	220	BIDNAL-NAGIHARI2	STATION NOT AFFECTED BIDNAL_220	14:53	17:21	2:28	LINE FAULT
412	15-Apr-21	BAGALKOT	220	BIDNAL-NAGIHARI2	STATION NOT AFFECTED BIDNAL_220	17:21 (15.04.2021)			LINE OPEN: LINE FAULT
413	15-Apr-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN: LINE CLEAR AVAILED
414	15-Apr-21	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	19:14 (14.04.2021)	19:36 (15.04.2021)	24:22 hrs	LINE CHARGED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
415	15-Apr-21	BAGALKOT	220	HAVERI-GUTTUR2	STATON NOT AFFECTED HAVERI 220	11:01	19:36	8:35	LINE CLEAR AVAILED
416	15-Apr-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR 220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
417	15-Apr-21	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	STATION NOT AFFECTED MAHALINGAPUR 220	9:38 (09.04.2021)			LOAD CURTAILMENT
418	15-Apr-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA 220	17:22 (30.03.2021)			LINE OPEN: LINE FAULT
419	15-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI 220	17:31 (10.04.2021)			LOAD CURTAILMENT
420	15-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI 220	18:08 (06.03.2021)			LOAD CURTAILMENT
421	15-Apr-21	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI 220	16:35 (11.04.2021)			LINE OPEN: LINE FAULT
422	15-Apr-21	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI 220	16:17 (23.02.2021)			LINE OPEN: LINE FAULT
423	15-Apr-21	BAGALKOT	220	VAJRAMATTI -MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI 220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
424	15-Apr-21	BENGALURU	66	BIDADI 220 - BOSCH (EHT)	BOSCH (EHT)	18:26	18:52	0:26	MAIN SUPPLY FAILURE
425	15-Apr-21	BENGALURU	66	BIDADI 220 - EPIPL (EHT)	EPIPL (EHT)	18:26	18:52	0:26	MAIN SUPPLY FAILURE
426	15-Apr-21	BENGALURU	66	BIDADI 220 - HEJJALA	HEJJALA	18:26	18:55	0:29	MAIN SUPPLY FAILURE
427	15-Apr-21	BENGALURU	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPANAHALLI	18:26	23:59	5:33	LINE FAULT
428	15-Apr-21	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	11:00	11:10	0:10	LOAD CHANGEOVER
429	15-Apr-21	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	13:34	13:56	0:22	LINE CLEAR AVAILED
430	15-Apr-21	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	16:19	16:30	0:11	LINE CLEAR AVAILED
431	15-Apr-21	BENGALURU	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA	13:30	13:33	0:03	LOAD CHANGEOVER
432	15-Apr-21	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	0:34	0:50	0:16	LINE FAULT
433	15-Apr-21	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	2:30	3:20	0:50	LINE FAULT
434	15-Apr-21	BENGALURU	66	HAL 220 - HOODY 1	HAL 220, EDC 220	3:22	3:40	0:18	LINE FAULT
435	15-Apr-21	BENGALURU	66	HSR LAYOUT 220 - ADUGODI 1	JAKKASANDRA	2:39	3:11	0:32	LINE FAULT
436	15-Apr-21	BENGALURU	66	HV1	KYALANUR	2:04	3:10	1:05	TRANSFORMER FAULT
437	15-Apr-21	BENGALURU	66	HV1	KANAKAPURA 66	12:50	12:55	0:05	LINE CLEAR AVAILED
438	15-Apr-21	BENGALURU	66	HV1	CHINTAMANI 66	17:59	18:18	0:18	TRANSFORMER FAULT
439	15-Apr-21	BENGALURU	66	HV1	M GOLLAHALLI	6:50	6:58	0:08	TRANSFORMER FAULT
440	15-Apr-21	BENGALURU	66	HV1	SOMENAHALLI	7:35	7:45	0:10	TRANSFORMER FAULT
441	15-Apr-21	BENGALURU	66	HV1	BAIRAKURU	6:10	8:30	2:20	TRANSFORMER FAULT
442	15-Apr-21	BENGALURU	66	HV1	EPIP 220	3:53	4:07	0:14	TRANSFORMER FAULT
443	15-Apr-21	BENGALURU	66	HV1	KADUBISANAHALLI	3:22	4:02	0:40	MAIN SUPPLY FAILURE
444	15-Apr-21	BENGALURU	66	HV1	NAGNATHPURA 220	20:15	20:19	0:04	TRANSFORMER FAULT
445	15-Apr-21	BENGALURU	66	HV1	ITI 220	6:42	7:00	0:18	MAIN SUPPLY FAILURE
446	15-Apr-21	BENGALURU	66	HV1	KUMBALAGODU	11:50	12:13	0:23	LINE CLEAR AVAILED
447	15-Apr-21	BENGALURU	66	HV1	KUMBALAGODU	13:38	14:51	1:13	LINE CLEAR AVAILED
448	15-Apr-21	BENGALURU	66	HV2	DODDABELAVANGALA	21:00	21:36	0:36	LINE CLEAR AVAILED
449	15-Apr-21	BENGALURU	66	HV2	WEL CAST STEEL	13:38	13:42	0:03	LINE CLEAR AVAILED
450	15-Apr-21	BENGALURU	66	HV2	KANAKAPURA 66	11:41	11:45	0:03	LINE CLEAR AVAILED
451	15-Apr-21	BENGALURU	66	HV2	DOMMASANDRA	12:10	12:19	0:09	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
452	15-Apr-21	BENGALURU	66	HV2	THAYALUR	4:59	5:38	0:39	TRANSFORMER FAULT
453	15-Apr-21	BENGALURU	66	HV2	ELECTRONIC CITY P2 S2	17:53	17:57	0:04	TRANSFORMER FAULT
454	15-Apr-21	BENGALURU	66	HV2	KADUBISANAHALLI	3:22	4:01	0:39	MAIN SUPPLY FAILURE
455	15-Apr-21	BENGALURU	66	HV2	KUMBALAGODU	12:00	12:18	0:18	LINE CLEAR AVAILED
456	15-Apr-21	BENGALURU	66	HV2	KUMBALAGODU	13:38	14:51	1:13	LINE CLEAR AVAILED
457	15-Apr-21	BENGALURU	66	HV3	ITI 220	6:42	7:00	0:18	MAIN SUPPLY FAILURE
458	15-Apr-21	BENGALURU	66	ITI 220 - BABHMANE WTP	BAGHMANE WTP	6:42	7:00	0:18	MAIN SUPPLY FAILURE
459	15-Apr-21	BENGALURU	66	ITI 220 - DRDO (EHT)	DRDO (EHT)	7:34	8:00	0:26	LINE FAULT
460	15-Apr-21	BENGALURU	66	ITI 220 - POTTERY ROAD	POTTERY ROAD	6:42	7:00	0:18	MAIN SUPPLY FAILURE
461	15-Apr-21	BENGALURU	66	KADUBISANAHALLI - CESSNA (EHT)	CESSNA (EHT)	3:22	4:14	0:52	MAIN SUPPLY FAILURE
462	15-Apr-21	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	15:14	15:41	0:27	LINE FAULT
463	15-Apr-21	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENHALLI, HAROBELE, BIJJAHALLI, KUNOOR	15:45	19:44	3:59	LINE CLEAR AVAILED
464	15-Apr-21	BENGALURU	66	KGF - KAMASAMUDRA	KAMASAMUDRA	3:36	4:54	1:18	LINE FAULT
465	15-Apr-21	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	2:38	3:39	1:01	LINE FAULT
466	15-Apr-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	15:23	15:36	0:13	MAIN SUPPLY FAILURE
467	15-Apr-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	15:23	15:35	0:12	MAIN SUPPLY FAILURE
468	15-Apr-21	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	15:23	15:36	0:13	MAIN SUPPLY FAILURE
469	15-Apr-21	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	10:50	10:53	0:03	LINE CLEAR AVAILED
470	15-Apr-21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELUR, CHAKAVELU, YENIGADALE	15:23	15:35	0:12	MAIN SUPPLY FAILURE
471	15-Apr-21	BENGALURU	66	NAGNATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT), JAKKASANDRA	20:15	20:19	0:04	LINE FAULT
472	15-Apr-21	BENGALURU	66	SOMENAHALLI - PERASANDRA	PERESANDRA	7:35	8:45	1:10	LINE CLEAR AVAILED
473	15-Apr-21	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	15:29	15:40	0:11	LINE FAULT
474	15-Apr-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	15:51	16:07	0:16	LINE FAULT
475	15-Apr-21	BENGALURU	220	BUS COUPLER	ITI 220	6:42	7:43	1:01	LINE FAULT
476	15-Apr-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN: LINE FAULT
477	15-Apr-21	BENGALURU	220	HV1	MITTERMARI 220	15:23	16:15	0:52	TRANSFORMER FAULT
478	15-Apr-21	BENGALURU	220	HV1	BIDADI 220	18:26	22:25	3:59	TRANSFORMER FAULT
479	15-Apr-21	BENGALURU	220	ITI 220 -MANYATHA 220	NO STATION AFFECTED	6:42	7:50	1:08	LINE FAULT
480	15-Apr-21	GULBARGA	66	ITTAGI-KUDLIGI1	KUDLIGI_66,KOGALI_66	12:40	13:32	0:52	LINE CLEAR AVAILED
481	15-Apr-21	GULBARGA	66	UJJAINI-KOTTUR	UJJANI_66	14:00	16:35	2:35	LINE CLEAR AVAILED
482	15-Apr-21	GULBARGA	110	GULBARGA UNIVERSITY-SHAHABAD1	GULBARGA UNIVERSITY_110	8:30(9.04.2021)			LINE OPEN: LINE CLEAR AVAILED
483	15-Apr-21	GULBARGA	110	HV2	DEODURGA_110	17:15	17:23	0:08	TRANSFORMER FAULT
484	15-Apr-21	GULBARGA	110	HV3	SINDHANOOR_110	11:29	14:40	3:11	LINE CLEAR AVAILED
485	15-Apr-21	GULBARGA	110	KUDITINI-BELLARY	KUDITINI_110,TORANGALU_110	4:15	4:23	0:08	LINE FAULT
486	15-Apr-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	2:01	2:11	0:10	LINE FAULT
487	15-Apr-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	3:18	3:28	0:10	LINE FAULT
488	15-Apr-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	4:08	4:20	0:12	LINE FAULT
489	15-Apr-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	5:02	5:12	0:10	LINE FAULT
490	15-Apr-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	4:12	4:22	0:10	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
491	15-Apr-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	20:51	21:05	0:14	LINE FAULT
492	15-Apr-21	GULBARGA	110	SINDHANOOR-PGLR_WIND	SINDHANOOR_220	12:10	12:35	0:25	LINE FAULT
493	15-Apr-21	GULBARGA	110	SINDHANOOR-PGLR_WIND	SINDHANOOR_220	12:55	13:30	0:35	LINE FAULT
494	15-Apr-21	GULBARGA	110	SINDHANOOR-THURVIHAL	THURVIHAL_110	16:35	16:55	0:20	LINE FAULT
495	15-Apr-21	GULBARGA	110	SINDHNOOR-SINDHNOOR2	SINDHNOOR_110	18:50(14.03.2021)	17:20(15.03.2021)	22:30 hrs	LINE CHARGED
496	15-Apr-21	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	7:20(15.4.21)	17:20(15.04.2021)	10:00 hrs	LINE CHARGED
497	15-Apr-21	GULBARGA	220	HV1	LINGASUGUR_220	11:15	13:55	2:40	LINE CLEAR AVAILED
498	15-Apr-21	GULBARGA	220	HV1	ITTAGI_220	5:55	6:07	0:12	TRANSFORMER FAULT
499	15-Apr-21	GULBARGA	220	KUSHTAGI-LINGAPUR	KUSHTAGI_220	15:30(15.04.2021)			LINE OPEN: LINE FAULT
500	15-Apr-21	GULBARGA	220	LINGAPUR-JINDAL2	JINDAL_220	14:37	18:59	4:22	NFBC ISSUED
501	15-Apr-21	GULBARGA	400	BTPS-GUTTUR	GUTTUR_400	22:16(14.04.2021)	13:55(15.04.2021)	15:39 hrs	LINE CHARGED
502	15-Apr-21	GULBARGA	400	BTPS-GUTTUR	GUTTUR_400	15:36(15.04.2021)			LINE OPEN: LINE FAULT
503	15-Apr-21	HASSAN	66	BANDISH-ADANI	BANDISHETTIHALLY_66	14:38	15:30	0:52	MAIN SUPPLY FAILURE
504	15-Apr-21	HASSAN	66	BANDISH-ADANI	BANDISHETTIHALLY_66	15:54	16:04	0:10	MAIN SUPPLY FAILURE
505	15-Apr-21	HASSAN	66	BANDISH-HNPURA	BANDISHETTIHALLY_66	14:38	16:03	1:25	NFBC ISSUED
506	15-Apr-21	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTIHALLY_66	14:37	15:30	0:53	MAIN SUPPLY FAILURE
507	15-Apr-21	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTIHALLY_66	15:52	16:03	0:11	MAIN SUPPLY FAILURE
508	15-Apr-21	HASSAN	66	BHADRA-SHMG 2	bhadra_gen	9:36	10:52	1:16	LINE FAULT
509	15-Apr-21	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLY_66	10:04	12:14	2:10	LINE CLEAR AVAILED
510	15-Apr-21	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	14:00	16:00	2:00	LINE CLEAR AVAILED
511	15-Apr-21	HASSAN	66	HV1	BANDISHETTIHALLY_66	14:37	15:30	0:53	MAIN SUPPLY FAILURE
512	15-Apr-21	HASSAN	66	HV1	BANDISHETTIHALLY_66	15:52	16:03	0:11	MAIN SUPPLY FAILURE
513	15-Apr-21	HASSAN	66	HV1	BYACHANAHALLY_66	7:20	7:25	0:05	TRANSFORMER FAULT
514	15-Apr-21	HASSAN	66	HV1	KIADB_66	11:25	16:54	5:29	LINE CLEAR AVAILED
515	15-Apr-21	HASSAN	66	HV2	SALAGAME_66	10:44	11:36	0:52	LINE CLEAR AVAILED
516	15-Apr-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	11:11	11:38	0:27	LINE FAULT
517	15-Apr-21	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
518	15-Apr-21	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
519	15-Apr-21	HASSAN	66	MRSSH-BD-2	MRSMG_220	9:37	10:52	1:15	LINE FAULT
520	15-Apr-21	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	8:50(12.4.2021)			LINE OPEN: LINE CLEAR AVAILED
521	15-Apr-21	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	12:01	18:32	6:31	LINE CLEAR AVAILED
522	15-Apr-21	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	14:10	19:17	5:07	NFBC ISSUED
523	15-Apr-21	HASSAN	110	HV2	PUTTUR_110	20:50(15.4.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
524	15-Apr-21	HASSAN	110	HV3	HIRIYADKA_110	21:31	21:42	0:11	TRANSFORMER FAULT
525	15-Apr-21	HASSAN	110	JOG110-AMBTR1	JOG_110	10:15(15.04.2021)			LINE OPEN: LINE CLEAR AVAILED
526	15-Apr-21	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	14:10	19:16	5:06	LINE CLEAR AVAILED
527	15-Apr-21	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	21:15(11.4.2021)			LINE OPEN: LINE FAULT
528	15-Apr-21	HASSAN	110	MRSSH-TRKER	MRSMG_220	9:23	11:43	2:20	NFBC ISSUED
529	15-Apr-21	HASSAN	110	NERALA-TEREKERE	NERALAKERE_110	9:23	11:43	2:20	LINE CLEAR AVAILED
530	15-Apr-21	HASSAN	220	KEMAR-BAJPE1	KEMAR_220	18:57(14.4.2021)	15:16(15.4.2021)	39:19hrs	LINE CHARGED
531	15-Apr-21	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	17:18(13.4.2021))	19:13(15.4.2021)	49:55hrs	LINE CHARGED
532	15-Apr-21	HASSAN	220	KEMAR-Varahi1	KEMAR_220	10:52	15:28	4:36	LINE CLEAR AVAILED
533	15-Apr-21	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	18:55(14.04.21)	15:16(15.4.2021)	20:21hrs	LINE CHARGED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
534	15-Apr-21	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	13:56(15.04.2021)			LINE OPEN: LINE CLEAR AVAILED
535	15-Apr-21	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	13:56(15.04.2021)			LINE OPEN: LINE CLEAR AVAILED
536	15-Apr-21	HASSAN	220	VARAHI-KEMAR1	varahi_gen	10:52	15:28	4:36	LINE CLEAR AVAILED
537	15-Apr-21	MYSURU	66	BANNIMANTAP-FTS	NO STATIONS EFFECTED	11:43 (12/04/2021)			LINE OPEN: LINE CLEAR AVAILED
538	15-Apr-21	MYSURU	66	CR NAGARA-CHANDAKAWADI	CHANDAKAVADI_66	14:56	15:42	0:46	LINE CLEAR AVAILED
539	15-Apr-21	MYSURU	66	HV1	BGPURA_66	9:05	9:37	0:32	LINE CLEAR AVAILED
540	15-Apr-21	MYSURU	66	HV1	HARADANAHALLI(JAK)_66	14:10	14:13	0:03	TRANSFORMER FAULT
541	15-Apr-21	MYSURU	66	HV1	K_HONNALGERE_66	12:18	13:44	1:26	LINE CLEAR AVAILED
542	15-Apr-21	MYSURU	66	HV1	K_HONNALGERE_66	15:28	15:50	0:22	MAIN SUPPLY FAILURE
543	15-Apr-21	MYSURU	66	HV1	K_HONNALGERE_66	15:52	16:20	0:27	MAIN SUPPLY FAILURE
544	15-Apr-21	MYSURU	66	HV1	KOLLEGALA_66	11:00	16:46	5:46	LINE CLEAR AVAILED
545	15-Apr-21	MYSURU	66	HV1	TARIPURA_66	15:14	16:00	0:45	LINE CLEAR AVAILED
546	15-Apr-21	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
547	15-Apr-21	MYSURU	66	HV2	MADIKERI_66	8:56	9:15	0:18	LINE CLEAR AVAILED
548	15-Apr-21	MYSURU	66	HV2	THANDYA_66	11:23	11:26	0:03	TRANSFORMER FAULT
549	15-Apr-21	MYSURU	66	HV5	SFCSHIVA_66	8:19 (4/4/2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
550	15-Apr-21	MYSURU	66	KADAKOLA-DK MAIDANA	NO STATIONS EFFECTED	18:43 (14/04/2021)	10:38 (15/04/2021)	15:55 hrs	LINE CHARGED
551	15-Apr-21	MYSURU	66	KM DODDI-TK HALLI	KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66	15:28	15:44	0:16	LINE FAULT
552	15-Apr-21	MYSURU	66	KM DODDI-TK HALLI	KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66	15:57	18:45	2:48	NFBC ISSUED
553	15-Apr-21	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN: LINE CLEAR AVAILED
554	15-Apr-21	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	20:46	20:51	0:05	LINE FAULT
555	15-Apr-21	MYSURU	66	PERIYAPATNA-HANGODU	HANAGODU_66 PONNAMPET_66 VIRAJPET_66	11:15	11:25	0:10	LINE FAULT
556	15-Apr-21	MYSURU	66	PERIYAPATNA-HUNSUR	KAMPALAPURA_66	16:05	16:18	0:12	LINE FAULT
557	15-Apr-21	MYSURU	220	CR NAGARA-MADHUVANAHALLI 1	NO STATIONS EFFECTED	12:34	13:34	0:59	NFBC ISSUED
558	15-Apr-21	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	11:40	11:50	0:10	LINE FAULT
559	15-Apr-21	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66	11:56	12:09	0:12	LINE FAULT
560	15-Apr-21	TUMKUR	66	ANCHEPALYA 220kV- AMRUTHUR	ANTHRASANAHALLI_220	8:24	9:29	1:05	LINE CLEAR AVAILED
561	15-Apr-21	TUMKUR	66	BRAHMASANDRA- ANKASANDRA_66	CHIKKATOTLUKERE_66	11:09	11:34	0:24	LINE CLEAR AVAILED
562	15-Apr-21	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:21	11:32	0:11	LINE FAULT
563	15-Apr-21	TUMKUR	66	DAVANGERE SRS- HARIHARA	HDPURA_66	0:04	0:06	0:01	LINE FAULT
564	15-Apr-21	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	HOLALKERE_66	11:27	12:41	1:14	LINE CLEAR AVAILED
565	15-Apr-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	6:12	6:15	0:02	LINE FAULT



SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
566	15-Apr-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	0:57	1:18	0:21	LINE FAULT
567	15-Apr-21	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR )	JIDDEGERE_66	11:15	12:59	1:44	MAIN SUPPLY FAILURE
568	15-Apr-21	TUMKUR	66	MADHUGIRI 220kV- KORATAGERE 2	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	18:02	18:14	0:11	LINE CLEAR AVAILED
569	15-Apr-21	TUMKUR	66	MADHUGIRI 220kV- KORATAGERE 2	MADHUGIRI_220	19:00	19:03	0:02	HAND TRIPPED
570	15-Apr-21	TUMKUR	66	MADHUGIRI 220kV- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	18:02	18:13	0:11	HAND TRIPPED
571	15-Apr-21	TUMKUR	66	MADHUGIRI 220kV- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	19:00	19:02	0:02	HAND TRIPPED
572	15-Apr-21	TUMKUR	66	RAMPURA66-ABLETEC(SSHTY)_IPP_66	ABLETEC(SSHTY)_IPP_66	9:21	9:40	0:19	HAND TRIPPED
573	15-Apr-21	TUMKUR	66	TR-1	BRAHMASANDRA_66	1:16	15:59	14:43	TRANSFORMER FAULT
574	15-Apr-21	TUMKUR	66	TR-1	CHIKKATOTLUKERE_66	13:04	13:18	0:14	LINE CLEAR AVAILED
575	15-Apr-21	TUMKUR	66	TR-1	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	6:40	6:50	0:10	TRANSFORMER FAULT
576	15-Apr-21	TUMKUR	66	TR-1	HDPURA_66	7:40	7:42	0:01	TRANSFORMER FAULT
577	15-Apr-21	TUMKUR	66	TR-1	BEVINAHALLI_66	10:36	10:50	0:14	TRANSFORMER FAULT
578	15-Apr-21	TUMKUR	66	TR-1	HOLALKERE_66	11:27	12:41	1:14	LINE CLEAR AVAILED
579	15-Apr-21	TUMKUR	66	TR-1	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	18:02	18:14	0:11	TRANSFORMER FAULT
580	15-Apr-21	TUMKUR	66	TR-1	MAVINAKATTE_66	10:10	10:11	0:01	TRANSFORMER FAULT
581	15-Apr-21	TUMKUR	66	TR-1	TUMKUR_66	2:58	3:05	0:07	TRANSFORMER FAULT
582	15-Apr-21	TUMKUR	66	TR-1	TUMKUR_66	4:23	4:39	0:15	TRANSFORMER FAULT
583	15-Apr-21	TUMKUR	66	TR-1	TUMKUR_66	5:30	6:50	1:20	TRANSFORMER FAULT
584	15-Apr-21	TUMKUR	66	TR-2	BRAHMASANDRA_66	16:02	16:16	0:14	TRANSFORMER FAULT
585	15-Apr-21	TUMKUR	66	TR-2	ANKASANDRA_66	12:40	12:54	0:13	TRANSFORMER FAULT
586	15-Apr-21	TUMKUR	66	TR-2	HOLALKERE_66	11:27	12:41	1:14	LINE CLEAR AVAILED
587	15-Apr-21	TUMKUR	66	TR-2	SHYLAPURA_66	19:14	19:21	0:07	TRANSFORMER FAULT
588	15-Apr-21	TUMKUR	66	TR-2	SANIKERE_66	13:02	13:21	0:18	TRANSFORMER FAULT
589	15-Apr-21	TUMKUR	66	TR-2(LV SIDE )	MADHUGIRI_66, BADAVANAHALLI_66	18:03	19:02	0:59	LINE CLEAR AVAILED
590	15-Apr-21	TUMKUR	66	TR-3	HOLALKERE_66	5:02	5:06	0:03	TRANSFORMER FAULT
591	15-Apr-21	TUMKUR	110	TR-1	GUNGURMALE_110	(14.04.2021)17:57:05	16:19:40(15.04.2021)	21:22	TRANSFORMER FAULT
592	15-Apr-21	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	15:00	16:11	1:11	LINE CLEAR AVAILED
593	15-Apr-21	TUMKUR	110	TR-1	SHETYKERE_110	1:23	1:34	0:10	TRANSFORMER FAULT
594	15-Apr-21	TUMKUR	110	TR-1	TURUVEKERE_110	2:03	9:55	7:51	TRANSFORMER FAULT
595	15-Apr-21	TUMKUR	110	TR-1	TURUVEKERE_110	14:21	15:51	1:29	TRANSFORMER FAULT
596	15-Apr-21	TUMKUR	110	TR-3	GUBBI_110	12:05	12:49	0:43	LINE CLEAR AVAILED
597	15-Apr-21	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	10:47	13:08	2:20	LINE CLEAR AVAILED
598	15-Apr-21	TUMKUR	220	CHITRADURGA 220kV- THALLAK	CHITRADURGA_220	13:07	13:28	0:20	LINE CLEAR AVAILED
599	15-Apr-21	TUMKUR	220	THALLAK 220kV- SEI VENUS DIAMOND IPP_66	SEI VENUS DIAMOND IPP_66	12:56	13:41	0:45	LINE FAULT
600	15-Apr-21	TUMKUR	220	TR-2	MADHUGIRI_220	18:05	19:01	0:56	LINE CLEAR AVAILED
601	16-Apr-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
602	16-Apr-21	BAGALKOT	110	110/11, HV1	STATION NOT AFFECTED NAREGAL 110	15:23	15:51	0:28	LINE CLEAR AVAILED
603	16-Apr-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED LAXMESHVAR 110	15:58	18:03	2:05	TRANSFORMER FAULT
604	16-Apr-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SIRSI 110	12:11	14:01	1:50	LINE CLEAR AVAILED
605	16-Apr-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SHIROL 110	12:11	14:01	1:50	LINE CLEAR AVAILED
606	16-Apr-21	BAGALKOT	110	110/11KV,HV1	STATON NOT AFFECTED BILAGI 110	10:34	11:43	1:09	LINE CLEAR AVAILED
607	16-Apr-21	BAGALKOT	110	220/110KV,HV2,LV2	STATON NOT AFFECTED CHIKKODI 220	10:44	13:18	2:34	LINE CLEAR AVAILED
608	16-Apr-21	BAGALKOT	110	AINAPUR SUGARS-AINAPUR	STATON NOT AFFECTED AINAPUR 110	23:59 (15.04.2021)	0:12 (16.04.2021)	0:13 hrs	LINE CHARGED
609	16-Apr-21	BAGALKOT	110	AMBEWADI(SIRSI)-KIRUVATTI	STATON NOT AFFECTED KIRUVATTI 110	16:46 (16.04.2021)			LINE OPEN: LINE CLEAR AVAILED
610	16-Apr-21	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATON NOT AFFECTED AMBEWADI 110	15:24	16:56	1:32	LINE CLEAR AVAILED
611	16-Apr-21	BAGALKOT	110	BADAMI-KERUR	BADAMI_110	5:32	6:11	0:39	LINE FAULT
612	16-Apr-21	BAGALKOT	110	BAGALKOT-KERUR	KERUR 110	5:56	6:01	0:05	LINE FAULT
613	16-Apr-21	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI 110	9:39 (06.04.2021)			LINE OPEN: LINE CLEAR AVAILED
614	16-Apr-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG 110	16:18 (11.04.2021)			LINE OPEN: LINE CLEAR AVAILED
615	16-Apr-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
616	16-Apr-21	BAGALKOT	110	HAVERI220-BYADAGI	BYADAGI_110	1:07	1:44	0:37	LINE FAULT
617	16-Apr-21	BAGALKOT	110	KADANKOPPA-KAVALWADA	STATON NOT AFFECTED KADANKOPPA 110	17:09 (15.04.2021)			LINE OPEN: LINE FAULT
618	16-Apr-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
619	16-Apr-21	BAGALKOT	110	KULIGOD-GAMESH	STATON NOT AFFECTED KULIGOD 110	9:35	16:50	7:15	LINE CLEAR AVAILED
620	16-Apr-21	BAGALKOT	110	KUMATA-SIRSI 1	STATION NOT AFFECTED KUMATA 110	12:22 (12.04.2021)			LINE OPEN: LINE CLEAR AVAILED
621	16-Apr-21	BAGALKOT	110	MACHE- UDYAMBAG	STATION NOT AFFECTED MACHE 110	8:11 (12.04.2021)			LINE OPEN: LINE CLEAR AVAILED
622	16-Apr-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR 220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
623	16-Apr-21	BAGALKOT	110	RANEBENNUR-BYADAGI	STATON NOT AFFECTED BYADAGI 110	1:07	10:26	9:19	LINE FAULT
624	16-Apr-21	BAGALKOT	110	RON-GAJENDRAGAD1	STATION NOT AFFECTED RON 110	6:29	11:01	4:32	LINE FAULT
625	16-Apr-21	BAGALKOT	110	RON-GAJENDRAGAD2	STATION NOT AFFECTED RON 110	6:29	11:02	4:33	LINE FAULT
626	16-Apr-21	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI 110	10:57 (05.03.2021)			LINE OPEN: LINE CLEAR AVAILED
627	16-Apr-21	BAGALKOT	110	SIRSI-JOG2	STATION NOT AFFECTED SIRSI 110	10:52	11:12	0:20	LINE CLEAR AVAILED
628	16-Apr-21	BAGALKOT	110	SIRSI-SIDDAPUR (JOG1)	STATION NOT AFFECTED SIRSI 110	10:52	11:12	0:20	LINE CLEAR AVAILED
629	16-Apr-21	BAGALKOT	110	TARIHAL-KIADB GAMANGATTI	STATION NOT AFFECTED TARIHAL 110	12:11 (15.04.2021)			LINE OPEN: LINE CLEAR AVAILED
630	16-Apr-21	BAGALKOT	220	AMBEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI 220	14:09 (14.04.2021)			LINE OPEN: LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
631	16-Apr-21	BAGALKOT	220	ATHANI220-RAVIURJA1	STATON NOT AFFECTED ATHANI 220	17:08	18:00	0:52	LINE CLEAR AVAILED
632	16-Apr-21	BAGALKOT	220	ATHANI220-RAVIURJA2	STATON NOT AFFECTED ATHANI 220	17:08	18:00	0:52	LINE CLEAR AVAILED
633	16-Apr-21	BAGALKOT	220	BAGALKOT-GADAG2	STATON NOT AFFECTED BAGALKOT 220	16:21 (15.04.2021)	18:11 (16.04.2021)	25:50 hrs	LINE CHARGED
634	16-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI1	STATON NOT AFFECTED BELGAUM 220	10:46 (15.04.2021)			LOAD CURTAILMENT
635	16-Apr-21	BAGALKOT	220	BIDNAL-NAGJHARI2	STATON NOT AFFECTED BIDNAL 220	17:21 (15.04.2021)	14:19 (16.04.2021)	20:58 hrs	LINE CHARGED
636	16-Apr-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG 220	10:48 (16.12.2020)			LINE OPEN: LINE CLEAR AVAILED
637	16-Apr-21	BAGALKOT	220	HUBLI-NAGAJHARI3	STATION NOT AFFECTED HUBLI 220	12:38	14:17	1:39	LINE CLEAR AVAILED
638	16-Apr-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR 220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
639	16-Apr-21	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	STATION NOT AFFECTED MAHALINGAPUR 220	9:38 (09.04.2021)			LOAD CURTAILMENT
640	16-Apr-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA 220	17:22 (30.03.2021)			LINE OPEN: LINE FAULT
641	16-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI 220	17:31 (10.04.2021)			LOAD CURTAILMENT
642	16-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI 220	18:08 (06.03.2021)			LOAD CURTAILMENT
643	16-Apr-21	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI 220	14:26	14:39	0:13	HAND TRIPPED
644	16-Apr-21	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI 220	16:35 (11.04.2021)			LINE OPEN: LINE FAULT
645	16-Apr-21	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI 220	16:17 (23.02.2021)			LINE OPEN: LINE FAULT
646	16-Apr-21	BAGALKOT	220	VAJRAMATTI -MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI 220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
647	16-Apr-21	BENGALURU	66	DB PURA 220 - D CROSS	D CROSS	17:32	17:38	0:06	MAIN SUPPLY FAILURE
648	16-Apr-21	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	6:26	6:38	0:11	LINE FAULT
649	16-Apr-21	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	17:32	17:38	0:06	MAIN SUPPLY FAILURE
650	16-Apr-21	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	17:32	17:38	0:06	MAIN SUPPLY FAILURE
651	16-Apr-21	BENGALURU	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSURU RAMAPURA, NITRALLI	12:35	13:55	1:20	MAIN SUPPLY FAILURE
652	16-Apr-21	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	KODIGENAHALLI, ID HALLI	12:35	13:55	1:20	MAIN SUPPLY FAILURE
653	16-Apr-21	BENGALURU	66	GOWRIBIDANUR 220 - MANCHENAHALLI	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE, ACC (EHT)	8:53	9:00	0:07	LINE FAULT
654	16-Apr-21	BENGALURU	66	HV1	HOSKOTE 66	12:58	13:15	0:16	LINE CLEAR AVAILED
655	16-Apr-21	BENGALURU	66	HV1	BANGARPET	10:47	10:59	0:12	TRANSFORMER FAULT
656	16-Apr-21	BENGALURU	66	HV1	TK HALLI 220	11:05	11:07	0:02	TRANSFORMER FAULT
657	16-Apr-21	BENGALURU	66	HV1	JIGANI 220	9:30	9:58	0:28	TRANSFORMER FAULT
658	16-Apr-21	BENGALURU	66	HV1	JIGANI 220	11:33	11:44	0:11	LOAD CHANGEVER
659	16-Apr-21	BENGALURU	66	HV1	JIGANI 220	15:05	15:34	0:29	LOAD CHANGEVER
660	16-Apr-21	BENGALURU	66	HV1	CHAKAVELU	8:25	8:36	0:11	LINE CLEAR AVAILED
661	16-Apr-21	BENGALURU	66	HV1	JAYANAGARA	11:02	11:09	0:07	LINE CLEAR AVAILED
662	16-Apr-21	BENGALURU	66	HV2	THIMMAMPALLI	12:16	12:58	0:42	LINE CLEAR AVAILED
663	16-Apr-21	BENGALURU	66	HV2	HOSKOTE 66	12:59	13:15	0:16	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
664	16-Apr-21	BENGALURU	66	HV2	TK HALLI 220	10:49	10:53	0:03	LINE CLEAR AVAILED
665	16-Apr-21	BENGALURU	66	HV2	JIGANI 220	11:33	11:44	0:11	LOAD CHANGEVER
666	16-Apr-21	BENGALURU	66	HV2	JIGANI 220	15:05	15:34	0:29	LOAD CHANGEVER
667	16-Apr-21	BENGALURU	66	HV2	BTM 4TH PHASE	15:29	15:34	0:05	TRANSFORMER FAULT
668	16-Apr-21	BENGALURU	66	HV2	JAYANAGARA	15:27	15:29	0:02	LINE CLEAR AVAILED
669	16-Apr-21	BENGALURU	66	HV3	HOSKOTE 66	2:00	2:05	0:05	TRANSFORMER FAULT
670	16-Apr-21	BENGALURU	66	JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI, BAGGANADODDI	11:33	11:44	0:11	LOAD CHANGEVER
671	16-Apr-21	BENGALURU	66	JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI, BAGGANADODDI	15:05	15:34	0:29	LOAD CHANGEVER
672	16-Apr-21	BENGALURU	66	JIGANI 66 - JIGANI 220	JIGANI 66	11:33	11:44	0:11	LOAD CHANGEVER
673	16-Apr-21	BENGALURU	66	JIGANI 66 - JIGANI 220	JIGANI 66	15:05	15:34	0:29	LOAD CHANGEVER
674	16-Apr-21	BENGALURU	66	KORMANGALA 220 - K & C VALLEY	K & C VALLEY, NAL (EHT)	12:55	13:40	0:45	LINE CLEAR AVAILED
675	16-Apr-21	BENGALURU	66	MEI LAYOUT - WIDIA	WIDIA,WIDIA(EHT)	6:00	6:38	0:38	LINE FAULT
676	16-Apr-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	18:09	18:14	0:05	LOAD CHANGEVER
677	16-Apr-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	18:09	18:14	0:05	LOAD CHANGEVER
678	16-Apr-21	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	18:09	18:14	0:05	LOAD CHANGEVER
679	16-Apr-21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELUR, CHAKAVELU, YENIGADALE	18:09	18:14	0:05	LOAD CHANGEVER
680	16-Apr-21	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	11:32	11:42	0:09	LINE FAULT
681	16-Apr-21	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	12:50	13:17	0:27	LINE FAULT
682	16-Apr-21	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT)	16:51	17:00	0:09	LINE FAULT
683	16-Apr-21	BENGALURU	66	YERANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	15:09	15:16	0:07	LOAD CHANGEVER
684	16-Apr-21	BENGALURU	66	YERANDANAHALLI 220 - ANEKAL 2	ANEKAL, ATTIBELE	15:09	15:16	0:07	LOAD CHANGEVER
685	16-Apr-21	BENGALURU	66	YERANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A, SYNGENE(EHT)	15:09	15:16	0:07	LOAD CHANGEVER
686	16-Apr-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN: LINE FAULT
687	16-Apr-21	BENGALURU	220	HV1	JIGANI 220	11:33	11:44	0:11	LOAD CHANGEVER
688	16-Apr-21	BENGALURU	220	HV1	JIGANI 220	15:05	15:34	0:29	LOAD CHANGEVER
689	16-Apr-21	BENGALURU	220	HV1	DB PURA 220	17:32	17:38	0:06	LINE CLEAR AVAILED
690	16-Apr-21	BENGALURU	220	HV2	JIGANI 220	11:33	11:44	0:11	LOAD CHANGEVER
691	16-Apr-21	BENGALURU	220	HV2	JIGANI 220	15:05	15:34	0:29	LOAD CHANGEVER
692	16-Apr-21	BENGALURU	220	HV3	GOWRIBIDANUR 220	12:35	13:55	1:20	LINE CLEAR AVAILED
693	16-Apr-21	GULBARGA	66	HV2	TAMBRAHALLI_66	11:00	11:15	0:15	LINE CLEAR AVAILED
694	16-Apr-21	GULBARGA	110	GULBARGA UNIVERSITY-SHAHABAD1	GULBARGA UNIVERSITY_110	8:30(9.04.2021)	22:45(16.04.2021)	206:15 hrs	LINE CHARGED
695	16-Apr-21	GULBARGA	110	HV1	KOLHAR_110	15:45	16:30	0:45	LINE CLEAR AVAILED
696	16-Apr-21	GULBARGA	110	HV1	KOLHAR_110	17:25	18:30	1:05	LINE CLEAR AVAILED
697	16-Apr-21	GULBARGA	110	HV1	KURKUNTA_110	18:55	19:35	0:40	TRANSFORMER FAULT
698	16-Apr-21	GULBARGA	110	HV2	BISIHALLI_110	11:16	11:21	0:05	TRANSFORMER FAULT
699	16-Apr-21	GULBARGA	110	HV2	KOLHAR_110	12:00	13:10	1:10	LINE CLEAR AVAILED
700	16-Apr-21	GULBARGA	110	HV2	KOLHAR_110	16:35	17:20	0:45	LINE CLEAR AVAILED
701	16-Apr-21	GULBARGA	110	HV3	SINDHANOOR_110	12:25	12:45	0:20	LINE CLEAR AVAILED
702	16-Apr-21	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110,MANVI_110	0:01	0:06	0:05	LINE FAULT
703	16-Apr-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	19:53	19:55	0:02	LINE FAULT
704	16-Apr-21	GULBARGA	110	SINDHANOOR-PGLR_WIND	SINDHANOOR_220	2:54	3:09	0:15	LINE FAULT
705	16-Apr-21	GULBARGA	110	SINDHANOOR-PGLR_WIND	SINDHANOOR_220	12:33	13:03	0:30	LINE FAULT
706	16-Apr-21	GULBARGA	110	SINDHANOOR-PGLR_WIND	SINDHANOOR_220	13:08	13:28	0:20	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
707	16-Apr-21	GULBARGA	220	KUSHTAGI-LINGAPUR	KUSHTAGI_220	15:30(15.04.2021)	13:19(16.04.2021)	21:49 hrs	LINE CHARGED
708	16-Apr-21	GULBARGA	220	KUSHTAGI-LINGAPUR	KUSHTAGI_220	13:32	14:44	1:12	LINE FAULT
709	16-Apr-21	GULBARGA	220	LINGAPUR-BMM	LINGAPUR_220	13:30	16:54	3:24	LINE FAULT
710	16-Apr-21	GULBARGA	220	LINGASUGUR-RTPS1	BAGEWADI_220	9:45	13:15	3:30	LINE CLEAR AVAILED
711	16-Apr-21	GULBARGA	400	BTPS-GUTTUR	GUTTUR_400	15:36(15.04.2021)	11:31(16.04.2021)	19:55 hrs	LINE CHARGED
712	16-Apr-21	HASSAN	66	BHADRA-SHMG 1	bhadra_gen	23:38	23:54	0:16	LINE FAULT
713	16-Apr-21	HASSAN	66	HASSN22-HN PURA	HASSAN_220	6:29	7:09	0:40	LINE FAULT
714	16-Apr-21	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	21:33	21:44	0:11	LINE FAULT
715	16-Apr-21	HASSAN	66	HV1	BANDISHETTIHALLY_66	11:26	12:45	1:19	LINE CLEAR AVAILED
716	16-Apr-21	HASSAN	66	HV1	BANDISHETTIHALLY_66	14:13	15:06	0:53	LINE CLEAR AVAILED
717	16-Apr-21	HASSAN	66	HV1	BYACHANAHALLY_66	17:07	17:23	0:16	LINE CLEAR AVAILED
718	16-Apr-21	HASSAN	66	HV1	SIGEBAGE_66	15:43	16:11	0:28	LINE CLEAR AVAILED
719	16-Apr-21	HASSAN	66	HV1	SOMANAHALLY_66	17:15	17:21	0:06	HAND TRIPPED
720	16-Apr-21	HASSAN	66	HV2	HOLEHONNUR_66	11:18	11:54	0:36	LINE CLEAR AVAILED
721	16-Apr-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
722	16-Apr-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
723	16-Apr-21	HASSAN	66	MRSSHM-BD-1	MTSMG_220	23:37	23:49	0:12	LINE FAULT
724	16-Apr-21	HASSAN	66	SAKALE-IIPCL2	SAKLESH PURA_66	18:30	19:10	0:40	LINE FAULT
725	16-Apr-21	HASSAN	66	SAKALE-IIPCL2	SAKLESH PURA_66	19:10	20:25	1:15	LINE FAULT
726	16-Apr-21	HASSAN	66	SAKALE-IIPCL2	SAKLESH PURA_66	21:06	21:12	0:06	HAND TRIPPED
727	16-Apr-21	HASSAN	66	SAKALE-IIPCL2	SAKLESH PURA_66	21:15	21:25	0:10	HAND TRIPPED
728	16-Apr-21	HASSAN	66	SAKALE-IIPCL2	SAKLESH PURA_66	21:25	21:47	0:22	LINE FAULT
729	16-Apr-21	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	8:50(12.4.2021)			LINE OPEN: LINE CLEAR AVAILED
730	16-Apr-21	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	9:03	18:30	9:27	LINE CLEAR AVAILED
731	16-Apr-21	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	15:43	16:11	0:28	LINE CLEAR AVAILED
732	16-Apr-21	HASSAN	66	SIGEBAG-SMG-DVG2	SIGEBAGE_66	15:43	16:11	0:28	LINE CLEAR AVAILED
733	16-Apr-21	HASSAN	66	TAVAREC-HONNALI	TAVARECHATNAHALLY_66	13:11	13:21	0:10	LINE FAULT
734	16-Apr-21	HASSAN	110	HV1	BARANGI_110	10:05	17:01	6:56	LINE CLEAR AVAILED
735	16-Apr-21	HASSAN	110	HV1	SHIKARIPURA_110	22:29	22:44	0:15	TRANSFORMER FAULT
736	16-Apr-21	HASSAN	110	HV2	PUTTUR_110	20:50(15.4.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
737	16-Apr-21	HASSAN	110	HV2	GURUVAYANAKERE_110	16:22	17:34	1:12	LINE CLEAR AVAILED
738	16-Apr-21	HASSAN	110	HV3	HIRIYADKA_110	9:11	9:23	0:12	TRANSFORMER FAULT
739	16-Apr-21	HASSAN	110	JOG110-AMBTR1	JOG_110	10:15(15.04.2021)			LINE OPEN: LINE CLEAR AVAILED
740	16-Apr-21	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	21:15(11.4.2021)			LINE OPEN: LINE FAULT
741	16-Apr-21	HASSAN	220	KADUR-SHIMOGA	KADUR_220	16:17	18:35	2:18	NFCB ISSUED
742	16-Apr-21	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	16:17	18:35	2:18	LINE CLEAR AVAILED
743	16-Apr-21	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	10:11	13:46	3:35	LINE CLEAR AVAILED
744	16-Apr-21	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	13:56(15.04.2021)	11:05(16.4.2021)	21:09hrs	LINE CHARGED
745	16-Apr-21	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	11:34	18:40	7:06	LINE FAULT
746	16-Apr-21	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	13:56(15.04.2021)	11:05(16.4.2021)	21:09hrs	LINE CHARGED
747	16-Apr-21	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	11:34	18:40	7:06	LINE FAULT
748	16-Apr-21	MYSURU	66	BANNIMANTAP-FTS	NO STATIONS EFFECTED	11:43 (12/04/2021)	16:01 (16/04/2021)	100:18 hrs	LINE CHARGED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
749	16-Apr-21	MYSURU	66	HANNUR-AMP SOLAR	NO STATIONS EFFECTED	8:43	10:00	1:17	LINE CLEAR AVAIED
750	16-Apr-21	MYSURU	66	HANNUR-AMP SOLAR	NO STATIONS EFFECTED	11:40	12:30	0:49	HAND TRIPPED
751	16-Apr-21	MYSURU	66	HV1	DMG_HALLI_66	12:09	14:08	1:59	LINE CLEAR AVAIED
752	16-Apr-21	MYSURU	66	HV1	DODDABYADARAHALLI_66	10:44	12:13	1:28	LINE CLEAR AVAIED
753	16-Apr-21	MYSURU	66	HV1	HANNUR_66	11:28	13:14	1:46	LINE CLEAR AVAIED
754	16-Apr-21	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN: LINE CLEAR AVAIED
755	16-Apr-21	MYSURU	66	HV2	AKKIHEBBAL_66	19:25	19:45	0:20	TRANSFORMER FAULT
756	16-Apr-21	MYSURU	66	HV2	AKKIHEBBAL_66	20:20	20:30	0:10	TRANSFORMER FAULT
757	16-Apr-21	MYSURU	66	HV2	ELAVALA_66	11:16	12:59	1:43	LINE CLEAR AVAIED
758	16-Apr-21	MYSURU	66	HV2	HDKOTE_66	11:02	14:44	3:42	LINE CLEAR AVAIED
759	16-Apr-21	MYSURU	66	HV2	JYOTHINAGARA_66	14:05	14:33	0:27	LINE CLEAR AVAIED
760	16-Apr-21	MYSURU	66	HV5	SFCSHIVA_66	8:19 (4/4/2021)			TRANSFORMER OPEN: LINE CLEAR AVAIED
761	16-Apr-21	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)	13:40 (16/04/2021)	2089:57 hrs	LINE CHARGED
762	16-Apr-21	MYSURU	66	KR NAGARA-BILIKERE	KRNAGARA_66	12:09	13:47	1:37	LINE CLEAR AVAIED
763	16-Apr-21	MYSURU	66	KR NAGARA-CHUNCHANAKATTE	KRNAGARA_66	12:09	13:39	1:30	LINE CLEAR AVAIED
764	16-Apr-21	MYSURU	66	KUSHALNAGARA 220-HARANGI	NO STATIONS EFFECTED	17:39	17:51	0:11	LINE FAULT
765	16-Apr-21	MYSURU	66	KUSHALNAGARA 220-MERCERA-1	MADIKERI_66	18:39	18:50	0:10	LINE FAULT
766	16-Apr-21	MYSURU	66	KUSHALNAGARA 220-SUNTIKOPPA	NO STATIONS EFFECTED	22:32	22:59	0:27	LINE FAULT
767	16-Apr-21	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	10:41	10:47	0:05	LINE FAULT
768	16-Apr-21	MYSURU	66	PERIYAPATNA-HANGODU	HANAGODU_66 PONNAMPET_66 VIRAJPET_66	22:54	23:05	0:10	LINE FAULT
769	16-Apr-21	MYSURU	66	VAJMANGALA-MEGHALAPURA	NO STATIONS EFFECTED	11:52	11:58	0:06	LINE FAULT
770	16-Apr-21	TUMKUR	66	GULIGENAHALLI- SIRA2	SIRA_66	5:18	5:31	0:12	LINE FAULT
771	16-Apr-21	TUMKUR	66	HANAGAL-THALLAK	HANAGAL_66	5:38	5:56	0:17	LINE FAULT
772	16-Apr-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	13:03	14:07	1:03	LINE CLEAR AVAIED
773	16-Apr-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	15:50	16:05	0:14	LINE CLEAR AVAIED
774	16-Apr-21	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	15:37	15:50	0:13	LINE FAULT
775	16-Apr-21	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	11:00	11:09	0:09	LINE FAULT
776	16-Apr-21	TUMKUR	66	PAVAGADA-MIDIGESHI	MEDIGESHI_66	16:27	16:41	0:13	LINE FAULT
777	16-Apr-21	TUMKUR	66	THALLAK 220kv -BGKERE 1	BGKERE_66, HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	5:38	5:55	0:17	LINE FAULT
778	16-Apr-21	TUMKUR	66	TR-1	SANTEMNAVATTUR_66	16:47	18:45	1:58	LINE CLEAR AVAIED
779	16-Apr-21	TUMKUR	66	TR-1	HAGALWADI_66	20:09	20:12	0:02	LINE CLEAR AVAIED
780	16-Apr-21	TUMKUR	66	TR-2	BADDIHALLI_66	15:28	20:28	4:59	LINE CLEAR AVAIED
781	16-Apr-21	TUMKUR	66	TR-2	SHYLAURA_66	9:23	9:37	0:13	TRANSFORMER FAULT
782	16-Apr-21	TUMKUR	66	TR-3	HARIYABBE_66	18:02	18:06	0:04	TRANSFORMER FAULT
783	16-Apr-21	TUMKUR	110	TR-1	SHETYKERE_110	10:19	10:44	0:25	LINE CLEAR AVAIED
784	16-Apr-21	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	10:03	17:17	7:13	LINE CLEAR AVAIED
785	17-Apr-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAIED
786	17-Apr-21	BAGALKOT	110	110/11KV ,HV2	AIGALI_110	13:00	13:16	0:16	TRANSFORMER FAULT
787	17-Apr-21	BAGALKOT	110	110/11KV, HV4	VADAGOAN_110	1:06	2:10	1:04	LINE CLEAR AVAIED
788	17-Apr-21	BAGALKOT	110	AMBEWADI(SIRSI)-KIRUVATTI	STATON NOT AFFECTED KIRUVATTI_110	16:46 (16.04.2021)			LINE OPEN: LINE CLEAR AVAIED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
789	17-Apr-21	BAGALKOT	110	AMBEWADI-NK2	HALIYAL_110	15:57	17:31	1:34	LINE CLEAR AVAILED
790	17-Apr-21	BAGALKOT	110	BAGALKOT-GULEDGUDD	GULEDGUDD_110	17:29	18:31	1:02	LINE FAULT
791	17-Apr-21	BAGALKOT	110	BAGALKOT-KERUR	KERUR_110	17:29	18:34	1:05	LINE FAULT
792	17-Apr-21	BAGALKOT	110	BAGALKOT-NAVANAGAR1	NAVANAGAR_110	17:29	17:30	0:01	LINE FAULT
793	17-Apr-21	BAGALKOT	110	BAGALKOT-NEERBUDIHAL	NEERBUDIHAL_110	16:33	17:29	0:56	LINE FAULT
794	17-Apr-21	BAGALKOT	110	BAGEWADI-MAMADAPUR1	MAMADAPUR_110	16:51	17:13	0:22	HAND TRIPPED
795	17-Apr-21	BAGALKOT	110	BAGEWADI-MUDEDEBIHAL	MUDEDEBIHAL_110	16:50	17:12	0:22	HAND TRIPPED
796	17-Apr-21	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	16:50	17:12	0:22	HAND TRIPPED
797	17-Apr-21	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN: LINE CLEAR AVAILED
798	17-Apr-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	16:18 (11.04.2021)			LINE OPEN: LINE CLEAR AVAILED
799	17-Apr-21	BAGALKOT	110	GAMESHA- RON	RON_110	18:50	19:01	0:11	HAND TRIPPED
800	17-Apr-21	BAGALKOT	110	GMNAVAR- SALAHALLI	STATION NOT AFFECTED SALAHALLI_110	10:03	17:53	7:50	LINE CLEAR AVAILED
801	17-Apr-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
802	17-Apr-21	BAGALKOT	110	HIRA SUGAR FACTORY1- SANKESHWAR	STATION NOT AFFECTED SANKESHWAR_110	11:36	15:46	4:10	LINE CLEAR AVAILED
803	17-Apr-21	BAGALKOT	110	HIREHAL-MFR SOLAR	HIREHAL_110	13:29	14:24	0:55	HAND TRIPPED
804	17-Apr-21	BAGALKOT	110	KADANKOPPA-KAVALWADA	STATON NOT AFFECTED KADANKOPPA_110	17:09 (15.04.2021)			LINE OPEN: LINE FAULT
805	17-Apr-21	BAGALKOT	110	KERUR- BADAMI	KERUR_110	16:41	18:38	1:57	LINE CLEAR AVAILED
806	17-Apr-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
807	17-Apr-21	BAGALKOT	110	KUMATA-SIRSI 1	STATION NOT AFFECTED KUMATA_110	12:22 (12.04.2021)			LINE OPEN: LINE CLEAR AVAILED
808	17-Apr-21	BAGALKOT	110	MACHE- UDYAMBAG	STATION NOT AFFECTED MACHE_110	8:11 (12.04.2021)			LINE OPEN: LINE CLEAR AVAILED
809	17-Apr-21	BAGALKOT	110	MAHALINGAPUR- RABKAVI	RABKAVI_110	16:29	16:41	0:12	HAND TRIPPED
810	17-Apr-21	BAGALKOT	110	MAHALINGAPUR- TERDAL	TERDAL_110	16:18	16:51	0:33	HAND TRIPPED
811	17-Apr-21	BAGALKOT	110	MATRIX WIND- MUKARTIHAL	MUKARTIHAL_110	14:10	14:32	0:22	HAND TRIPPED
812	17-Apr-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
813	17-Apr-21	BAGALKOT	110	RON- GAJENDRAGAD1&2	GAJENDRAGAD_110	18:50	19:01	0:11	HAND TRIPPED
814	17-Apr-21	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:57 (05.03.2021)			LINE OPEN: LINE CLEAR AVAILED
815	17-Apr-21	BAGALKOT	110	SPV SOLAR- MUKARTIHAL	MUKARTIHAL_110	14:10	14:32	0:22	HAND TRIPPED
816	17-Apr-21	BAGALKOT	110	TARIHAL-KIADB GAMANGATTI	STATION NOT AFFECTED TARIHAL_110	12:11 (15.04.2021)			LINE OPEN: LINE CLEAR AVAILED
817	17-Apr-21	BAGALKOT	110	TUMMINKATTI- RATTIHALI	STATION NOT AFFECTED TUMMINKATTI_110	0:56	1:21	0:25	LINE FAULT
818	17-Apr-21	BAGALKOT	110	VAJRAMATTI220- KATARKI	KATARKI_110	17:06	17:39	0:33	HAND TRIPPED
819	17-Apr-21	BAGALKOT	110	VAJRAMATTI220- MANTUR1&2	VAJRAMATTI_220	16:53	17:57	1:04	LINE CLEAR AVAILED
820	17-Apr-21	BAGALKOT	110	VAJRAMATTI220-BILAGI	BILAGI_110	16:53	17:51	0:58	HAND TRIPPED
821	17-Apr-21	BAGALKOT	220	220/110KV, HV1&LV1	VAJRAMATTI_220	17:19	17:25	0:06	HAND TRIPPED
822	17-Apr-21	BAGALKOT	220	220/110KV, HV2&LV2	VAJRAMATTI_220	17:19	17:26	0:07	HAND TRIPPED
823	17-Apr-21	BAGALKOT	220	AMBEWADI-PONDA1	AMBEWADI_220	10:05	13:31	3:26	LINE CLEAR AVAILED
824	17-Apr-21	BAGALKOT	220	AMBEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI_220	14:09 (14.04.2021)	16:29 (17.04.2021)	74:20 hrs	LINE CHARGED
825	17-Apr-21	BAGALKOT	220	BAGALKOT-GADAG1	BAGALKOT_220	11:51	18:26	6:35	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
826	17-Apr-21	BAGALKOT	220	BAGALKOT-GADAG2	BAGALKOT_220	12:37	18:26	5:49	LINE CLEAR AVAILED
827	17-Apr-21	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	BAGALKOT_220	12:20	18:25	6:05	LINE CLEAR AVAILED
828	17-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI1	STATON NOT AFFECTED BELGAUM_220	10:46 (15.04.2021)			LOAD CURTAILMENT
829	17-Apr-21	BAGALKOT	220	BIDNAL-HIREBENDIGERI1&2	BIDNAL_220	8:27	15:28	7:01	NFBC ISSUED
830	17-Apr-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN: LINE CLEAR AVAILED
831	17-Apr-21	BAGALKOT	220	HUBLI- NARENDRA2	STATION NOT AFFECTED HUBLI_220	12:06	16:42	4:36	LINE FAULT
832	17-Apr-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
833	17-Apr-21	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	STATION NOT AFFECTED MAHALINGAPUR_220	9:38 (09.04.2021)			LOAD CURTAILMENT
834	17-Apr-21	BAGALKOT	220	NARENDRA- HUBLI2	STATION NOT AFFECTED NARENDRA_220	12:06	16:40	4:34	LINE FAULT
835	17-Apr-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN: LINE FAULT
836	17-Apr-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	13:44	13:53	0:09	HAND TRIPPED
837	17-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	17:31 (10.04.2021)			LOAD CURTAILMENT
838	17-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)			LOAD CURTAILMENT
839	17-Apr-21	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI_220	16:35 (11.04.2021)			LINE OPEN: LINE FAULT
840	17-Apr-21	BAGALKOT	220	VAJRAMATTI- BAGALKOT1	VAJRAMATTI_220	12:22	18:25	6:03	LINE CLEAR AVAILED
841	17-Apr-21	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN: LINE FAULT
842	17-Apr-21	BAGALKOT	220	VAJRAMATTI -MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
843	17-Apr-21	BENGALURU	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA	6:41	6:47	0:06	LINE CLEAR AVAILED
844	17-Apr-21	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	13:42	13:52	0:10	LINE FAULT
845	17-Apr-21	BENGALURU	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSURU RAMAPURA, NITRALLI	14:10	14:23	0:13	LOAD CHANGEOVER
846	17-Apr-21	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	KODIGENAHALLI, ID HALLI	14:10	14:23	0:13	LOAD CHANGEOVER
847	17-Apr-21	BENGALURU	66	GOWRIBIDANUR 220 - MANCHENAHALLI	MANCHENAHALLI, THONDEBHAVI	5:55	6:13	0:18	LINE FAULT
848	17-Apr-21	BENGALURU	66	GOWRIBIDANUR 220 - MANCHENAHALLI	MANCHENAHALLI, THONDEBHAVI	11:09	11:20	0:11	LINE FAULT
849	17-Apr-21	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKALLU, D PALYA, GUDIBANDE	14:10	14:23	0:13	LOAD CHANGEOVER
850	17-Apr-21	BENGALURU	66	HV1	AMARJYOTHI	13:30	13:40	0:10	LINE CLEAR AVAILED
851	17-Apr-21	BENGALURU	66	HV1	MAASTHI	14:42	16:45	2:03	LINE CLEAR AVAILED
852	17-Apr-21	BENGALURU	66	HV1	KAMASAMUDRA	10:59	12:18	1:18	LINE CLEAR AVAILED
853	17-Apr-21	BENGALURU	66	HV1	GOWRIBIDANUR 220	21:46	22:00	0:14	TRANSFORMER FAULT
854	17-Apr-21	BENGALURU	66	HV1	BANGARPET	16:15	16:25	0:10	TRANSFORMER FAULT
855	17-Apr-21	BENGALURU	66	HV2	AMARJYOTHI	10:15	10:25	0:10	LINE CLEAR AVAILED
856	17-Apr-21	BENGALURU	66	HV2	BYADRAHALLI	12:18	12:45	0:27	TRANSFORMER FAULT
857	17-Apr-21	BENGALURU	66	HV2	KAMASAMUDRA	10:59	12:18	1:18	LINE CLEAR AVAILED
858	17-Apr-21	BENGALURU	66	HV2	BANGARPET	23:00(17-4-2021)			TRANSFORMER OPEN: TRANSFORMER FAULT



SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
859	17-Apr-21	BENGALURU	66	HV3	YARANDANAHALLI 220	10:38	10:49	0:11	LOAD CHANGEOVER
860	17-Apr-21	BENGALURU	66	JAGAMKOTE - VIJAYPURA	JAGAMKOTE	15:14	17:30	2:16	LINE CLEAR AVAILED
861	17-Apr-21	BENGALURU	66	KAMASAMUDRA - KGF	KAMASAMUDRA	10:59	12:18	1:18	LINE CLEAR AVAILED
862	17-Apr-21	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	11:15	11:25	0:10	LINE FAULT
863	17-Apr-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN: LINE FAULT
864	17-Apr-21	BENGALURU	220	GOWRIBIDANUR 220 - RAILWAY TRACTION 2	NO STATION AFFECTED	14:48	15:25	0:37	LINE CLEAR AVAILED
865	17-Apr-21	BENGALURU	220	HV3	GOWRIBIDANUR 220	14:25	15:48	1:23	LINE CLEAR AVAILED
866	17-Apr-21	GULBARGA	110	CHINCHOLI-RENEW SOLAR	CHINCHOLI_110	18:55	21:55	3:00	LINE CLEAR AVAILED
867	17-Apr-21	GULBARGA	110	HALBARGA-CHIDRI2	CHIDRI_110	5:15	5:22	0:07	LINE FAULT
868	17-Apr-21	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110	16:30	16:47	0:17	MAIN SUPPLY FAILURE
869	17-Apr-21	GULBARGA	110	HATTI-SINDHANOOR	HATTI_110	18:16	18:18	0:02	MAIN SUPPLY FAILURE
870	17-Apr-21	GULBARGA	110	HV1	NIRNA_110	13:20	13:25	0:05	TRANSFORMER FAULT
871	17-Apr-21	GULBARGA	110	HV2	BISIHALLI_110	9:08	9:15	0:07	TRANSFORMER FAULT
872	17-Apr-21	GULBARGA	110	LINGASUGUR-CHAYADEVI_IPP	CHAYADEVI_IPP,KAREPOWER_IPP	16:34	17:07	0:33	LINE FAULT
873	17-Apr-21	GULBARGA	110	LINGASUGUR-GURGUNTA	GURGUNTA_110,KHEL_IPP,LJVL_IPP	16:34	17:04	0:30	LINE FAULT
874	17-Apr-21	GULBARGA	110	LINGASUGUR-HATTI	HATTI_110,MASKI_110,KAVITHAL_110,SOMANAMARDI_IPP,GAMESHA_IPP	16:34	16:51	0:17	LINE FAULT
875	17-Apr-21	GULBARGA	110	LINGASUGUR-KAREPOWER_IPP	CHAYADEVI_IPP,KAREPOWER_IPP	16:34	17:08	0:34	LINE FAULT
876	17-Apr-21	GULBARGA	110	LINGASUGUR-LATUR GAMESHA_IPP	HATTI_110	16:34	17:07	0:33	LINE FAULT
877	17-Apr-21	GULBARGA	110	LINGASUGUR-MUDGAL	MUDGAL_110	16:34	16:49	0:15	LINE FAULT
878	17-Apr-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	22:51	23:01	0:10	LINE FAULT
879	17-Apr-21	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	3:36	3:46	0:10	LINE FAULT
880	17-Apr-21	GULBARGA	110	NALWAR-SHAHAPUR	SHAHAPUR_110	11:13	12:07	0:54	LINE CLEAR AVAILED
881	17-Apr-21	GULBARGA	110	SINDHANOOR-SIRGUPPA	SIRAGUPPA_110	23:58(17.04.21)			LINE OPEN: LINE FAULT
882	17-Apr-21	GULBARGA	110	STAR METALLIC -MUNIRABAD	STAR METALLIC_IPP	12:50	13:12	0:22	LINE FAULT
883	17-Apr-21	GULBARGA	110	STAR METALLIC -MUNIRABAD	STAR METALLIC_IPP	19:10	19:28	0:18	LINE FAULT
884	17-Apr-21	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	12:20	12:55	0:35	MAIN SUPPLY FAILURE
885	17-Apr-21	GULBARGA	220	HV1	LINGASUGUR_220	16:34	17:19	0:45	TRANSFORMER FAULT
886	17-Apr-21	GULBARGA	220	HV2	LINGASUGUR_220	16:34	16:48	0:14	TRANSFORMER FAULT
887	17-Apr-21	GULBARGA	220	LINGAPUR-GADAG2	LINGAPUR_220	13:00	14:32	1:32	LINE FAULT
888	17-Apr-21	GULBARGA	220	LINGASUGUR-BAGEWADI1	BAGEWADI_220	16:34	17:10	0:36	LINE FAULT
889	17-Apr-21	GULBARGA	220	LINGASUGUR-BAGEWADI2	BAGEWADI_220	16:34	17:03	0:29	LINE FAULT
890	17-Apr-21	GULBARGA	220	LINGASUGUR-KUSTAGI	KUSTAGI_220	16:34	17:06	0:32	LINE FAULT
891	17-Apr-21	GULBARGA	220	LINGASUGUR-MALLAT	MALLAT_220	16:34	16:50	0:16	LINE FAULT
892	17-Apr-21	GULBARGA	220	LINGASUGUR-RTPS1	BAGEWADI_220	16:34	16:45	0:11	LINE FAULT
893	17-Apr-21	GULBARGA	220	LINGASUGUR-SHAHAPUR	SHAHAPUR_110	16:34	16:56	0:22	LINE FAULT
894	17-Apr-21	GULBARGA	220	LINGASUGUR-SINDANOOR	SINDHANOOR_220	16:34	16:52	0:18	LINE FAULT
895	17-Apr-21	HASSAN	66	HANUBAL-SAKLESPUR	HANBALU_66	11:30	15:00	3:30	MAIN SUPPLY FAILURE
896	17-Apr-21	HASSAN	66	HNPR2--HASS3	HOLENARASIPURA_220	20:08	20:23	0:15	HAND TRIPPED
897	17-Apr-21	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	8:20	8:30	0:10	LINE FAULT
898	17-Apr-21	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	16:24	17:03	0:39	LINE CLEAR AVAILED
899	17-Apr-21	HASSAN	66	HV1	HANBALU_66	11:30	15:00	3:30	MAIN SUPPLY FAILURE
900	17-Apr-21	HASSAN	66	HV1	MOSALEHOSAHALLI_66	12:50	13:10	0:20	MAIN SUPPLY FAILURE

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
901	17-Apr-21	HASSAN	66	HV1	MOSALEHOSAHALLI_66	20:13	20:26	0:13	HAND TRIPPED
902	17-Apr-21	HASSAN	66	HV1	MOSALEHOSAHALLI_66	20:28	20:32	0:04	HAND TRIPPED
903	17-Apr-21	HASSAN	66	HV1	SOMANAHALLI_66	10:15	10:18	0:03	LINE CLEAR AVAILED
904	17-Apr-21	HASSAN	66	HV2	HALLIMYSORE_66	8:20	8:30	0:10	MAIN SUPPLY FAILURE
905	17-Apr-21	HASSAN	66	HV2	RAMNATHPURA_66	10:06	17:27	7:21	LINE CLEAR AVAILED
906	17-Apr-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
907	17-Apr-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
908	17-Apr-21	HASSAN	66	MOSALEH-BIOMASS	MOSALEHOSAHALLI_66	20:15	20:32	0:17	HAND TRIPPED
909	17-Apr-21	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSAHALLI_66	12:45	20:22	7:37	MAIN SUPPLY FAILURE
910	17-Apr-21	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSAHALLI_66	20:30	20:40	0:10	HAND TRIPPED
911	17-Apr-21	HASSAN	66	MRSSHM-DVG1	MRSMSG_220	15:54	15:59	0:05	LINE FAULT
912	17-Apr-21	HASSAN	66	MRSSHM-DVG1	MRSMSG_220	16:54	17:04	0:10	LINE FAULT
913	17-Apr-21	HASSAN	66	RAMNAT-KADVINKOTE	RAMNATHPURA_66	10:06	17:27	7:21	LINE CLEAR AVAILED
914	17-Apr-21	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	10:06	17:27	7:21	LINE CLEAR AVAILED
915	17-Apr-21	HASSAN	66	RAMNAT-KUSALNAGARA	RAMNATHPURA_66	10:06	17:27	7:21	LINE CLEAR AVAILED
916	17-Apr-21	HASSAN	66	SAKALE-HANBAL	SAKLESHPURA_66	11:32	15:00	3:28	LINE CLEAR AVAILED
917	17-Apr-21	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	8:50(12.4.2021)			LINE OPEN: LINE CLEAR AVAILED
918	17-Apr-21	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	9:14	22:17	13:03	LINE CLEAR AVAILED
919	17-Apr-21	HASSAN	110	ANANDA-SHIMOGA	ANANDAPURA_110	10:12	11:15	1:03	LINE CLEAR AVAILED
920	17-Apr-21	HASSAN	110	ANAVATI-JADE	ANAVATTI_110	7:00	10:22	3:22	LINE CLEAR AVAILED
921	17-Apr-21	HASSAN	110	HITIYA-MANIPAL	HIRIYADKA_110	9:10	14:44	5:34	LINE CLEAR AVAILED
922	17-Apr-21	HASSAN	110	HV1	ESSUR_110	16:07	16:35	0:28	LINE CLEAR AVAILED
923	17-Apr-21	HASSAN	110	HV2	PUTTUR_110	20:50(15.4.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
924	17-Apr-21	HASSAN	110	HV2	KADUR_220	16:15	16:46	0:31	HAND TRIPPED
925	17-Apr-21	HASSAN	110	HV2	MSEZ_220	12:35	12:45	0:10	TRANSFORMER FAULT
926	17-Apr-21	HASSAN	110	HV3	GURUVAYANAKERE_110	10:03	14:31	4:28	LINE CLEAR AVAILED
927	17-Apr-21	HASSAN	110	JOG110-AMBTR1	JOG_110	10:15 (15.04.2021)	11:33 (17.04.2021)	49:21 hrs	LINE CHARGED
928	17-Apr-21	HASSAN	110	JOG110-AMBTR2	JOG_110	11:35	12:04	0:29	LINE CLEAR AVAILED
929	17-Apr-21	HASSAN	110	JOG110-MGHE	JOG_110	11:05	13:13	2:08	LINE CLEAR AVAILED
930	17-Apr-21	HASSAN	110	KADUR-AJAMPURA	KADUR_220	16:15	16:45	0:30	LINE FAULT
931	17-Apr-21	HASSAN	110	KADUR-NERELEKERE	KADUR_220	16:15	16:41	0:26	HAND TRIPPED
932	17-Apr-21	HASSAN	110	KADUR-NGNHL	KADUR_220	16:15	16:44	0:29	HAND TRIPPED
933	17-Apr-21	HASSAN	110	KADUR-TNGL	KADUR_220	16:15	16:44	0:29	HAND TRIPPED
934	17-Apr-21	HASSAN	110	KADUR-YGTI	KADUR_220	16:15	16:44	0:29	HAND TRIPPED
935	17-Apr-21	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	21:15(11.4.2021)			LINE OPEN: LINE FAULT
936	17-Apr-21	HASSAN	110	MRSSHM-SS2	MRSMSG_220	10:10	11:14	1:04	LINE CLEAR AVAILED
937	17-Apr-21	HASSAN	220	KADUR-SHIMOGA	KADUR_220	16:14	19:27	3:13	LINE FAULT
938	17-Apr-21	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	16:15	19:16	3:01	LINE FAULT
939	17-Apr-21	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	9:10	10:41	1:31	LINE CLEAR AVAILED
940	17-Apr-21	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	14:39	16:11	1:32	LINE CLEAR AVAILED
941	17-Apr-21	MYSURU	66	BG PURA-CHANDALLI	NO STATIONS EFFECTED	6:08	8:20	2:11	NFBC ISSUED
942	17-Apr-21	MYSURU	66	DEVNUR(N'GUD)-KADAKOLA	DEVANOORNGUDU_66 SUTTUR_66	5:26	5:33	0:06	LINE FAULT
943	17-Apr-21	MYSURU	66	HANNUR-AMP SOLAR	NO STATIONS EFFECTED	18:55	19:15	0:19	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
944	17-Apr-21	MYSURU	66	HV1	DODDABYADARAHALLI_66	11:30	13:51	2:21	LINE CLEAR AVOIDED
945	17-Apr-21	MYSURU	66	HV1	HADLI_66	15:14	15:35	0:20	LINE CLEAR AVOIDED
946	17-Apr-21	MYSURU	66	HV1	MYSORESOUTH_66	11:02	11:53	0:51	LINE CLEAR AVOIDED
947	17-Apr-21	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN: LINE CLEAR AVOIDED
948	17-Apr-21	MYSURU	66	HV2	AKKIHEBBAL_66	9:40	9:51	0:11	TRANSFORMER FAULT
949	17-Apr-21	MYSURU	66	HV2	AKKIHEBBAL_66	15:13	16:35	1:21	LINE CLEAR AVOIDED
950	17-Apr-21	MYSURU	66	HV5	SFCSHIVA_66	8:19 (4/4/2021)			TRANSFORMER OPEN: LINE CLEAR AVOIDED
951	17-Apr-21	MYSURU	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	6:02	6:08	0:05	LINE FAULT
952	17-Apr-21	MYSURU	66	TUBINKERE-MANDYA 2	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66	0:26	0:57	0:31	LINE FAULT
953	17-Apr-21	MYSURU	66	TUBINKERE-MANDYA 4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66	0:26	0:42	0:15	LINE FAULT
954	17-Apr-21	MYSURU	66	TUBINKERE-MANDYA 4	NO STATIONS EFFECTED	15:25	17:43	2:18	LINE CLEAR AVOIDED
955	17-Apr-21	MYSURU	66	TUBINKERE-NAGMANGALA 1	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BASARALI_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 KESLAGERE_66 VADERALLI_66	14:55	15:01	0:06	LINE FAULT
956	17-Apr-21	TUMKUR	66	BEVINAHALLI_66	TR-2	12:35	13:29	0:53	LINE CLEAR AVOIDED
957	17-Apr-21	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI TMK2_66	18:46	18:50	0:03	LINE FAULT
958	17-Apr-21	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR )	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	10:30	10:41	0:10	LINE FAULT
959	17-Apr-21	TUMKUR	66	KALAMARANAHALLI- BPCLSOLAR_IPP_66	BPCLSOLAR_IPP_66	16:42	16:52	0:09	LINE FAULT
960	17-Apr-21	TUMKUR	66	PAVAGADA-MADHUGIRI(PAVAGADA 220)	PAVAGADA_66	1:22	2:06	0:43	LINE FAULT
961	17-Apr-21	TUMKUR	66	PAVAGADA-MADHUGIRI(PAVAGADA 220)	PAVAGADA_66	6:04	6:06	0:01	LINE FAULT
962	17-Apr-21	TUMKUR	66	PAVAGADA-MADHUGIRI(PAVAGADA 220)	PAVAGADA_66	13:05	16:30	3:25	LINE CLEAR AVOIDED
963	17-Apr-21	TUMKUR	66	TR-2	HULIYURDURGA_66	21:28	21:39	0:10	TRANSFORMER FAULT
964	17-Apr-21	TUMKUR	66	TR-2	SASALUHALLA_66	16:02	16:04	0:02	TRANSFORMER FAULT
965	17-Apr-21	TUMKUR	66	TR-2	URDIGERE_66	8:28	8:53	0:25	LINE CLEAR AVOIDED
966	17-Apr-21	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	8:28	8:53	0:24	LINE CLEAR AVOIDED
967	17-Apr-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	3:01	9:44	6:43	LINE FAULT
968	17-Apr-21	TUMKUR	220	GUTUR_400-DAVANGERE SRS1	DAVANGERE_SRS_220	3:02	9:42	6:40	LINE FAULT
969	17-Apr-21	TUMKUR	220	HONNALLI 220kV- SHIMOGA 220kV	MRSMSG_220	8:33	10:03	1:30	LINE CLEAR AVOIDED
970	17-Apr-21	TUMKUR	220	HONNALLI 220kV-DAVANAGERE SRS	HONNALLI_220	8:33	10:03	1:30	LINE CLEAR AVOIDED
971	18-Apr-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVOIDED
972	18-Apr-21	BAGALKOT	110	110/11KV, HV1	TAKKALAKI_110	12:42	12:46	0:04	TRANSFORMER FAULT
973	18-Apr-21	BAGALKOT	110	110/11KV, HV2	TARIHAL_110	10:46	18:30	7:44	LINE CLEAR AVOIDED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
974	18-Apr-21	BAGALKOT	110	110/11KV,HV2	HIDIKAL_110	15:02	15:36	0:34	HAND TRIPPED
975	18-Apr-21	BAGALKOT	110	110/11KV,HV2	KALAGHATGI_110	19:53	20:00	0:07	TRANSFORMER FAULT
976	18-Apr-21	BAGALKOT	110	110/11KV,HV3	JAMAKHANDI_110	10:03	18:06	8:03	LINE CLEAR AVAILED
977	18-Apr-21	BAGALKOT	110	110/33KV, HV3	KULIGOD_110, ARALI_33, TIGADI_33	21:39	22:01	0:22	HAND TRIPPED
978	18-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, ALSANGI_33	5:22	5:31	0:09	TRANSFORMER FAULT
979	18-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, ALSANGI_33	6:56	7:05	0:09	TRANSFORMER FAULT
980	18-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, ALSANGI_33	11:14	11:18	0:04	TRANSFORMER FAULT
981	18-Apr-21	BAGALKOT	110	110/33KV,HV2	HUNGUND_110 &AMINGAD&KARADI_33	18:47	18:50	0:03	TRANSFORMER FAULT
982	18-Apr-21	BAGALKOT	110	AMBEWADI(SIRSI)-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	16:46 (16.04.2021)	21:37 (18.04.2021)	52:51 hrs	LINE CHARGED
983	18-Apr-21	BAGALKOT	110	AMBEWADI-NK2	HALIYAL_110	18:45	18:52	0:07	LINE FAULT
984	18-Apr-21	BAGALKOT	110	BAGALKOT-GULEDGUDD	GULEDGUDD_110	20:39	21:01	0:22	LINE FAULT
985	18-Apr-21	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN: LINE CLEAR AVAILED
986	18-Apr-21	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	16:36	19:52	3:16	LINE FAULT
987	18-Apr-21	BAGALKOT	110	BIDNAL-NAVALGUND	NAVALGUND_110	15:53 (18.04.2021)			LINE OPEN: LINE FAULT
988	18-Apr-21	BAGALKOT	110	DAMBAL-EILS(L1)	DAMBAL_110 (STATION NOT AFFECTED)	18:39 (18.04.2021)			LINE OPEN: LINE FAULT
989	18-Apr-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	16:18 (11.04.2021)			LINE OPEN: LINE CLEAR AVAILED
990	18-Apr-21	BAGALKOT	110	GHATAPRABHA220-GHTATAPRABHA2	GHATAPRABHA_110	4:02	4:21	0:19	LINE FAULT
991	18-Apr-21	BAGALKOT	110	GMNAVAR- SALAHALLI	STATION NOT AFFECTED SALAHALLI_110	9:42	14:57	5:15	LINE CLEAR AVAILED
992	18-Apr-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
993	18-Apr-21	BAGALKOT	110	HAVERI-HANAGALL(TILUVALLI)	HANAGALL_110	16:34	17:47	1:13	LINE FAULT
994	18-Apr-21	BAGALKOT	110	HUBLI- KALGHATAGI	STATION NOT AFFECTED KALGHATAGI_110	20:55 (18.04.2021)			LINE OPEN: LINE FAULT
995	18-Apr-21	BAGALKOT	110	HUBLI- TARIHAL1	STATION NOT AFFECTED TARIHAL_110	20:55 (18.04.2021)			LINE OPEN: LINE FAULT
996	18-Apr-21	BAGALKOT	110	HUNGUND-KUDALSANGAM	HUNGUND_110	12:05	12:17	0:12	LINE FAULT
997	18-Apr-21	BAGALKOT	110	KADANKOPPA-KAVALWADA	STATON NOT AFFECTED KADANKOPPA_110	17:09 (15.04.2021)			LINE OPEN: LINE FAULT
998	18-Apr-21	BAGALKOT	110	KARWAR220- ARG (KUMTA)	KUMTA_110	21:26	23:03	1:37	LINE FAULT
999	18-Apr-21	BAGALKOT	110	KARWAR220- ARG (KUMTA)	KUMTA_110	23:17	23:23	0:06	HAND TRIPPED
1000	18-Apr-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
1001	18-Apr-21	BAGALKOT	110	KUDALA SANGAM- HUNGUND	KUDALA SANGAM_110	12:06	12:18	0:12	LINE FAULT
1002	18-Apr-21	BAGALKOT	110	KUMATA-SIRSI 1	STATION NOT AFFECTED KUMATA_110	12:22 (12.04.2021)	21:39 (18.04.2021)	153:17 hrs	LINE CHARGED
1003	18-Apr-21	BAGALKOT	110	MACHE- UDYAMBAG	STATION NOT AFFECTED MACHE_110	8:11 (12.04.2021)			LINE OPEN: LINE CLEAR AVAILED
1004	18-Apr-21	BAGALKOT	110	MKHUBLI110- KITTUR	KITTUR_110	17:53	18:26	0:33	LINE FAULT
1005	18-Apr-21	BAGALKOT	110	MUDDEBIHAL- BALAJI SUAGRS	MUDDEBIHAL_110	2:34	2:47	0:13	LINE FAULT
1006	18-Apr-21	BAGALKOT	110	NAVALGUND- BIDNAL	STATION NOT AFFECTED NAVALGUND_110	16:41 (18.04.2021)			LINE OPEN: LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
1007	18-Apr-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
1008	18-Apr-21	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:57 (05.03.2021)	17:20 (18.04.2021)	1062:23 hrs	LINE CHARGED
1009	18-Apr-21	BAGALKOT	110	TARIHAL-KIADB GAMANGATTI	STATION NOT AFFECTED TARIHAL_110	12:11 (15.04.2021)			LINE OPEN: LINE CLEAR AVOIDED
1010	18-Apr-21	BAGALKOT	110	UMMACHAGI- KIRUVATTI	UMMACHAGI_110	18:53	18:58	0:05	LINE FAULT
1011	18-Apr-21	BAGALKOT	110	VIJAYANAGAR SUGARS- MUNDARGI	MUNDARGI_110	5:09	5:24	0:15	LINE FAULT
1012	18-Apr-21	BAGALKOT	110	VIJAYANAGAR SUGARS- MUNDARGI	MUNDARGI_110	18:39	19:08	0:29	LINE FAULT
1013	18-Apr-21	BAGALKOT	220	BAGEWADI-NANDIHAL1&2	BAGEWADI_220	7:21	9:59	2:38	NFBC ISSUED
1014	18-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:46 (15.04.2021)	7:24 (18.04.2021)	68:38 hrs	LINE CHARGED
1015	18-Apr-21	BAGALKOT	220	BIDNAL-HIREBENDIGERI1&2	BIDNAL_220	7:31	15:58	8:27	NFBC ISSUED
1016	18-Apr-21	BAGALKOT	220	BIDNAL-NARENDRA	BIDNAL_220	19:39	21:40	2:01	LINE FAULT
1017	18-Apr-21	BAGALKOT	220	BIJAPUR-NANDIHAL1	BIJAPUR_220	8:15	10:07	1:52	LINE CLEAR AVOIDED
1018	18-Apr-21	BAGALKOT	220	BIJAPUR-NANDIHAL2	BIJAPUR_220	8:15	11:09	2:54	LINE CLEAR AVOIDED
1019	18-Apr-21	BAGALKOT	220	CHIKKODI- GHATAPRABHA1 (MUGALKOD)	CHIKKODI_220	7:33 (18.04.2021)			LINE OPEN: LINE CLEAR AVOIDED
1020	18-Apr-21	BAGALKOT	220	CHIKKODI- GHATAPRABHA2 (KUDACHI2)	CHIKKODI_220	7:22	22:13	14:51	LINE CLEAR AVOIDED
1021	18-Apr-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN: LINE CLEAR AVOIDED
1022	18-Apr-21	BAGALKOT	220	GADAG-HARTI1&2	GADAG_220	9:22 (18.04.2021)			LINE OPEN: LINE CLEAR AVOIDED
1023	18-Apr-21	BAGALKOT	220	HUBLI- SIRSI2	STATION NOT AFFECTED HUBLI_220	14:51 (18.04.2021)			LINE OPEN: LINE FAULT
1024	18-Apr-21	BAGALKOT	220	KUDACHI- CHIKKODI1 (MUGALKOD)	KUDACHI_220	8:15 (18.04.2021)			LINE OPEN: LINE CLEAR AVOIDED
1025	18-Apr-21	BAGALKOT	220	KUDACHI- CHIKKODI2 (CHIKKODI)	KUDACHI_220	7:22	22:12	14:50	LINE CLEAR AVOIDED
1026	18-Apr-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVOIDED
1027	18-Apr-21	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	STATION NOT AFFECTED MAHALINGAPUR_220	9:38 (09.04.2021)			LOAD CURTAILMENT
1028	18-Apr-21	BAGALKOT	220	MUGALKOD- CHIKKODI1	STATION NOT AFFECTED MUGALKOD_220	7:34	21:56	14:22	NFBC ISSUED
1029	18-Apr-21	BAGALKOT	220	NAGJHARI1-AMBEWADI	AMBEWADI_220	19:31	22:25	2:54	LINE FAULT
1030	18-Apr-21	BAGALKOT	220	NAGJHARI2-BIDNAL	BIDNAL_220	17:19	18:36	1:17	LINE FAULT
1031	18-Apr-21	BAGALKOT	220	NARENDRA- BIDNAL	STATION NOT AFFECTED NARENDRA_220	19:39	21:40	2:01	LINE FAULT
1032	18-Apr-21	BAGALKOT	220	NARENDRA- HUBLI1	STATION NOT AFFECTED NARENDRA_220	17:56	18:26	0:30	LINE FAULT
1033	18-Apr-21	BAGALKOT	220	NARENDRA- HUBLI2	STATION NOT AFFECTED NARENDRA_220	17:56	18:26	0:30	LINE FAULT
1034	18-Apr-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN: LINE FAULT
1035	18-Apr-21	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	17:15 (18.04.2021)			LINE OPEN: LINE CLEAR AVOIDED
1036	18-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	17:31 (10.04.2021)			LOAD CURTAILMENT
1037	18-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)	16:45 (18.04.2021)	1030:37 hrs	LINE CHARGED
1038	18-Apr-21	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI_220	16:35 (11.04.2021)			LINE OPEN: LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
1039	18-Apr-21	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN: LINE FAULT
1040	18-Apr-21	BAGALKOT	220	VAJRAMATTI -MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
1041	18-Apr-21	BENGALURU	66	ATTUR YELAHANKA - DG3	ATTUR YELAHANKA	22:20	22:25	0:05	LOAD CHANGEOVER
1042	18-Apr-21	BENGALURU	66	ATTUR YELAHANKA - DG4	PLATINUM CITY	12:40	13:14	0:34	LINE FAULT
1043	18-Apr-21	BENGALURU	66	ATTUR YELAHANKA - DG4	ATTUR YELAHANKA	12:40	12:46	0:06	LOAD CHANGEOVER
1044	18-Apr-21	BENGALURU	66	C STATION 1 & 2 - A STATION 220	C STATION	17:30	17:34	0:04	LOAD CHANGEOVER
1045	18-Apr-21	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	11:56	11:58	0:02	LINE CLEAR AVAILED
1046	18-Apr-21	BENGALURU	66	CHANDAPURA - YARANDANAHALLI 220	CHANDAPURA	14:46	14:48	0:02	LINE CLEAR AVAILED
1047	18-Apr-21	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	2:45	2:50	0:05	LOAD CHANGEOVER
1048	18-Apr-21	BENGALURU	66	ELECTRONIC CITY P2 S2 - NAGNATHPURA 220	ELECTRONIC CITY P2 S2, BIOCON (EHT)	17:15	17:30	0:15	LINE FAULT
1049	18-Apr-21	BENGALURU	66	HANUMANTHNAGAR - SOMANAHALLI 220	HANUMANTHNAGAR, YEDUMADU	9:20	9:30	0:10	LOAD CHANGEOVER
1050	18-Apr-21	BENGALURU	66	HEBBALA 220 - C STATION 1 & 2	C STATION	12:47	13:11	0:24	LINE CLEAR AVAILED
1051	18-Apr-21	BENGALURU	66	HEBBALA 220 - IISc	IISc	12:47	13:00	0:13	LINE CLEAR AVAILED
1052	18-Apr-21	BENGALURU	66	HEBBALA 220 - L R BANDE	L R BANDE	12:47	13:05	0:18	LINE CLEAR AVAILED
1053	18-Apr-21	BENGALURU	66	HOSKOTE 66 - HOODY 220	HOSKOTE 66	12:00	12:05	0:05	LOAD CHANGEOVER
1054	18-Apr-21	BENGALURU	66	HOSKOTE 66 - HOSKOTE 220	HOSKOTE 66	19:05	19:10	0:05	LOAD CHANGEOVER
1055	18-Apr-21	BENGALURU	66	HV1	BANASAWADI	12:48	13:04	0:16	LINE CLEAR AVAILED
1056	18-Apr-21	BENGALURU	66	HV1	BANASAWADI	13:42	13:48	0:06	LOAD CHANGEOVER
1057	18-Apr-21	BENGALURU	66	HV2	BANGARPET	23:00(17-4-2021)	1:40(18-4-2021)	2:39	TRANSFORMER FAULT
1058	18-Apr-21	BENGALURU	66	HV3	BANASAWADI	12:48	13:04	0:16	LINE CLEAR AVAILED
1059	18-Apr-21	BENGALURU	66	HV3	BANASAWADI	13:42	13:48	0:06	LOAD CHANGEOVER
1060	18-Apr-21	BENGALURU	66	IISc - NRS 220	IISc	16:28	16:31	0:03	LOAD CHANGEOVER
1061	18-Apr-21	BENGALURU	66	KANASWADI - DB PURA 220	KANASWADI	15:00	15:05	0:05	LOAD CHANGEOVER
1062	18-Apr-21	BENGALURU	66	L R BANDE - HBR LAYOUT	L R BANDE	13:18	13:24	0:06	LOAD CHANGEOVER
1063	18-Apr-21	BENGALURU	66	RAJANUKUNTE - YELAHANKA 220	RAJANUKUNTE	7:00	7:15	0:15	LINE FAULT
1064	18-Apr-21	BENGALURU	66	SAHAKARI NAGAR - MANYATHA TECH PARK 220	SAHAKARI NAGAR	12:32	12:36	0:04	LOAD CHANGEOVER
1065	18-Apr-21	BENGALURU	66	SAHAKARI NAGAR - YELAHANKA 220	SAHAKARI NAGAR	22:00	22:03	0:03	LOAD CHANGEOVER
1066	18-Apr-21	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	11:55	11:57	0:01	LINE CLEAR AVAILED
1067	18-Apr-21	BENGALURU	66	SIDDLAGHATTA - CHINTAMANI 220	SIDDLAGHATTA	12:50	15:20	2:30	MAIN SUPPLY FAILURE
1068	18-Apr-21	BENGALURU	66	YEDUMADU - KANAKAPURA 220	YEDUMADU	20:50	21:10	0:20	LOAD CHANGEOVER
1069	18-Apr-21	BENGALURU	66	YEDUMADU - SOMANAHALLI 220	YEDUMADU	9:30	9:45	0:15	LOAD CHANGEOVER
1070	18-Apr-21	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	2:12	2:28	0:16	LINE FAULT
1071	18-Apr-21	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	2:28	2:53	0:25	LINE FAULT
1072	18-Apr-21	BENGALURU	66	YELAHANKA 220 - LINE7	NO STATION AFFECTED	2:53	14:54	12:01	LINE CLEAR AVAILED
1073	18-Apr-21	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	6:59	7:07	0:07	LINE FAULT
1074	18-Apr-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN: LINE FAULT
1075	18-Apr-21	BENGALURU	220	HV1	HEBBALA 220	12:47	13:04	0:17	TRANSFORMER FAULT
1076	18-Apr-21	BENGALURU	220	HV2	HEBBALA 220	12:47	13:35	0:48	TRANSFORMER FAULT
1077	18-Apr-21	GULBARGA	66	HV2	HANASI_66	11:30	11:50	0:20	LINE CLEAR AVAILED
1078	18-Apr-21	GULBARGA	110	BISIHALLI-ALIPUR	BISIHALLI_110	6:07	6:18	0:11	MAIN SUPPLY FAILURE
1079	18-Apr-21	GULBARGA	110	BISIHALLI-ALIPUR	BISIHALLI_110	18:56	19:07	0:11	MAIN SUPPLY FAILURE
1080	18-Apr-21	GULBARGA	110	GURUMITAKAL-SEDAM	GURUMITAKAL_110,KONKAL_110	22:20	22:27	0:07	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
1081	18-Apr-21	GULBARGA	110	HV2	HATTI_110	13:26	13:36	0:10	TRANSFORMER FAULT
1082	18-Apr-21	GULBARGA	110	KUSHTAGI-ILKAL1	ILKAL_110	14:05	14:44	0:39	LINE FAULT
1083	18-Apr-21	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110,MANVI_110	20:41	20:52	0:11	LINE FAULT
1084	18-Apr-21	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	9:50	11:30	1:40	LINE FAULT
1085	18-Apr-21	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	11:30	14:05	2:35	NFBC ISSUED
1086	18-Apr-21	GULBARGA	110	SHAHABAD-RAICHUR1	JEEWARGI_110	12:58	13:40	0:42	LINE CLEAR AVAILED
1087	18-Apr-21	GULBARGA	110	SHAHABAD-RAICHUR2	SHAHAPUR_110	11:15	13:40	2:25	LINE CLEAR AVAILED
1088	18-Apr-21	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	4:47	5:02	0:15	LINE FAULT
1089	18-Apr-21	GULBARGA	110	SINDHANOOR-SIRGUPPA	SIRAGUPPA_110	23:58(17.04.2021)	00:02(18.04.2021)	0:04	LINE FAULT
1090	18-Apr-21	GULBARGA	110	YELBURGA-TALTSLR	YELBURGA_110	12:55	13:12	0:17	LINE CLEAR AVAILED
1091	18-Apr-21	GULBARGA	220	SINDHANOOR-LINGASUGUR	LINGASUGUR_220	14:05	14:42	0:37	LINE FAULT
1092	18-Apr-21	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	14:21	19:35	5:14	LINE FAULT
1093	18-Apr-21	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	10:20	12:20	2:00	LINE CLEAR AVAILED
1094	18-Apr-21	HASSAN	66	HV1	MOSALEHOSAHALLI_66	14:55	15:00	0:05	HAND TRIPPED
1095	18-Apr-21	HASSAN	66	HV1	SAKLESH PURA_66	15:17	15:30	0:13	TRANSFORMER FAULT
1096	18-Apr-21	HASSAN	66	HV1	MALLAPURA_66	10:29	14:15	3:46	LINE CLEAR AVAILED
1097	18-Apr-21	HASSAN	66	HV2	MAGGE_66	7:15	8:05	0:50	LINE CLEAR AVAILED
1098	18-Apr-21	HASSAN	66	HV2	MALLAPURA_66	10:29	14:15	3:46	LINE CLEAR AVAILED
1099	18-Apr-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	14:15	17:17	3:02	LINE FAULT
1100	18-Apr-21	HASSAN	66	LV2	MRS MG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
1101	18-Apr-21	HASSAN	66	LV4	MRS MG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
1102	18-Apr-21	HASSAN	66	SAKALE-HANBAL	SAKLESH PURA_66	15:15	15:50	0:35	LINE FAULT
1103	18-Apr-21	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	8:50(12.4.2021)			LINE OPEN: LINE CLEAR AVAILED
1104	18-Apr-21	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	8:41	19:05	10:24	LINE CLEAR AVAILED
1105	18-Apr-21	HASSAN	110	HV1	SALATHUR_110	18:44	20:10	1:26	LINE CLEAR AVAILED
1106	18-Apr-21	HASSAN	110	HV1	SHIV PURA_110	11:10	12:25	1:15	LINE CLEAR AVAILED
1107	18-Apr-21	HASSAN	110	HV2	PUTTUR_110	20:50(15.4.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
1108	18-Apr-21	HASSAN	110	HV4	MANIPAL_110	23:49 (18.4.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
1109	18-Apr-21	HASSAN	110	JOG110-MGHE	JOG_110	9:18	20:13	10:55	LINE CLEAR AVAILED
1110	18-Apr-21	HASSAN	110	JOG-JLT3	mghejog_gen	9:14	20:13	10:59	LINE CLEAR AVAILED
1111	18-Apr-21	HASSAN	110	JOG-JLT4	mghejog_gen	9:02	20:17	11:15	LINE CLEAR AVAILED
1112	18-Apr-21	HASSAN	110	JOG-JST1	mghejog_gen	9:12	20:10	10:58	LINE CLEAR AVAILED
1113	18-Apr-21	HASSAN	110	JOG-JST2	mghejog_gen	9:12	20:11	10:59	LINE CLEAR AVAILED
1114	18-Apr-21	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	18:21(18.04.2021)			LINE OPEN: LINE FAULT
1115	18-Apr-21	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	19:55	20:28	0:33	LINE FAULT
1116	18-Apr-21	HASSAN	110	LPH-MGHE 2	lph_gen	9:40	20:16	10:36	LINE CLEAR AVAILED
1117	18-Apr-21	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	21:15(11.4.2021)			LINE OPEN: LINE FAULT
1118	18-Apr-21	HASSAN	110	SAGARA-JST1	SAGARA_110	9:39	20:10	10:31	NFBC ISSUED
1119	18-Apr-21	HASSAN	110	SAGARA-JST2	SAGARA_110	9:40	20:11	10:31	NFBC ISSUED
1120	18-Apr-21	HASSAN	110	SAGARA-SORABA	SAGARA_110	8:34	8:50	0:16	HAND TRIPPED
1121	18-Apr-21	HASSAN	110	SHIVAPU-NERLEKERE	SHIV PURA_110	11:12	12:23	1:11	LINE CLEAR AVAILED
1122	18-Apr-21	HASSAN	110	SORABA-SHR220	SORABA_110	8:35	8:47	0:12	HAND TRIPPED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
1123	18-Apr-21	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	23:03(18.4.2021)			LINE OPEN: LINE CLEAR AVAILED
1124	18-Apr-21	HASSAN	220	KEMAR-Varahi1	KEMAR_220	16:46	20:32	3:46	LINE FAULT
1125	18-Apr-21	HASSAN	220	KEMAR-Varahi2	KEMAR_220	16:48	18:49	2:01	LINE FAULT
1126	18-Apr-21	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	10:21	17:23	7:02	LINE CLEAR AVAILED
1127	18-Apr-21	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	16:02	16:27	0:25	LINE FAULT
1128	18-Apr-21	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	15:48	17:35	1:47	LINE FAULT
1129	18-Apr-21	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	17:57	18:27	0:30	LINE FAULT
1130	18-Apr-21	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	19:26	19:46	0:20	LINE FAULT
1131	18-Apr-21	HASSAN	220	SHRAVITY-SHIMOGA3	sharavathy_gen	16:02	16:27	0:25	LINE FAULT
1132	18-Apr-21	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	6:35	11:45	5:10	LINE FAULT
1133	18-Apr-21	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	10:04	16:36	6:32	LINE CLEAR AVAILED
1134	18-Apr-21	HASSAN	220	VARAH1-KEMAR1	varahi_gen	16:36	20:34	3:58	LINE FAULT
1135	18-Apr-21	HASSAN	220	VARAH1-KEMAR2	varahi_gen	16:36	18:45	2:09	LINE FAULT
1136	18-Apr-21	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	15:47	17:35	1:48	LINE FAULT
1137	18-Apr-21	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	17:57	18:27	0:30	LINE FAULT
1138	18-Apr-21	MYSURU	66	CR NAGARA-BADANKUPPE-1	BADANAGUPPE_66	10:10	14:17	4:07	NFBC ISSUED
1139	18-Apr-21	MYSURU	66	CR NAGARA-BADANKUPPE-2	BADANAGUPPE_66	10:10	14:17	4:07	NFBC ISSUED
1140	18-Apr-21	MYSURU	66	CR NAGARA-CHANDAKAWADI	CHANDAKAVADI_66	10:11	16:35	6:24	NFBC ISSUED
1141	18-Apr-21	MYSURU	66	CR NAGARA-GUNDLUPETE-2	GUNDULPET_66 TERAKANAMBE_66	9:11	19:28	10:17	NFBC ISSUED
1142	18-Apr-21	MYSURU	66	CR NAGARA-KABBALLI	NO STATIONS EFFECTED	1:45	1:51	0:06	LINE FAULT
1143	18-Apr-21	MYSURU	66	HANNUR-AMP SOLAR	NO STATIONS EFFECTED	6:54	9:10	2:15	LINE FAULT
1144	18-Apr-21	MYSURU	66	HARVEY-BEGUR	HARVEY_66	8:00	16:33	8:33	LINE CLEAR AVAILED
1145	18-Apr-21	MYSURU	66	HOOTAGALLI-VIJAYANAGARA	BANNIMANTAP_66 VIJAYANAGRAMYS_66	10:49	11:02	0:13	LINE FAULT
1146	18-Apr-21	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
1147	18-Apr-21	MYSURU	66	HV5	SFCSHIVA_66	8:19 (4/4/2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
1148	18-Apr-21	MYSURU	66	KABBALLI-GUNDLUPETE	GUNDULPET_66	9:22	19:15	9:52	NFBC ISSUED
1149	18-Apr-21	MYSURU	66	PONNAMPETE-VIRAJPETE	VIRAJPET_66	15:25	15:36	0:11	LINE FAULT
1150	18-Apr-21	MYSURU	220	CR NAGARA-MADHUVANAHALLI 1	NO STATIONS EFFECTED	14:39	15:12	0:33	LINE FAULT
1151	18-Apr-21	MYSURU	220	CR NAGARA-MADHUVANAHALLI 2	NO STATIONS EFFECTED	14:39	15:12	0:33	LINE FAULT
1152	18-Apr-21	MYSURU	220	HV1	CRNAGAR_220	10:02	13:51	3:49	LINE CLEAR AVAILED
1153	18-Apr-21	TUMKUR	66	ANTHRASANAHALLI 220KV- TUMKUR	TUMKUR_66	10:18	13:34	3:15	LINE CLEAR AVAILED
1154	18-Apr-21	TUMKUR	66	CHIKKABANAGERE- HARIYABBE	CHIKKABANAGERE_66	16:28	18:11	1:43	LINE CLEAR AVAILED
1155	18-Apr-21	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	12:02	12:09	0:06	LINE FAULT
1156	18-Apr-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	20:55	21:16	0:21	LINE FAULT
1157	18-Apr-21	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	6:55	18:36	11:41	LINE CLEAR AVAILED
1158	18-Apr-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	14:16	14:28	0:12	LINE FAULT
1159	18-Apr-21	TUMKUR	66	TR-1	HDPURA_66	7:31	7:34	0:03	TRANSFORMER FAULT
1160	18-Apr-21	TUMKUR	66	TR-1	HDPURA_66	7:48	7:52	0:03	TRANSFORMER FAULT
1161	18-Apr-21	TUMKUR	66	TR-2	HOLALKERE_66	12:28	12:37	0:08	TRANSFORMER FAULT



SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
1162	18-Apr-21	TUMKUR	66	TR-2	HOLALKERE_66	12:50	13:05	0:15	TRANSFORMER FAULT
1163	18-Apr-21	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	19:28	20:28	0:59	LINE FAULT
1164	18-Apr-21	TUMKUR	110	TR-1	SHETYKERE_110	19:52	20:22	0:30	TRANSFORMER FAULT
1165	18-Apr-21	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	19:36	19:45	0:08	TRANSFORMER FAULT
1166	18-Apr-21	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	19:59	20:13	0:14	TRANSFORMER FAULT
1167	18-Apr-21	TUMKUR	220	TR-2	KBCROSS_220	19:28	20:14	0:46	TRANSFORMER FAULT
1168	19-Apr-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVOIDED
1169	19-Apr-21	BAGALKOT	110	110/11KV, HV2	SIRSI_110	13:52	14:19	0:27	LINE CLEAR AVOIDED
1170	19-Apr-21	BAGALKOT	110	110/11KV, HV2	SHIROL_110	12:59	13:33	0:34	LINE CLEAR AVOIDED
1171	19-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, NEVARGI_33, DHULKED_33, ALSANGI_33	6:13	6:25	0:12	TRANSFORMER FAULT
1172	19-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, NEVARGI_33, DHULKED_33, ALSANGI_33	6:38	6:42	0:04	TRANSFORMER FAULT
1173	19-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, NEVARGI_33, DHULKED_33, ALSANGI_33	7:04	7:25	0:21	TRANSFORMER FAULT
1174	19-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, NEVARGI_33, DHULKED_33, ALSANGI_33	7:51	8:19	0:28	TRANSFORMER FAULT
1175	19-Apr-21	BAGALKOT	110	110/33KV,HV1&HV2	JAMAKHANDI_110 &HIPPARAGI,MADARAKHANDI,HIPP ARAGI LIS&HIPPARAGI_33	8:20	10:49	2:29	LINE CLEAR AVOIDED
1176	19-Apr-21	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	7:40	12:04	4:24	LINE FAULT
1177	19-Apr-21	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN: LINE CLEAR AVOIDED
1178	19-Apr-21	BAGALKOT	110	BIDNAL-NAVALGUND	NAVALGUND_110	15:53 (18.04.2021)	10:16 (19.04.2021)	18:23	LINE FAULT
1179	19-Apr-21	BAGALKOT	110	DAMBAL-EILS(L1)	DAMBAL_110 (STATION NOT AFFECTED)	18:39 (18.04.2021)	1:00 (19.04.2021)	6:21	LINE FAULT
1180	19-Apr-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	16:18 (11.04.2021)			LINE OPEN: LINE CLEAR AVOIDED
1181	19-Apr-21	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA2	GHATAPRABHA_110	6:14	6:45	0:31	LINE FAULT
1182	19-Apr-21	BAGALKOT	110	GOPANAKOPPA-NAVALGUND(BIDNAL-NAVALGUND)	GOPANAKOPPA_110	10:32	12:47	2:15	LINE CLEAR AVOIDED
1183	19-Apr-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVOIDED
1184	19-Apr-21	BAGALKOT	110	HAVERI-BYADAGI	BYADAGI_110	14:58	18:29	3:31	LINE CLEAR AVOIDED
1185	19-Apr-21	BAGALKOT	110	HIREHAL-MFR SOLAR	HIREHAL_110	18:14 (19.04.2021)			LINE OPEN: LINE CLEAR AVOIDED
1186	19-Apr-21	BAGALKOT	110	HUBLI- KALGHATAGI	STATION NOT AFFECTED KALGHATAGI_110	20:55 (18.04.2021)	11:31 (19.04.2021)	14:36	LINE FAULT
1187	19-Apr-21	BAGALKOT	110	HUBLI- TARIHAL1	STATION NOT AFFECTED TARIHAL_110	20:55 (18.04.2021)			LINE OPEN: LINE FAULT
1188	19-Apr-21	BAGALKOT	110	HUKKERI-HATTARAGI	HATTARAGI_110	13:14	14:02	0:48	LINE CLEAR AVOIDED
1189	19-Apr-21	BAGALKOT	110	KADANKOPPA-KAVALWADA	STATON NOT AFFECTED KADANKOPPA_110	17:09 (15.04.2021)			LINE OPEN: LINE FAULT
1190	19-Apr-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
1191	19-Apr-21	BAGALKOT	110	KUDACHI-AINAPUR	AINAPUR_110	14:11	17:31	3:20	LINE CLEAR AVOIDED
1192	19-Apr-21	BAGALKOT	110	MACHE- UDYAMBAG	STATION NOT AFFECTED MACHE_110	8:11 (12.04.2021)			LINE OPEN: LINE CLEAR AVOIDED
1193	19-Apr-21	BAGALKOT	110	MAHALINGAPUR- RABKAVI	RABKAVI_110	11:29	12:10	0:41	HAND TRIPPED
1194	19-Apr-21	BAGALKOT	110	MAHALINGAPUR-JAMAKHANDI	JAMAKHANDI_110	2:02	8:28	6:26	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
1195	19-Apr-21	BAGALKOT	110	MKHUBLI220- HIREBAGEWADI	HIREBAGEWADI_110	17:39	18:03	0:24	LINE FAULT
1196	19-Apr-21	BAGALKOT	110	NAVALGUND- BIDNAL	STATION NOT AFFECTED NAVALGUND_110	16:41 (18.04.2021)	14:58 (19.04.2021)	22:17	LINE FAULT
1197	19-Apr-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
1198	19-Apr-21	BAGALKOT	110	TARIHAL-KIADB GAMANGATTI	STATION NOT AFFECTED TARIHAL_110	12:11 (15.04.2021)			LINE OPEN: LINE CLEAR AVOIDED
1199	19-Apr-21	BAGALKOT	110	TUMMINKATTI- RATTIHALI	TUMMINKATTI_110	12:27	15:15	2:48	LINE CLEAR AVOIDED
1200	19-Apr-21	BAGALKOT	110	VAJRAMATTI220- MELLIGERI	MELLIGERI_110	3:10	3:15	0:05	HAND TRIPPED
1201	19-Apr-21	BAGALKOT	220	220/110KV,HV1,2 & LV1,2	HAVERI_220	14:58	15:22	0:24	HAND TRIPPED
1202	19-Apr-21	BAGALKOT	220	220/110KV,HV2 & LV2	HAVERI_220	10:33	13:39	3:06	LINE CLEAR AVOIDED
1203	19-Apr-21	BAGALKOT	220	BIDNAL-HIREBENDIGERI 1(TADAS1)	BIDNAL_220	11:20	16:06	4:46	LINE CLEAR AVOIDED
1204	19-Apr-21	BAGALKOT	220	CHIKKODI- GHATAPRABHA1 (MUGALKOD)	CHIKKODI_220	7:33 (18.04.2021)	21:57 (19.04.2021)	38:24 hrs	LINE CHARGED
1205	19-Apr-21	BAGALKOT	220	CHIKKODI-KUDACHI2(GHATAPRABHA2)	CHIKKODI_220	8:25	19:55	11:30	LINE CLEAR AVOIDED
1206	19-Apr-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN: LINE CLEAR AVOIDED
1207	19-Apr-21	BAGALKOT	220	GADAG-HARTI1&2	GADAG_220	9:22 (18.04.2021)	11:12 (19.04.2021)	25:50 hrs	LINE CHARGED
1208	19-Apr-21	BAGALKOT	220	HUBLI- SIRSI2	STATION NOT AFFECTED HUBLI_220	14:51 (18.04.2021)	8:30 (19.04.2021)	17:39	LINE FAULT
1209	19-Apr-21	BAGALKOT	220	KUDACHI- CHIKKODI1 (MUGALKOD)	KUDACHI_220	8:15 (18.04.2021)			LINE OPEN: LINE CLEAR AVOIDED
1210	19-Apr-21	BAGALKOT	220	KUDACHI-CHIKKODI2	KUDACHI_220	13:52	19:55	6:03	LINE CLEAR AVOIDED
1211	19-Apr-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVOIDED
1212	19-Apr-21	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	STATION NOT AFFECTED MAHALINGAPUR_220	9:38 (09.04.2021)	11:09 (19.04.2021)	230:22 hrs	LINE CHARGED
1213	19-Apr-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN: LINE FAULT
1214	19-Apr-21	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	17:15 (18.04.2021)			LINE OPEN: LINE CLEAR AVOIDED
1215	19-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	17:31 (10.04.2021)			LOAD CURTAILMENT
1216	19-Apr-21	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	SOUDATTI_220	12:07	12:53	0:46	LINE FAULT
1217	19-Apr-21	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI_220	16:35 (11.04.2021)	11:05 (19.04.2021)	186:30 hrs	LINE CHARGED
1218	19-Apr-21	BAGALKOT	220	VAJRAMATTI- KUDAGI1	VAJRAMATTI_220	11:11	18:47	7:36	LINE CLEAR AVOIDED
1219	19-Apr-21	BAGALKOT	220	VAJRAMATTI- KUDAGI1	VAJRAMATTI_220	11:12	19:12	8:00	LINE CLEAR AVOIDED
1220	19-Apr-21	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN: LINE FAULT
1221	19-Apr-21	BAGALKOT	220	VAJRAMATTI -MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVOIDED
1222	19-Apr-21	BENGALURU	66	C STATION 1 & 2 - A STATION 220	C STATION	17:23	17:26	0:03	LOAD CHANGE OVER
1223	19-Apr-21	BENGALURU	66	ELECTRONIC CITY- ELECTRONIC CITY P2 S1	ELECTRONIC CITY	11:03	11:13	0:10	LOAD CHANGE OVER
1224	19-Apr-21	BENGALURU	66	ELECTRONIC CITY- YARANDANAHALLI 220	ELECTRONIC CITY	14:46	14:51	0:05	LOAD CHANGE OVER
1225	19-Apr-21	BENGALURU	66	GOWRIBIDANUR 220 - AFTL SOLAR	AFTL SOLAR	15:20	15:40	0:20	LINE FAULT
1226	19-Apr-21	BENGALURU	66	GOWRIBIDANUR 220 - MANCHENAHALLI	MANCHENAHALLI, THONDEBHAVI	15:20	15:45	0:25	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
1227	19-Apr-21	BENGALURU	66	GOWRIBIDANUR 220 - MANCHENAHALLI	MANCHENAHALLI, THONDEBHAVI	15:45	16:46	1:01	LINE CLEAR AVAILED
1228	19-Apr-21	BENGALURU	66	HANUMANTHNAGARA - KANAKAPURA 220	HANUMANTHNAGARA	12:40	12:45	0:05	LOAD CHANGEOVER
1229	19-Apr-21	BENGALURU	66	HANUMANTHNAGARA - SOMANAHALLI 220	NO STATION AFFECTED	6:35	7:14	0:39	LINE FAULT
1230	19-Apr-21	BENGALURU	66	HEBBALA 220 - C STATION 1 & 2	C STATION	13:01	13:19	0:18	LINE CLEAR AVAILED
1231	19-Apr-21	BENGALURU	66	HEBBALA 220 - IISc	IISc	13:01	13:20	0:19	LINE CLEAR AVAILED
1232	19-Apr-21	BENGALURU	66	HEBBALA 220 - L R BANDE	L R BANDE	13:01	13:10	0:09	LINE CLEAR AVAILED
1233	19-Apr-21	BENGALURU	66	HEBBALA 220 - NRS 220	IISc	15:10	15:15	0:05	LOAD CHANGEOVER
1234	19-Apr-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	7:12	7:33	0:21	LINE FAULT
1235	19-Apr-21	BENGALURU	66	HV1	BANASAWADI	13:01	13:26	0:25	LOAD CHANGEOVER
1236	19-Apr-21	BENGALURU	66	HV1	BANASAWADI	14:07	14:10	0:03	LOAD CHANGEOVER
1237	19-Apr-21	BENGALURU	66	HV1	JAYANAGARA	9:25	9:32	0:07	LINE CLEAR AVAILED
1238	19-Apr-21	BENGALURU	66	HV3	BANASAWADI	13:01	13:26	0:25	LOAD CHANGEOVER
1239	19-Apr-21	BENGALURU	66	HV3	BANASAWADI	14:07	14:10	0:03	LOAD CHANGEOVER
1240	19-Apr-21	BENGALURU	66	L R BANDE - HBR LAYOUT	L R BANDE	13:47	13:51	0:04	LOAD CHANGEOVER
1241	19-Apr-21	BENGALURU	66	MANYATHA TECH PARK 220 - MANYATHA TECH PARK 66	MANYATHA TECH PARK 66	13:01	13:41	0:40	LINE CLEAR AVAILED
1242	19-Apr-21	BENGALURU	66	PATHPALYA - THIMMAMPALLI	THIMMAMPALLI	10:45	12:10	1:25	LINE CLEAR AVAILED
1243	19-Apr-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN: LINE FAULT
1244	19-Apr-21	BENGALURU	220	HEBBALA 220 - MANYATHA TECH PARK 220	HEBBALA 220	13:01	13:34	0:33	LINE FAULT
1245	19-Apr-21	BENGALURU	220	MANYATHA TECH PARK 220 - HEBBALA 220	NO STATION AFFECTED	13:01	14:43	1:42	LINE FAULT
1246	19-Apr-21	BENGALURU	220	MANYATHA TECH PARK 220 - YELAHANKA 220	MANYATHA TECH PARK 220	13:01	13:41	0:40	LINE FAULT
1247	19-Apr-21	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110,DIGGI_110	19:02	19:05	0:03	LINE FAULT
1248	19-Apr-21	GULBARGA	110	HANUMASAGAR-KUSHTAGI	HANUMASAGAR_110,HANUMANAL_110,HIREGONNAGAR_110	0:00	0:15	0:15	LINE FAULT
1249	19-Apr-21	GULBARGA	110	HANUMASAGAR-KUSHTAGI	HANUMASAGAR_110,HANUMANAL_110,HIREGONNAGAR_110	11:08	12:10	1:02	LINE CLEAR AVAILED
1250	19-Apr-21	GULBARGA	110	HV2	DEODURGA_110	9:00	9:14	0:14	TRANSFORMER FAULT
1251	19-Apr-21	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110,MANVI_110	5:06	5:13	0:07	LINE FAULT
1252	19-Apr-21	GULBARGA	110	RAICHUR-APMC1	APMC_110,CHICHSUGUR_110,SHAK THINAGAR_110	15:25 (19.04.21)			LINE OPEN: LINE CLEAR AVAILED
1253	19-Apr-21	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHICHSUGUR_110,SHAK THINAGAR_110	10:05	14:53	4:48	LINE CLEAR AVAILED
1254	19-Apr-21	GULBARGA	110	SHAHABAD-RAICHUR1	JEEWARGI_110	17:05	17:59	0:54	LINE CLEAR AVAILED
1255	19-Apr-21	GULBARGA	110	SHAHABAD-RAICHUR2	SHAHAPUR_110	15:10	15:17	0:07	LINE CLEAR AVAILED
1256	19-Apr-21	GULBARGA	110	SHAHABAD-RAICHUR2	SHAHAPUR_110	17:01	17:25	0:24	LINE CLEAR AVAILED
1257	19-Apr-21	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	4:47	5:02	0:15	LINE FAULT
1258	19-Apr-21	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SRNAGAR_110,GAN GAVATHI_110,VENKATAGIRI_110	15:05	15:15	0:10	LINE FAULT
1259	19-Apr-21	GULBARGA	110	SINDHANOOR-PGLR_WIND	SINDHANOOR_220	2:05	2:25	0:20	LINE FAULT
1260	19-Apr-21	GULBARGA	220	HV2	ALIPUR_220	11:27	11:37	0:10	HAND TRIPPED
1261	19-Apr-21	GULBARGA	220	SHAHAPUR-RTPS2	SHAHAPUR_220	8:26	18:27	10:01	LINE CLEAR AVAILED
1262	19-Apr-21	GULBARGA	220	SHAHAPUR-RTPS2	SHAHAPUR_220	18:28	18:36	0:08	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
1263	19-Apr-21	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	10:59	12:14	1:15	LINE CLEAR AVAILED
1264	19-Apr-21	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	14:17	14:41	0:24	LINE FAULT
1265	19-Apr-21	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	17:32	18:17	0:45	NFBC ISSUED
1266	19-Apr-21	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	14:17	14:32	0:15	LINE FAULT
1267	19-Apr-21	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	17:28	18:16	0:48	NFBC ISSUED
1268	19-Apr-21	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTIHALLY_66	16:04	17:19	1:15	LINE CLEAR AVAILED
1269	19-Apr-21	HASSAN	66	HV1	BANDISHETTIHALLY_66	16:04	17:08	1:04	LINE CLEAR AVAILED
1270	19-Apr-21	HASSAN	66	HV1	HALLYMYSORE_66	11:19	14:19	3:00	LINE CLEAR AVAILED
1271	19-Apr-21	HASSAN	66	HV1	S.BELAGOLA_66	14:29	16:01	1:32	LINE CLEAR AVAILED
1272	19-Apr-21	HASSAN	66	HV2	SALAGAME_66	15:36	15:46	0:10	TRANSFORMER FAULT
1273	19-Apr-21	HASSAN	66	HV2	S.BELAGOLA_66	13:45	14:27	0:42	LINE CLEAR AVAILED
1274	19-Apr-21	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
1275	19-Apr-21	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
1276	19-Apr-21	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	8:50(12.4.2021)			LINE OPEN: LINE CLEAR AVAILED
1277	19-Apr-21	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	8:51	18:57	10:06	LINE CLEAR AVAILED
1278	19-Apr-21	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	16:55	17:21	0:26	LINE FAULT
1279	19-Apr-21	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLY_66	13:54	14:14	0:20	LINE FAULT
1280	19-Apr-21	HASSAN	110	ANAVATI-BARNGI	ANAVATI_110	6:58	7:12	0:14	LINE CLEAR AVAILED
1281	19-Apr-21	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	10:24	12:49	2:25	NFBC ISSUED
1282	19-Apr-21	HASSAN	110	HIRIYA-MANIPAL	HIRIYADKA_110	11:54	13:21	1:27	LINE CLEAR AVAILED
1283	19-Apr-21	HASSAN	110	HV1	KADUR_220	11:36	11:41	0:05	LINE CLEAR AVAILED
1284	19-Apr-21	HASSAN	110	HV1	MSEZ_220	10:04	14:32	4:28	LINE CLEAR AVAILED
1285	19-Apr-21	HASSAN	110	HV2	PUTTUR_110	20:50(15.4.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
1286	19-Apr-21	HASSAN	110	HV2	SORABA_110	18:00	18:25	0:25	LINE CLEAR AVAILED
1287	19-Apr-21	HASSAN	110	HV4	MANIPAL_110	23:49 (18.4.2021)	11:27(19.4.2021)	11:38hrs	TRANSFORMER CHARGED
1288	19-Apr-21	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	18:21(18.04.2021)	12:48(19.4.2021)	18:27hrs	LINE CHARGED
1289	19-Apr-21	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	21:15(11.4.2021)			LINE OPEN: LINE FAULT
1290	19-Apr-21	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	23:03(18.4.2021)	5:25(19.4.2021)	6:22hrs	LINE CHARGED
1291	19-Apr-21	HASSAN	220	MRSSHM-VARAH1	MRSMG_220	13:01	13:10	0:09	HAND TRIPPED
1292	19-Apr-21	HASSAN	220	SHRAVITY-SIRISI 2	sharavthy_gne	11:06	18.04	13:51	LINE FAULT
1293	19-Apr-21	HASSAN	220	VARAH1-SHIMOGA1	varahi_gen	13:01	13:10	0:09	HAND TRIPPED
1294	19-Apr-21	MYSURU	66	BG NAGARA-YEDIYUR	ADICHUNCHANAGIRI_66 VADERALLI_66	11:43	12:12	0:28	LINE FAULT
1295	19-Apr-21	MYSURU	66	HAMPAPURA-BASARALU	BASARALU_66	1:46	1:53	0:07	LINE FAULT
1296	19-Apr-21	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
1297	19-Apr-21	MYSURU	66	HV5	SFCSHIVA_66	8:19 (4/4/2021)	5:07 (19/04/2021)	356:48 hrs	TRANSFORMER CHARGED
1298	19-Apr-21	MYSURU	66	KADAKOLA-SARGUR 2	DOORA_66 HURA_66 HULLAHALLI_66,	6:25	6:31	0:06	LINE FAULT
1299	19-Apr-21	MYSURU	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	11:13	11:23	0:09	LINE FAULT
1300	19-Apr-21	MYSURU	66	KUSGALNAGARA-HARANGI	NO STATIONS EFFECTED	17:01	17:11	0:10	LINE FAULT
1301	19-Apr-21	MYSURU	66	KUSGALNAGARA-RAMANATHAPURA-1	ALUR SIDDAPURA_66 KANAGAL_66	18:59	19:09	0:10	LINE FAULT
1302	19-Apr-21	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	1:41	1:46	0:05	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REMARKS
1303	19-Apr-21	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	5:50	5:55	0:05	LINE FAULT
1304	19-Apr-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 KESLAGERE_66 VADERALLI_66	11:42	11:52	0:09	LINE FAULT
1305	19-Apr-21	TUMKUR	66	CHIKKABANAGERE- GLOBAL TECKPARK	GLOBAL TECKPARK_IPP_66	1:44	18:06	16:22	LINE CLEAR AVAILED
1306	19-Apr-21	TUMKUR	66	CHITRADURGA 220kV- CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	22:39	23:19	0:39	LINE FAULT
1307	19-Apr-21	TUMKUR	66	CHITRADURGA 220kV- HGML	CHITRADURGA_220	22:39	23:17	0:37	LINE FAULT
1308	19-Apr-21	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	22:39	23:16	0:36	LINE FAULT
1309	19-Apr-21	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, RAMAGIRI_66	22:39	23:22	0:42	LINE FAULT
1310	19-Apr-21	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	22:39	23:15	0:36	LINE FAULT
1311	19-Apr-21	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA 1	CHITRADURGA_220	22:39	23:28	0:48	LINE FAULT
1312	19-Apr-21	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA2	CHITRADURGA_220	22:39	23:24	0:44	LINE FAULT
1313	19-Apr-21	TUMKUR	66	CHITRADURGA 66kV- DAVANAGERE2	CHITRADURGA_66	23:12	23:17	0:04	MAIN SUPPLY FAILURE
1314	19-Apr-21	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	JAVAGODANAHALLI_66	13:01	13:06	0:05	LINE FAULT
1315	19-Apr-21	TUMKUR	66	LINGADAHALLI- SHIMOGA	LINGDHALLI_66	17:21	17:26	0:04	LINE FAULT
1316	19-Apr-21	TUMKUR	66	LV1	CHITRADURGA_220	22:39	23:14	0:34	TRANSFORMER FAULT
1317	19-Apr-21	TUMKUR	66	MADHUGIRI 220kV- PULAMAGATTA	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	11:07	12:02	0:55	LINE CLEAR AVAILED
1318	19-Apr-21	TUMKUR	66	MADHUGIRI 220kV- PULAMAGATTA	PULAMAGATTA_66	11:12	12:04	0:51	MAIN SUPPLY FAILURE
1319	19-Apr-21	TUMKUR	66	TR-1	CHALLAKERE_66	11:21	12:12	0:50	LINE CLEAR AVAILED
1320	19-Apr-21	TUMKUR	66	TR-1	HDPURA_66	21:30	21:33	0:03	TRANSFORMER FAULT
1321	19-Apr-21	TUMKUR	66	TR-1	KANCHIPURA_66	11:34	12:41	1:06	LINE CLEAR AVAILED
1322	19-Apr-21	TUMKUR	66	TR-1	MADHUGIRI_220	14:01	15:00	0:59	LINE CLEAR AVAILED
1323	19-Apr-21	TUMKUR	66	TR-2	BALENAHALLI_66	12:21	12:30	0:09	TRANSFORMER FAULT
1324	19-Apr-21	TUMKUR	66	TR-2	BALENAHALLI_66	18:00	18:06	0:05	TRANSFORMER FAULT
1325	19-Apr-21	TUMKUR	66	TR-2	BALENAHALLI_66	19:21	19:36	0:14	TRANSFORMER FAULT
1326	19-Apr-21	TUMKUR	66	TR-2	CHANNAGIRI_66	4:06	8:28	4:22	TRANSFORMER FAULT
1327	19-Apr-21	TUMKUR	66	TR-2	HOLALKERE_66	6:54	6:57	0:03	TRANSFORMER FAULT
1328	19-Apr-21	TUMKUR	66	TR-2	HOLALKERE_66	11:14	11:17	0:03	TRANSFORMER FAULT
1329	19-Apr-21	TUMKUR	66	TR-2	HOLALKERE_66	12:30	12:38	0:07	TRANSFORMER FAULT
1330	19-Apr-21	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	20:28	21:03	0:35	LINE CLEAR AVAILED
1331	19-Apr-21	TUMKUR	110	TR-1	SAMPIGE_110	12:14	13:00	0:45	LINE CLEAR AVAILED
1332	19-Apr-21	TUMKUR	110	TR-1	SHETYKERE_110	11:08	11:18	0:09	TRANSFORMER FAULT
1333	19-Apr-21	TUMKUR	110	TR-1	SHETYKERE_110	16:00	16:06	0:06	TRANSFORMER FAULT
1334	19-Apr-21	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	11:35	14:52	3:17	LINE CLEAR AVAILED
1335	19-Apr-21	TUMKUR	220	TR-2	NITTUR_220	13:19	19:21	6:02	LINE CLEAR AVAILED