

400/220/110/66 kV TRANSMISSION INTERRUPTIONS DUE TO LC, LS AND FAULTS : 15.12.20 To 21.12.20

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	15-Dec-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN : LINE CLEAR AVAILED
2	15-Dec-20	BAGALKOT	110	110/11KV, HV1	NIDAGUNDI 110	18:16	21:24	3:08	TRANSFORMER FAULT
3	15-Dec-20	BAGALKOT	110	110/11KV, HV2	SHIROL 110	12:05	14:15	2:10	LINE CLEAR AVOIDED
4	15-Dec-20	BAGALKOT	110	110/11KV, HV4	BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
5	15-Dec-20	BAGALKOT	110	110/11KV,HV 2	HIDIKAL DAM_110	16:57	17:14	0:17	LINE CLEAR AVOIDED
6	15-Dec-20	BAGALKOT	110	110/11KV,HV1	BANAHATTI_110	08:15	09:44	1:29	TRANSFORMER FAULT
7	15-Dec-20	BAGALKOT	110	110/11KV,HV2	DAVALESHWAR_110	10:15	11:26	1:11	LINE CLEAR AVOIDED
8	15-Dec-20	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	12:24	18:03	5:39	LINE CLEAR AVOIDED
9	15-Dec-20	BAGALKOT	110	110/33KV,HV2	HUNGUND_110 & AMINGAD ,KARADI 33	11:52	12:09	0:17	HAND TRIPPED
10	15-Dec-20	BAGALKOT	110	110/33KV,HV3	GUTTAL_110,HOSARITTI_33	13:10	16:49	3:39	LINE CLEAR AVOIDED
11	15-Dec-20	BAGALKOT	110	110/33KV,HV3	HIDIKAL DAM_110 & RUSTUMPUR,BGM W/S 1,2,3 33	09:55	17:40	7:45	LINE CLEAR AVOIDED
12	15-Dec-20	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED KARWAR 220	19:07 (08.11.2020)	20:01 15.12.2020)	168:54 hrs	TRANSFORMER CHARGED
13	15-Dec-20	BAGALKOT	110	BAGEWADI220- MUKARTIHAL	MUKARTIHAL_110	10:56	13:02	2:06	LINE CLEAR AVOIDED
14	15-Dec-20	BAGALKOT	110	BAGEWADI220- MUKARTIHAL	MUKARTIHAL_110	17:21	21:36	4:15	LINE CLEAR AVOIDED
15	15-Dec-20	BAGALKOT	110	BAGEWADI-MUDEDEBIHAL	MUDEDEBIHAL_110	10:54	12:57	2:03	LINE CLEAR AVOIDED
16	15-Dec-20	BAGALKOT	110	BAGEWADI-MUDEDEBIHAL	MUDEDEBIHAL_110	15:52	19:59	4:07	LINE FAULT
17	15-Dec-20	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	10:55	12:58	2:03	LINE CLEAR AVOIDED
18	15-Dec-20	BAGALKOT	110	BAGEWADI-NIDAGUNDI	STATION NOT AFFECTED NIDAGUNDI 110	17:05	20:12	3:07	LINE CLEAR AVOIDED
19	15-Dec-20	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL 220	12:39 (28.11.2020)			LINE OPEN : LINE CLEAR AVAILED
20	15-Dec-20	BAGALKOT	110	BIDNAL-NAVALGUND	STATION NOT AFFECTED NAVALGUND 110	11:41 (28.11.2020)	14:39 (15.12.2020)	410:58 hrs	LINE CHARGED
21	15-Dec-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00 (21.07.2020)			LINE OPEN : LINE CLEAR AVAILED
22	15-Dec-20	BAGALKOT	110	HAVERI-TILUVALI(HANGAL)	STATION NOT AFFECTED TILUVALI 110	09:31	19:52	10:21	LINE CLEAR AVOIDED
23	15-Dec-20	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI 110	9:18 (21.11.2020)			LINE OPEN : LINE CLEAR AVAILED
24	15-Dec-20	BAGALKOT	110	KARAWAR-SOLARIS	BINAGA_110	18:21	21:21	3:00	LINE CLEAR AVOIDED
25	15-Dec-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
26	15-Dec-20	BAGALKOT	110	KUDUCHI-TERDAL	STATION NOT AFFECTED TERDAL 110	13:10 (14.12.2020)			LINE OPEN : LINE FAULT
27	15-Dec-20	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	STATION NOT AFFECTED BANAHATTI 110	18:45 (14.12.2020)	13:11 (15.11.2020)	18:26	LINE FAULT
28	15-Dec-20	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAHATTI_110	11:01	11:45	0:44	LINE CLEAR AVOIDED
29	15-Dec-20	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAHATTI_110	13:00	13:10	0:10	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
30	15-Dec-20	BAGALKOT	110	NARENDRA220- BELUR2	STATION NOT AFFECTED BELUR_110	13:14	16:33	3:19	LINE CLEAR AVAILED
31	15-Dec-20	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN : LINE FAULT
32	15-Dec-20	BAGALKOT	110	SUZLON-BYADAGI	BYADAGI_110	09:29	09:31	0:02	LINE FAULT
33	15-Dec-20	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)	20:02 15.12.2020)	168:55 hrs	TRANSFORMER CHARGED
34	15-Dec-20	BAGALKOT	220	220/110KV,HV1,KV1	HAVERI_220	10:40	19:52	9:12	LINE CLEAR AVAILED
35	15-Dec-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN : LINE CLEAR AVAILED
36	15-Dec-20	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	21:06 (14.12.2020)	8:04 (15.12.2020)	11:00	LOAD CURTAILMENT
37	15-Dec-20	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM_220	21:04 (14.12.2020)	8:03 (15.12.2020)	10:59	LOAD CURTAILMENT
38	15-Dec-20	BAGALKOT	220	GHATAPRABHA- KUDACHI	GHATAPRABHA_220	6:39 (07.12.2020)	18:16 (15.10.2020)	203:37 hrs	LINE CHARGED
39	15-Dec-20	BAGALKOT	220	GHATAPRABHA-CHIKKODI	GHATAPRABHA_220	6:39 (07.12.2020)			LINE OPEN : LINE CLEAR AVAILED
40	15-Dec-20	BAGALKOT	220	NAGJHARI 1-HUBLI	HUBLI_220	6:18	15:39	9:21	LINE CLEAR AVAILED
41	15-Dec-20	BAGALKOT	220	NAGJHARI 2-HUBLI	HUBLI_220	6:39	15:40	9:01	LINE CLEAR AVAILED
42	15-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
43	15-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
44	15-Dec-20	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN : LINE CLEAR AVAILED
45	15-Dec-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN : LINE FAULT
46	15-Dec-20	BENGALURU	66	HV1	SIR M V LAYOUT	07:10	08:10	01:00	LINE CLEAR AVAILED
47	15-Dec-20	BENGALURU	66	HV1	YARANDANAHALLI 220	19:33	19:40	00:07	LOAD CHANGE OVER
48	15-Dec-20	BENGALURU	66	HV1	MUDIYANUR	10:53	11:30	00:37	LINE CLEAR AVAILED
49	15-Dec-20	BENGALURU	66	HV1	HAL 220	05:57	07:20	01:23	TRANSFORMER FAULT
50	15-Dec-20	BENGALURU	66	HV2	T K HALLI 220	11:35	11:50	00:15	LINE CLEAR AVAILED
51	15-Dec-20	BENGALURU	66	JIGANI 66 - JIGANI 220	JIGANI 66	21:22	22:00	00:38	LOAD CHANGE OVER
52	15-Dec-20	BENGALURU	66	KOLAR 220 - BANGARPET 1	BANGARPET	16:34	17:00	00:26	LINE CLEAR AVAILED
53	15-Dec-20	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	16:34	17:00	00:26	LINE CLEAR AVAILED
54	15-Dec-20	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	16:34	17:00	00:26	LINE CLEAR AVAILED
55	15-Dec-20	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	16:34	17:00	00:26	LINE CLEAR AVAILED
56	15-Dec-20	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR, SM MANGALA	16:34	17:00	00:26	LINE CLEAR AVAILED
57	15-Dec-20	BENGALURU	66	KOLAR 220 - SRINIVASPURA	DRDO(EHT), MALLASANDRA, DALASANUR, YELDUR	16:34	17:00	00:26	LINE CLEAR AVAILED
58	15-Dec-20	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	16:34	17:00	00:26	LINE CLEAR AVAILED
59	15-Dec-20	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	16:34	17:00	00:26	LINE CLEAR AVAILED
60	15-Dec-20	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	16:34	17:00	00:26	LINE CLEAR AVAILED
61	15-Dec-20	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	16:34	17:07	00:33	LINE CLEAR AVAILED
62	15-Dec-20	BENGALURU	66	MALUR 220 - HOSKOTE 2	MALUR I/A, JADIGENAHALLI, STAR PANEL(EHT)	07:32	07:56	00:24	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
63	15-Dec-20	BENGALURU	66	MALUR 220 - HOSKOTE 2	MALUR I/A, JADIGENAHALLI, STAR PANEL(EHT)	16:34	17:07	00:33	LINE CLEAR AVAILED
64	15-Dec-20	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	16:34	17:07	00:33	LINE CLEAR AVAILED
65	15-Dec-20	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	16:34	17:07	00:33	LINE CLEAR AVAILED
66	15-Dec-20	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	19:40(15/12/2020)			LINE OPEN : LINE CLEAR AVAILED
67	15-Dec-20	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	16:34	17:07	00:33	LINE CLEAR AVAILED
68	15-Dec-20	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	17:56(15/12/2020)			LINE OPEN : LINE FAULT
69	15-Dec-20	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	16:34	17:07	00:33	LINE CLEAR AVAILED
70	15-Dec-20	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, LAKKUR, DEVANGONDHI	16:34	17:07	00:33	LINE CLEAR AVAILED
71	15-Dec-20	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	16:34	17:07	00:33	LINE CLEAR AVAILED
72	15-Dec-20	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	16:34	17:10	00:36	LINE CLEAR AVAILED
73	15-Dec-20	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	16:34	17:10	00:36	LINE CLEAR AVAILED
74	15-Dec-20	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI	16:22	17:50	01:28	LINE FAULT
75	15-Dec-20	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	16:34	17:10	00:36	LINE CLEAR AVAILED
76	15-Dec-20	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	16:34	17:10	00:36	LINE CLEAR AVAILED
77	15-Dec-20	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	16:34	17:10	00:36	LINE CLEAR AVAILED
78	15-Dec-20	BENGALURU	66	YARANDANAHALLI 220 - JIGANI 66	JIGANI 66	22:57	23:22	00:25	LINE FAULT
79	15-Dec-20	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN : LINE CLEAR AVAILED
80	15-Dec-20	BENGALURU	220	DABUSPETE 220 - KADUR 220	NO STATION AFFECTED	9:10(12/12/2020)	13:04(15/12/2020)	75:54HRS	LINE CHARGED
81	15-Dec-20	BENGALURU	220	HV2	T K HALLI 220	16:22	16:43	00:21	TRANSFORMER FAULT
82	15-Dec-20	BENGALURU	220	KOLAR 220 - PGCIL 1 & 2	KOLAR 220	16:34	16:58	00:24	MAIN SUPPLY FAILURE
83	15-Dec-20	BENGALURU	220	MALUR 220 - KOLAR 1	MALUR 220	16:34	17:07	00:33	MAIN SUPPLY FAILURE
84	15-Dec-20	BENGALURU	220	MALUR 220 - KOLAR 3	SARJAPURA 220, MALUR 220, VIKAS TECH PARK 220	16:34	17:07	00:33	LINE CLEAR AVAILED
85	15-Dec-20	GULBARGA	110	HV1	KUDITINI_110	11:17	11:24	00:07	TRANSFORMER FAULT
86	15-Dec-20	GULBARGA	110	KUSHTAGI-ILKAL1	ILKAL_110	18:55	19:13	00:18	LINE FAULT
87	15-Dec-20	GULBARGA	110	NIRNA-CHITAGUPPA	NIRNA_110	10:50	12:00	01:10	LINE CLEAR AVAILED
88	15-Dec-20	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGL_110	05:29	05:39	00:10	LINE FAULT
89	15-Dec-20	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	04:22	04:30	00:08	LINE FAULT
90	15-Dec-20	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	01:53	02:02	00:09	LINE FAULT
91	15-Dec-20	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	05:16	05:28	00:12	LINE FAULT
92	15-Dec-20	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	23:03	23:11	00:08	LINE FAULT
93	15-Dec-20	GULBARGA	220	HV1	RAICHUR_220	10:42	13:31	02:49	LINE CLEAR AVAILED
94	15-Dec-20	GULBARGA	220	HV1	ITTAGGI_220	12:20	12:25	00:05	LINE CLEAR AVAILED
95	15-Dec-20	GULBARGA	220	HV1	ITTAGGI_220	12:20	12:25	00:05	LINE CLEAR AVAILED
96	15-Dec-20	GULBARGA	220	HV1	SHAHAPUR_220	10:02	11:18	01:16	LINE CLEAR AVAILED
97	15-Dec-20	GULBARGA	220	LINGASUGUR-B.BAGEWADI2	BASVANA BAGEWADI_220	14:20	15:53	01:33	LINE CLEAR AVAILED
98	15-Dec-20	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	10:24	14:15	03:51	LINE CLEAR AVAILED
99	15-Dec-20	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	08:51	10:33	01:42	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
100	15-Dec-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	10:56 (5.12.2020)			LINE OPEN : LINE CLEAR AVAILED
101	15-Dec-20	HASSAN	66	BHADRA-SHMGGA 1	bhadra_gen	16:26 (5.12.2020)			LINE OPEN : LINE CLEAR AVAILED
102	15-Dec-20	HASSAN	66	BYACHAN-HNPURA	BYACHANAHALLI_66	08:30	14:00	05:30	LINE FAULT
103	15-Dec-20	HASSAN	66	HNPUR2-RNPR2	HOLENARASIPURA_220	08:52	11:23	02:31	LINE FAULT
104	15-Dec-20	HASSAN	66	HV1	ARKD_66	12:22	12:59	00:37	TRANSFORMER FAULT
105	15-Dec-20	HASSAN	66	HV1	BELUR_66	08:51	10:33	01:42	TRANSFORMER FAULT
106	15-Dec-20	HASSAN	66	HV1	BYACHANAHALLI_66	08:30	14:00	05:30	TRANSFORMER FAULT
107	15-Dec-20	HASSAN	66	HV1	BYACHANAHALLI_66	14:54	15:23	00:29	TRANSFORMER FAULT
108	15-Dec-20	HASSAN	66	HV1	HANBALU_66	15:54	16:26	00:32	TRANSFORMER FAULT
109	15-Dec-20	HASSAN	66	HV1	KUDLIGERE_66	15:31	15:44	00:13	TRANSFORMER FAULT
110	15-Dec-20	HASSAN	66	HV2	BELUR_66	08:51	10:33	01:42	TRANSFORMER FAULT
111	15-Dec-20	HASSAN	66	HV2	HOLEHONNUR_66	13:17	13:21	00:04	TRANSFORMER FAULT
112	15-Dec-20	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
113	15-Dec-20	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
114	15-Dec-20	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
115	15-Dec-20	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	16:26 (5.12.2020)			LINE OPEN : LINE CLEAR AVAILED
116	15-Dec-20	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	10:10	15:52	05:42	LINE FAULT
117	15-Dec-20	HASSAN	110	HV1	BARANGI_110	14:44	16:00	01:16	TRANSFORMER FAULT
118	15-Dec-20	HASSAN	110	HV1	MADHUVANA_110	10:05	15:58	05:53	MAIN SUPPLY FAILURE
119	15-Dec-20	HASSAN	110	JOG110-LPH	JOG_110	12:23	14:24	02:01	LINE FAULT
120	15-Dec-20	HASSAN	110	LV1	KEMAR_220	10:49	12:02	01:13	TRANSFORMER FAULT
121	15-Dec-20	HASSAN	110	LV2	MSEZ_220	12:00	12:36	00:36	TRANSFORMER FAULT
122	15-Dec-20	HASSAN	110	MADHUV-HIRIYADKA	MADHUVANA_110	10:05	15:52	05:47	LINE FAULT
123	15-Dec-20	HASSAN	110	MADHUV-KUNDAPURA	MADHUVANA_110	10:19	15:54	05:35	MAIN SUPPLY FAILURE
124	15-Dec-20	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	11:26	21:56	10:30	LINE FAULT
125	15-Dec-20	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	11:26	21:56	10:30	LINE FAULT
126	15-Dec-20	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	10:26	12:34	02:08	LINE FAULT
127	15-Dec-20	HASSAN	110	MSEZ-GSS32	MSEZ_220	15:26	19:02	03:36	LINE FAULT
128	15-Dec-20	HASSAN	220	ARSK2-HSN	ARASIKERE_220	9:11 (12.12.2020)	13:05 (15.12.2020)	75:53 hrs	LINE CHARGED
129	15-Dec-20	HASSAN	220	HV1	KEMAR_220	10:49	12:02	01:13	TRANSFORMER FAULT
130	15-Dec-20	HASSAN	220	HV2	MSEZ_220	12:00	12:36	00:36	TRANSFORMER FAULT
131	15-Dec-20	HASSAN	220	KADUR-DABUSET	KADUR_220	9:12 (12.12.2020)	13:06 (15.12.2020)	75:53 hrs	LINE CHARGED
132	15-Dec-20	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	12:47	13:42	00:55	LINE FAULT
133	15-Dec-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	13:19 (14.12.2020)			LINE OPEN : LINE CLEAR AVAILED
134	15-Dec-20	MYSORE	66	DEVNUR(N'GUD)-KADAKOLA	DEVANOORNGUDU_66 SUTTUR_66	14:38	14:45	0:06	LINE FAULT
135	15-Dec-20	MYSORE	66	HV1	BILIKERE-	14:36	16:11	1:34	LINE CLEAR AVAILED
136	15-Dec-20	MYSORE	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	5:50	5:55	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
137	15-Dec-20	MYSORE	220	VAJMANGLA-TK HALLY	NO STATIONS EFFECTED	14:10	17:36	3:26	NFBC ISSUED
138	15-Dec-20	TUMKUR	66	KANCHIPURA-MATHOD	KANCHIPURA_66	9:22	13:33	4:11	LINE CLEAR AVAILED
139	15-Dec-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	5:18	5:35	0:16	LINE FAULT
140	15-Dec-20	TUMKUR	66	MATHOD- AVNTI_SLR_IPP_66	AVNTI_SLR_IPP_66	16:15	16:24	0:08	HAND TRIPPED
141	15-Dec-20	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	16:15	16:24	0:09	HAND TRIPPED
142	15-Dec-20	TUMKUR	66	MATHOD-RAMCO CEMENT _EHT_66	RAMCO CEMENT _EHT_66	16:15	16:24	0:09	HAND TRIPPED
143	15-Dec-20	TUMKUR	66	TR-1	HARIHAR_66	16:31	16:41	0:09	LINE CLEAR AVAILED
144	15-Dec-20	TUMKUR	66	TR-1	HOLALKERE_66	15:35	15:50	0:14	LINE CLEAR AVAILED
145	15-Dec-20	TUMKUR	66	TR-1	KANCHIPURA_66	9:22	13:33	4:11	LINE CLEAR AVAILED
146	15-Dec-20	TUMKUR	66	TR-1	KORA_66	12:01	13:18	1:17	LINE CLEAR AVAILED
147	15-Dec-20	TUMKUR	66	TR-1	MADHUGIRI_66	12:15	12:23	0:08	TRANSFORMER FAULT
148	15-Dec-20	TUMKUR	66	TR-1	MADHUGIRI_66	12:25	15:03	2:38	TRANSFORMER FAULT
149	15-Dec-20	TUMKUR	66	TR-1	MATHOD_66	15:43	16:25	0:41	HAND TRIPPED
150	15-Dec-20	TUMKUR	66	TR-1	RANGANATHAPURA_66	8:29	8:56	0:26	LINE CLEAR AVAILED
151	15-Dec-20	TUMKUR	66	TR-2	HOLALKERE_66	13:15	13:57	0:41	LINE CLEAR AVAILED
152	15-Dec-20	TUMKUR	66	TR-2	MATHOD_66	16:16	16:25	0:08	HAND TRIPPED
153	15-Dec-20	TUMKUR	66	TR-2	URDIGERE_66	12:16	12:40	0:23	HAND TRIPPED
154	15-Dec-20	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	10:30	15:13	4:43	LINE CLEAR AVAILED
155	16-Dec-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN : LINE CLEAR AVAILED
156	16-Dec-20	BAGALKOT	110	110/11KV, HV2	GULEDAGUDDA_110	10:47	10:54	0:07	LINE CLEAR AVAILED
157	16-Dec-20	BAGALKOT	110	110/11KV, HV4	BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
158	16-Dec-20	BAGALKOT	110	110/11KV,HV3	STATION NOT AFFECTED SAVALAGI_110	10:45	12:17	1:32	LINE CLEAR AVAILED
159	16-Dec-20	BAGALKOT	110	ANKOLA- KUMTA	ANKOLA_110	10:21	13:32	3:11	LINE CLEAR AVAILED
160	16-Dec-20	BAGALKOT	110	ANKOLA-ARGA	ANKOLA_110	10:22	13:32	3:10	LINE CLEAR AVAILED
161	16-Dec-20	BAGALKOT	110	BAGALKOT220- GULEDAGUDDA	GULEDAGUDDA_110	10:05	10:15	0:10	LINE CLEAR AVAILED
162	16-Dec-20	BAGALKOT	110	BIDNAL- ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	10:02	16:41	6:39	LINE CLEAR AVAILED
163	16-Dec-20	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL_220	12:39 (28.11.2020)			LINE OPEN : LINE CLEAR AVAILED
164	16-Dec-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN : LINE CLEAR AVAILED
165	16-Dec-20	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN : LINE CLEAR AVAILED
166	16-Dec-20	BAGALKOT	110	KARWAR220 -ARGA	ARGA_110	22:00 (15.12.2020)	10:02 (16.12.2020)	12:02	LINE FAULT
167	16-Dec-20	BAGALKOT	110	KARWAR220 -ARGA	ARGA_110	10:20	17:25	7:05	LINE CLEAR AVAILED
168	16-Dec-20	BAGALKOT	110	KARWAR220 -SOLARIS (BINAGA)	BINAGA_110	11:05	17:25	6:20	LINE CLEAR AVAILED
169	16-Dec-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
170	16-Dec-20	BAGALKOT	110	KUDUCHI-TERDAL	STATION NOT AFFECTED TERDAL_110	13:10 (14.12.2020)			LINE OPEN : LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
171	16-Dec-20	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR 220	13:16 (17.11.2020)			LINE OPEN : LINE FAULT
172	16-Dec-20	BAGALKOT	110	RANEBENNUR220-GUTTAL(BYADAGI)	GUTTAL_110	11:03	12:22	1:19	LINE CLEAR AVAILED
173	16-Dec-20	BAGALKOT	220	BAGALKOT- GADAG1	STATION NOT AFFECTED BAGALKOT 220	10:50	14:22	3:32	LINE CLEAR AVAILED
174	16-Dec-20	BAGALKOT	220	BAGALKOT- GADAG2	STATION NOT AFFECTED BAGALKOT 220	10:50	14:22	3:32	LINE CLEAR AVAILED
175	16-Dec-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI 220	16:21 (02.11.2020)			LINE OPEN : LINE CLEAR AVAILED
176	16-Dec-20	BAGALKOT	220	BIDNAL- NARENDRA	STATION NOT AFFECTED BIDNAL 220	12:23	14:22	1:59	NFBC ISSUED
177	16-Dec-20	BAGALKOT	220	BIDNAL- NARENDRA	STATION NOT AFFECTED BIDNAL 220	14:54	17:27	2:33	LINE FAULT
178	16-Dec-20	BAGALKOT	220	GADAG- BAGALKOT1	STATION NOT AFFECTED GADAG 220	10:46	14:18	3:32	LINE CLEAR AVAILED
179	16-Dec-20	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG 220	10:48 (16.12.2020)			LINE OPEN : LINE CLEAR AVAILED
180	16-Dec-20	BAGALKOT	220	GHATAPRABHA-CHIKKODI	GHATAPRABHA_220	6:39 (07.12.2020)	18:08 (16.12.2020)	227:29hrs	LINE CHARGED
181	16-Dec-20	BAGALKOT	220	GUTTUR2- HAVERI	STATION NOT AFFECTED HAVERI 220	16:26 (16.12.2020)			LINE OPEN : LINE CLEAR AVAILED
182	16-Dec-20	BAGALKOT	220	KUDACHI- CHIKKODI	STATION NOT AFFECTED KUDACHI 220	16:45	20:40	3:55	LINE CLEAR AVAILED
183	16-Dec-20	BAGALKOT	220	KUDACHI- GHATAPRABHA	STATION NOT AFFECTED KUDACHI 220	14:00	14:05	0:05	LINE FAULT
184	16-Dec-20	BAGALKOT	220	KUDACHI- MAHALINGAPUR2	STATION NOT AFFECTED KUDACHI 220	10:53	16:33	5:40	LINE CLEAR AVAILED
185	16-Dec-20	BAGALKOT	220	MK HUBLI-NARENDRA 1	STATION NOT AFFECTED MK HUBLI 220	11:47	14:42	2:55	LINE CLEAR AVAILED
186	16-Dec-20	BAGALKOT	220	NAGJHARI 1-SRSHUBLI	STATION NOT AFFECTED HUBLI 220	08:18	16:12	7:54	LINE CLEAR AVAILED
187	16-Dec-20	BAGALKOT	220	NAGJHARI 2-SRSHUBLI	STATION NOT AFFECTED HUBLI 220	08:18	16:28	8:10	LINE CLEAR AVAILED
188	16-Dec-20	BAGALKOT	220	NARENDRA-BIDNAL	STATION NOT AFFECTED NARENDRA 220	12:22	14:30	2:08	LINE CLEAR AVAILED
189	16-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI 220	6:15 (28.11.2020)			LOAD CURTAILMENT
190	16-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI 220	6:15 (28.11.2020)			LOAD CURTAILMENT
191	16-Dec-20	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN : LINE CLEAR AVAILED
192	16-Dec-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN : LINE FAULT
193	16-Dec-20	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	06:18	06:28	00:09	LINE FAULT
194	16-Dec-20	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	11:31	11:43	00:11	LOAD CHANGE OVER
195	16-Dec-20	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	10:17	10:23	00:06	LOAD CHANGE OVER
196	16-Dec-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	07:20	07:30	00:09	LINE FAULT
197	16-Dec-20	BENGALURU	66	HV1	MITTEMARI 220	12:12	16:18	04:05	LINE CLEAR AVAILED
198	16-Dec-20	BENGALURU	66	HV1	MITTEMARI 220	16:20	16:47	00:27	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
199	16-Dec-20	BENGALURU	66	HV1	GODUR	09:25	17:14	07:48	MAIN SUPPLY FAILURE
200	16-Dec-20	BENGALURU	66	HV2	KODIHALLI	07:34	07:44	00:10	TRANSFORMER FAULT
201	16-Dec-20	BENGALURU	66	HV2	VOLVO	09:35	12:23	02:48	TRANSFORMER FAULT
202	16-Dec-20	BENGALURU	66	HV2	SADLI	09:27	11:50	02:22	LINE CLEAR AVAILED
203	16-Dec-20	BENGALURU	66	HV2	MAASTHI	12:55	15:15	02:20	LINE CLEAR AVAILED
204	16-Dec-20	BENGALURU	66	HV2	IRGAMPALLI	20:59	21:06	00:06	TRANSFORMER FAULT
205	16-Dec-20	BENGALURU	66	HV2	ANEKAL	10:55	11:27	00:32	LINE CLEAR AVAILED
206	16-Dec-20	BENGALURU	66	JAYANAGARA - NATIONAL COLLEGE	NATIONAL	15:38	15:41	00:03	LOAD CHANGE OVER
207	16-Dec-20	BENGALURU	66	JAYANAGARA - NIMHANS 220	JAYANAGARA	11:51	12:03	00:12	LOAD CHANGE OVER
208	16-Dec-20	BENGALURU	66	JIGANI 66 - JIGANI 220	JIGANI 66	07:45	07:55	00:10	LOAD CHANGE OVER
209	16-Dec-20	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	09:25	10:33	01:07	LINE CLEAR AVAILED
210	16-Dec-20	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	16:20	17:11	00:51	LINE CLEAR AVAILED
211	16-Dec-20	BENGALURU	66	KANASWADI - DB PURA 220	KANASWADI	11:30	11:40	00:10	LOAD CHANGE OVER
212	16-Dec-20	BENGALURU	66	KANASWADI - YELAHANKA 220	KANASWADI	15:25	15:30	00:05	LOAD CHANGE OVER
213	16-Dec-20	BENGALURU	66	KORMANGALA 220 - L3	NO STATION AFFECTED	21:57 (TRIPPED ON 16 12 2020)			LINE OPEN : LINE FAULT
214	16-Dec-20	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	00:00	06:52	06:52	LINE CLEAR AVAILED
215	16-Dec-20	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	19:40(15/12/2020)	6:52(16/12/2020)	11:12HRS	LINE CHARGED
216	16-Dec-20	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	00:00	06:52	06:52	LINE FAULT
217	16-Dec-20	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	17:56(15/12/2020)	6:52(16/12/2020)	12:56HRS	LINE CHARGED
218	16-Dec-20	BENGALURU	66	PADMANABHANAGAR - NATIONAL COLLEGE	PADMANABHANAGAR	16:04	16:07	00:03	LOAD CHANGE OVER
219	16-Dec-20	BENGALURU	66	PADMANABHANAGAR - SUBRAMANYAPURA 220	PADMANABHANAGAR	11:31	11:36	00:05	LOAD CHANGE OVER
220	16-Dec-20	BENGALURU	66	PLATINUM CITY - YELAHANKA 220	PLATINUM CITY	8:00(16/12/2020)			LINE OPEN : LINE CLEAR AVAILED
221	16-Dec-20	BENGALURU	66	TK HALLI 220 - MANDYA 2	KK DODDI	10:19	14:07	03:47	LINE CLEAR AVAILED
222	16-Dec-20	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN : LINE CLEAR AVAILED
223	16-Dec-20	GULBARGA	66	HV1	KUDLIGI_66	07:20	08:10	00:50	TRANSFORMER FAULT
224	16-Dec-20	GULBARGA	66	HV1	KUDLIGI_66	08:35	08:40	00:05	TRANSFORMER FAULT
225	16-Dec-20	GULBARGA	66	HV2	TUNGA BHADRA_66	06:00	06:30	00:30	TRANSFORMER FAULT
226	16-Dec-20	GULBARGA	66	HV3	KUDLIGI_66	13:40	13:45	00:05	TRANSFORMER FAULT
227	16-Dec-20	GULBARGA	66	HV3	TUNGA BHADRA_66	06:00	06:26	00:26	TRANSFORMER FAULT
228	16-Dec-20	GULBARGA	66	HV4	TUNGA BHADRA_66	06:00	09:39	03:39	TRANSFORMER FAULT
229	16-Dec-20	GULBARGA	66	ITTAGI-HIREHADAGALI1	ITTAGI_220	06:05	06:16	00:11	LINE FAULT
230	16-Dec-20	GULBARGA	110	GABUR-RAICHUR	GABUR_110	02:55	03:00	00:05	MAIN SUPPLY FAILURE
231	16-Dec-20	GULBARGA	110	GABUR-RAICHUR	GABUR_110	03:35	03:40	00:05	MAIN SUPPLY FAILURE
232	16-Dec-20	GULBARGA	110	GABUR-RAICHUR	GABUR_110	17:00	17:25	00:25	MAIN SUPPLY FAILURE
233	16-Dec-20	GULBARGA	110	HV1	HANUMANAL_110	16:45	17:20	00:35	LINE CLEAR AVAILED
234	16-Dec-20	GULBARGA	110	HV1	HANUMASAGAR_110	08:15	09:15	01:00	LINE CLEAR AVAILED
235	16-Dec-20	GULBARGA	110	MARAGUTTI-CLN SLR	MARAGUTTI_110	18:25	22:35	04:10	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
236	16-Dec-20	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	02:52	02:58	00:06	LINE FAULT
237	16-Dec-20	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	03:35	03:42	00:07	LINE FAULT
238	16-Dec-20	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	01:18	01:28	00:10	LINE FAULT
239	16-Dec-20	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	04:18	04:30	00:12	LINE FAULT
240	16-Dec-20	GULBARGA	220	HUMNABAD-SEDAM1	SEDAM_220	15:21	17:20	01:59	LINE CLEAR AVAILED
241	16-Dec-20	GULBARGA	220	HV2	RAICHUR_220	10:20	17:25	07:05	LINE CLEAR AVAILED
242	16-Dec-20	GULBARGA	400	BTPS-HIRIYUR2	HIRIYUR_400	13:01(16.12.20)			LINE OPEN : LINE CLEAR AVAILED
243	16-Dec-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	10:56 (5.12.2020)			LINE OPEN : LINE CLEAR AVAILED
244	16-Dec-20	HASSAN	66	BHADRA-SHMGGA 1	bhadra_gen	16:26 (5.12.2020)			LINE OPEN : LINE CLEAR AVAILED
245	16-Dec-20	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	18:01	18:05	00:04	HAND TRIPPED
246	16-Dec-20	HASSAN	66	HV1	MALLIPATNA_66	14:05	15:30	01:25	LINE CLEAR AVAILED
247	16-Dec-20	HASSAN	66	HV1	MALLIPATNA_66	15:50	16:00	00:10	LINE CLEAR AVAILED
248	16-Dec-20	HASSAN	66	HV2	HOLEHONNUR_66	07:44	07:51	00:07	HAND TRIPPED
249	16-Dec-20	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
250	16-Dec-20	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
251	16-Dec-20	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
252	16-Dec-20	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	16:26 (5.12.2020)			LINE OPEN : LINE CLEAR AVAILED
253	16-Dec-20	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	18:42	18:52	00:10	LINE FAULT
254	16-Dec-20	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	19:44	23:56	04:12	LINE CLEAR AVAILED
255	16-Dec-20	HASSAN	110	HV1	KULASHEKARA-110	10:01	16:18	06:17	LINE CLEAR AVAILED
256	16-Dec-20	HASSAN	110	HV1	MADHUVANA_110	18:55	23:57	05:02	LINE CLEAR AVAILED
257	16-Dec-20	HASSAN	110	HV1	SALATHUR_110	11:40	13:02	01:22	LINE CLEAR AVAILED
258	16-Dec-20	HASSAN	110	HV2	NAVUNDA_110	18:42 (16.12.2020)			LINE CLEAR AVAILED
259	16-Dec-20	HASSAN	110	HV2	KUNDAPURA_110	18:53	23:58	05:05	MAIN SUPPLY FAILURE
260	16-Dec-20	HASSAN	110	HV5	MRSMSG_220	10:46	10:50	00:04	HAND TRIPPED
261	16-Dec-20	HASSAN	110	KEMAR-BELMAN	KEMAR_220	08:06	16:49	08:43	LINE CLEAR AVAILED
262	16-Dec-20	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	10:45	14:26	03:41	LINE CLEAR AVAILED
263	16-Dec-20	HASSAN	110	NAVUNDA-MADHUVANA	NAVUNDA_110	18:42 (16.12.2020)			LINE CLEAR AVAILED
264	16-Dec-20	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	10:22	17:26	07:04	LINE CLEAR AVAILED
265	16-Dec-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	13:19 (14.12.2020)	7:22 (16.12.2020)	42:02 hrs	LINE CHARGED
266	16-Dec-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	10:22	17:25	07:03	LINE CLEAR AVAILED
267	16-Dec-20	MYSORE	66	CR NAGARA-CHANDAKWADI	CHANDAKAVADI_66	9:47	9:57	0:10	LINE FAULT
268	16-Dec-20	MYSORE	66	CR NAGARA-HONNALLY	ATTIGULIPURA_66 HONNALLY_MYS_66	9:47	9:59	0:12	LINE FAULT
269	16-Dec-20	MYSORE	66	DR PETE-CR NAGAR 1	NO STATIONS EFFECTED	15:09	15:55	0:46	HAND TRIPPED
270	16-Dec-20	MYSORE	66	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	11:55	12:04	0:09	LINE FAULT
271	16-Dec-20	MYSORE	66	HUNSUR-HOOTAGALLI	HOSURGATE_66	6:08	6:20	0:11	LINE FAULT
272	16-Dec-20	MYSORE	66	HV1	DODDABYADARAHALLI_66	12:25	13:47	1:22	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
273	16-Dec-20	MYSORE	66	HV1	DEVANOORMYS_66	10:34	10:53	0:18	TRANSFORMER FAULT
274	16-Dec-20	MYSORE	66	HV1	SANIVARASANTHE_66	12:35	14:22	1:47	LINE CLEAR AVAILED
275	16-Dec-20	MYSORE	66	HV1	SANIVARASANTHE_66	16:46	16:54	0:07	LINE CLEAR AVAILED
276	16-Dec-20	MYSORE	66	HV2	DODDABYADARAHALLI_66	10:50	12:30	1:40	LINE CLEAR AVAILED
277	16-Dec-20	MYSORE	66	HV2	SANIVARASANTHE_66	11:45	12:45	1:00	LINE CLEAR AVAILED
278	16-Dec-20	MYSORE	66	HV2	SANIVARASANTHE_66	12:55	13:00	0:05	TRANSFORMER FAULT
279	16-Dec-20	MYSORE	66	KM DODDI-KK DODDI	KOLKARANADODDI_66	10:28	14:08	3:40	NFBC ISSUED
280	16-Dec-20	MYSORE	66	KM DODDI-TK HALLI	KMDODDI_66	10:20	10:42	0:21	HAND TRIPPED
281	16-Dec-20	MYSORE	66	TALAKADU-PARINAMIPURA	CHANDALLI_66	6:18	6:25	0:07	LINE FAULT
282	16-Dec-20	TUMKUR	66	GULIGENAHALLI- SIRA	GULIGENAHALLI_66	23:04	23:09	0:05	LINE FAULT
283	16-Dec-20	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	11:00	12:13	1:13	LINE CLEAR AVAILED
284	16-Dec-20	TUMKUR	66	SIRA- BUKKAPATNA	SIRA_66	23:12	23:14	0:02	MAIN SUPPLY FAILURE
285	16-Dec-20	TUMKUR	66	SIRA- MADHUGIRI 2	SIRA_66	23:12	23:14	0:01	MAIN SUPPLY FAILURE
286	16-Dec-20	TUMKUR	66	TR-1	PAVAGADA_220	15:38	15:44	0:05	TRANSFORMER FAULT
287	16-Dec-20	TUMKUR	66	TR-1(LV SIDE)	ANTHRASANAHALLI_220	11:39	14:18	2:39	LINE CLEAR AVAILED
288	16-Dec-20	TUMKUR	66	TR-2	KORATAGERE_66	12:03	12:24	0:21	LINE CLEAR AVAILED
289	16-Dec-20	TUMKUR	66	TR-2	KORATAGERE_66	13:31	14:37	1:06	LINE CLEAR AVAILED
290	16-Dec-20	TUMKUR	66	TR-3	IMANGALA_66	15:16	20:15	4:58	LINE CLEAR AVAILED
291	16-Dec-20	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	12:50	13:31	0:41	LINE CLEAR AVAILED
292	16-Dec-20	TUMKUR	220	HONNALLI 220kV- SHIMOGA 220kV	HONNALLI_220	13:01	13:12	0:11	LOAD CURTAILMENT
293	16-Dec-20	TUMKUR	220	HONNALLI 220kV-DAVANAGERE SRS	HONNALLI_220	13:01	13:12	0:11	LOAD CURTAILMENT
294	17-Dec-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN : LINE CLEAR AVAILED
295	17-Dec-20	BAGALKOT	110	110/11KV, HV2	ZALKI_110	16:07	16:13	0:06	TRANSFORMER FAULT
296	17-Dec-20	BAGALKOT	110	110/11KV, HV2	UGARKHUD_110	11:10	18:26	7:16	LINE CLEAR AVAILED
297	17-Dec-20	BAGALKOT	110	110/11KV, HV3	UGARKHUD_110	10:08	18:00	7:52	LINE CLEAR AVAILED
298	17-Dec-20	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
299	17-Dec-20	BAGALKOT	110	110/11KV, HV4	KERUR_110	12:14	12:19	0:05	TRANSFORMER FAULT
300	17-Dec-20	BAGALKOT	110	110/33KV,HV3	KIADB BIJAPUR_110 & HONNUTAGI_33,NAGATHAN_33	10:47	11:35	0:48	HAND TRIPPED
301	17-Dec-20	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL_220	12:39 (28.11.2020)			LINE OPEN : LINE CLEAR AVAILED
302	17-Dec-20	BAGALKOT	110	GHATAPRABHA-HIDIKAL DAM	HIDIKAL DAM_110	13:54	14:19	0:25	LINE FAULT
303	17-Dec-20	BAGALKOT	110	GSML1- MAHALINGAPUR	MAHALINGAPUR_220	18:27	18:41	0:14	LINE FAULT
304	17-Dec-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN : LINE CLEAR AVAILED
305	17-Dec-20	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN : LINE CLEAR AVAILED
306	17-Dec-20	BAGALKOT	110	HUKKERI- HATTARGI	STATION NOT AFFECTED HUKKERI_110	21:40 (17.12.2020)			LINE OPEN : LINE FAULT
307	17-Dec-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
308	17-Dec-20	BAGALKOT	110	KUDUCHI-TERDAL	STATION NOT AFFECTED TERDAL_110	13:10 (14.12.2020)			LINE OPEN : LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
309	17-Dec-20	BAGALKOT	110	RANEENNUR- BYADAGI (GUTTAL)	STATION NOT AFFECTED GUTTAL 110	14:07	20:38	6:31	LINE CLEAR AVOIDED
310	17-Dec-20	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR 220	13:16 (17.11.2020)			LINE OPEN : LINE FAULT
311	17-Dec-20	BAGALKOT	220	220/110KV, HV3	MAHALINGAPUR_220, RABAKAVI_110, ITANAL_110, HIDIKAL 110	18:15	18:46	0:31	TRANSFORMER FAULT
312	17-Dec-20	BAGALKOT	220	220/110KV,HV1 &LV1	BIJAPUR_220	13:14	13:49	0:35	LINE CLEAR AVOIDED
313	17-Dec-20	BAGALKOT	220	220/110KV,HV2 &LV2	BAGALKOT_220	12:36	16:58	4:22	LINE CLEAR AVOIDED
314	17-Dec-20	BAGALKOT	220	220/110KV,HV2 &LV2	BIJAPUR_220	11:43	13:13	1:30	LINE CLEAR AVOIDED
315	17-Dec-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI 220	16:21 (02.11.2020)			LINE OPEN : LINE CLEAR AVALIED
316	17-Dec-20	BAGALKOT	220	BELGAUM-KANABARGI1 (NARENDRA1)	BELGAUM_220	10:36	18:39	8:03	NFBC ISSUED
317	17-Dec-20	BAGALKOT	220	BELGAUM-KANABARGI2 (NARENDRA2)	BELGAUM_220	10:45	18:40	7:55	NFBC ISSUED
318	17-Dec-20	BAGALKOT	220	DHONI-GADAG1	DHONI_400	10:33	17:07	6:34	LINE CLEAR AVOIDED
319	17-Dec-20	BAGALKOT	220	DHONI-GADAG2	DHONI_400	05:54	17:07	11:13	LINE FAULT
320	17-Dec-20	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG 220	10:48 (16.12.2020)			LINE OPEN : LINE CLEAR AVALIED
321	17-Dec-20	BAGALKOT	220	GUTTUR2- HAVERI	STATION NOT AFFECTED HAVERI 220	16:26 (16.12.2020)			LINE OPEN : LINE CLEAR AVALIED
322	17-Dec-20	BAGALKOT	220	KUDACHI- ATHANI	KUDACHI_220	12:05	17:04	4:59	LINE CLEAR AVOIDED
323	17-Dec-20	BAGALKOT	220	KUDACHI- ATHANI	KUDACHI_220	18:27	19:55	1:28	LINE FAULT
324	17-Dec-20	BAGALKOT	220	MAHALINGAPUR- ATHANI	MAHALINGAPUR_220	18:30	18:55	0:25	LINE FAULT
325	17-Dec-20	BAGALKOT	220	MAHALINGAPUR- KUDACHI	MAHALINGAPUR_220	18:13	18:54	0:41	LINE FAULT
326	17-Dec-20	BAGALKOT	220	NARENDRA- BELGAUM1	NARENDRA_220	10:37	19:38	9:01	LINE CLEAR AVOIDED
327	17-Dec-20	BAGALKOT	220	NARENDRA- BELGAUM2	NARENDRA_220	10:37	19:37	9:00	LINE CLEAR AVOIDED
328	17-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI 220	6:15 (28.11.2020)			LOAD CURTAILMENT
329	17-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI 220	6:15 (28.11.2020)			LOAD CURTAILMENT
330	17-Dec-20	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	VAJRAMATTI_220	18:27	19:01	0:34	LINE FAULT
331	17-Dec-20	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR2	VAJRAMATTI_220	18:27	19:02	0:35	LINE FAULT
332	17-Dec-20	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN : LINE CLEAR AVALIED
333	17-Dec-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN : LINE FAULT
334	17-Dec-20	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	11:30	13:16	01:46	LINE CLEAR AVOIDED
335	17-Dec-20	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	15:10	15:14	00:04	LOAD CHANGE OVER
336	17-Dec-20	BENGALURU	66	HBR LAYOUT-HOSKOTE 220	HBR LAYOUT, BELL CERAMICS (EHT)	14:15	14:23	00:08	MAIN SUPPLY FAILURE
337	17-Dec-20	BENGALURU	66	HBR LAYOUT-HOSKOTE 220	HBR LAYOUT, BELL CERAMICS (EHT)	16:40	16:49	00:09	LOAD CHANGE OVER
338	17-Dec-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	NO STATION AFFECTED	14:15	14:37	00:22	LINE FAULT
339	17-Dec-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	NO STATION AFFECTED	16:40	19:08	02:28	LINE FAULT
340	17-Dec-20	BENGALURU	66	HV1	CHATRA	12:43	13:29	00:46	LINE CLEAR AVOIDED
341	17-Dec-20	BENGALURU	66	HV1	HOSKOTE 66	13:19	13:41	00:22	TRANSFORMER FAULT
342	17-Dec-20	BENGALURU	66	HV1	KOLAR 220	17:12	19:57	02:45	TRANSFORMER FAULT
343	17-Dec-20	BENGALURU	66	HV1	YELAHANKA 220	11:27	11:30	00:03	LINE CLEAR AVOIDED
344	17-Dec-20	BENGALURU	66	HV1	BIJAHALLI	15:59	16:05	00:06	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
345	17-Dec-20	BENGALURU	66	HV2	CHATRA	11:08	12:38	01:30	LINE CLEAR AVAILED
346	17-Dec-20	BENGALURU	66	HV2	NAGANATHPURA 220	12:24	12:27	00:03	LINE CLEAR AVAILED
347	17-Dec-20	BENGALURU	66	HV2	HOSKOTE 66	11:05	13:02	01:57	TRANSFORMER FAULT
348	17-Dec-20	BENGALURU	66	HV2	MULBAGAL	09:04	09:43	00:39	LINE CLEAR AVAILED
349	17-Dec-20	BENGALURU	66	HV2	MULBAGAL	10:57	11:57	01:00	LINE CLEAR AVAILED
350	17-Dec-20	BENGALURU	66	KORMANGALA 220 - L3	NO STATION AFFECTED	21:57 (16/12/2020)	2:41(17/12/2020)	4:44 HRS	LINE CHARGED
351	17-Dec-20	BENGALURU	66	PLATINUM CITY - YELAHANKA 220	PLATINUM CITY	8:00(16/12/2020)	19:30(17/12/2020)	35:30 HRS	LINE CHARGED
352	17-Dec-20	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN : LINE CLEAR AVAILED
353	17-Dec-20	BENGALURU	220	HV2	EAST DIVISION COMPOUND	12:35(17/12/2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
354	17-Dec-20	GULBARGA	110	KAPNOOR-HUMNABABD1	MAHAGOAN,MARAGUTTI_110	03:29	06:51	03:22	LINE CLEAR AVAILED
355	17-Dec-20	GULBARGA	110	KAPNOOR-HUMNABABD1	MAHAGOAN,MARAGUTTI_110	09:45	17:30	07:45	LINE CLEAR AVAILED
356	17-Dec-20	GULBARGA	110	KOLHAR-NSSK	NSSK_I PP	02:05	02:11	00:06	LINE FAULT
357	17-Dec-20	GULBARGA	110	KUSTAGI- HANUMASAGAR	HANUMASAGAR,HIREGONNAGAR,HU NUMNAL_110	02:00	11:20	09:20	LINE CHARGED
358	17-Dec-20	GULBARGA	110	SINDHANOOR-RAICHUR1	SINDHANOOR_110	11:10	14:10	03:00	LINE FAULT
359	17-Dec-20	GULBARGA	110	SINDHANOOR-RAICHUR2	MANVI_110,MADLAPUR_110,KURDI CROSS_110	04:35	04:45	00:10	LINE FAULT
360	17-Dec-20	GULBARGA	220	ALIPUR-BTPS	GOOTY_220	12:15	18:06	05:51	LINE CLEAR AVAILED
361	17-Dec-20	GULBARGA	220	KAPNOOR-MADIYAL	MADIYAL,NSL,SUGARFACTOR,CHOWD APUR_110	11:00	17:57	06:57	LINE CLEAR AVAILED
362	17-Dec-20	GULBARGA	220	LINGAPUR-SINDHANOOR	SINDHANOOR_220	08:44	13:59	05:15	LINE CLEAR AVAILED
363	17-Dec-20	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	03:54	04:18	00:24	LINE FAULT
364	17-Dec-20	GULBARGA	400	BTPS-HIRIYUR2	HIRIYUR_400	13:01(16.12.2020)	5:55(17.12.2020)	16:54HRS	LINE CHARGED
365	17-Dec-20	GULBARGA	400	JSWVL-GUTTUR	GUTTUR_400	10:50	19:54	09:04	LINE CLEAR AVAILED
366	17-Dec-20	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	10:58	13:10	02:12	NFBC ISSUED
367	17-Dec-20	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	15:15	15:40	00:25	MAIN SUPPLY FAILURE
368	17-Dec-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	10:56 (5.12.2020)	12:45 (17.12.2020)	289:48 hrs	LINE CHARGED
369	17-Dec-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	15:40	16:40	01:00	LINE FAULT
370	17-Dec-20	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	16:26 (5.12.2020)	15:05 (17.12.2020)	286:38 hrs	LINE CHARGED
371	17-Dec-20	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	15:40	16:20	00:40	LINE FAULT
372	17-Dec-20	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	15:30	16:30	01:00	LINE CLEAR AVAILED
373	17-Dec-20	HASSAN	66	HASSN220-ARAKALGUD	HASSN_220	15:15	15:37	00:22	LINE FAULT
374	17-Dec-20	HASSAN	66	HASSN220-HN PURA	HASSN_220	13:51	14:51	01:00	LINE CLEAR AVAILED
375	17-Dec-20	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	10:59	12:54	01:55	LINE CLEAR AVAILED
376	17-Dec-20	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	11:00	13:03	02:03	MAIN SUPPLY FAILURE
377	17-Dec-20	HASSAN	66	HV1	MALALI_66	11:01	13:02	02:01	NFBC ISSUED
378	17-Dec-20	HASSAN	66	HV1	SOMANAHALLI_66	16:40	17:28	00:48	LINE CLEAR AVAILED
379	17-Dec-20	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
380	17-Dec-20	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
381	17-Dec-20	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
382	17-Dec-20	HASSAN	66	MALALI-CRPATNA	MALALI_66	11:01	13:01	02:00	NFBC ISSUED
383	17-Dec-20	HASSAN	66	MALALI-HASSAN	MALALI_66	11:01	13:01	02:00	NFBC ISSUED
384	17-Dec-20	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	16:26 (5.12.2020)	14:58 (17.12.2020)	286:31 hrs	LINE CHARGED
385	17-Dec-20	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	15:29	16:11	00:42	HAND TRIPPED
386	17-Dec-20	HASSAN	110	HALADY11-HOSANGADI	HALADY_110	10:57	18:11	07:14	LINE CLEAR AVAILED
387	17-Dec-20	HASSAN	110	HOSNGD-VTRG1	HOSANGADI_110	09:53	17:50	07:57	LINE CLEAR AVAILED
388	17-Dec-20	HASSAN	110	HOSNGD-VTRG2	HOSANGADI_110	09:53	17:50	07:57	LINE CLEAR AVAILED
389	17-Dec-20	HASSAN	110	HULICA-KVR	HULICAL_110	09:05	17:18	08:13	LINE CLEAR AVAILED
390	17-Dec-20	HASSAN	110	HV1	HOSANGADI_110	09:38	17:35	07:57	LINE CLEAR AVAILED
391	17-Dec-20	HASSAN	110	HV2	NAVUNDA_110	18:42 (16.12.2020)	0:03 (17.12.2020)	5:20 hrs	TRANSFORMER CHARGED
392	17-Dec-20	HASSAN	110	HV2	HOSANGADI_110	10:52	17:40	06:48	LINE CLEAR AVAILED
393	17-Dec-20	HASSAN	110	MSEZ-BAIKAMPADY	MSEZ_220	09:46	14:40	04:54	LINE CLEAR AVAILED
394	17-Dec-20	HASSAN	110	NAVUNDA-MADHUVANA	NAVUNDA_110	18:42 (16.12.2020)	0:03 (17.12.2020)	5:20 hrs	LINE CHARGED
395	17-Dec-20	HASSAN	220	KEMAR-Varahi3	KEMAR_220	09:53	11:35	01:42	LINE CLEAR AVAILED
396	17-Dec-20	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	14:27	16:29	02:02	LINE CLEAR AVAILED
397	17-Dec-20	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	14:27	16:21	01:54	LINE CLEAR AVAILED
398	17-Dec-20	HASSAN	220	VARAHI-KEMAR3	varahi_gen	09:53	11:36	01:43	NFBC ISSUED
399	17-Dec-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	15:00	17:10	02:10	LINE FAULT
400	17-Dec-20	MYSORE	66	CR NAGARA-HONNALLY	HONNALLY_MYS_66 ATTIGULIPURA_66	10:38	10:43	0:05	LINE FAULT
401	17-Dec-20	MYSORE	66	HV1	DATTAGALLY_66	12:08	14:36	2:27	LINE CLEAR AVAILED
402	17-Dec-20	MYSORE	66	HV1	MADDUR_66	12:42	14:25	1:42	LINE CLEAR AVAILED
403	17-Dec-20	MYSORE	66	HV1	KABHALLY_66	13:47	14:17	0:30	LINE CLEAR AVAILED
404	17-Dec-20	MYSORE	66	HV1	PONNAMPET_66	11:01	11:35	0:33	LINE CLEAR AVAILED
405	17-Dec-20	MYSORE	66	HV1	PONNAMPET_66	11:40	11:57	0:16	LINE CLEAR AVAILED
406	17-Dec-20	MYSORE	66	HV1	SHIVALLY_66	13:25	13:27	0:01	HAND TRIPPED
407	17-Dec-20	MYSORE	66	HV2	MADDUR_66	14:20	15:00	0:39	LINE CLEAR AVAILED
408	17-Dec-20	MYSORE	66	HV2	MEGALAPURA_66	9:48	9:51	0:02	HAND TRIPPED
409	17-Dec-20	MYSORE	66	HV2	KOLLEGALA_66	15:27	16:30	1:02	LINE CLEAR AVAILED
410	17-Dec-20	MYSORE	66	KADAKOLA-DEVANUR (N'GUD)	NO STATIONS EFFECTED	9:53	18:33	8:40	LINE CLEAR AVAILED
411	17-Dec-20	MYSORE	66	KADAKOLA-RK NAGAR	NO STATIONS EFFECTED	10:08	18:32	8:24	LINE CLEAR AVAILED
412	17-Dec-20	MYSORE	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66 ANTHARSANTHE_66 HDKOTE_66	9:58	10:11	0:13	HAND TRIPPED
413	17-Dec-20	MYSORE	66	KADAKOLA-THANDYA	NO STATIONS EFFECTED	9:18	18:35	9:16	LINE CLEAR AVAILED
414	17-Dec-20	MYSORE	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	11:12 (17.12.2020)			LINE OPEN : LINE CLEAR AVAILED
415	17-Dec-20	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	20:07	20:11	0:03	LINE FAULT
416	17-Dec-20	MYSORE	66	VAJAMANGALA-MEGHALAPURA	MEGALAPURA_66	11:37	16:28	4:50	NFBC ISSUED
417	17-Dec-20	MYSORE	220	HOOTAGALLI-KADAKOLA	NO STATIONS EFFECTED	9:18	15:31	6:12	LINE CLEAR AVAILED
418	17-Dec-20	MYSORE	220	HV1	KADAKOLA_220	10:15	14:34	4:18	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
419	17-Dec-20	MYSORE	220	HV2	KADAKOLA_220	14:36	18:29	3:53	LINE CLEAR AVAILED
420	17-Dec-20	MYSORE	220	HV2	TUBINAKERE_220	10:38	14:10	3:32	LINE CLEAR AVAILED
421	17-Dec-20	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	12:57	14:25	1:28	MAIN SUPPLY FAILURE
422	17-Dec-20	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	18:30	18:39	0:09	LINE FAULT
423	17-Dec-20	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	4:20	4:29	0:08	MAIN SUPPLY FAILURE
424	17-Dec-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	12:47	14:31	1:43	LINE FAULT
425	17-Dec-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	15:02	15:08	0:06	LINE FAULT
426	17-Dec-20	TUMKUR	66	KALAMARANAHALLI- PR PURA	KALAMARANAHALLI_66	4:10	4:34	0:23	LINE FAULT
427	17-Dec-20	TUMKUR	66	MALEBENNUR-HONNALLI220	MALEBENNUR_66	8:37	9:30	0:52	LINE FAULT
428	17-Dec-20	TUMKUR	66	NAGASAMUDRA- HANAGAL	NAGASAMUDRA_66	18:29	18:39	0:10	LINE FAULT
429	17-Dec-20	TUMKUR	66	NAGASAMUDRA- IPP_SOLAR	IPP_SOLAR_66	18:38	18:41	0:03	HAND TRIPPED
430	17-Dec-20	TUMKUR	66	NAGASAMUDRA- RAMPURA	NAGASAMUDRA_66	18:29	18:46	0:17	LINE FAULT
431	17-Dec-20	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHANGIDU RGA_66,PALLAGATTE_66, SOKKE_66	15:50	15:59	0:08	LINE FAULT
432	17-Dec-20	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHANGIDU RGA_66,PALLAGATTE_66, SOKKE_66	16:05	16:22	0:16	LINE FAULT
433	17-Dec-20	TUMKUR	66	RAMPURA66-ABLETEC(SSHTY)_IPP_66	ABLETEC(SSHTY)_IPP_66	18:52	19:15	0:22	HAND TRIPPED
434	17-Dec-20	TUMKUR	66	TR-1	DEVARAHALLI_66	12:57	14:25	1:28	MAIN SUPPLY FAILURE
435	17-Dec-20	TUMKUR	66	TR-1	LINGADAHALLI_TMK2_66	10:43	10:58	0:14	TRANSFORMER FAULT
436	17-Dec-20	TUMKUR	66	TR-1	RANGENAHALLI_66	17:04	17:25	0:21	HAND TRIPPED
437	17-Dec-20	TUMKUR	66	TR-2	MALEBENNUR_66	8:37	9:32	0:54	LINE CLEAR AVAILED
438	17-Dec-20	TUMKUR	66	TR-2(LV SIDE)	ANTHRASANAHALLI_220	15:34	18:52	3:18	LINE CLEAR AVAILED
439	17-Dec-20	TUMKUR	220	NITTUR 220kV- NELAMANGALA	NITTUR_220	12:49	18:17	5:27	LINE CLEAR AVAILED
440	17-Dec-20	TUMKUR	220	TR-2(HV SIDE)	ANTHRASANAHALLI_220	15:35	18:52	3:17	LINE CLEAR AVAILED
441	18-Dec-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN : LINE CLEAR AVAILED
442	18-Dec-20	BAGALKOT	110	110/11KV HV1	ATHARGA_110	12:59	13:04	0:05	HAND TRIPPED
443	18-Dec-20	BAGALKOT	110	110/11KV, HV1	BYADAGI_110	15:18	15:27	0:09	TRANSFORMER FAULT
444	18-Dec-20	BAGALKOT	110	110/11KV, HV2	MAMADAPUR(B)_110	11:48	14:29	2:41	LINE CLEAR AVAILED
445	18-Dec-20	BAGALKOT	110	110/11KV, HV2	KAGAWAD_110	14:13	15:16	1:03	LINE CLEAR AVAILED
446	18-Dec-20	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
447	18-Dec-20	BAGALKOT	110	110/11KV,HV1	ANANDNAGAR_110	11:03	12:02	0:59	LINE CLEAR AVAILED
448	18-Dec-20	BAGALKOT	110	110/33KV, HV2	SADALAGA_110, BHOJ_33	11:37	12:43	1:06	LINE CLEAR AVAILED
449	18-Dec-20	BAGALKOT	110	110/33KV,HV4	GOPANAKOPPA_110 & KUSUGAL_33	10:01(18.12.20)			TRANSFORMER OPEN : LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
450	18-Dec-20	BAGALKOT	110	110/33KV,HV4	GOPANAKOPPA_110 & KMC_33	10:01	17:52	7:51	LINE CLEAR AVAILED
451	18-Dec-20	BAGALKOT	110	AMBEWADI-SUPA1	AMBEWADI_220	17:18	18:04	0:46	LINE CLEAR AVAILED
452	18-Dec-20	BAGALKOT	110	ATHARGA - KN SOLAR	ATHARGA_110	12:48	13:42	0:54	HAND TRIPPED
453	18-Dec-20	BAGALKOT	110	ATHARGA - KN SOLAR	ATHARGA_110	13:36	13:42	0:06	HAND TRIPPED
454	18-Dec-20	BAGALKOT	110	ATHARGA-DEVER HIPPARAGI (BAGEWADI)	DEVAR HIPPARAGI_110	13:03	13:04	0:01	HAND TRIPPED
455	18-Dec-20	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL_220	12:39 (28.11.2020)			LINE OPEN : LINE CLEAR AVAILED
456	18-Dec-20	BAGALKOT	110	GHATAPRABHA-HIDIKAL DAM	HIDIKAL DAM_110	14:11	14:25	0:14	LINE FAULT
457	18-Dec-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN : LINE CLEAR AVAILED
458	18-Dec-20	BAGALKOT	110	HIREBEVANUR-SHIVASAGAR SUGARS	HIREBEVANUR_110	11:25	11:28	0:03	LINE FAULT
459	18-Dec-20	BAGALKOT	110	HUBLI- KADANKOPPA	KADANKOPPA_110	12:33	12:34	0:01	LINE CLEAR AVAILED
460	18-Dec-20	BAGALKOT	110	HUBLI- KADANKOPPA	KADANKOPPA_110	13:01	13:02	0:01	LINE CLEAR AVAILED
461	18-Dec-20	BAGALKOT	110	HUBLI- RAMANKOPPA	RAMANKOPPA_110	11:31	11:33	0:02	LINE CLEAR AVAILED
462	18-Dec-20	BAGALKOT	110	HUBLI- RAMANKOPPA	RAMANKOPPA_110	12:36	12:37	0:01	LINE CLEAR AVAILED
463	18-Dec-20	BAGALKOT	110	HUBLI- TARIHAL	TARIHAL_110	12:43	12:44	0:01	LINE CLEAR AVAILED
464	18-Dec-20	BAGALKOT	110	HUBLI- TARIHAL	TARIHAL_110	13:00	13:01	0:01	LINE CLEAR AVAILED
465	18-Dec-20	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN : LINE CLEAR AVAILED
466	18-Dec-20	BAGALKOT	110	HUKKERI- HATTARGI	STATION NOT AFFECTED HUKKERI_110	21:40 (17.12.2020)	7:38 (18.12.2020)	9:58HRS	LINE CHARGED
467	18-Dec-20	BAGALKOT	110	HUKKERI-VISHWANATH SUGARS	HUKKERI_110	7:12	7:46	0:34	LINE FAULT
468	18-Dec-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
469	18-Dec-20	BAGALKOT	110	KUDUCHI-TERDAL	STATION NOT AFFECTED TERDAL_110	13:10 (14.12.2020)			LINE OPEN : LINE FAULT
470	18-Dec-20	BAGALKOT	110	NARENDRA- KUD1	STATION NOT AFFECTED KUD DHARWAD_110	10:48	16:57	6:09	LINE CLEAR AVAILED
471	18-Dec-20	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN : LINE FAULT
472	18-Dec-20	BAGALKOT	220	220/110KV, HV1 & LV1	CHIKKODI_220	10:00	13:11	3:11	LINE CLEAR AVAILED
473	18-Dec-20	BAGALKOT	220	220/110KV, HV1 & LV1	GADAG_220	11:25	18:19	6:54	LINE CLEAR AVAILED
474	18-Dec-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN : LINE CLEAR AVAILED
475	18-Dec-20	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	15:00	17:20	2:20	NFBC ISSUED
476	18-Dec-20	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN : LINE CLEAR AVAILED
477	18-Dec-20	BAGALKOT	220	GUTTUR2- HAVERI	STATION NOT AFFECTED HAVERI_220	16:26 (16.12.2020)	14:50 (18.12.2020)	46:24HRS	LINE CHARGED
478	18-Dec-20	BAGALKOT	220	MKHUBLI- NARENDRA1	MKHUBLI_220	13:09 (18.12.2020)			LINE OPEN : LINE CLEAR AVAILED
479	18-Dec-20	BAGALKOT	220	NAGJHARI3- HUBLI	HUBLI_220	11:37	12:31	0:54	LINE CLEAR AVAILED
480	18-Dec-20	BAGALKOT	220	NAGJHARI3- HUBLI	HUBLI_220	12:54	15:56	3:02	LINE CLEAR AVAILED
481	18-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
482	18-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
483	18-Dec-20	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN : LINE CLEAR AVAILED
484	18-Dec-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN : LINE FAULT
485	18-Dec-20	BENGALURU	66	HBR LAYOUT - L R BANDE	HBR LAYOUT	07:05	07:11	00:06	LOAD CHANGE OVER
486	18-Dec-20	BENGALURU	66	HV1	ELECTRONIC CITY PH-2 SEC-2	17:48	17:56	00:08	TRANSFORMER FAULT
487	18-Dec-20	BENGALURU	66	HV1	DEVANAHALLI	14:15	14:25	00:10	TRANSFORMER FAULT
488	18-Dec-20	BENGALURU	66	HV1	YEDUMADU	10:30	11:15	00:45	LINE CLEAR AVOID
489	18-Dec-20	BENGALURU	66	HV2	MAASTHI	10:25	11:15	00:50	TRANSFORMER FAULT
490	18-Dec-20	BENGALURU	66	HV2	MAASTHI	13:15	14:10	00:55	LINE CLEAR AVOID
491	18-Dec-20	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN : LINE CLEAR AVAILED
492	18-Dec-20	BENGALURU	220	HV2	EAST DIVISION COMPOUND	12:35(17/12/2020)	19:32(18/12/2020)	30:57HRS	TRANSFORMER CHARGED
493	18-Dec-20	GULBARGA	66	KUDLIGI-HANASI	HAMASI_66	14:15	15:10	00:55	LINE CLEAR AVOID
494	18-Dec-20	GULBARGA	110	HV1	SANKLAPUR_110	10:30	10:34	00:04	TRANSFORMER FAULT
495	18-Dec-20	GULBARGA	110	KADAGANCHI-TARUNKIRANBHOOMI_IPP	KADAGANCHI_110	19:15	23:05	03:50	LINE CLEAR AVOID
496	18-Dec-20	GULBARGA	110	SHAHAPUR-KEMBHAVI2	KBJNL_110	11:37	15:35	03:58	LINE CLEAR AVOID
497	18-Dec-20	GULBARGA	110	SINDHNOOR-SIRIGUPPA	SIRIGUPPA_110	14:20	14:30	00:10	LINE FAULT
498	18-Dec-20	GULBARGA	220	ALIPUR-BTPS	NEELGUNDA_220,GOOTY_220	06:42	15:25	08:43	LINE FAULT
499	18-Dec-20	GULBARGA	220	LINGAPUR-BTPS	LINGAPUR_220	12:14	14:48	02:34	NFBC ISSUED
500	18-Dec-20	GULBARGA	400	BTPS-RTPS	RTPS_400	10:34	20:25	09:51	LINE CLEAR AVOID
501	18-Dec-20	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	09:56	16:26	06:30	LINE CLEAR AVOID
502	18-Dec-20	HASSAN	66	HASSN220-ARAKALGUD	HASSAN_220	06:50	08:46	01:56	LINE FAULT
503	18-Dec-20	HASSAN	66	HNNPR2-MYSOR1	HOLENARASIPURA_220	06:30	06:35	00:05	LINE FAULT
504	18-Dec-20	HASSAN	66	HV1	MALALI_66	15:15	15:20	00:05	LINE CLEAR AVOID
505	18-Dec-20	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN : LINE CLEAR AVOID
506	18-Dec-20	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN : LINE CLEAR AVOID
507	18-Dec-20	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN : LINE CLEAR AVOID
508	18-Dec-20	HASSAN	66	MRSSH-M-BD-2	MRSMSG_220	09:56	12:49	02:53	NFBC ISSUED
509	18-Dec-20	HASSAN	66	MRSSH-M-DVG2	MRSMSG_220	11:07	12:05	00:58	LINE FAULT
510	18-Dec-20	HASSAN	66	MRSSH-M-DVG2	MRSMSG_220	13:05	13:24	00:19	LINE FAULT
511	18-Dec-20	HASSAN	66	MRSSH-M-DVG2	MRSMSG_220	13:46	13:55	00:09	LINE FAULT
512	18-Dec-20	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	10:20	14:22	04:02	LINE CLEAR AVOID
513	18-Dec-20	HASSAN	110	HV2	KULASHEKARA_110	09:36	14:56	05:20	LINE CLEAR AVOID
514	18-Dec-20	HASSAN	220	MRSSH-M-VARAH13	MRSMSG_220	02:42	18:30	15:48	LINE FAULT
515	18-Dec-20	HASSAN	220	VARAH1-SHMG3	varahi_gen	02:42	18:30	15:48	LINE FAULT
516	18-Dec-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	21:12 (18.12.2020)			LINE OPEN : LINE CLEAR AVAILED
517	18-Dec-20	MYSORE	66	CR NAGARA-DR PETE 1	NO STATIONS EFFECTED	17:54	18:09	0:14	LINE FAULT
518	18-Dec-20	MYSORE	66	CR NAGARA-HONNALLY	ATTIGULIPURA_66 HONNALLY_MYS_66	16:58	17:09	0:11	LINE FAULT
519	18-Dec-20	MYSORE	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	8:42	8:47	0:05	LINE FAULT
520	18-Dec-20	MYSORE	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	10:01	10:07	0:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
521	18-Dec-20	MYSORE	66	HOOTAGALLI-BELAGOLA	BELAGOLA_66	15:05	17:13	2:08	NFBC ISSUED
522	18-Dec-20	MYSORE	66	HOOTAGALLI-HAMPAPURA	KAGGERE HAMPAPURA_66	2:12	2:30	0:18	LINE FAULT
523	18-Dec-20	MYSORE	66	HOOTAGALLI-HAMPAPURA	KAGGERE HAMPAPURA_66	3:27	3:38	0:11	LINE FAULT
524	18-Dec-20	MYSORE	66	HOOTAGALLI-HAMPAPURA	KAGGERE HAMPAPURA_66	4:12	12:20	8:08	LINE FAULT
525	18-Dec-20	MYSORE	66	HV2	MEGALAPURA_66	13:40	14:14	0:34	LINE CLEAR AVAILED
526	18-Dec-20	MYSORE	66	HV3	KRPET_66	9:30	12:11	2:41	LINE CLEAR AVAILED
527	18-Dec-20	MYSORE	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	11:12 (17.12.2020)			LINE OPEN : LINE CLEAR AVAILED
528	18-Dec-20	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJIHALLI_66	10:11	19:48	9:36	LINE CLEAR AVAILED
529	18-Dec-20	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL EHT_66	11:03	11:13	0:10	LINE FAULT
530	18-Dec-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	6:49	6:54	0:05	LINE FAULT
531	18-Dec-20	TUMKUR	66	MADHUGIRI 220kV- PULAMAGATTA	PULAMG_66	18:11	18:32	0:20	LINE FAULT
532	18-Dec-20	TUMKUR	66	PULAMGHATTA66- MADHUGIRI 220kV	PULAMG_66	18:27	18:35	0:08	LINE FAULT
533	18-Dec-20	TUMKUR	66	RANGENAHALLI- AZURESOLAR	AZURESOLAR_IPP_66	6:35	6:48	0:12	LINE FAULT
534	18-Dec-20	TUMKUR	66	RANGENAHALLI- BORUKHASOLAR	BORUKHASOLAR_IPP_66	6:35	6:42	0:06	LINE FAULT
535	18-Dec-20	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	12:45	13:23	0:37	LINE FAULT
536	18-Dec-20	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	14:09	14:26	0:17	LINE FAULT
537	18-Dec-20	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	15:31	15:54	0:23	LINE FAULT
538	18-Dec-20	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUNSOLAR2_IPP_66	12:45	13:25	0:39	LINE FAULT
539	18-Dec-20	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUNSOLAR2_IPP_66	14:12	14:30	0:18	LINE FAULT
540	18-Dec-20	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUNSOLAR2_IPP_66	15:56	17:14	1:18	LINE FAULT
541	18-Dec-20	TUMKUR	66	TR-1	KANCHIPURA_66	14:00	14:55	0:54	HAND TRIPPED
542	18-Dec-20	TUMKUR	66	TR-1	RANGENAHALLI_66	12:25	13:37	1:12	LINE CLEAR AVAILED
543	18-Dec-20	TUMKUR	66	TR-1	SHYLAURA_66	9:17	9:39	0:22	TRANSFORMER FAULT
544	18-Dec-20	TUMKUR	66	TR-1(LV SIDE)	ANTHRASANAHALLI_220	15:25	19:15	3:50	LINE CLEAR AVAILED
545	18-Dec-20	TUMKUR	66	TR-2	BEVINAHALLI_66	15:51	15:54	0:03	LINE CLEAR AVAILED
546	18-Dec-20	TUMKUR	66	TR-2	CHANNAGIRI_66	10:34	10:43	0:08	LINE CLEAR AVAILED
547	18-Dec-20	TUMKUR	66	TR-2	CHANNAGIRI_66	10:46	10:59	0:13	TRANSFORMER FAULT
548	18-Dec-20	TUMKUR	66	TR-2	HIREHALLY_66	6:34	11:48	5:13	LINE CLEAR AVAILED
549	18-Dec-20	TUMKUR	66	TR-2	HULIYURDURGA_66	2:01	2:10	0:08	TRANSFORMER FAULT
550	18-Dec-20	TUMKUR	110	SHETTIKERE- HANDANKERE	SHETYKERE_110	13:15	13:34	0:19	LINE CLEAR AVAILED
551	18-Dec-20	TUMKUR	110	TR-1	HANDANKERE_110	10:59	17:35	6:35	LINE CLEAR AVAILED
552	18-Dec-20	TUMKUR	110	TR-1	SHETYKERE_110	12:15	13:34	1:19	LINE CLEAR AVAILED
553	18-Dec-20	TUMKUR	220	TR-2(HV SIDE)	ANTHRASANAHALLI_220	15:25	19:15	3:50	LINE CLEAR AVAILED
554	18-Dec-20	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	4:00	7:18	3:18	LINE FAULT
555	19-Dec-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN : LINE CLEAR AVAILED
556	19-Dec-20	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED AREMALLAPUR_110	09:05	10:05	1:00	LINE CLEAR AVAILED
557	19-Dec-20	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED DAVALESHWAR_110	07:14	12:30	5:16	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
558	19-Dec-20	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED AREMALLAPUR_110	18:52	19:08	0:16	TRANSFORMER FAULT
559	19-Dec-20	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED DAVALESHWAR_110	12:33	12:57	0:24	HAND TRIPPED
560	19-Dec-20	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
561	19-Dec-20	BAGALKOT	110	110/11KV,HV1	MALGHAN(B)_110	9:15	9:35	0:20	LINE CLEAR AVOIDED
562	19-Dec-20	BAGALKOT	110	110/11KV,HV1	HATTARAGI_110	12:00	14:34	2:34	LINE CLEAR AVOIDED
563	19-Dec-20	BAGALKOT	110	110/33KV,HV3	GUTTAL_110, HOSARITHI_33	13:09	14:06	0:57	LINE CLEAR AVOIDED
564	19-Dec-20	BAGALKOT	110	110/33KV,HV4	GOPANAKOPPA_110,AL_33	10:01 (18.12.2020)	18:12 (19.12.2020)	32:59HRS	TRANSFORMER CHARGED
565	19-Dec-20	BAGALKOT	110	110/33KV,HV4	GOPANAKOPPA_110, KUSUGAL_33	19:07	19:53	0:46	LINE CLEAR AVOIDED
566	19-Dec-20	BAGALKOT	110	110/33KV,HV4	GOPANAKOPPA_110, KUSUGAL_33	18:30	19:00	0:30	LINE CLEAR AVOIDED
567	19-Dec-20	BAGALKOT	110	110/33KV,HV4(HV3)	LAKAMANAHALLI_110,ALNAVAR_33	7:13	7:25	0:12	TRANSFORMER FAULT
568	19-Dec-20	BAGALKOT	110	110/33KV,HV4(HV3)	LAKAMANAHALLI_110,ALNAVAR_33	14:48	14:57	0:09	TRANSFORMER FAULT
569	19-Dec-20	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL_220	12:39 (28.11.2020)			LINE OPEN : LINE CLEAR AVALIED
570	19-Dec-20	BAGALKOT	110	GOPANAKOPPA-GADAG ROAD	STATION NOT AFFECTED GOPANKOPPA_110	11:19	18:27	7:08	LINE CLEAR AVOIDED
571	19-Dec-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN : LINE CLEAR AVALIED
572	19-Dec-20	BAGALKOT	110	HUBLI- KADANKOPPA	STATION NOT AFFECTED HUBLI_220	10:21 (19.12.2020)			LINE OPEN : LINE CLEAR AVALIED
573	19-Dec-20	BAGALKOT	110	HUBLI- KALGHATAGI (SIRSI)	STATION NOT AFFECTED HUBLI_220	10:21 (19.12.2020)			LINE OPEN : LINE CLEAR AVALIED
574	19-Dec-20	BAGALKOT	110	HUBLI-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	10:13 (19.12.2020)			LINE OPEN : LINE CLEAR AVALIED
575	19-Dec-20	BAGALKOT	110	HUBLI-KALAGATAGI	STATION NOT AFFECTED KALAGATAGI_110	10:26 (19.12.2020)			LINE OPEN : LINE CLEAR AVALIED
576	19-Dec-20	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN : LINE CLEAR AVALIED
577	19-Dec-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
578	19-Dec-20	BAGALKOT	110	KUDUCHI-TERDAL	STATION NOT AFFECTED TERDAL_110	13:10 (14.12.2020)			LINE OPEN : LINE FAULT
579	19-Dec-20	BAGALKOT	110	KUMTA-SIRSI1&2	STATION NOT AFFECTED KUMTA_110	9:06 (19.12.2020)			LINE OPEN : LINE CLEAR AVALIED
580	19-Dec-20	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN : LINE FAULT
581	19-Dec-20	BAGALKOT	110	RANEBENNUR-RATTIHALLI(TUMMINAKATTI)	STATION NOT AFFECTED TUMMINAKATTI_110	10:27	10:36	0:09	LINE FAULT
582	19-Dec-20	BAGALKOT	110	SIRSI- JOG1 (SIDDAPUR)	SIDDAPUR_110	15:23	15:49	0:26	LINE CLEAR AVOIDED
583	19-Dec-20	BAGALKOT	110	SIRSI- JOG2	STATION NOT AFFECTED SIRSI_110	12:53	15:29	2:36	LINE CLEAR AVOIDED
584	19-Dec-20	BAGALKOT	110	SIRSI- JOG2	STATION NOT AFFECTED SIRSI_110	15:44	15:49	0:05	LINE CLEAR AVOIDED
585	19-Dec-20	BAGALKOT	110	SIRSI- KUMTA2	STATION NOT AFFECTED SIRSI_110	13:18	17:40	4:22	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
586	19-Dec-20	BAGALKOT	110	SIRSI220- SIRSI1(HUBLI1)	STATION NOT AFFECTED SIRSI_110	09:07	20:12	11:05	LINE CLEAR AVAILED
587	19-Dec-20	BAGALKOT	110	SIRSI220- SIRSI2(KAVALWADA)	STATION NOT AFFECTED SIRSI_110	14:57	19:30	4:33	LINE CLEAR AVAILED
588	19-Dec-20	BAGALKOT	220	220/110KV, HV2 & LV2	STATION NOT AFFECTED CHIKKODI_220	10:01	12:45	2:44	LINE CLEAR AVAILED
589	19-Dec-20	BAGALKOT	220	220/110KV,HV1,LV1	MK HUBLI_220	6:03	10:54	4:51	LINE CLEAR AVAILED
590	19-Dec-20	BAGALKOT	220	220/110KV,HV2,LV2	MK HUBLI_220	6:01	11:00	4:59	LINE CLEAR AVAILED
591	19-Dec-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN : LINE CLEAR AVAILED
592	19-Dec-20	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN : LINE CLEAR AVAILED
593	19-Dec-20	BAGALKOT	220	GADAG-BAGALKOT1	STATION NOT AFFECTED GADAG_220	15:08	18:54	3:46	LINE CLEAR AVAILED
594	19-Dec-20	BAGALKOT	220	KUDUCHI-ATHANI	STATION NOT AFFECTED KUDUCHI_220	12:37	13:11	0:34	LINE CLEAR AVAILED
595	19-Dec-20	BAGALKOT	220	MK HUBLI-NARENDRA2	STATION NOT AFFECTED MK HUBLI_220	6:19	10:54	4:35	NFBC ISSUED
596	19-Dec-20	BAGALKOT	220	MKHUBLI- NARENDRA1	MKHUBLI_220	13:09 (18.12.2020)	11:05 (19.12.2020)	21:56HRS	LINE CHARGED
597	19-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
598	19-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
599	19-Dec-20	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN : LINE CLEAR AVAILED
600	19-Dec-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN : LINE FAULT
601	19-Dec-20	BENGALURU	66	BRIGADE MEADOWS - SOMANAHALLI 220	BRIGADE MEADOWS, SHOBHA FOREST	00:48	01:13	00:25	MAIN SUPPLY FAILURE
602	19-Dec-20	BENGALURU	66	BRIGADE MEADOWS - SOMANAHALLI 220	BRIGADE MEADOWS, SHOBHA FOREST	01:13	01:49	00:36	LINE CLEAR AVAILED
603	19-Dec-20	BENGALURU	66	BRIGADE MEADOWS - SUBRAMANYAPURA 220	BRIGADE MEADOWS, SHOBHA FOREST	09:34	09:40	00:06	LOAD CHANGE OVER
604	19-Dec-20	BENGALURU	66	HANUMANTHNAGARA - KANAKAPURA 220	HANUMANTHNAGARA	10:45	11:05	00:20	MAIN SUPPLY FAILURE
605	19-Dec-20	BENGALURU	66	HANUMANTHNAGARA - SOMANAHALLI 220	HANUMANTHNAGARA	15:55	16:15	00:20	MAIN SUPPLY FAILURE
606	19-Dec-20	BENGALURU	66	HANUMANTHNAGARA - SOMANAHALLI 220	HANUMANTHNAGARA	17:25	17:30	00:05	LOAD CHANGE OVER
607	19-Dec-20	BENGALURU	66	HV1	NELAMANGALA 66	09:17	09:25	00:08	MAIN SUPPLY FAILURE
608	19-Dec-20	BENGALURU	66	HV1	NELAMANGALA 66	11:31	11:38	00:07	LOAD CHANGE OVER
609	19-Dec-20	BENGALURU	66	HV1	KAMASAMUDRA	14:31	14:50	00:19	TRANSFORMER FAULT
610	19-Dec-20	BENGALURU	66	HV2	VOLVO	16:10	16:15	00:05	LINE CLEAR AVAILED
611	19-Dec-20	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, YEDUMADU, GODUR	10:45	11:32	00:47	LINE CLEAR AVAILED
612	19-Dec-20	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, YEDUMADU, GODUR	12:42	13:32	00:50	LINE CLEAR AVAILED
613	19-Dec-20	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, YEDUMADU, GODUR	16:46	17:32	00:46	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
614	19-Dec-20	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 2	NO STATION AFFECTED	00:48	01:15	00:27	LINE FAULT
615	19-Dec-20	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 2	NO STATION AFFECTED	01:19	08:58	07:39	LINE CLEAR AVAILED
616	19-Dec-20	BENGALURU	66	SRS PEENYA 220 - NELAMANGALA 66	NO STATION AFFECTED	09:18	11:24	02:06	LINE FAULT
617	19-Dec-20	BENGALURU	66	YELAHANKA 220 - LINE 7	KANASWADI	07:53	08:28	00:35	LINE FAULT
618	19-Dec-20	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN : LINE CLEAR AVAILED
619	19-Dec-20	GULBARGA	66	HV1	UJJANI_66	08:11	13:25	05:14	LINE CLEAR AVAILED
620	19-Dec-20	GULBARGA	66	MAGALA-ITTAGGI	MAGALA_66	13:40	14:10	00:30	MAIN SUPPLY FAILURE
621	19-Dec-20	GULBARGA	110	HV1	HANUMASAGAR_110	11:30	11:50	00:20	LINE CLEAR AVAILED
622	19-Dec-20	GULBARGA	110	HV2	KOLHAR_110	09:29	09:40	00:11	LINE CLEAR AVAILED
623	19-Dec-20	GULBARGA	110	HV3	KOLHAR_110	09:29	09:40	00:11	LINE CLEAR AVAILED
624	19-Dec-20	GULBARGA	110	SHAHAPUR-KEMBHAVI2	KBJNL_IPP	16:38	16:56	00:18	LINE CLEAR AVAILED
625	19-Dec-20	GULBARGA	110	SHAHAPUR-KEMBHAVI2	KBJNL_IPP	19:51	20:31	00:40	LINE FAULT
626	19-Dec-20	GULBARGA	400	BTPS-JINDAL	JINDAL_400	09:47	14:16	04:29	LINE CLEAR AVAILED
627	19-Dec-20	GULBARGA	400	BTPS-RTPS	RTPS_400	02:26	06:51	04:25	LINE CLEAR AVAILED
628	19-Dec-20	GULBARGA	400	BTPS-RTPS	RTPS_400	21:21(19.12.2020)			LINE OPEN : LINE CLEAR AVAILED
629	19-Dec-20	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	10:47	12:13	01:26	MAIN SUPPLY FAILURE
630	19-Dec-20	HASSAN	66	GANGUR-HASSAN	GANGUR_66	10:59	12:12	01:13	MAIN SUPPLY FAILURE
631	19-Dec-20	HASSAN	66	HV1	BELUR_66	10:43	12:10	01:27	MAIN SUPPLY FAILURE
632	19-Dec-20	HASSAN	66	HV1	HALEBEEDU_66	10:51	12:21	01:30	MAIN SUPPLY FAILURE
633	19-Dec-20	HASSAN	66	HV2	BELUR_66	10:43	12:10	01:27	MAIN SUPPLY FAILURE
634	19-Dec-20	HASSAN	66	HV2	HALEBEEDU_66	10:51	12:21	01:30	MAIN SUPPLY FAILURE
635	19-Dec-20	HASSAN	66	HV2	HOLALUR_66	16:30	18:47	02:17	LINE CLEAR AVAILED
636	19-Dec-20	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
637	19-Dec-20	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
638	19-Dec-20	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
639	19-Dec-20	HASSAN	110	BANTWA-SALATTUR	BANTWAL_110	17:59	18:10	00:11	LINE FAULT
640	19-Dec-20	HASSAN	110	HV1	KALLUSADARAHALLY_110	10:55	15:10	04:15	LINE CLEAR AVAILED
641	19-Dec-20	HASSAN	110	HV1	MANIPAL_110	15:08	15:42	00:34	LINE CLEAR AVAILED
642	19-Dec-20	HASSAN	110	HV2	AJJAMPURA_110	11:09	11:51	00:42	LINE CLEAR AVAILED
643	19-Dec-20	HASSAN	110	KALLUSA-KADUR	KALLUSADARAHALLY_110	10:50	15:14	04:24	LINE CLEAR AVAILED
644	19-Dec-20	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	09:02	11:22	02:20	LINE CLEAR AVAILED
645	19-Dec-20	HASSAN	220	MRSSTM-SHARAVATHY2	MRSMSG_220	12:29	17:29	05:00	LINE CLEAR AVAILED
646	19-Dec-20	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	11:41	13:34	01:53	LINE CLEAR AVAILED
647	19-Dec-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	21:12 (18.12.2020)	7:14 (19.12.2020)	10:01 hrs	LINE CHARGED
648	19-Dec-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	21:19 (19.12.2020)			LINE OPEN : LINE CLEAR AVAILED
649	19-Dec-20	MYSORE	66	HOOTAGALLI-BOGADHI	NO STATIONS EFFECTED	9:46	13:05	3:18	LINE CLEAR AVAILED
650	19-Dec-20	MYSORE	66	HV1	BILIKERE_66	13:09	13:22	0:13	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
651	19-Dec-20	MYSORE	66	HV1	HOOTAGALLY_220	10:01	12:38	2:37	LINE CLEAR AVAILED
652	19-Dec-20	MYSORE	66	HV2	BILIKERE_66	13:00	16:22	3:21	LINE CLEAR AVAILED
653	19-Dec-20	MYSORE	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	11:12 (17.12.2020)			LINE OPEN : LINE CLEAR AVAILED
654	19-Dec-20	MYSORE	66	SATHEGALA-BPCL	NO STATIONS EFFECTED	13:25	17:21	3:56	LINE CLEAR AVAILED
655	19-Dec-20	MYSORE	220	HV1	HOOTAGALLY_220	10:01	12:34	2:33	LINE CLEAR AVAILED
656	19-Dec-20	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, RAMAGIRI_66, CHITRA HALLI_66	6:40	8:14	1:33	LINE FAULT
657	19-Dec-20	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	6:34	6:44	0:10	LINE FAULT
658	19-Dec-20	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1	MEGMICON_1_IPP_66	6:40	8:03	1:22	LINE FAULT
659	19-Dec-20	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	CHITRADURGA_66	6:40	7:11	0:30	LINE FAULT
660	19-Dec-20	TUMKUR	66	HALURAMESHWARA-MATHOD	HALURAMESHWARA_66	6:13	11:22	5:08	LINE CLEAR AVAILED
661	19-Dec-20	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	10:21	11:44	1:23	LINE CLEAR AVAILED
662	19-Dec-20	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	11:54	16:24	4:29	LINE CLEAR AVAILED
663	19-Dec-20	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	12:07	12:28	0:21	HAND TRIPPED
664	19-Dec-20	TUMKUR	66	MAYAKONDA- DAVANAGERE SRS 220KV	MAYAKONDA_66	11:59	18:17	6:18	LINE CLEAR AVAILED
665	19-Dec-20	TUMKUR	66	NEELAGUNDA 220kV-HULUVAGALU	HALUVAGALU_66	12:06	15:32	3:26	LINE CLEAR AVAILED
666	19-Dec-20	TUMKUR	66	TR-1	GOWRASAMUDRA_66	11:06	11:13	0:06	LINE CLEAR AVAILED
667	19-Dec-20	TUMKUR	66	TR-1	HALURAMESHWARA_66	6:11	11:22	5:10	LINE CLEAR AVAILED
668	19-Dec-20	TUMKUR	66	TR-2	CHANNAGIRI_66	13:11	14:34	1:23	TRANSFORMER FAULT
669	19-Dec-20	TUMKUR	66	TR-2	HALURAMESHWARA_66	6:11	11:22	5:11	LINE CLEAR AVAILED
670	19-Dec-20	TUMKUR	66	TR-2	NAYAKANAHATTI_66	16:25	16:48	0:23	LINE CLEAR AVAILED
671	19-Dec-20	TUMKUR	110	TR-2	MAYASANDRA_110	12:16	12:45	0:28	TRANSFORMER FAULT
672	19-Dec-20	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	5:39	6:15	0:35	LINE FAULT
673	20-Dec-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN : LINE CLEAR AVAILED
674	20-Dec-20	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED ANANDANAGAR_110	15:28	16:40	1:12	LINE CLEAR AVAILED
675	20-Dec-20	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
676	20-Dec-20	BAGALKOT	110	110/11KV, HV1	KULIGOD_110	13:39 (20.12.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
677	20-Dec-20	BAGALKOT	110	110/11KV, HV2	RANNABELAGALI_110	01:29	01:38	0:09	TRANSFORMER FAULT
678	20-Dec-20	BAGALKOT	110	110/11KV, HV2	RANNABELAGALI_110	01:48	01:54	0:06	TRANSFORMER FAULT
679	20-Dec-20	BAGALKOT	110	110/33KV, HV4	GOPANAKOPPA_110, KUSUGAL_33	10:23	10:46	0:23	LINE CLEAR AVAILED
680	20-Dec-20	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	14:13 (20.12.2020)			LOAD CURTAILMENT
681	20-Dec-20	BAGALKOT	110	ANNIGERI-GADAG	STATION NOT AFFECTED GADAG_110	13:50	21:48	7:58	LINE CLEAR AVAILED
682	20-Dec-20	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL_220	12:39 (28.11.2020)			LINE OPEN : LINE CLEAR AVAILED
683	20-Dec-20	BAGALKOT	110	BPCL-NARGUND	NARAGUND_110	13:13	15:39	2:26	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
684	20-Dec-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00 (21.07.2020)			LINE OPEN : LINE CLEAR AVAILED
685	20-Dec-20	BAGALKOT	110	HUBLI- KADANKOPPA	STATION NOT AFFECTED HUBLI 220	10:21 (19.12.2020)			LINE OPEN : LINE CLEAR AVAILED
686	20-Dec-20	BAGALKOT	110	HUBLI- KALGHATAGI (SIRSI)	STATION NOT AFFECTED HUBLI 220	10:21 (19.12.2020)			LINE OPEN : LINE CLEAR AVAILED
687	20-Dec-20	BAGALKOT	110	HUBLI-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA 110	10:13 (19.12.2020)			LINE OPEN : LINE CLEAR AVAILED
688	20-Dec-20	BAGALKOT	110	HUBLI-KALAGATAGI	STATION NOT AFFECTED KALAGATAGI 110	10:26 (19.12.2020)			LINE OPEN : LINE CLEAR AVAILED
689	20-Dec-20	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI 110	9:18 (21.11.2020)			LINE OPEN : LINE CLEAR AVAILED
690	20-Dec-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
691	20-Dec-20	BAGALKOT	110	KUDUCHI-TERDAL	STATION NOT AFFECTED TERDAL 110	13:10 (14.12.2020)			LINE OPEN : LINE FAULT
692	20-Dec-20	BAGALKOT	110	KUMTA-SIRSI1&2	STATION NOT AFFECTED KUMTA 110	9:06 (19.12.2020)	8:10 (20.12.2020)	23:04HRS	LINE CHARGED
693	20-Dec-20	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR 220	13:16 (17.11.2020)			LINE OPEN : LINE FAULT
694	20-Dec-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI 220	16:21 (02.11.2020)			LINE OPEN : LINE CLEAR AVAILED
695	20-Dec-20	BAGALKOT	220	BELGAUM-CHKKODI1	STATION NOT AFFECTED BELGAUM 220	19:45 (20.12.2020)			LOAD CURTAILMENT
696	20-Dec-20	BAGALKOT	220	BELGAUM-NARENDRA1(KANABARGI1)	STATION NOT AFFECTED BELGAUM 220	20:01 (20.12.2020)			LOAD CURTAILMENT
697	20-Dec-20	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG 220	10:48 (16.12.2020)			LINE OPEN : LINE CLEAR AVAILED
698	20-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI 220	6:15 (28.11.2020)			LOAD CURTAILMENT
699	20-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI 220	6:15 (28.11.2020)			LOAD CURTAILMENT
700	20-Dec-20	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN : LINE CLEAR AVAILED
701	20-Dec-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN : LINE FAULT
702	20-Dec-20	BENGALURU	66	BRINDAVANA - NELAKADIRNAHALLI	NELAKADIRNAHALLI	10:05	19:15	09:10	LINE CLEAR AVOIDED
703	20-Dec-20	BENGALURU	66	HV2	MALLASANDRA	15:56	16:40	00:44	TRANSFORMER FAULT
704	20-Dec-20	BENGALURU	66	KOLAR 220 - BANGARPET 1	BANGARPET	21:25	21:52	00:27	LINE CLEAR AVOIDED
705	20-Dec-20	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	21:25	21:51	00:26	LINE CLEAR AVOIDED
706	20-Dec-20	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	21:25	21:51	00:26	LINE CLEAR AVOIDED
707	20-Dec-20	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA	21:25	21:51	00:26	LINE CLEAR AVOIDED
708	20-Dec-20	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	14:08	14:20	00:12	LINE FAULT
709	20-Dec-20	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR, SM MANGALA	21:25	21:51	00:26	LINE CLEAR AVOIDED
710	20-Dec-20	BENGALURU	66	KOLAR 220 - SRINIVASPURA	DRDO(EHT), MALLASANDRA, DALASANUR, YELDUR	21:25	21:51	00:26	LINE CLEAR AVOIDED
711	20-Dec-20	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	21:25	21:52	00:27	LINE CLEAR AVOIDED
712	20-Dec-20	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	21:25	21:52	00:27	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
713	20-Dec-20	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	21:25	21:51	00:26	LINE CLEAR AVAILED
714	20-Dec-20	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	21:25	21:58	00:33	MAIN SUPPLY FAILURE
715	20-Dec-20	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	21:25	21:58	00:33	MAIN SUPPLY FAILURE
716	20-Dec-20	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	21:25	21:58	00:33	MAIN SUPPLY FAILURE
717	20-Dec-20	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	11:00	14:33	03:33	LINE CLEAR AVAILED
718	20-Dec-20	BENGALURU	66	MALUR 220 - KGF 1 & 2	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	21:25	21:58	00:33	MAIN SUPPLY FAILURE
719	20-Dec-20	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	21:25	21:58	00:33	MAIN SUPPLY FAILURE
720	20-Dec-20	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	11:00	14:33	03:33	LINE CLEAR AVAILED
721	20-Dec-20	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	21:25	21:58	00:33	MAIN SUPPLY FAILURE
722	20-Dec-20	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	21:25	21:58	00:33	MAIN SUPPLY FAILURE
723	20-Dec-20	BENGALURU	66	TADIGOLU - SOMAYAJANAHALLI	SOMAYAJANAHALLI	07:50	08:20	00:30	LINE FAULT
724	20-Dec-20	BENGALURU	66	YARANDANAHALLI 220 - CHANDAPURA	CHANDAPURA	10:34	11:44	01:10	LINE CLEAR AVAILED
725	20-Dec-20	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN : LINE CLEAR AVAILED
726	20-Dec-20	BENGALURU	220	KOLAR 220 - MALUR 1	MALUR 220	21:25	21:51	00:26	LINE CLEAR AVAILED
727	20-Dec-20	BENGALURU	220	KOLAR 220 - MALUR 3	SARJAPURA 220, VIKAS TECH PARK 220	21:25	21:54	00:29	LINE CLEAR AVAILED
728	20-Dec-20	BENGALURU	220	KOLAR 220 - PGCIL 1	KOLAR 220	21:25	21:48	00:23	MAIN SUPPLY FAILURE
729	20-Dec-20	BENGALURU	220	KOLAR 220 - PGCIL 2	KOLAR 220	21:25	21:50	00:25	MAIN SUPPLY FAILURE
730	20-Dec-20	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	12:02	12:07	00:05	LINE FAULT
731	20-Dec-20	GULBARGA	110	HUMNABAD-ALAND	ALAND_110,KADAGANCHI_110	16:56	17:03	00:07	LINE FAULT
732	20-Dec-20	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	00:21	00:47	00:26	LINE FAULT
733	20-Dec-20	GULBARGA	110	HV1	KUDITINI_110	10:20	10:32	00:12	TRANSFORMER FAULT
734	20-Dec-20	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,ASKI_110,HUNSAGI_110	06:26	06:37	00:11	LINE FAULT
735	20-Dec-20	GULBARGA	110	SHAHAPUR-KEMBHAVI2	KBJNL_IPP	06:06	06:14	00:08	LINE FAULT
736	20-Dec-20	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	00:51	01:03	00:12	LINE FAULT
737	20-Dec-20	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	01:46	02:03	00:17	LINE FAULT
738	20-Dec-20	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	09:37	11:01	01:24	MAIN SUPPLY FAILURE
739	20-Dec-20	GULBARGA	220	HUMNABAD-KAPNOOR1	HUMNABAD_220	09:48	10:47	00:59	LINE CLEAR AVAILED
740	20-Dec-20	GULBARGA	220	HUMNABAD-KAPNOOR2	HUMNABAD_220	09:48	10:48	01:00	LINE CLEAR AVAILED
741	20-Dec-20	GULBARGA	220	HV1	KUSHTAGI_220	03:40	04:04	00:24	TRANSFORMER FAULT
742	20-Dec-20	GULBARGA	220	KUSHTAGI-LINGAPUR	LINGAPUR_220	03:40	12:10	08:30	LINE FAULT
743	20-Dec-20	GULBARGA	220	KUSHTAGI-LINGASUGUR	LINGASUGUR_220	09:37	09:48	00:11	LINE FAULT
744	20-Dec-20	GULBARGA	220	KUSHTAGI-LINGASUGUR	LINGASUGUR_220	10:41	10:50	00:09	LINE FAULT
745	20-Dec-20	GULBARGA	220	SHAHAPUR-KAPNOOR	KAPNOOR_220	09:57	17:39	07:42	LINE CLEAR AVAILED
746	20-Dec-20	GULBARGA	400	BTPS-RTPS	RTPS_400	21:21(19.12.2020)	7:31(20.12.2020)	10:10 HRS	LINE CHARGED
747	20-Dec-20	HASSAN	66	HV1	DUDDA_66	12:30	12:55	00:25	LINE CLEAR AVAILED
748	20-Dec-20	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	14:50	14:57	00:07	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
749	20-Dec-20	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	14:50	14:56	00:06	HAND TRIPPED
750	20-Dec-20	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
751	20-Dec-20	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
752	20-Dec-20	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
753	20-Dec-20	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	09:19	15:56	06:37	NFBC ISSUED
754	20-Dec-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	21:19 (19.12.2020)			LINE OPEN : LINE CLEAR AVAILED
755	20-Dec-20	MYSORE	66	DEVNUR(N'GUD)-SUTTUR	SUTTUR_66	15:43	16:15	0:32	LINE CLEAR AVAILED
756	20-Dec-20	MYSORE	66	MADHUVANAHALLI-MAMBALLY	MAMBALLI_66	6:41	6:48	0:07	LINE FAULT
757	20-Dec-20	MYSORE	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	11:12 (17.12.2020)			LINE OPEN : LINE CLEAR AVAILED
758	20-Dec-20	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	6:32	6:48	0:15	LINE FAULT
759	20-Dec-20	TUMKUR	66	AVAREGERE 66kV-DAVANGERE SRS	AVAREGERE_66	12:54	13:28	0:34	LINE FAULT
760	20-Dec-20	TUMKUR	66	CHAWDANKUPPE-ESENGY_SLR_IPP_66	ESENGY_SLR_IPP_66	17:50	20:22	2:31	LINE CLEAR AVAILED
761	20-Dec-20	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1	MEGMICON 1_IPP_66	10:15	10:34	0:18	LINE FAULT
762	20-Dec-20	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	6:19	6:32	0:12	LINE FAULT
763	20-Dec-20	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	12:55	13:19	0:24	HAND TRIPPED
764	20-Dec-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	6:48	7:04	0:16	LINE FAULT
765	20-Dec-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	15:12	15:30	0:18	LINE FAULT
766	20-Dec-20	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	6:48	6:58	0:10	LINE FAULT
767	20-Dec-20	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	15:12	15:24	0:11	LINE FAULT
768	20-Dec-20	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	6:48	6:56	0:08	LINE FAULT
769	20-Dec-20	TUMKUR	66	TR-1	MYLANAHALLI_66	8:58	9:04	0:06	TRANSFORMER FAULT
770	20-Dec-20	TUMKUR	66	TR-1(LV SIDE)	DAVANGERE_SRS_220	12:54	13:19	0:25	TRANSFORMER FAULT
771	20-Dec-20	TUMKUR	66	TR-2	HULIYURDURGA_66	2:36	3:03	0:27	LINE CLEAR AVAILED
772	20-Dec-20	TUMKUR	66	TR-2	HULIYURDURGA_66	11:07	16:46	5:39	LINE CLEAR AVAILED
773	20-Dec-20	TUMKUR	66	UCHANGIDURGA- I/C220SRSDAVANGERE	UCHCHANGIDURGA_66	23:12	23:31	0:18	LINE FAULT
774	20-Dec-20	TUMKUR	220	NITTUR 220kV- NELAMANGALA	NITTUR_220	15:10	16:01	0:50	LINE FAULT
775	20-Dec-20	TUMKUR	220	TR-1	DAVANGERE_SRS_220	12:54	13:19	0:25	TRANSFORMER FAULT
776	21-Dec-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN : LINE CLEAR AVAILED
777	21-Dec-20	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED SIRSI_110	12:27	13:36	1:09	LINE CLEAR AVAILED
778	21-Dec-20	BAGALKOT	110	110/11KV, HV2	TIKOTA_110	23:47	23:55	0:08	TRANSFORMER FAULT
779	21-Dec-20	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
780	21-Dec-20	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED KULIGOD_110	13:39 (20.12.2020)			TRANSFORMER OPEN : LINE CLEAR AVOIDED
781	21-Dec-20	BAGALKOT	110	110/11KV,HV1	ACHANUR_110	11:22	14:45	3:23	LINE CLEAR AVOIDED
782	21-Dec-20	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED BIDNAL_220	16:21	18:00	1:39	LINE CLEAR AVOIDED
783	21-Dec-20	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	11:55	12:01	0:06	LINE CLEAR AVOIDED
784	21-Dec-20	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	17:53	18:52	0:59	TRANSFORMER FAULT
785	21-Dec-20	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED BIDNAL_220	13:07	16:13	3:06	LINE CLEAR AVOIDED
786	21-Dec-20	BAGALKOT	110	110/11KV,HV2	ITANAL_110	13:11	13:39	0:28	LINE CLEAR AVOIDED
787	21-Dec-20	BAGALKOT	110	110/33KV, HV3	KULIGOD_110, TIGADI_33, ARALIMATTI_33	14:57	17:58	3:01	LINE CLEAR AVOIDED
788	21-Dec-20	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, HALSANGI_33, NEVARGI_33	15:07	15:39	0:32	LINE CLEAR AVOIDED
789	21-Dec-20	BAGALKOT	110	220/110KV, LV3	STATION NOT AFFECTED MAHALINGAPUR_220	02:30	02:40	0:10	TRANSFORMER FAULT
790	21-Dec-20	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL_220	12:39 (28.11.2020)	10:58 (21.12.2020)	982:19 hrs	LINE CHARGED
791	21-Dec-20	BAGALKOT	110	HALIYAL-GMR	HALIYAL_110,GMR	18:30	18:38	0:08	LINE FAULT
792	21-Dec-20	BAGALKOT	110	HALIYAL-GMR	HALIYAL_110,GMR	20:29	21:31	1:02	LINE CLEAR AVOIDED
793	21-Dec-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN : LINE CLEAR AVOIDED
794	21-Dec-20	BAGALKOT	110	HUBLI- KADANKOPPA	STATION NOT AFFECTED HUBLI_220	10:21 (19.12.2020)			LINE OPEN : LINE CLEAR AVOIDED
795	21-Dec-20	BAGALKOT	110	HUBLI- KALGHATAGI (SIRSI)	STATION NOT AFFECTED HUBLI_220	10:21 (19.12.2020)			LINE OPEN : LINE CLEAR AVOIDED
796	21-Dec-20	BAGALKOT	110	HUBLI220-BIDNAL	STATION NOT AFFECTED HUBLI_220	16:24	20:57	4:33	NFBC ISSUED
797	21-Dec-20	BAGALKOT	110	HUBLI-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	10:13 (19.12.2020)			LINE OPEN : LINE CLEAR AVOIDED
798	21-Dec-20	BAGALKOT	110	HUBLI-KALAGATAGI	STATION NOT AFFECTED KALAGATAGI_110	10:26 (19.12.2020)			LINE OPEN : LINE CLEAR AVOIDED
799	21-Dec-20	BAGALKOT	110	HUDLI-BELGAUM220	NO STATION AFFECTED HUDLI_110	9:18 (21.11.2020)			LINE OPEN : LINE CLEAR AVOIDED
800	21-Dec-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
801	21-Dec-20	BAGALKOT	110	KUDUCHI-TERDAL	STATION NOT AFFECTED TERDAL_110	13:10 (14.12.2020)			LINE OPEN : LINE FAULT
802	21-Dec-20	BAGALKOT	110	MAHALINGAPUR-ITNAL	ITNAL_110	02:30	08:30	6:00	LINE FAULT
803	21-Dec-20	BAGALKOT	110	MAHALINGAPUR-RABAKAVI	RABAKAVI_110	02:30	02:42	0:12	HAND TRIPPED
804	21-Dec-20	BAGALKOT	110	MAMADAPURA-BABALESHWAR	BABALESHWAR_110	17:50	18:25	0:35	LINE CLEAR AVOIDED
805	21-Dec-20	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN : LINE FAULT
806	21-Dec-20	BAGALKOT	110	RATHIHALLI- TIMMANAKATTI(RANEENNUR22)	STATION NOT AFFECTED TIMMANAKATTI_110	13:15	18:17	5:02	LINE CLEAR AVOIDED
807	21-Dec-20	BAGALKOT	220	220/110KV, HV3	STATION NOT AFFECTED MAHALINGAPUR_220	02:30	02:35	0:05	TRANSFORMER FAULT
808	21-Dec-20	BAGALKOT	220	220/110KV,HV1 & LV1	STATION NOT AFFECTED GADAG_220	10:50	18:05	7:15	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
809	21-Dec-20	BAGALKOT	220	220/110KV,LV2	STATION NOT AFFECTED MK HUBLI_220	14:13 (20.12.2020)	7:34 (21.12.2020)	17:21 hrs	TRANSFORMER CHARGED
810	21-Dec-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN : LINE CLEAR AVAILED
811	21-Dec-20	BAGALKOT	220	BELGAUM-CHIKKODI 1	STATION NOT AFFECTED BELGAUM_220	21:43 (21.12.2020)			LOAD CURTAILMENT
812	21-Dec-20	BAGALKOT	220	BELGAUM-CHKKODI1	STATION NOT AFFECTED BELGAUM_220	19:45 (20.12.2020)	7:06 (21.12.2020)	11:21 hrs	LINE CHARGED
813	21-Dec-20	BAGALKOT	220	BELGAUM-NARENDRA 1	STATION NOT AFFECTED BELGAUM_220	19:55 (21.12.2020)			LINE OPEN : LINE CLEAR AVAILED
814	21-Dec-20	BAGALKOT	220	BELGAUM-NARENDRA1(KANABARGI1)	STATION NOT AFFECTED BELGAUM_220	20:01 (20.12.2020)	7:08 (21.12.2020)	11:07 hrs	LINE CHARGED
815	21-Dec-20	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN : LINE CLEAR AVAILED
816	21-Dec-20	BAGALKOT	220	GHATAPRABHA-NARENDRA 2	STATION NOT AFFECTED GHATAPRABHA_220	10:43	15:20	4:37	LINE FAULT
817	21-Dec-20	BAGALKOT	220	HUBLI-BIDNAL	STATION NOT AFFECTED HUBLI_220	01:35	09:09	7:34	LINE FAULT
818	21-Dec-20	BAGALKOT	220	MAHALINGAPUR-NARENDRA1	STATION NOT AFFECTED MAHALINGAPUR_220	09:48	15:05	5:17	NFBC ISSUED
819	21-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
820	21-Dec-20	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	6:15 (28.11.2020)			LOAD CURTAILMENT
821	21-Dec-20	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	15:54(17/11/2020)			LINE OPEN : LINE CLEAR AVAILED
822	21-Dec-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN : LINE FAULT
823	21-Dec-20	BENGALURU	66	HV1	BYADARHALLI	07:23	07:35	00:12	TRANSFORMER FAULT
824	21-Dec-20	BENGALURU	66	HV1	SOMENAHALLI	12:35	12:40	00:05	TRANSFORMER FAULT
825	21-Dec-20	BENGALURU	66	HV2	AMAR JYOTHI	15:05	15:15	00:10	LINE CLEAR AVAILED
826	21-Dec-20	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	10:58	15:27	04:29	LINE CLEAR AVAILED
827	21-Dec-20	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI	10:58	15:27	04:29	LINE CLEAR AVAILED
828	21-Dec-20	BENGALURU	66	TK HALLI 220 - SHIMSHA 2	TK HALLI 220	10:58	15:27	04:29	LINE CLEAR AVAILED
829	21-Dec-20	BENGALURU	220	BEGUR 220 - HOSKOTE 220	NO STATION AFFECTED	15:10(17/11/2020)			LINE OPEN : LINE CLEAR AVAILED
830	21-Dec-20	GULBARGA	110	HV1	HANUMANAL_110	16:50	17:45	00:55	LINE CLEAR AVAILED
831	21-Dec-20	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	22:28	22:39	00:11	LINE FAULT
832	21-Dec-20	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110, VALKAMDINNI_110	19:39	19:47	00:08	LINE FAULT
833	21-Dec-20	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110, VALKAMDINNI_110	20:53	21:10	00:17	LINE FAULT
834	21-Dec-20	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110,HATTI_110	03:08	03:15	00:07	MAIN SUPPLY FAILURE
835	21-Dec-20	GULBARGA	110	PD HALLI-CLNSLR	PD_HALLI_110	18:50	19:10	00:20	LINE CLEAR AVAILED
836	21-Dec-20	GULBARGA	110	SINDHANOOR-RAICHUR1	SINDHANOOR_110	10:55	14:10	03:15	NFBC ISSUED
837	21-Dec-20	GULBARGA	110	SINDHANOOR-RAICHUR2	MANVI_110,MADLAPUR_110,KURDI CROSS_110	10:05	14:05	04:00	LINE CLEAR AVAILED
838	21-Dec-20	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	20:05	20:15	00:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
839	21-Dec-20	GULBARGA	220	HUMNABAD-KAPNOOR1	HUMNABAD_220	02:03	08:02	05:59	LINE CLEAR AVAILED
840	21-Dec-20	GULBARGA	220	KAPNOOR-SHAHABAD	SHAHABAD_220	09:52	17:05	07:13	LINE CLEAR AVAILED
841	21-Dec-20	GULBARGA	220	KAPNOOR-SHAHABAD	SHAHABAD_220	23:25(21.12.2020)	05:52(22.12.2020)	06:27	LINE CLEAR AVAILED
842	21-Dec-20	GULBARGA	220	KAPNOOR-SHAHAPUR1	HUMNABAD_220	09:52	19:08	09:16	LINE CLEAR AVAILED
843	21-Dec-20	GULBARGA	400	BTPS-HIRYUR1	HIRYUR_400	11:37	17:17	05:40	LINE CLEAR AVAILED
844	21-Dec-20	HASSAN	66	BHADRA-SHMG 2	bhadra_gen	09:30	10:45	01:15	LINE CLEAR AVAILED
845	21-Dec-20	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	02:20	02:26	00:06	LINE FAULT
846	21-Dec-20	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	05:31	05:38	00:07	LINE FAULT
847	21-Dec-20	HASSAN	66	HV1	MALALI_66	02:20	02:30	00:10	MAIN SUPPLY FAILURE
848	21-Dec-20	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
849	21-Dec-20	HASSAN	66	LV3	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
850	21-Dec-20	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
851	21-Dec-20	HASSAN	66	MALALI-CRPATNA	MALALI_66	02:20	02:30	00:10	MAIN SUPPLY FAILURE
852	21-Dec-20	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAG	14:58	15:11	00:13	LINE FAULT
853	21-Dec-20	HASSAN	110	HV1	BELAGUMBA_110	15:58	17:05	01:07	LINE CLEAR AVAILED
854	21-Dec-20	HASSAN	110	HV2	BELAGUMBA_110	15:09	16:22	01:13	LINE CLEAR AVAILED
855	21-Dec-20	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	09:19	15:56	06:37	NFBC ISSUED
856	21-Dec-20	HASSAN	220	SHRAVITY-ST3	sharavathy_gen	11:11	12:32	01:21	LINE CLEAR AVAILED
857	21-Dec-20	HASSAN	220	TALAGU-ST3	TALAGUPPA_400	11:30	12:32	01:02	LINE CLEAR AVAILED
858	21-Dec-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	21:19 (19.12.2020)	8:42 (21.12.2020)	35:22 hrs	LINE CHARGED
859	21-Dec-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:44(21.12.2020)			LINE OPEN : LINE CLEAR AVAILED
860	21-Dec-20	MYSORE	66	HV1	HONNALLY_MYS_66	12:25	13:05	0:40	LINE CLEAR AVAILED
861	21-Dec-20	MYSORE	66	HV1	K_HONNALGERE_66	10:55	11:30	0:35	MAIN SUPPLY FAILURE
862	21-Dec-20	MYSORE	66	HV2	HONNALLY_MYS_66	15:51	16:25	0:33	LINE CLEAR AVAILED
863	21-Dec-20	MYSORE	66	HV2	K_HONNALGERE_66	10:55	11:30	0:35	MAIN SUPPLY FAILURE
864	21-Dec-20	MYSORE	66	HV2	KRPET_66	12:34	13:24	0:50	TRANSFORMER FAULT
865	21-Dec-20	MYSORE	66	HV2	KRPET_66	14:40	14:54	0:14	TRANSFORMER FAULT
866	21-Dec-20	MYSORE	66	K HONNALGERE-IGLOOR	NO STATIONS EFFECTED	11:30	15:56	4:26	LINE CLEAR AVAILED
867	21-Dec-20	MYSORE	66	KM DODDI-TK HALLI	KIADBMANDYA_66 KMDODDI_66 KOLKARANADODDI_66 MADDUR_66 SOMANAHALLI_66 TUMBEKERE_66	10:46	16:04	5:18	MAIN SUPPLY FAILURE
868	21-Dec-20	MYSORE	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	11:12 (17.12.2020)			LINE OPEN : LINE CLEAR AVAILED
869	21-Dec-20	MYSORE	66	PARINAMIPURA-TALKADU	CHANDALLI_66 THALAKADU_66	4:52	4:58	0:06	LINE FAULT
870	21-Dec-20	MYSORE	66	SATHEGALA-HEBBANI	NO STATIONS EFFECTED	12:20	17:34	5:14	LINE CLEAR AVAILED
871	21-Dec-20	MYSORE	220	HV1	MADHUVANAHALLI_220	15:47	17:46	1:58	LINE CLEAR AVAILED
872	21-Dec-20	TUMKUR	66	BELADADARA-CTKERE	BELADARA_66	0:12	0:15	0:03	HAND TRIPPED
873	21-Dec-20	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	13:15	15:01	1:46	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
874	21-Dec-20	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, RAMAGIRI_66, CHITRA HALLI_66	16:35	16:56	0:20	LINE FAULT
875	21-Dec-20	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	17:48	18:05	0:16	LINE FAULT
876	21-Dec-20	TUMKUR	66	CHITRADURGA 66kv- MEGMICON 1	MEGMICON 1_IPP_66	16:35	17:50	1:15	LINE FAULT
877	21-Dec-20	TUMKUR	66	CHITRADURGA 66kv- PANDARAHALLI 2	CHITRADURGA_66	16:35	17:19	0:43	LINE FAULT
878	21-Dec-20	TUMKUR	66	HIREGUNTANUR- CHITRADURGA	HIREGUNTANUR_66	13:25	15:01	1:36	LINE CLEAR AVAILED
879	21-Dec-20	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66, MALEBENNUR_66	6:36	6:47	0:11	LINE FAULT
880	21-Dec-20	TUMKUR	66	MEDIGESHI- CLEANSOLAR_IPP_66	CLEANSOLAR_IPP_66	16:13	16:50	0:37	HAND TRIPPED
881	21-Dec-20	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	WELSPUN SOLAR_IPP_66	18:40	22:25	3:45	LINE CLEAR AVAILED
882	21-Dec-20	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	WELSPUN SOLAR_IPP_66	18:40	22:26	3:45	LINE CLEAR AVAILED
883	21-Dec-20	TUMKUR	66	TR-1(LV SIDE)	THALLAKK_220	15:25	18:04	2:39	LINE CLEAR AVAILED
884	21-Dec-20	TUMKUR	66	TR-2	BEVINAHALLI_66	12:30	12:57	0:26	LINE CLEAR AVAILED
885	21-Dec-20	TUMKUR	66	TR-2	CHELURU_66	15:33	17:57	2:23	LINE CLEAR AVAILED
886	21-Dec-20	TUMKUR	110	TR-1	BANDIHALLI_110	12:28	13:12	0:43	LINE CLEAR AVAILED
887	21-Dec-20	TUMKUR	110	TR-2	BANDIHALLI_110	13:14	13:37	0:23	LINE CLEAR AVAILED