

400/220/110/66 kV TRANSMISSION OUTAGES FROM : 12 to 18 Apr 22

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1	12-Apr-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED SIDDAPUR_110	10:15	17:23	7:08	LINE CLEAR AVAILED
2	12-Apr-22	BAGALKOT	110	110/11KV,HV1	KAWALWAD_110	11:40	12:20	0:40	LINE CLEAR AVAILED
3	12-Apr-22	BAGALKOT	110	110/11KV,HV1	KATARAKI_110	16:10	18:10	2:00	LINE CLEAR AVAILED
4	12-Apr-22	BAGALKOT	110	110/11KV,HV2	AIGALI_110	16:32	16:50	0:18	TRANSFORMER FAULT
5	12-Apr-22	BAGALKOT	110	110/11KV,HV2	KALGHATGI_110	10:40	20:00	9:20	LINE CLEAR AVAILED
6	12-Apr-22	BAGALKOT	110	110/11KV,HV2	MANTUR(B)_110	8:45	9:10	0:25	HAND TRIPPED
7	12-Apr-22	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	AMBEWADI_220	10:40	10:50	0:10	LINE FAULT
8	12-Apr-22	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	AMBEWADI_220	17:01	17:08	0:07	LINE FAULT
9	12-Apr-22	BAGALKOT	110	DAMBAL-MUNDARAGI	MUNDARAGI_110	9:23	10:00	0:37	LINE FAULT
10	12-Apr-22	BAGALKOT	110	DAMBAL-MUNDARAGI	MUNDARAGI_110	12:24	13:43	1:19	LINE FAULT
11	12-Apr-22	BAGALKOT	110	GHATAPRABHA220- SURYODAYA SOLAR	GHATAPRABHA_220	22:35	23:22	0:47	LINE FAULT
12	12-Apr-22	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN :LINE CLEAR AVAILED
13	12-Apr-22	BAGALKOT	110	HALIYAL- KAWALWADA	HALIYAL_110	9:30	9:39	0:09	HAND TRIPPED
14	12-Apr-22	BAGALKOT	110	HALIYAL-KAWALWADA	STATION NOT AFFECTED HALIYAL_110	17:56 (07.04.2022)			LINE OPEN:LINE FAULT
15	12-Apr-22	BAGALKOT	110	KAMBAGI-TODALBAGI	KAMBAGI_110	15:49	16:17	0:28	HAND TRIPPED
16	12-Apr-22	BAGALKOT	110	KARWAR220- ARGA(KUMATA)	KARWAR_220	10:51	12:48	1:57	NFBC ISSUED
17	12-Apr-22	BAGALKOT	110	KIRUVATTI-KAVALWAD(SIRSI)	KAVALWAD_110	9:31	9:42	0:11	HAND TRIPPED
18	12-Apr-22	BAGALKOT	110	KUDACHI220- AINAPUR(YELPARAHATTI)	KUDACHI_220	10:00	20:14	10:14	LINE CLEAR AVAILED
19	12-Apr-22	BAGALKOT	110	MK HUBLI-MK HUBLI1	STATION NOT AFFECTED MK HUBLI_220	10:59 (31.03.2022)			LINE OPEN :LINE CLEAR AVAILED
20	12-Apr-22	BAGALKOT	110	MKHUBLI220- HIREBAGEWADI	MK HUBLI_220	15:20	15:29	0:09	MAIN SUPPLY FAILURE
21	12-Apr-22	BAGALKOT	110	MUGALKHOD-RAIBAG1	MUGALKHOD_220	10:07	13:17	3:10	LINE CLEAR AVAILED
22	12-Apr-22	BAGALKOT	110	NARENDRA-MRUTHYUNJAY NAGAR2 (UAS)	NARENDRA_220	11:15	13:45	2:30	LINE CLEAR AVAILED
23	12-Apr-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN :LINE CLEAR AVAILED
24	12-Apr-22	BAGALKOT	110	SAVALAGI-AIGALI	STATION NOT AFFECTED SAVALAGI_110	7:51	18:24	10:33	LINE CLEAR AVAILED
25	12-Apr-22	BAGALKOT	110	SHIRAGUPPI -BILAGI	GIRISAGAR_110,TOLAMATTI_11 0, BILAGI_110, BISANAL_110	5:50	6:05	0:15	LINE FAULT
26	12-Apr-22	BAGALKOT	110	SIRSI-KUMTA2	STATION NOT AFFECTED SIRSI_110	13:10	13:35	0:25	HAND TRIPPED
27	12-Apr-22	BAGALKOT	110	SIRSI-UMMACHAGI	SIRSI_220	10:48	10:51	0:03	HAND TRIPPED
28	12-Apr-22	BAGALKOT	110	SIRSI-UMMACHAGI	SIRSI_220	17:04	17:05	0:01	HAND TRIPPED
29	12-Apr-22	BAGALKOT	110	SUVARNASOUDHA-MACHE	MACHE_110	15:32	16:16	0:44	HAND TRIPPED
30	12-Apr-22	BAGALKOT	110	TAKKALAKI-KN SOLAR	KN SOLAR_110 TAKKALAKI_110	15:38	15:42	0:04	HAND TRIPPED
31	12-Apr-22	BAGALKOT	110	TAKKALAKI-TIKOTA	TIKOTA_110	16:17	16:23	0:06	HAND TRIPPED
32	12-Apr-22	BAGALKOT	110	TAKKALAKI-WARDA SOLAR	WARDA SOLAR_110 STATION NOT AFFECTED TAKKALAKI_110	16:01	16:19	0:18	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
33	12-Apr-22	BAGALKOT	110	TAKKALAKI-WARDA SOLAR	WARDA SOLAR_110 TAKKALAKI_110	15:38	15:42	0:04	HAND TRIPPED
34	12-Apr-22	BAGALKOT	110	TARIHAL(NARENDRA220)- TADASINKOPPA	STATION NOT AFFECTED TADASINKOPPA_110	16:06 (10.04.2022)			LINE CLEAR AVAILED
35	12-Apr-22	BAGALKOT	110	UDAYMBAG-MACHE	STATION NOT AFFECTED UDAYMBAG_110	10:10 (10.04.2022)			LINE OPEN :LINE CLEAR AVAILED
36	12-Apr-22	BAGALKOT	110	VAJRAMATTI220-SHIRAGUPPI	VAJRAMATTI_220	5:50	6:00	0:10	LINE FAULT
37	12-Apr-22	BAGALKOT	110	YALLAMMANAWADI-SAVALGI	STATION NOT AFFECTED YALLAMMANAWADI_110	7:50	18:20	10:30	NFBC ISSUED
38	12-Apr-22	BAGALKOT	220	220/110KV, HV2	MK HUBLI_220	15:20	15:57	0:37	TRANSFORMER FAULT
39	12-Apr-22	BAGALKOT	220	220/110KV, HV2	KARWAR_220	11:05	13:00	1:55	LINE CLEAR AVAILED
40	12-Apr-22	BAGALKOT	220	220/110KV, LV2	MK HUBLI_220	15:20	16:04	0:44	TRANSFORMER FAULT
41	12-Apr-22	BAGALKOT	220	AQUES- CHIKKODI1	STATION NOT AFFECTED AQUES_220	17:41 (10.04.2022)			LINE OPEN :LINE CLEAR AVAILED
42	12-Apr-22	BAGALKOT	220	ATHANI-RVIURJA(KAKAMARI1)	STATION NOT AFFECTED ATHANI_220	16:34 (09.04.2022)			LINE OPEN:LINE FAULT
43	12-Apr-22	BAGALKOT	220	ATHANI-RVIURJA(KAKAMARI2)	STATION NOT AFFECTED ATHANI_220	16:34 (09.04.2022)			LINE OPEN:LINE FAULT
44	12-Apr-22	BAGALKOT	220	CHIKKODI-BELGAUM1(AEQU51)	STATION NOT AFFECTED CHIKKODI_220	17:40 (10.04.2022)	13:54 (12.04.2022)	45:14 hrs	LINE CHARGED
45	12-Apr-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN :LINE CLEAR AVAILED
46	12-Apr-22	BAGALKOT	220	HUBLI-BIDNAL1	HUBLI_220	10:21	13:55	3:34	LINE CLEAR AVAILED
47	12-Apr-22	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	9:26	18:06	8:40	NFBC ISSUED
48	12-Apr-22	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	9:18	18:07	8:49	NFBC ISSUED
49	12-Apr-22	BAGALKOT	220	MUGALKHOD-MAHALINGPUR	MUGALKHOD_220	10:54	12:07	1:13	LINE CLEAR AVAILED
50	12-Apr-22	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	9:40 (31.03.2022)	11:07 (12.04.2022)	289:27 hrs	LINE CHARGED
51	12-Apr-22	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	17:30 (31.03.2022)			LINE OPEN :LINE CLEAR AVAILED
52	12-Apr-22	BAGALKOT	220	SIRSI-SHARAVATI 1	SIRSI_220	9:46	18:11	8:25	LINE CLEAR AVAILED
53	12-Apr-22	BAGALKOT	220	SIRSI-SHARAVATI 2	SIRSI_220	9:46 (12.04.2022)			LINE OPEN :LINE CLEAR AVAILED
54	12-Apr-22	BAGALKOT	220	SIRSI-SHUBLI1	SIRSI_220	13:24 (12.04.2022)			LINE OPEN :LINE CLEAR AVAILED
55	12-Apr-22	BENGALURU	66	HBR LAYOUT 220 - HENNUR CROSS	HENNUR CROSS	11:27	11:45	0:18	LINE FAULT
56	12-Apr-22	BENGALURU	66	HV2	TELECOM LAYOUT	9:03	9:43	0:40	TRANSFORMER FAULT
57	12-Apr-22	BENGALURU	66	MANYATHA TECH PARK 220 - BYATARAYANAPURA	NO STATION AFFECTED	9:04	12:58	3:54	LINE FAULT
58	12-Apr-22	BENGALURU	66	MANYATHA TECH PARK 220 - HOSKOTE 2	SHOBHA CITY	10:59	11:18	0:19	LINE FAULT
59	12-Apr-22	BENGALURU	66	SARAKKI - JAYADEVA 2	SARAKKI	11:45	11:50	0:05	LINE FAULT
60	12-Apr-22	BENGALURU	66	SHOBHA CITY - HENNUR CROSS	SHOBHA CITY	11:29	11:39	0:10	LOAD CHANGE OVER
61	12-Apr-22	GULBARGA	66	HV2	BENNEHALLI_66	3:25	3:30	0:05	TRANSFORMER FAULT
62	12-Apr-22	GULBARGA	110	CHOWDAPUR-AFZALPUR	CHOWDAPUR_110	11:07	11:12	0:05	LINE FAULT
63	12-Apr-22	GULBARGA	110	CHOWDAPUR-AFZALPUR	CHOWDAPUR_110	20:42	20:57	0:15	LINE FAULT
64	12-Apr-22	GULBARGA	110	HV1	KADAGANCHI_110	15:55	16:00	0:05	LINE CLEAR AVAILED
65	12-Apr-22	GULBARGA	110	HV1	KADAGANCHI_110	16:30	16:35	0:05	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
66	12-Apr-22	GULBARGA	110	HV1	CHOWDAPUR_110	18:15	18:20	0:05	TRANSFORMER FAULT
67	12-Apr-22	GULBARGA	110	HV2	NIRNA_110	12:45	12:50	0:05	TRANSFORMER FAULT
68	12-Apr-22	GULBARGA	110	KADAGANCHI-KAPNOOR	KADAGANCHI_110	19:24	19:54	0:30	MAIN SUPPLY FAILURE
69	12-Apr-22	GULBARGA	110	MADIYAL-KAPNOOR	MADIYAL_110,NSLSUGARFACTO R_IPP	19:23	19:55	0:32	LINE FAULT
70	12-Apr-22	GULBARGA	110	MALLAT-BYGWAT	BYAGWAT_110, VALKAMDINNI_110	4:20	4:25	0:05	LINE FAULT
71	12-Apr-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	0:27	0:37	0:10	LINE FAULT
72	12-Apr-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	1:01	1:11	0:10	LINE FAULT
73	12-Apr-22	GULBARGA	110	MASKI-SINDHNOOR	MASKI_110	15:35	15:40	0:05	LINE FAULT
74	12-Apr-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN :LINE CLEAR AVAILED
75	12-Apr-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110, WADAGERA_110,SANNATHI_IPP, COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN :LINE CLEAR AVAILED
76	12-Apr-22	GULBARGA	220	BTPSG-LINGAPUR	LINGAPUR_220	9:20(12.04.2022)			LINE OPEN:LINE FAULT
77	12-Apr-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
78	12-Apr-22	GULBARGA	220	HV2,LV2	KAPNOOR_220	19:24	19:57	0:33	TRANSFORMER FAULT
79	12-Apr-22	GULBARGA	220	LINGAPUR-HALAWARTHI	HALAWARTHI_220	13:56	22:28	8:32	LINE FAULT
80	12-Apr-22	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	23:01 (12.04.2022)			LINE OPEN:LINE FAULT
81	12-Apr-22	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	22:07	22:18	0:11	LINE FAULT
82	12-Apr-22	HASSAN	66	BANDISH-ADANI	BANDISHETTIHALLY_66	15:13	15:25	0:12	LINE FAULT
83	12-Apr-22	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	5:33	5:46	0:13	LINE FAULT
84	12-Apr-22	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	5:56	6:49	0:53	HAND TRIPPED
85	12-Apr-22	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	6:56	7:36	0:40	HAND TRIPPED
86	12-Apr-22	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	8:15	9:43	1:28	LINE CLEAR AVAILED
87	12-Apr-22	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	1:47	2:04	0:17	LINE FAULT
88	12-Apr-22	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	4:58	5:09	0:11	LINE FAULT
89	12-Apr-22	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	8:40	9:43	1:03	LINE CLEAR AVAILED
90	12-Apr-22	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	10:50	13:20	2:30	LINE CLEAR AVAILED
91	12-Apr-22	HASSAN	66	HV1	HOLALUR_66	16:04	17:33	1:29	TRANSFORMER FAULT
92	12-Apr-22	HASSAN	66	HV1	MALALI_66	8:40	9:44	1:04	MAIN SUPPLY FAILURE
93	12-Apr-22	HASSAN	66	HV1	MOSALEHOSAHALLY_66	10:52	14:51	3:59	NFBC ISSUED
94	12-Apr-22	HASSAN	66	HV2	RAMESHWARANAGARA_66	19:06	19:28	0:22	LOAD CURTAILMENT
95	12-Apr-22	HASSAN	66	HV4	BALEHONNUR_66	14:54	15:09	0:15	HAND TRIPPED
96	12-Apr-22	HASSAN	66	HV4	BALEHONNUR_66	16:46	17:41	0:55	HAND TRIPPED
97	12-Apr-22	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	10:02	14:52	4:50	LINE CLEAR AVAILED
98	12-Apr-22	HASSAN	66	MALALI-CRPATNA	MALALI_66	8:40	9:44	1:04	MAIN SUPPLY FAILURE
99	12-Apr-22	HASSAN	66	MALALI-HASSAN	MALALI_66	8:40	9:31	0:51	MAIN SUPPLY FAILURE
100	12-Apr-22	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSAHALLY_66	10:52	14:51	3:59	NFBC ISSUED
101	12-Apr-22	HASSAN	66	RMWNGR-SHANTI	RAMESHWARANAGARA_66	9:07	10:11	1:04	MAIN SUPPLY FAILURE
102	12-Apr-22	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	9:55	18:55	9:00	LINE CLEAR AVAILED
103	12-Apr-22	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	9:55	18:55	9:00	LINE CLEAR AVAILED
104	12-Apr-22	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	10:02	14:52	4:50	LINE CLEAR AVAILED
105	12-Apr-22	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATANAHALLY_66	7:22	7:37	0:15	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
106	12-Apr-22	HASSAN	110	ARSK2-ARSKR	ARASIKERE_220	12:32	16:22	3:50	LINE CLEAR AVAILED
107	12-Apr-22	HASSAN	110	GAJNUR-IPP IC LINE	GAJANUR_110	10:35	16:49	6:14	LINE CLEAR AVAILED
108	12-Apr-22	HASSAN	110	HV1	ARASIKERE_110	10:34	17:28	6:54	LINE CLEAR AVAILED
109	12-Apr-22	HASSAN	110	HV1	JAVAGAL_110	19:05	19:18	0:13	LOAD CURTAILMENT
110	12-Apr-22	HASSAN	110	HV2	MSEZ_220	10:14	19:35	9:21	LINE CLEAR AVAILED
111	12-Apr-22	HASSAN	110	HV2	ARASIKERE_110	10:34	17:28	6:54	LINE CLEAR AVAILED
112	12-Apr-22	HASSAN	110	HV2	GANDASI_110	19:05	19:19	0:14	LOAD CURTAILMENT
113	12-Apr-22	HASSAN	110	JOG110-AMBTR2	JOG_110	10:05 (11.04.2022)	11:45 (12.04.2022)	15:00HRS	LINE CHARGED
114	12-Apr-22	HASSAN	110	KADUR-NERELEKERE	KADUR_220	10:46	12:32	1:46	LINE FAULT
115	12-Apr-22	HASSAN	110	KEMAR-Manipal1	KEMAR_220	11:18	12:51	1:33	LINE CLEAR AVAILED
116	12-Apr-22	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	12:10	12:59	0:49	NFBC ISSUED
117	12-Apr-22	HASSAN	110	SHIRAL-SHKARPURA	SHIRALKOPPA_110	9:50	14:15	4:25	MAIN SUPPLY FAILURE
118	12-Apr-22	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	12:55	13:34	0:39	LINE FAULT
119	12-Apr-22	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	9:50	14:15	4:25	LINE CLEAR AVAILED
120	12-Apr-22	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	12:07	14:22	2:15	LINE CLEAR AVAILED
121	12-Apr-22	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	9:49	18:18	8:29	NFBC ISSUED
122	12-Apr-22	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	9:49(12.04.2022)			LINE OPEN :LINE CLEAR AVAILED
123	12-Apr-22	MYSURU	66	ATIGULIPURA-HONNALLY	ATTIGULIPURA_66	14:20	14:29	0:09	HAND TRIPPED
124	12-Apr-22	MYSURU	66	BANNIMANTAP-FTS	NO STATIONS EFFECTED	9:51	17:15	7:24	LINE CLEAR AVAILED
125	12-Apr-22	MYSURU	66	BANNIMANTAP-VIJAYNAGARA	BANNIMANTAP_66	10:02	16:24	6:21	LINE CLEAR AVAILED
126	12-Apr-22	MYSURU	66	DEVNOOR MYSORE-VAJMANGALA	DEVANOORMYS_66 RAJEEVNAGARA_66 FTS_66	17:05	18:52	1:47	LINE FAULT
127	12-Apr-22	MYSURU	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	17:23	21:02	3:38	LINE CLEAR AVAILED
128	12-Apr-22	MYSURU	66	FTS-RAJEEV NAGARA	NO STATIONS EFFECTED	17:18:04 (11.04.2022)			LINE OPEN:LINE FAULT
129	12-Apr-22	MYSURU	66	HD KOTE-TARAKA	NO STATIONS EFFECTED	17:28	17:36	0:08	LINE FAULT
130	12-Apr-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (8/12/2021)			LINE OPEN :LINE CLEAR AVAILED
131	12-Apr-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	16:58:00 (13/12/2021)			LINE OPEN :LINE CLEAR AVAILED
132	12-Apr-22	MYSURU	66	HOOTAGALLI-FTS 1	NO STATIONS EFFECTED	10:34	16:25	5:51	LINE CLEAR AVAILED
133	12-Apr-22	MYSURU	66	HOOTAGALLI-FTS 2	NO STATIONS EFFECTED	10:34	16:25	5:51	LINE CLEAR AVAILED
134	12-Apr-22	MYSURU	66	HV1	HANAGODU_66	19:05	19:13	0:08	LINE CLEAR AVAILED
135	12-Apr-22	MYSURU	66	HV1	HARVEY_66	15:30	15:35	0:05	TRANSFORMER FAULT
136	12-Apr-22	MYSURU	66	HV1	K_HONNALLGERE_66	23:55	23:59	0:03	TRANSFORMER FAULT
137	12-Apr-22	MYSURU	66	HV1	MADIKERI_66	15:03	16:42	1:38	LINE CLEAR AVAILED
138	12-Apr-22	MYSURU	66	HV1	PANDAVAPURA_66	19:06	19:18	0:12	LINE CLEAR AVAILED
139	12-Apr-22	MYSURU	66	HV1	PONNAMPET_66	9:00	9:05	0:05	TRANSFORMER FAULT
140	12-Apr-22	MYSURU	66	HV1	THUMBLA_66	16:45	16:56	0:11	TRANSFORMER FAULT
141	12-Apr-22	MYSURU	66	HV1	SANIVARASANTHE_66	15:29:47 (11.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
142	12-Apr-22	MYSURU	66	HV2	DEVANOORNGUDU_66	15:16	15:56	0:39	LINE CLEAR AVAILED
143	12-Apr-22	MYSURU	66	HV2	HANNUR_66	19:05	19:10	0:05	LINE CLEAR AVAILED
144	12-Apr-22	MYSURU	66	HV2	HARVEY_66	13:50	15:44	1:54	LINE CLEAR AVAILED
145	12-Apr-22	MYSURU	66	HV2	HARVEY_66	21:45:08 (11.04.2022)	7:45:00 (12.04.2022)	9:59 hrs	LINE CHARGED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
146	12-Apr-22	MYSURU	66	KHB STATION-HOOTAGALLI	NO STATIONS EFFECTED	21:00:29 (12.04.2022)			LINE OPEN :LINE CLEAR AVAILED
147	12-Apr-22	MYSURU	66	NAGAMANGALA 220-KOPPA	NO STATIONS EFFECTED	12:15	18:20	6:05	NFBC ISSUED
148	12-Apr-22	MYSURU	66	TUBINKERE-MC- 4	NO STATIONS EFFECTED	12:05	13:10	1:05	LINE CLEAR AVAILED
149	12-Apr-22	MYSURU	66	VAJMANGALA-JYOTHINAGARA	JYOTHINAGARA_66DKMAIDANA 66	17:07	17:14	0:07	LINE FAULT
150	12-Apr-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN :LINE CLEAR AVAILED
151	12-Apr-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN :LINE CLEAR AVAILED
152	12-Apr-22	MYSURU	220	KADAKOLA-BASTIPURA 2	NO STATIONS EFFECTED	8:37	11:53	3:15	LINE CLEAR AVAILED
153	12-Apr-22	TUMKUR	66	ANCHEPALYA 220KV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66,NIDSALE_6 6,DUNDANAHALLI_66	3:20	3:30	0:10	LINE FAULT
154	12-Apr-22	TUMKUR	66	ANCHEPALYA 220KV- KUNIGAL66	KUNIGAL_66	13:43	13:50	0:07	HAND TRIPPED
155	12-Apr-22	TUMKUR	66	BELLAVI-ANTHRASANAHALLI	BELLAVI_66	10:00	13:06	3:06	LINE CLEAR AVAILED
156	12-Apr-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	8:13	8:23	0:10	LINE FAULT
157	12-Apr-22	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	14:30	14:56	0:26	HAND TRIPPED
158	12-Apr-22	TUMKUR	66	HIRIYUR 220KV-P R PURA	P R PURA_66	14:30	14:56	0:26	HAND TRIPPED
159	12-Apr-22	TUMKUR	66	HIRIYUR220-BEVINAHALLI66	BEVINAHALLI_66,JAVAGONDANA HALLI_66,DASUDI_66	14:30	14:56	0:26	HAND TRIPPED
160	12-Apr-22	TUMKUR	66	HIRIYUR220-MATHOD 2&1 LINE CLUB	MATHOD_66,HINDASGHATTA_6 6,KANCHIPURA_66,GARAGA_66, PANCHANAHALLI_66,HOSADURG A_66	14:30	14:56	0:26	HAND TRIPPED
161	12-Apr-22	TUMKUR	66	HIRIYUR220-THALLAK220	HIRIYUR_220	14:30	14:56	0:26	HAND TRIPPED
162	12-Apr-22	TUMKUR	66	TR-2	SANIKERE_66	6:43	7:28	0:45	MAIN SUPPLY FAILURE
163	12-Apr-22	TUMKUR	66	TR-2	SANIKERE_66	7:33	7:50	0:17	MAIN SUPPLY FAILURE
164	12-Apr-22	TUMKUR	66	TR-2	PATTANAYAKANAHALLI_66	7:23	8:14	0:51	LINE CLEAR AVAILED
165	12-Apr-22	TUMKUR	66	TR-2	HOSAKRE_66	7:37	10:15	2:37	LINE CLEAR AVAILED
166	12-Apr-22	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110,KATRIKEHAL_11 0	12:45	12:50	0:05	LINE FAULT
167	12-Apr-22	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	13:27	13:33	0:05	LINE CLEAR AVAILED
168	12-Apr-22	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	14:21	14:41	0:19	HAND TRIPPED
169	13-Apr-22	BAGALKOT	110	110/11KV, HV2	SANKESHWAR_110	15:50	15:55	0:05	LINE CLEAR AVAILED
170	13-Apr-22	BAGALKOT	110	110/11KV, HV2	SHIRAGUPPI_110	16:55	18:30	1:35	LINE CLEAR AVAILED
171	13-Apr-22	BAGALKOT	110	110/11KV,HV1	YADWAD_110	10:48	17:02	6:14	LINE CLEAR AVAILED
172	13-Apr-22	BAGALKOT	110	110/11KV,HV1	YARAGATTI_110	9:01	11:13	2:12	MAIN SUPPLY FAILURE
173	13-Apr-22	BAGALKOT	110	110/11KV,HV1(HV4)	GOPANAKOPPA_110	10:04	16:38	6:34	LINE CLEAR AVAILED
174	13-Apr-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	22:00	22:05	0:05	TRANSFORMER FAULT
175	13-Apr-22	BAGALKOT	110	110/11KV,HV2	YADWAD_110	11:34	17:02	5:28	LINE CLEAR AVAILED
176	13-Apr-22	BAGALKOT	110	110/11KV,HV2	YARAGATTI_110	9:01	11:14	2:13	MAIN SUPPLY FAILURE
177	13-Apr-22	BAGALKOT	110	110/11KV,HV2(HV3)	GOPANAKOPPA_110	10:04	16:37	6:33	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
178	13-Apr-22	BAGALKOT	110	110/33KV,HV3	YARAGATTI_110, SHIVAPUR_33, BOSCH_IPP, CHUNCHNUR_LIS	9:01	11:12	2:11	MAIN SUPPLY FAILURE
179	13-Apr-22	BAGALKOT	110	BENAKATTI- YARAGATTI	YARAGATTI_110	9:00	11:05	2:05	LINE CLEAR AVAILED
180	13-Apr-22	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN :LINE CLEAR AVAILED
181	13-Apr-22	BAGALKOT	110	HALIYAL-KAWALWADA	STATION NOT AFFECTED HALIYAL_110	17:56 (07.04.2022)			LINE OPEN:LINE FAULT
182	13-Apr-22	BAGALKOT	110	HIREBEVANUR-RODAGI	RODAGI_110	21:05	21:23	0:18	LINE FAULT
183	13-Apr-22	BAGALKOT	110	KAMBAGI-TODALBAGI	STATION NOT AFFECTED KEMBAGI_110	13:51	14:19	0:28	HAND TRIPPED
184	13-Apr-22	BAGALKOT	110	KAMBAGI-TODALBAGI	STATION NOT AFFECTED KAMBAGI_110	16:57 (13.04.2022)			LINE OPEN :LINE CLEAR AVAILED
185	13-Apr-22	BAGALKOT	110	KIADB BIJAPUR-BHUTNAL	BHUTNAL_110	17:17	17:28	0:11	LINE FAULT
186	13-Apr-22	BAGALKOT	110	MK HUBLI-MK HUBLI1	STATION NOT AFFECTED MK HUBLI_220	10:59 (31.03.2022)			LINE OPEN :LINE CLEAR AVAILED
187	13-Apr-22	BAGALKOT	110	MRUTHYUNJAYANAGAR-UAS	MRUTHYUNJAYANAGAR_110	14:17	18:16	3:59	LINE CLEAR AVAILED
188	13-Apr-22	BAGALKOT	110	MUGALKHOD- RAIBAG2	STATION NOT AFFECTED MUGALKHOD_220	10:04	11:37	1:33	LINE CLEAR AVAILED
189	13-Apr-22	BAGALKOT	110	MUGALKHOD- SAIDAPUR	STATION NOT AFFECTED MUGALKHOD_220	10:37	12:14	1:37	LINE CLEAR AVAILED
190	13-Apr-22	BAGALKOT	110	NARENDRA- MRUTHYUNJAY NAGAR	STATION NOT AFFECTED NARENDRA_220	14:17	18:15	3:58	LINE CLEAR AVAILED
191	13-Apr-22	BAGALKOT	110	NARENDRA- SHEDBAL	STATION NOT AFFECTED NARENDRA_220	12:06	18:09	6:03	LINE CLEAR AVAILED
192	13-Apr-22	BAGALKOT	110	NARENDRA1- MRUTHYUNJAYANAGAR	STATION NOT AFFECTED MRUTHYUNJAYANAGAR_110	14:17	18:16	3:59	LINE CLEAR AVAILED
193	13-Apr-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN :LINE CLEAR AVAILED
194	13-Apr-22	BAGALKOT	110	SAVALAGI- AIGALI(YELLAMANAWADI)	SAVALAGI_110	9:19	18:16	8:57	LINE CLEAR AVAILED
195	13-Apr-22	BAGALKOT	110	TAKKALKI-KNSC	TAKKALKI_110	5:29	5:30	0:01	MAIN SUPPLY FAILURE
196	13-Apr-22	BAGALKOT	110	TAKKALKI-WRD	TAKKALKI_110	5:29	5:30	0:01	MAIN SUPPLY FAILURE
197	13-Apr-22	BAGALKOT	110	TARIHAL(NARENDRA220)- TADASINKOPPA	STATION NOT AFFECTED TADASINKOPPA_110	16:06 (10.04.2022)			LINE CLEAR AVAILED
198	13-Apr-22	BAGALKOT	110	UDAYMBAG-MACHE	STATION NOT AFFECTED UDAYMBAG_110	10:10 (10.04.2022)			LINE OPEN :LINE CLEAR AVAILED
199	13-Apr-22	BAGALKOT	110	UGARKH-UGRKHUGAR SUGAR WORK	STATION NOT AFFECTED UGHARKHUD_110	8:36	11:34	2:58	LINE CLEAR AVAILED
200	13-Apr-22	BAGALKOT	110	YARAGATTI- KATAKOL	KATAKOL_110	9:00	11:05	2:05	LINE CLEAR AVAILED
201	13-Apr-22	BAGALKOT	110	YDWAD-ISEL Cbreaker	YADWAD_110, IZARA_IPP	15:32	17:01	1:29	LINE CLEAR AVAILED
202	13-Apr-22	BAGALKOT	110	YDWAD-ISEL Cbreaker	YADWAD_110, IZARA_IPP	17:04	17:08	0:04	LINE CLEAR AVAILED
203	13-Apr-22	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED NARENDRA_220	13:40	17:57	4:17	LINE CLEAR AVAILED
204	13-Apr-22	BAGALKOT	220	220/110KV, HV2&LV2	STATION NOT AFFECTED BIJAPUR_220	12:09	13:01	0:52	LINE CLEAR AVAILED
205	13-Apr-22	BAGALKOT	220	AEQUUS- BELGAUM1	STATION NOT AFFECTED AEQUAS_220	15:39	18:16	2:37	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
206	13-Apr-22	BAGALKOT	220	AMBEWADI- NARENDRA1	STATION NOT AFFECTED AMBEWADI_220	12:12	12:53	0:41	LINE FAULT
207	13-Apr-22	BAGALKOT	220	AMBEWADI- NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	12:40	13:12	0:32	LINE FAULT
208	13-Apr-22	BAGALKOT	220	AQUES- CHIKKODI1	STATION NOT AFFECTED AQUES_220	17:41 (10.04.2022)	15:31 (13.04.2022)	69:50 hrs	LINE CHARGED
209	13-Apr-22	BAGALKOT	220	ATHANI-RVIURJA(KAKAMARI1)	STATION NOT AFFECTED ATHANI_220	16:34 (09.04.2022)			LINE OPEN:LINE FAULT
210	13-Apr-22	BAGALKOT	220	ATHANI-RVIURJA(KAKAMARI2)	STATION NOT AFFECTED ATHANI_220	16:34 (09.04.2022)			LINE OPEN:LINE FAULT
211	13-Apr-22	BAGALKOT	220	BELGAUM- CHIKKODI1 (AQUAS1)	STATION NOT AFFECTED BELGAUM_220	15:40	18:16	2:36	LINE CLEAR AVAILED
212	13-Apr-22	BAGALKOT	220	BELGAUM- CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	6:03	6:38	0:35	LINE FAULT
213	13-Apr-22	BAGALKOT	220	BELGAUM- CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	11:10	12:33	1:23	LINE CLEAR AVAILED
214	13-Apr-22	BAGALKOT	220	CHIKKODI- AQUAS1	STATION NOT AFFECTED CHIKKODI_220	6:03	6:43	0:40	LINE FAULT
215	13-Apr-22	BAGALKOT	220	CHIKKODI- BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	6:38	6:39	0:01	HAND TRIPPED
216	13-Apr-22	BAGALKOT	220	CHIKKODI- BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	11:11	12:33	1:22	NFBC ISSUED
217	13-Apr-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN :LINE CLEAR AVAILED
218	13-Apr-22	BAGALKOT	220	HUBLI- NAGJHARI1	STATION NOT AFFECTED HUBLI_220	11:36	14:51	8:40	LINE CLEAR AVAILED
219	13-Apr-22	BAGALKOT	220	KUDACHI- CHIKKODI1	STATION NOT AFFECTED KUDACHI_220	6:03	6:36	0:33	LINE FAULT
220	13-Apr-22	BAGALKOT	220	NARENDRA- AMBEWADI1	STATION NOT AFFECTED NARENDRA_220	12:12	12:53	0:41	LINE FAULT
221	13-Apr-22	BAGALKOT	220	NARENDRA- AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	12:40	13:12	0:32	LINE FAULT
222	13-Apr-22	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	17:30 (31.03.2022)			LINE OPEN :LINE CLEAR AVAILED
223	13-Apr-22	BAGALKOT	220	SIRSI-SHARAVATI2	SIRSI_220	9:46 (12.04.2022)	9:11 (13.04.2022)	23:25	LINE CHARGED
224	13-Apr-22	BAGALKOT	220	SIRSI-SHUBLI1	SIRSI_220	13:24 (12.04.2022)			LINE OPEN :LINE CLEAR AVAILED
225	13-Apr-22	BENGALURU	66	A STATION 1 66 - A STATION 220	A STATION 1 66	16:09	16:24	0:15	LOAD CHANGE OVER
226	13-Apr-22	BENGALURU	66	A STATION 1 66 - A STATION 220	A STATION 1 66	23:23	23:25	0:02	LOAD CHANGE OVER
227	13-Apr-22	BENGALURU	66	ADUGODI - HSR LAYOUT 220	ADUGODI, BOSCH (EHT)	11:30	11:38	0:08	MAIN SUPPLY FAILURE
228	13-Apr-22	BENGALURU	66	AMAR JYOTHI - HAL 220	AMAR JYOTHI	8:22	8:45	0:23	LOAD CHANGE OVER
229	13-Apr-22	BENGALURU	66	AMAR JYOTHI - HAL 220	AMAR JYOTHI	11:15	11:20	0:05	LOAD CHANGE OVER
230	13-Apr-22	BENGALURU	66	BANASHANKARI - VRISHABHAVATHI 220	BANASHANKARI	16:19	16:32	0:13	MAIN SUPPLY FAILURE
231	13-Apr-22	BENGALURU	66	BRIGADE MEADOWS - SHOBHA FOREST	SHOBHA FOREST	16:05	16:27	0:22	LINE FAULT
232	13-Apr-22	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI, DIBBURAHALLI	0:16	1:16	1:00	LOAD CURTAILMENT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
233	13-Apr-22	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	0:14	1:15	1:01	LOAD CURTAILMENT
234	13-Apr-22	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	11:00	11:05	0:05	LINE FAULT
235	13-Apr-22	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	11:16	11:25	0:09	LINE FAULT
236	13-Apr-22	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	6:07	6:17	0:10	LINE FAULT
237	13-Apr-22	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	4:19	4:41	0:21	LINE FAULT
238	13-Apr-22	BENGALURU	66	DEVARABISANAHALLI - CESSNA	DEVARABISANAHALLI, GLOBAL TECH PARK	11:22	11:40	0:18	LINE FAULT
239	13-Apr-22	BENGALURU	66	GOKULA - SRS PEENYA 220	GOKULA, BEL (EHT), HMT (EHT)	21:02	21:15	0:13	LOAD CHANGE OVER
240	13-Apr-22	BENGALURU	66	GOWRIBIDANUR 220 - ACC (EHT)	ACC (EHT)	11:09	11:40	0:31	LINE CLEAR AVAILED
241	13-Apr-22	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	11:09	12:01	0:52	LINE CLEAR AVAILED
242	13-Apr-22	BENGALURU	66	HEBBALA 220 - LR BANDE	NO STATION AFFECTED	5:42	17:44	12:02	LINE FAULT
243	13-Apr-22	BENGALURU	66	HV1	BRIGADE MEADOWS	16:05	16:09	0:04	LINE CLEAR AVAILED
244	13-Apr-22	BENGALURU	66	HV1	HAL 220	8:22	8:33	0:11	LINE CLEAR AVAILED
245	13-Apr-22	BENGALURU	66	HV1	BAIRAKURU	7:52	9:40	1:47	LINE CLEAR AVAILED
246	13-Apr-22	BENGALURU	66	HV1	GOWRIBIDANUR 220	20:40	20:54	0:14	TRANSFORMER FAULT
247	13-Apr-22	BENGALURU	66	HV1	DODDABELAVANGALA	10:50	10:55	0:04	LINE CLEAR AVAILED
248	13-Apr-22	BENGALURU	66	HV2	BRIGADE MEADOWS	16:05	16:09	0:04	LINE CLEAR AVAILED
249	13-Apr-22	BENGALURU	66	HV2	EAST DIVISION COMPOUND 220	10:55	10:56	0:01	LINE CLEAR AVAILED
250	13-Apr-22	BENGALURU	66	HV2	HAL 220	8:22	8:33	0:11	LINE CLEAR AVAILED
251	13-Apr-22	BENGALURU	66	HV2	MELLAHALLI	18:13	18:41	0:28	TRANSFORMER FAULT
252	13-Apr-22	BENGALURU	66	HV2	PADMANABHANAGARA	16:59	17:06	0:07	TRANSFORMER FAULT
253	13-Apr-22	BENGALURU	66	HV2	REMC0	15:07	15:17	0:10	MAIN SUPPLY FAILURE
254	13-Apr-22	BENGALURU	66	HV2	REMC0	16:19	16:46	0:27	MAIN SUPPLY FAILURE
255	13-Apr-22	BENGALURU	66	HV2	REMC0	21:23	21:27	0:04	LOAD CHANGE OVER
256	13-Apr-22	BENGALURU	66	HV2	KEMBODI	2:05	2:10	0:05	TRANSFORMER FAULT
257	13-Apr-22	BENGALURU	66	JAYADEVA - NIMHANS 220	JAYADEVA	11:21	11:29	0:08	LOAD CHANGE OVER
258	13-Apr-22	BENGALURU	66	JAYADEVA - SARAKKI	JAYADEVA	13:35	13:43	0:08	LOAD CHANGE OVER
259	13-Apr-22	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENHALLI, HAROBELE, BIJJALALLI	14:34	14:43	0:09	LINE FAULT
260	13-Apr-22	BENGALURU	66	KENERI SATELLITE TOWN - SIR MV LAYOUT	KENERI SATELLITE TOWN	16:20	16:57	0:37	MAIN SUPPLY FAILURE
261	13-Apr-22	BENGALURU	66	KENERI SATELLITE TOWN - SIR MV LAYOUT	KENERI SATELLITE TOWN	17:20	17:32	0:12	LOAD CHANGE OVER
262	13-Apr-22	BENGALURU	66	KIADB DB PURA 220 - APPEAREL PARK	APPEAREL PARK	16:44	17:16	0:32	MAIN SUPPLY FAILURE
263	13-Apr-22	BENGALURU	66	KIADB DB PURA 220 - HIMAT SINGHA FACTORY (EHT)	HIMAT SINGHA FACTORY (EHT)	16:44	17:16	0:32	MAIN SUPPLY FAILURE
264	13-Apr-22	BENGALURU	66	KIADB DB PURA 220 - INDO MM (EHT)	INDO MM (EHT)	16:44	17:16	0:32	MAIN SUPPLY FAILURE
265	13-Apr-22	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	1:13	2:04	0:51	LOAD CURTAILMENT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
266	13-Apr-22	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	0:49	1:56	1:07	LOAD CURTAILMENT
267	13-Apr-22	BENGALURU	66	LAKSHMIPURA - TADIGOL CROSS	LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	13:45	13:55	0:10	LINE FAULT
268	13-Apr-22	BENGALURU	66	MAGADI 220 - MAGADI 66	MAGADI 66, GUDEMARANAHALLI, HOSPALYA CIRCLE	18:12	18:29	0:16	LINE FAULT
269	13-Apr-22	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	22:41	22:48	0:07	LOAD CHANGE OVER
270	13-Apr-22	BENGALURU	66	MALUR 220 - HOSKOTE 1	NO STATION AFFECTED	6:45	6:50	0:04	LINE FAULT
271	13-Apr-22	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	19:08	19:12	0:04	LOAD CHANGE OVER
272	13-Apr-22	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	21:48	21:59	0:11	LOAD CHANGE OVER
273	13-Apr-22	BENGALURU	66	NRS 220 - TELECOM LEYOUT 2	TELECOM LAYOUT	16:39	16:56	0:17	LINE FAULT
274	13-Apr-22	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	18:55	18:58	0:03	LOAD CHANGE OVER
275	13-Apr-22	BENGALURU	66	RMZ - VIKAS TECH PARK 220	RMZ	11:20	11:50	0:30	MAIN SUPPLY FAILURE
276	13-Apr-22	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	10:08	10:12	0:04	LOAD CHANGE OVER
277	13-Apr-22	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	15:08	15:14	0:06	MAIN SUPPLY FAILURE
278	13-Apr-22	BENGALURU	66	RR NAGAR - VRISHABHAVATHI 220	RR NAGAR	14:43	14:48	0:05	LOAD CHANGE OVER
279	13-Apr-22	BENGALURU	66	RR NAGAR - VRISHABHAVATHI 220	RR NAGAR	16:20	16:52	0:32	MAIN SUPPLY FAILURE
280	13-Apr-22	BENGALURU	66	RR NAGAR - VRISHABHAVATHI 220	RR NAGAR	17:52	17:55	0:03	LOAD CHANGE OVER
281	13-Apr-22	BENGALURU	66	SRS PEENYA 220 - TG HALLI	BYADRAHALLI, KODIHALLI, SRIGANDA KAVALLU	16:18	17:43	1:25	LINE FAULT
282	13-Apr-22	BENGALURU	66	ST JOHN WOOD - HSR LAYOUT 220	ST JOHN WOOD	11:30	11:37	0:07	MAIN SUPPLY FAILURE
283	13-Apr-22	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	REMCO, GLOBAL VILLAGE (EHT)	15:07	15:17	0:10	LINE FAULT
284	13-Apr-22	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66	10:33	10:39	0:06	LOAD CHANGE OVER
285	13-Apr-22	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66	14:21	14:29	0:08	LOAD CHANGE OVER
286	13-Apr-22	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	15:00	15:21	0:21	LINE CLEAR AVAILED
287	13-Apr-22	BENGALURU	66	TK HALLI 220 - IGGALUR	IGGALUR, K HONALGERE, YATHAMBADI	15:00	15:21	0:21	LINE CLEAR AVAILED
288	13-Apr-22	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	15:00	16:04	1:04	LINE CLEAR AVAILED
289	13-Apr-22	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	15:00	16:04	1:04	LINE CLEAR AVAILED
290	13-Apr-22	BENGALURU	66	TK HALLI 220 - SIMSHA	TK HALLI 220	15:00	16:14	1:14	LINE CLEAR AVAILED
291	13-Apr-22	BENGALURU	66	VRISHABHAVATHI 220 - SIR MV LAYOUT	KNGERI SATELLITE TOWN, SIR MV LAYOUT	16:20	16:40	0:20	LINE CLEAR AVAILED
292	13-Apr-22	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	16:40	17:02	0:22	LINE FAULT
293	13-Apr-22	BENGALURU	220	DABUSPET 220 - KADUR 220	NO STATION AFFECTED	9:05	16:38	7:33	LOAD CURTAILMENT
294	13-Apr-22	BENGALURU	220	GOWRIBIDANUR 220 - KIADB DB PURA 220	KIADB DB PURA 220	16:44	17:16	0:32	LINE FAULT
295	13-Apr-22	BENGALURU	220	GOWRIBIDANUR 220 - KIADB DB PURA 220	NO STATION AFFECTED	17:55	20:40	2:45	LINE FAULT
296	13-Apr-22	BENGALURU	220	HV2	HAL 220	8:22	8:33	0:11	TRANSFORMER FAULT
297	13-Apr-22	BENGALURU	220	HV2	HSR LAYOUT 220	11:30	11:36	0:06	LOAD CHANGE OVER
298	13-Apr-22	BENGALURU	220	HV2	TK HALLI 220	15:00	15:16	0:16	TRANSFORMER FAULT
299	13-Apr-22	BENGALURU	220	NELAMANGALA 400 - SRS PEENYA 1	SRS PEENYA 220	16:29(13-4-2022)			LINE OPEN:LINE FAULT
300	13-Apr-22	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 1 220	NO STATION AFFECTED	16:29(13/04/2022)			LINE OPEN:LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
301	13-Apr-22	BENGALURU	220	VRISHABHAVATHI 220 - TATAGUNI 220(EHT)	VRISHABHAVATHI 220	16:20	16:40	0:20	LINE FAULT
302	13-Apr-22	GULBARGA	66	HV2	TAMBRAHALI_66	8:00	8:05	0:05	TRANSFORMER FAULT
303	13-Apr-22	GULBARGA	66	HV2	TAMBRAHALI_66	10:00	10:05	0:05	TRANSFORMER FAULT
304	13-Apr-22	GULBARGA	66	HV2	HANASI_66	14:35	14:45	0:10	TRANSFORMER FAULT
305	13-Apr-22	GULBARGA	66	MUNIRABAD-MHDLIN	VENKATAPUR_66,UPANAYAKAN AHALLI_66,HAGARIBOMMANAH ALLI_66,RR STEELS_IPP	10:00	14:55	4:55	LINE CLEAR AVAILED
306	13-Apr-22	GULBARGA	66	MUNIRABAD-MSD	HANASI_110	10:00	14:55	4:55	LINE CLEAR AVAILED
307	13-Apr-22	GULBARGA	66	PUNABGHATA-UCHCHANGIDURGA	UCHCHANGIDURGA_66	10:40	10:50	0:10	LINE CLEAR AVAILED
308	13-Apr-22	GULBARGA	110	DUBALGUNDI-HUMNABAD	DUBALGUNDI_110	15:50	16:00	0:10	MAIN SUPPLY FAILURE
309	13-Apr-22	GULBARGA	110	GHATTARGA-AFZALPUR	AFZALPUR_110	17:35	17:40	0:05	LINE FAULT
310	13-Apr-22	GULBARGA	110	GHATTARGA-AFZALPUR	AFZALPUR_110	17:45	17:50	0:05	LINE CLEAR AVAILED
311	13-Apr-22	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110,AFZALPUR_110	17:35	17:50	0:15	MAIN SUPPLY FAILURE
312	13-Apr-22	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGOAN_110,DIGGI_110	12:53	12:58	0:05	LINE FAULT
313	13-Apr-22	GULBARGA	110	HUMNABAD-DUBALGUNDI	DUBALGUNDI_110	15:54	15:57	0:03	LINE FAULT
314	13-Apr-22	GULBARGA	110	HUMNABAD-HALBARGA	HALBARGA_110	15:54	15:57	0:03	LINE FAULT
315	13-Apr-22	GULBARGA	110	HUMNABAD-HUMNABAD_2	HUMNABAD_110	15:54	15:57	0:03	LINE FAULT
316	13-Apr-22	GULBARGA	110	HUMNABAD-SASTHAPUR	RAJESHWAR_110,SASTHAPUR_110,MANTHAL_110	15:54	15:57	0:03	LINE FAULT
317	13-Apr-22	GULBARGA	110	HV1,HV2	MYLAR_110	17:35	17:50	0:15	LINE CLEAR AVAILED
318	13-Apr-22	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPURA_110,NSL SUGARS FACTORY	19:21	20:15	0:54	LINE CLEAR AVAILED
319	13-Apr-22	GULBARGA	110	KAPNOOR-MAHAGAON	MAHAGAON_110,MARAGUTTI_110	11:20	14:40	3:20	LINE CLEAR AVAILED
320	13-Apr-22	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	17:33	20:22	2:49	LINE FAULT
321	13-Apr-22	GULBARGA	110	MADIYAL-KAPNOOR	MADIYAL_110,CHOWDAPUR_110,NSL SUAGR_IPP	17:43	17:45	0:02	LINE FAULT
322	13-Apr-22	GULBARGA	110	MALLAT-BYGWAT	BYAGWAT_110, VALKAMDINNI_110	18:55	19:05	0:10	LINE FAULT
323	13-Apr-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	0:27	0:39	0:12	LINE FAULT
324	13-Apr-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	9:22	9:28	0:06	LINE CLEAR AVAILED
325	13-Apr-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	15:45	15:50	0:05	LINE CLEAR AVAILED
326	13-Apr-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	1:23	1:33	0:10	LINE FAULT
327	13-Apr-22	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	5:28	5:38	0:10	LINE FAULT
328	13-Apr-22	GULBARGA	110	MUNIRABAD-TIE LINE	MUNIRABAD_220	10:00	14:55	4:55	LINE CLEAR AVAILED
329	13-Apr-22	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	15:51	15:59	0:08	LINE FAULT
330	13-Apr-22	GULBARGA	110	SEDAM-CHITTAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	13:40	13:46	0:06	LINE FAULT
331	13-Apr-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN :LINE CLEAR AVAILED
332	13-Apr-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN :LINE CLEAR AVAILED
333	13-Apr-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110, WADAGERA_110,SANNATHI_IPP, COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN :LINE CLEAR AVAILED
334	13-Apr-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110, WADAGERA_110,SANNATHI_IPP, COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN :LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
335	13-Apr-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALAPURA_110	10:55	11:05	0:10	LINE FAULT
336	13-Apr-22	GULBARGA	220	ALIPUR-RAGALPADU	ALIPUR_220	12:59	13:36	0:37	LINE FAULT
337	13-Apr-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
338	13-Apr-22	GULBARGA	220	HV2	SINDHANOOR_220	13:25	13:55	0:30	LINE CLEAR AVAILED
339	13-Apr-22	GULBARGA	220	LINGAPUR-BTPS	LINGAPUR_220	20:47	21:57	1:10	LINE CLEAR AVAILED
340	13-Apr-22	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	23:01 (12.04.2022)	5:07 (13.04.2022)	6:06 HRS	LINE CHARGED
341	13-Apr-22	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	23:01 (12.04.2022)	5:07 (13.04.2022)	6:06 HRS	LINE CHARGED
342	13-Apr-22	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	20:25	21:10	0:45	LINE FAULT
343	13-Apr-22	HASSAN	66	BHADRA-SHMG 2	gen_bhadra	21:20	22:04	0:44	LINE FAULT
344	13-Apr-22	HASSAN	66	CRPATNA-CRPTNA1	CRPATNA_220	16:35	16:57	0:22	LINE FAULT
345	13-Apr-22	HASSAN	66	CRPATNA-CRPTNA2	CRPATNA_220	16:35	16:57	0:22	LINE FAULT
346	13-Apr-22	HASSAN	66	CRPATNA-MATTANAVILE	CRPATNA_220	16:35	16:57	0:22	LINE FAULT
347	13-Apr-22	HASSAN	66	CRPATNA-SBELAGOLA	CRPATNA_220	16:18	17:01	0:43	LINE FAULT
348	13-Apr-22	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	16:35	17:28	0:53	LINE FAULT
349	13-Apr-22	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	11:35	11:47	0:12	LINE FAULT
350	13-Apr-22	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	16:45	17:30	0:45	LINE FAULT
351	13-Apr-22	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	6:19	6:30	0:11	LINE FAULT
352	13-Apr-22	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	16:50	17:35	0:45	LINE FAULT
353	13-Apr-22	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	16:46	17:30	0:44	LINE FAULT
354	13-Apr-22	HASSAN	66	HV1	BALEHONNUR_66	20:26	21:09	0:43	TRANSFORMER FAULT
355	13-Apr-22	HASSAN	66	HV1	DODDAHALLI_66	6:21	6:35	0:14	MAIN SUPPLY FAILURE
356	13-Apr-22	HASSAN	66	HV1	DODDAHALLI_66	16:57	17:33	0:36	MAIN SUPPLY FAILURE
357	13-Apr-22	HASSAN	66	HV1	HOLEHONNUR_66	16:19	16:53	0:34	LINE CLEAR AVAILED
358	13-Apr-22	HASSAN	66	HV1	HOLEHONNUR_66	18:51	19:50	0:59	LINE CLEAR AVAILED
359	13-Apr-22	HASSAN	66	HV1	SAKALESHPURA_66	18:00	18:10	0:10	TRANSFORMER FAULT
360	13-Apr-22	HASSAN	66	HV1 CB	NAGARTHI_66	6:20	6:21	0:01	MAIN SUPPLY FAILURE
361	13-Apr-22	HASSAN	66	HV1 CB	NAGARTHI_66	22:22	22:24	0:02	HAND TRIPPED
362	13-Apr-22	HASSAN	66	HV2	UDAYAPURA_66	17:51(13.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
363	13-Apr-22	HASSAN	66	HV2	BALEHONNUR_66	10:18	11:10	0:52	LINE CLEAR AVAILED
364	13-Apr-22	HASSAN	66	HV2	DUDDA_66	15:20	15:35	0:15	TRANSFORMER FAULT
365	13-Apr-22	HASSAN	66	HV2	HOLEHONNUR_66	18:51	19:50	0:59	LINE CLEAR AVAILED
366	13-Apr-22	HASSAN	66	HV2	RAMNATHPURA_66	3:42	4:03	0:21	TRANSFORMER FAULT
367	13-Apr-22	HASSAN	66	HV2	RAMNATHPURA_66	16:47	17:40	0:53	MAIN SUPPLY FAILURE
368	13-Apr-22	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	21:18	22:04	0:46	LINE FAULT
369	13-Apr-22	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN :LINE CLEAR AVAILED
370	13-Apr-22	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	9:30	17:35	8:05	LINE CLEAR AVAILED
371	13-Apr-22	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	18:36	19:05	0:29	LINE FAULT
372	13-Apr-22	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	9:30	17:35	8:05	LINE CLEAR AVAILED
373	13-Apr-22	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	18:35	18:45	0:10	LINE FAULT
374	13-Apr-22	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	16:55	17:00	0:05	LINE FAULT
375	13-Apr-22	HASSAN	66	UDDUKO-SUZLON2	UDDURKOPPLU_66	17:30	20:10	2:40	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
376	13-Apr-22	HASSAN	66	UDDURKO-HASSAN1	UDDURKOPPLU_ 66	15:58	16:15	0:17	HAND TRIPPED
377	13-Apr-22	HASSAN	66	UDDURKO-SUZLON1	UDDURKOPPLU_ 66	18:57 (13.04.2022)			LINE OPEN:LINE FAULT
378	13-Apr-22	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	21:15	21:21	0:06	LINE FAULT
379	13-Apr-22	HASSAN	110	GAJNUR-SHIMOGA IC LINE	GAJNUR_110	21:30(13.04.2022)			LINE CLEAR AVAILED
380	13-Apr-22	HASSAN	110	GURUVA-KEMAR1	GURUVAYANKERE_110	11:16	12:56	1:40	NFBC ISSUED
381	13-Apr-22	HASSAN	110	GURUVA-KEMAR1	GURUVAYANKERE_110	17:49	18:47	0:58	MAIN SUPPLY FAILURE
382	13-Apr-22	HASSAN	110	GURUVA-KEMAR1	GURUVAYANKERE_110	21:14	22:36	1:22	MAIN SUPPLY FAILURE
383	13-Apr-22	HASSAN	110	GURUVA-KEMAR2	GURUVAYANKERE_110	17:49	18:40	0:51	MAIN SUPPLY FAILURE
384	13-Apr-22	HASSAN	110	GURUVA-KEMAR2	GURUVAYANKERE_110	21:14	21:59	0:45	MAIN SUPPLY FAILURE
385	13-Apr-22	HASSAN	110	GURUVA-SLVPWR	GURUVAYANKERE_110	17:52	18:43	0:51	MAIN SUPPLY FAILURE
386	13-Apr-22	HASSAN	110	GURUVA-SLVPWR	GURUVAYANKERE_110	21:14	22:03	0:49	MAIN SUPPLY FAILURE
387	13-Apr-22	HASSAN	110	HASSN-UDDURKOPLU	HASSAN_66	15:56	16:11	0:15	LINE FAULT
388	13-Apr-22	HASSAN	110	HGUNJE-LINE1	HEGUNJE_220	21:14	23:05	1:51	MAIN SUPPLY FAILURE
389	13-Apr-22	HASSAN	110	HGUNJE-LINE1	HEGUNJE_220	21:14	23:48	2:34	MAIN SUPPLY FAILURE
390	13-Apr-22	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	21:14	23:06	1:52	MAIN SUPPLY FAILURE
391	13-Apr-22	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	21:14	23:57	2:43	MAIN SUPPLY FAILURE
392	13-Apr-22	HASSAN	110	HIRIYA-MANIPAL	HIRIYADKA_110	21:14	23:59	2:45	MAIN SUPPLY FAILURE
393	13-Apr-22	HASSAN	110	HV1	HEGUNJE_220	21:14	22:48	1:34	MAIN SUPPLY FAILURE
394	13-Apr-22	HASSAN	110	HV1	KEMAR_220	21:14	21:51	0:37	MAIN SUPPLY FAILURE
395	13-Apr-22	HASSAN	110	HV1	HOSUR_110	13:30	14:04	0:34	LINE CLEAR AVAILED
396	13-Apr-22	HASSAN	110	HV2	KEMAR_220	21:14	21:54	0:40	MAIN SUPPLY FAILURE
397	13-Apr-22	HASSAN	110	HV2	MSEZ_220	21:14	22:13	0:59	MAIN SUPPLY FAILURE
398	13-Apr-22	HASSAN	110	HV2	KADUR_220	16:38	16:48	0:10	TRANSFORMER FAULT
399	13-Apr-22	HASSAN	110	HV2	KULASHEKAR_110	19:01	20:29	1:28	TRANSFORMER FAULT
400	13-Apr-22	HASSAN	110	HV2	KULASHEKAR_110	20:29	21:14	0:45	TRANSFORMER FAULT
401	13-Apr-22	HASSAN	110	HV2	KULASHEKAR_110	21:14	21:57	0:43	MAIN SUPPLY FAILURE
402	13-Apr-22	HASSAN	110	HV2	VITTALA_110	19:55	20:16	0:21	HAND TRIPPED
403	13-Apr-22	HASSAN	110	HV2	VITTALA_110	21:14	22:01	0:47	MAIN SUPPLY FAILURE
404	13-Apr-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN : LINE CLEAR AVAILED
405	13-Apr-22	HASSAN	110	HV4	PUTTUR_220	23:02	23:15	0:13	TRANSFORMER FAULT
406	13-Apr-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN :LINE CLEAR AVAILED
407	13-Apr-22	HASSAN	110	KAVOOR-AMR	KAVOOR_220	20:02	22:10	2:08	LINE FAULT
408	13-Apr-22	HASSAN	110	KAVOOR-KOCL	KAVOOR_220	20:04	22:11	2:07	LINE FAULT
409	13-Apr-22	HASSAN	110	KEMAR-BELMAN	KEMAR_220	21:14	22:03	0:49	MAIN SUPPLY FAILURE
410	13-Apr-22	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	11:16	12:56	1:40	LINE CLEAR AVAILED
411	13-Apr-22	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	21:14	22:36	1:22	MAIN SUPPLY FAILURE
412	13-Apr-22	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	17:49	18:48	0:59	LINE FAULT
413	13-Apr-22	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	21:14	22:36	1:22	MAIN SUPPLY FAILURE
414	13-Apr-22	HASSAN	110	KEMAR-HIRIYADKA	KEMAR_220	21:14	22:01	0:47	MAIN SUPPLY FAILURE
415	13-Apr-22	HASSAN	110	KEMAR-Manipal1	KEMAR_220	21:14	22:00	0:46	MAIN SUPPLY FAILURE
416	13-Apr-22	HASSAN	110	KEMAR-Manipal2	KEMAR_220	21:14	22:19	1:05	MAIN SUPPLY FAILURE
417	13-Apr-22	HASSAN	110	KEMAR-MBDR	KEMAR_220	21:14	22:02	0:48	MAIN SUPPLY FAILURE
418	13-Apr-22	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	21:14	22:03	0:49	MAIN SUPPLY FAILURE

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
419	13-Apr-22	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	22:18(13.04.2022)			LINE OPEN:LINE FAULT
420	13-Apr-22	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	15:36	10:56	19:20	LINE CLEAR AVAILED
421	13-Apr-22	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	19:39	22:17	2:38	LINE FAULT
422	13-Apr-22	HASSAN	110	LPH-MGHE 1	lph_gen	20:31 (10.04.2022)			LINE OPEN :LINE CLEAR AVAILED
423	13-Apr-22	HASSAN	110	LV1	HEGUNJE_220	21:14	22:48	1:34	MAIN SUPPLY FAILURE
424	13-Apr-22	HASSAN	110	LV1	KEMAR_220	21:14	22:02	0:48	MAIN SUPPLY FAILURE
425	13-Apr-22	HASSAN	110	LV2	HEGUNJE_220	21:14	22:48	1:34	MAIN SUPPLY FAILURE
426	13-Apr-22	HASSAN	110	LV2	KEMAR_220	21:14	21:52	0:38	MAIN SUPPLY FAILURE
427	13-Apr-22	HASSAN	110	LV3	KEMAR_220	21:14	21:53	0:39	MAIN SUPPLY FAILURE
428	13-Apr-22	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	21:16	22:30	1:14	MAIN SUPPLY FAILURE
429	13-Apr-22	HASSAN	110	MANIPAL-KEMAR2	MANIPAL_110	21:16	22:22	1:06	MAIN SUPPLY FAILURE
430	13-Apr-22	HASSAN	110	MRSSTM-GAINUR	MRSMSG_220	21:28(13.04.2022)			LINE OPEN:LINE FAULT
431	13-Apr-22	HASSAN	110	NANDIKU-ISTRIL	NANDIKUR_110	21:15	22:03	0:48	MAIN SUPPLY FAILURE
432	13-Apr-22	HASSAN	110	NDKR-SUZLON	NANDIKUR_110	21:15	22:03	0:48	MAIN SUPPLY FAILURE
433	13-Apr-22	HASSAN	110	PUTR_SLTUR	VITTALA_110	15:53	17:08	1:15	LINE FAULT
434	13-Apr-22	HASSAN	110	PUTR_SLTUR	VITTALA_110	19:48	20:15	0:27	LINE FAULT
435	13-Apr-22	HASSAN	110	PUTR_SLTUR	VITTALA_110	21:15	22:00	0:45	MAIN SUPPLY FAILURE
436	13-Apr-22	HASSAN	110	PUTR_SLTUR	VITTALA_110	1:56	2:40	0:44	MAIN SUPPLY FAILURE
437	13-Apr-22	HASSAN	110	PUTTUR-MADAVU	PUTTUR_220	19:01	20:09	1:08	LINE FAULT
438	13-Apr-22	HASSAN	110	PUTTUR-MADAVU	PUTTUR_220	21:14	21:58	0:44	HAND TRIPPED
439	13-Apr-22	HASSAN	110	PUTTUR-PUTTUR1	PUTTUR_220	19:35	20:22	0:47	LINE FAULT
440	13-Apr-22	HASSAN	110	PUTTUR-PUTTUR1	PUTTUR_220	19:39	20:12	0:33	LINE FAULT
441	13-Apr-22	HASSAN	110	PUTTUR-PUTTUR1	PUTTUR_220	21:14	22:03	0:49	HAND TRIPPED
442	13-Apr-22	HASSAN	110	PUTTUR-PUTTUR2	PUTTUR_220	16:38	17:03	0:25	LINE FAULT
443	13-Apr-22	HASSAN	110	PUTTUR-PUTUR 2	PUTTUR_220	21:14	22:01	0:47	HAND TRIPPED
444	13-Apr-22	HASSAN	110	PUTTUR-VITLA	PUTTUR_220	19:55	20:14	0:19	LINE FAULT
445	13-Apr-22	HASSAN	110	PUTTUR-VITLA	PUTTUR_220	21:14	22:00	0:46	HAND TRIPPED
446	13-Apr-22	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	15:35	15:52	0:17	LINE FAULT
447	13-Apr-22	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	16:05	17:35	1:30	MAIN SUPPLY FAILURE
448	13-Apr-22	HASSAN	110	TNGL	KADUR_220	16:38	16:48	0:10	LINE FAULT
449	13-Apr-22	HASSAN	110	YGTI	KADUR_220	16:38	16:48	0:10	LINE FAULT
450	13-Apr-22	HASSAN	220	ARSK2-HSN	ARSIKERE_220	16:52	17:35	0:43	LINE FAULT
451	13-Apr-22	HASSAN	220	CRPATNA-HUYGNH	CRPATNA_220	16:25	16:51	0:26	LINE FAULT
452	13-Apr-22	HASSAN	220	HGUNJE-KEMAR	HEGUNJE_220	21:14	22:44	1:30	MAIN SUPPLY FAILURE
453	13-Apr-22	HASSAN	220	HGUNJE-VARAH	HEGUNJE_220	21:14	22:54	1:40	MAIN SUPPLY FAILURE
454	13-Apr-22	HASSAN	220	HV1	KEMAR_220	21:14	22:02	0:48	MAIN SUPPLY FAILURE
455	13-Apr-22	HASSAN	220	HV2	HEGUNJE_220	21:14	22:54	1:40	MAIN SUPPLY FAILURE
456	13-Apr-22	HASSAN	220	HV2	KEMAR_220	21:14	21:52	0:38	MAIN SUPPLY FAILURE
457	13-Apr-22	HASSAN	220	HV3	KEMAR_220	21:14	21:53	0:39	MAIN SUPPLY FAILURE
458	13-Apr-22	HASSAN	220	KAVOOR-KB1	KAVOOR_220	20:03	21:09	1:06	LINE FAULT
459	13-Apr-22	HASSAN	220	KAVOOR-KB2	KAVOOR_220	20:10(13.04.2022)			LINE OPEN:LINE FAULT
460	13-Apr-22	HASSAN	220	KAVOOR-KVRBYKMDPY	KAVOOR_220	20:00	22:15	2:15	LINE FAULT
461	13-Apr-22	HASSAN	220	KEMAR-BAIPE1	KEMAR_220	21:14	22:10	0:56	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
462	13-Apr-22	HASSAN	220	KEMAR-BAJPE2	KEMAR_220	21:14	22:11	0:57	LINE FAULT
463	13-Apr-22	HASSAN	220	KEMAR-Kavoor	KEMAR_220	21:14	21:56	0:42	LINE FAULT
464	13-Apr-22	HASSAN	220	KEMAR-NETLA1	KEMAR_220	21:14	21:55	0:41	LINE FAULT
465	13-Apr-22	HASSAN	220	KEMAR-NETLA2	KEMAR_220	21:14	22:12	0:58	LINE FAULT
466	13-Apr-22	HASSAN	220	KEMAR-UPCL1	KEMAR_220	21:14	21:49	0:35	LINE FAULT
467	13-Apr-22	HASSAN	220	KEMAR-UPCL2	KEMAR_220	21:14	21:49	0:35	LINE FAULT
468	13-Apr-22	HASSAN	220	KEMAR-Varahi1	KEMAR_220	21:14	22:37	1:23	LINE FAULT
469	13-Apr-22	HASSAN	220	KEMAR-Varahi2	KEMAR_220	21:14(13.0.2022)			LINE OPEN:LINE FAULT
470	13-Apr-22	HASSAN	220	KEMAR-Varahi3	KEMAR_220	21:14	22:43	1:29	LINE FAULT
471	13-Apr-22	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	21:12(13.04.2022)			LINE OPEN:LINE FAULT
472	13-Apr-22	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	21:16(13.04.2022)			LINE OPEN:LINE FAULT
473	13-Apr-22	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	20:03 (13.04.2022)			LINE OPEN:LINE FAULT
474	13-Apr-22	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	20:03	22:05	2:02	LINE FAULT
475	13-Apr-22	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	21:14	22:10	0:56	MAIN SUPPLY FAILURE
476	13-Apr-22	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	21:14	22:10	0:56	MAIN SUPPLY FAILURE
477	13-Apr-22	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	21:14	21:55	0:41	MAIN SUPPLY FAILURE
478	13-Apr-22	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	21:14	22:13	0:59	MAIN SUPPLY FAILURE
479	13-Apr-22	HASSAN	220	SHRAVTY-SHIMOGA4	gen_sharavthy	21:12(13.04.2022)			LINE OPEN:LINE FAULT
480	13-Apr-22	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	9:49(12.04.2022)			LINE OPEN :LINE CLEAR AVAILED
481	13-Apr-22	HASSAN	220	VARAHI-KEMAR1	gen-sharavthy	21:14	22:40	1:26	LINE FAULT
482	13-Apr-22	HASSAN	220	VARAHI-KEMAR2	gen_varahi	21:14(13.04.2022)			LINE OPEN:LINE FAULT
483	13-Apr-22	HASSAN	220	VARAHI-KEMAR3	gen_varahi	21:14	22:58	1:44	LINE FAULT
484	13-Apr-22	HASSAN	220	VARAHI-SHIMOGA1	gen_varahi	21:14	21:51	0:37	LINE FAULT
485	13-Apr-22	HASSAN	220	VARAHI-SHIMOGA2	gen_varahi	21:14	23:12	1:58	LINE FAULT
486	13-Apr-22	HASSAN	220	VARAHI-SHMG3	gen_varahi	21:14(13.04.2022)			LINE OPEN:LINE FAULT
487	13-Apr-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN :LINE CLEAR AVAILED
488	13-Apr-22	MYSURU	66	CR NAGARA-HONGANURU	NO STATIONS EFFECTED	6:43	6:56	0:13	LINE FAULT
489	13-Apr-22	MYSURU	66	DR PETE-KUNTHUR	NO STATIONS EFFECTED	13:39	13:46	0:07	LINE FAULT
490	13-Apr-22	MYSURU	66	FTS-RAJEEV NAGARA	NO STATIONS EFFECTED	17:18:04 (11.04.2022)	14:24(11.04.22)	45:05Hrs	LINE CHARGED
491	13-Apr-22	MYSURU	66	HANNUR-AJIPURA	AJIPURA_66 BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66	15:01	15:10	0:08	LINE FAULT
492	13-Apr-22	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16:00 (8/12/2021)			LINE OPEN :LINE CLEAR AVAILED
493	13-Apr-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	16:58:00 (13/12/2021)			LINE OPEN :LINE CLEAR AVAILED
494	13-Apr-22	MYSURU	66	HOOTAGALLI-BARC1	NO STATIONS EFFECTED	17:25(13.4.22)			LINE OPEN:LINE FAULT
495	13-Apr-22	MYSURU	66	HOOTAGALLI-BARC2	NO STATIONS EFFECTED	10:03	17:07	7:04	NFBC ISSUED
496	13-Apr-22	MYSURU	66	HOOTAGALLI-ELVALA	NO STATIONS EFFECTED	16:42	16:58	0:16	LINE FAULT
497	13-Apr-22	MYSURU	66	HUNSUR-ELWALA	GAVADAGERE_66	16:59	17:15	0:16	LINE FAULT
498	13-Apr-22	MYSURU	66	HV1	BANNUR_66	12:40	12:50	0:09	TRANSFORMER FAULT
499	13-Apr-22	MYSURU	66	HV1	GUDDENAHALLI_66	16:15	16:25	0:10	MAIN SUPPLY FAILURE
500	13-Apr-22	MYSURU	66	HV1	JAIPUR_66	15:34	17:32	1:58	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
501	13-Apr-22	MYSURU	66	HV1	KIADBMANDYA_66	15:00	15:50	0:50	MAIN SUPPLY FAILURE
502	13-Apr-22	MYSURU	66	HV1	MADDUR_66	15:00	15:46	0:45	MAIN SUPPLY FAILURE
503	13-Apr-22	MYSURU	66	HV1	MALAVALLI_66	15:00	16:18	1:18	MAIN SUPPLY FAILURE
504	13-Apr-22	MYSURU	66	HV1	SANIVARASANTHE_66	15:29:47 (11.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
505	13-Apr-22	MYSURU	66	HV2	GUDDENAHALLI_66	16:15	16:25	0:10	MAIN SUPPLY FAILURE
506	13-Apr-22	MYSURU	66	HV2	JAKKANAHALLY_66	20:36(13.04.22)			TRANSFORMER OPEN: TRANSFORMER FAULT
507	13-Apr-22	MYSURU	66	HV2	KIADBMANDYA_66	15:00	15:50	0:50	MAIN SUPPLY FAILURE
508	13-Apr-22	MYSURU	66	HV2	MADDUR_66	15:00	15:46	0:45	MAIN SUPPLY FAILURE
509	13-Apr-22	MYSURU	66	HV2	MALAVALLI_66	15:00	16:18	1:18	MAIN SUPPLY FAILURE
510	13-Apr-22	MYSURU	66	HV2	SANTHEMARAHALLI_66	13:30	13:50	0:19	TRANSFORMER FAULT
511	13-Apr-22	MYSURU	66	HV2	SRIRANGAPATNA_66	14:43	14:52	0:09	HAND TRIPPED
512	13-Apr-22	MYSURU	66	HV3	KUSHALANAGARA_66	12:37	16:45	4:07	LINE CLEAR AVAILED
513	13-Apr-22	MYSURU	66	KHB STATION-HOOTAGALLI	NO STATIONS EFFECTED	21:00:29 (12.04.2022)	14:30(13.04.22)	17:29Hrs	LINE CHARGED
514	13-Apr-22	MYSURU	66	KM DODDI-TK HALLI	KMDODDI_66 KOLKARANADODDI_66	15:54	16:00	0:05	HAND TRIPPED
515	13-Apr-22	MYSURU	66	KR PETE 220-KR PETE 1	AKKIHEBBAL_66 KIKKERI_66 KRPET_66	16:25	16:52	0:26	LINE FAULT
516	13-Apr-22	MYSURU	66	KR PETE 220-KR PETE 2	AKKIHEBBAL_66 KIKKERI_66 KRPET_66	16:25(13..4.22)			LINE OPEN:LINE FAULT
517	13-Apr-22	MYSURU	66	KUSHALANAGARA 220-MADIKERI 1	MADIKERI_66	17:21	18:05	0:44	LINE FAULT
518	13-Apr-22	MYSURU	66	KUSHALANAGARA 220-PERİYAPATNA-1	NO STATIONS EFFECTED	17:19	18:02	0:43	LINE FAULT
519	13-Apr-22	MYSURU	66	KUSHALANAGARA 220-RAMANTHAPURA 1	ALUR SIDDAPURA_66 KANAGAL_66	18:06	18:11	0:05	LINE FAULT
520	13-Apr-22	MYSURU	66	KUSHALANAGARA 220-SUNTIKOPPA	SUNTIKOPPA_66	17:21	18:05	0:44	LINE FAULT
521	13-Apr-22	MYSURU	66	MADHUVANAHALLI-HANNUR 1	NO STATIONS EFFECTED	20:03	20:08	0:05	LINE FAULT
522	13-Apr-22	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	11:23	11:28	0:05	LINE FAULT
523	13-Apr-22	MYSURU	66	TUBINAKERE-G UKKADA	GARUDANAUKADDA_66 SRIRANGAPATNA_66	16:38	16:45	0:06	LINE FAULT
524	13-Apr-22	MYSURU	66	VAJAMANGALA-BANNUR	BANNUR_66	16:25	18:17	1:52	LINE FAULT
525	13-Apr-22	MYSURU	66	VAJAMANGALA-BANNUR	NO STATIONS EFFECTED	18:15	18:21	0:06	LINE FAULT
526	13-Apr-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN :LINE CLEAR AVAILED
527	13-Apr-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN :LINE CLEAR AVAILED
528	13-Apr-22	MYSURU	220	KR PETE 220-YACHANAHALLI	NO STATIONS EFFECTED	16:26	16:40	0:13	LINE FAULT
529	13-Apr-22	MYSURU	220	KUSHALANAGARA 220-BASTIPURA 1	NO STATIONS EFFECTED	17:17	18:46	1:29	LINE FAULT
530	13-Apr-22	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGAL WADI_66	4:23	4:35	0:12	LOAD CURTAILMENT
531	13-Apr-22	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA & URDIGERE66	KOLALA_66, URDIGERE_66	4:23	4:35	0:12	LOAD CURTAILMENT
532	13-Apr-22	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLTEGERE	KOLTEGERE,CHIKKATOTLUKERE_ 66, BELADARA_66	4:23	4:35	0:12	LOAD CURTAILMENT
533	13-Apr-22	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, BRAHMASANDRA_66,THOVINAK ERE_66,ANKASANDRA_66	18:05	18:21	0:16	LINE FAULT
534	13-Apr-22	TUMKUR	66	I D HALLI- CLEAN MAX SOLAR1 IPP_66	CLEANMAXSOLAR 1_IPP_66	5:53	6:00	0:07	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
535	13-Apr-22	TUMKUR	66	KUNDUR- SUZLON_IPP_66	SUZLON_IPP_66	6:07	7:25	1:18	MAIN SUPPLY FAILURE
536	13-Apr-22	TUMKUR	66	MADHUGIRI 220kv- PULAMAGATTA	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	16:10	17:10	1:00	LINE FAULT
537	13-Apr-22	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	0:42	1:05	0:23	LINE FAULT
538	13-Apr-22	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	3:28	3:34	0:06	LINE FAULT
539	13-Apr-22	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	3:45	4:00	0:15	LINE FAULT
540	13-Apr-22	TUMKUR	66	TR-1	SAVALANGA_66	11:06	11:34	0:27	LINE CLEAR AVAILED
541	13-Apr-22	TUMKUR	66	TR-2	BILCHODU_66	10:40	11:00	0:20	MAIN SUPPLY FAILURE
542	13-Apr-22	TUMKUR	110	HONNAVALLI 110- KADUR110(ARASIKERE 220)	HONNAVALLI_110	18:35	20:15	1:40	LINE FAULT
543	13-Apr-22	TUMKUR	110	NITTUR 220-KADABA	KADABA_110	9:17	10:07	0:50	LOAD CURTAILMENT
544	13-Apr-22	TUMKUR	220	NITTUR 220-ARASIKERE	NITTUR_220	16:53	17:37	0:44	LINE FAULT
545	14-Apr-22	BAGALKOT	110	110/11KV, HV1	GANESH GUDI_110	18:15	18:20	0:05	LINE CLEAR AVAILED
546	14-Apr-22	BAGALKOT	110	110/11KV,HV1	THORVI_110	14:11	14:16	0:05	TRANSFORMER FAULT
547	14-Apr-22	BAGALKOT	110	110/11KV,HV1	KAGAWADA_110	22:13	23:02	0:49	TRANSFORMER FAULT
548	14-Apr-22	BAGALKOT	110	110/11KV,HV1	SIRSI_110	17:21	21:27	4:06	LINE CLEAR AVAILED
549	14-Apr-22	BAGALKOT	110	110/11KV,HV1	NAVALAGI_110	9:56	10:14	0:18	TRANSFORMER FAULT
550	14-Apr-22	BAGALKOT	110	110/11KV,HV1(HV4)	GOPANAKOPPA_110	23:04 (14.04.2022)			TRANSFORMER OPEN : LINE CLEAR AVAILED
551	14-Apr-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	12:45	12:50	0:05	TRANSFORMER FAULT
552	14-Apr-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	15:38	15:49	0:11	TRANSFORMER FAULT
553	14-Apr-22	BAGALKOT	110	110/33KV,HV1	JAMAKHANDI_110	5:26	6:00	0:34	LINE CLEAR AVAILED
554	14-Apr-22	BAGALKOT	110	110/33KV,HV2	KAROSHI_33,KERUR_33 CHIKKODI_110	21:04	22:18	1:14	TRANSFORMER FAULT
555	14-Apr-22	BAGALKOT	110	110/33KV,HV2	KAROSHI_33,KERUR_33 CHIKKODI_110	22:22	22:26	0:04	TRANSFORMER FAULT
556	14-Apr-22	BAGALKOT	110	110/33KV,HV2	JAMAKHANDI_110	5:26	6:00	0:34	LINE CLEAR AVAILED
557	14-Apr-22	BAGALKOT	110	AMBEWADI-NK-1	STATION NOT AFFECTED AMBEWADI_220	19:52 (14.04.2022)			LINE OPEN:LINE FAULT
558	14-Apr-22	BAGALKOT	110	AMBEWADI-NK-2	STATION NOT AFFECTED AMBEWADI_220	9:04	9:12	0:08	HAND TRIPPED
559	14-Apr-22	BAGALKOT	110	AMBEWADI-NK-2	STATION NOT AFFECTED KAVALWAD_110	18:26	18:31	0:05	MAIN SUPPLY FAILURE
560	14-Apr-22	BAGALKOT	110	AMBEWADI-NK-2	KAVALWAD_110	9:00	9:10	0:10	MAIN SUPPLY FAILURE
561	14-Apr-22	BAGALKOT	110	ATHANI-HALYAL	HALYAL_110	19:45	21:10	1:25	LINE FAULT
562	14-Apr-22	BAGALKOT	110	BAGEWADI- RBRK	STATION NOT AFFECTED BAGEWADI_220	17:15	17:53	0:38	LINE FAULT
563	14-Apr-22	BAGALKOT	110	BELGAUM220- ANKALAGI	ANKALAGI_110	16:44	17:04	0:20	LINE FAULT
564	14-Apr-22	BAGALKOT	110	BELGAUM220- HUKKERI(UCHAGOAN)	UCHAGOAN_110, UDYAMBAG_110, HONAGA_110	16:22	16:51	0:29	LINE FAULT
565	14-Apr-22	BAGALKOT	110	CHIKKODI220-SADALAGA	SADALAGA_110	21:32	22:06	0:34	MAIN SUPPLY FAILURE
566	14-Apr-22	BAGALKOT	110	DAMBAL-GADAG2	DAMBAL_110	18:29	18:59	0:30	LINE FAULT
567	14-Apr-22	BAGALKOT	110	DAMBAL-SAMBAPUR ROAD	DAMBAL_110	18:29	18:58	0:29	LINE FAULT
568	14-Apr-22	BAGALKOT	110	GADAG220- SAMBAPUR ROAD	STATION NOT AFFECTED GADAG_220	18:29	21:52	3:23	LINE FAULT
569	14-Apr-22	BAGALKOT	110	GADAG220-SAMAPUR ROAD	SAMAPUR ROAD_110	19:01	21:52	2:51	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
570	14-Apr-22	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN :LINE CLEAR AVALIED
571	14-Apr-22	BAGALKOT	110	HALIYAL-KAWALWADA	STATION NOT AFFECTED HALIYAL_110	17:56 (07.04.2022)			LINE OPEN:LINE FAULT
572	14-Apr-22	BAGALKOT	110	KADAKLAT-(F2)NIPPANI	NIPPANI_110	21:37	22:09	0:32	HAND TRIPPED
573	14-Apr-22	BAGALKOT	110	KAMBAGI-TODALBAGI	STATION NOT AFFECTED KAMBAGI_110	16:57 (13.04.2022)	20:11 (14.04.2022)	27:14 hrs	LINE CHARGED
574	14-Apr-22	BAGALKOT	110	KIADB BIJAPUR-BHUTNAL	BHUTNAL_110	15:56	15:59	0:03	LINE FAULT
575	14-Apr-22	BAGALKOT	110	KPR SUGARS-ALMEL	ALMEL_110	17:06	18:24	1:18	LINE CLEAR AVALIED
576	14-Apr-22	BAGALKOT	110	M L PURA(RANNBELAGALI)- UTTUR	UTTUR_110	21:54 (14.04.2022)			LINE OPEN:LINE FAULT
577	14-Apr-22	BAGALKOT	110	MAHALINGAPUR- HIDIKAL	STATION NOT AFFECTED MAHALINGAPR_220	1:18	8:36	7:18	LINE FAULT
578	14-Apr-22	BAGALKOT	110	MAHALINGAPUR- TERDAL	STATION NOT AFFECTED MAHALINGAPR_220	19:37	21:13	1:36	LINE FAULT
579	14-Apr-22	BAGALKOT	110	MK HUBLI-MK HUBLI1	STATION NOT AFFECTED MK HUBLI_220	10:59 (31.03.2022)			LINE OPEN :LINE CLEAR AVALIED
580	14-Apr-22	BAGALKOT	110	MUNDARGI-VIJAY SUGARS	MUNDARGI_110	18:30	18:59	0:29	HAND TRIPPED
581	14-Apr-22	BAGALKOT	110	NAVALAGI-F1(JKD)	NAVALAGI_110	19:54:00 (14.04.2022)			LINE OPEN:LINE FAULT
582	14-Apr-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN :LINE CLEAR AVALIED
583	14-Apr-22	BAGALKOT	110	RANNABELAGALI- MUDHOL(UTTUR)	RANNABELAGALI_110	20:44	21:27	0:43	LINE FAULT
584	14-Apr-22	BAGALKOT	110	SAVALAGI- AIGALI(YELLAMANAWADI)	SAVALAGI_110	21:14 (14.04.2022)			LINE OPEN :LINE CLEAR AVALIED
585	14-Apr-22	BAGALKOT	110	SIRSI(AMBEWADI)-KIRUVATTI	KIRUVATTI_110	9:13	20:17	11:04	LINE CLEAR AVALIED
586	14-Apr-22	BAGALKOT	110	SOUDATTI220- YARAGATTI (BENAKATTI)	SOUDATTI_220	7:22	7:52	0:30	LINE FAULT
587	14-Apr-22	BAGALKOT	110	SOUDATTI220- YARAGATTI (BENAKATTI)	SOUDATTI_220	8:10	9:22	1:12	LINE FAULT
588	14-Apr-22	BAGALKOT	110	TAKKALKI-KNSC	TAKKALKI_110	15:59	16:00	0:01	MAIN SUPPLY FAILURE
589	14-Apr-22	BAGALKOT	110	TARIHAL(NARENDRA220)- TADASINKOPPA	STATION NOT AFFECTED TADASINKOPPA_110	16:06 (10.04.2022)			LINE CLEAR AVALIED
590	14-Apr-22	BAGALKOT	110	UDAYMBAG-MACHE	STATION NOT AFFECTED UDAYMBAG_110	10:10 (10.04.2022)			LINE OPEN :LINE CLEAR AVALIED
591	14-Apr-22	BAGALKOT	110	VAJRAMATTI220- JK CEMENT	STATION NOT AFFECTED VAJRAMATTI_220	16:15	16:27	0:12	LINE FAULT
592	14-Apr-22	BAGALKOT	110	YLWD-F2 Cbreaker(SAVALAGI)	SAVALAGI_110	19:22:00 (14.04.2022)			LINE OPEN:LINE FAULT
593	14-Apr-22	BAGALKOT	110	YLWD-F3 Cbreaker(ALBAL)	ALBAL_110	19:32	20:33	1:01	LINE FAULT
594	14-Apr-22	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED NARENDRA_220	14:10	19:17	5:07	LINE CLEAR AVALIED
595	14-Apr-22	BAGALKOT	220	220/110KV, HV3	STATION NOT AFFECTED HUBLI_220	9:37	17:34	7:57	LINE CLEAR AVALIED
596	14-Apr-22	BAGALKOT	220	400/220KV, ICT2(LV)	STATION NOT AFFECTED DHONI_220	12:16	15:08	2:52	TRANSFORMER FAULT
597	14-Apr-22	BAGALKOT	220	AMBEWADI- NAGJHARI1	STATION NOT AFFECTED AMBEWADI_220	18:55	21:44	2:49	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
598	14-Apr-22	BAGALKOT	220	ATHANI-RVIURJA(KAKAMARI1)	STATION NOT AFFECTED ATHANI_220	16:34 (09.04.2022)			LINE OPEN:LINE FAULT
599	14-Apr-22	BAGALKOT	220	ATHANI-RVIURJA(KAKAMARI2)	STATION NOT AFFECTED ATHANI_220	16:34 (09.04.2022)			LINE OPEN:LINE FAULT
600	14-Apr-22	BAGALKOT	220	BELGAUM- CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	21:21	22:01	0:40	LINE FAULT
601	14-Apr-22	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	18:12 (14.04.2022)			LINE OPEN:LINE FAULT
602	14-Apr-22	BAGALKOT	220	CHIKKODI- AQUAS1	STATION NOT AFFECTED CHIKKODI_220	21:33	23:59	2:26	LINE FAULT
603	14-Apr-22	BAGALKOT	220	CHIKKODI- BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	21:06	22:02	0:56	LINE FAULT
604	14-Apr-22	BAGALKOT	220	CHIKKODI- GHATAPRABHA2 (KUDACHI2)	STATION NOT AFFECTED CHIKKODI_220	21:33	22:05	0:32	LINE FAULT
605	14-Apr-22	BAGALKOT	220	CHIKKODI- KUDACHI2	STATION NOT AFFECTED CHIKKODI_220	21:33	22:05	0:32	LINE FAULT
606	14-Apr-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN :LINE CLEAR AVAILED
607	14-Apr-22	BAGALKOT	220	KUDACHI- CHIKKODI1	STATION NOT AFFECTED KUDACHI_220	21:32	22:05	0:33	LINE FAULT
608	14-Apr-22	BAGALKOT	220	MAHALINGAPUR- SOUDATTI	STATION NOT AFFECTED MAHALINGAPR_220	16:14	17:30	1:16	LINE FAULT
609	14-Apr-22	BAGALKOT	220	MUGALKHOD- CHIKKODI1	STATION NOT AFFECTED MUGALKHOD_220	21:33	22:23	0:50	LINE FAULT
610	14-Apr-22	BAGALKOT	220	MUGALKHOD- CHIKKODI2	STATION NOT AFFECTED MUGALKHOD_220	21:33	22:23	0:50	LINE FAULT
611	14-Apr-22	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	17:30 (31.03.2022)			LINE OPEN :LINE CLEAR AVAILED
612	14-Apr-22	BAGALKOT	220	SIRSI-SHUBLI1	SIRSI_220	13:24 (12.04.2022)			LINE OPEN :LINE CLEAR AVAILED
613	14-Apr-22	BAGALKOT	220	SOUDATTI- BIDNAL	STATION NOT AFFECTED SOUDATTI_220	18:13 (14.04.2022)			LINE OPEN:LINE FAULT
614	14-Apr-22	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI_220	16:14	17:29	1:15	LINE FAULT
615	14-Apr-22	BAGALKOT	400	400/220KV, ICT2(HV)	STATION NOT AFFECTED DHONI_220	12:16	15:03	2:47	TRANSFORMER FAULT
616	14-Apr-22	BENGALURU	66	ALUR - NELAMANGALA 66	ALUR, BIEC	5:42	5:45	0:03	LOAD CHANGE OVER
617	14-Apr-22	BENGALURU	66	BAGMANE WTP - ITI 220	BAGMANE WTP	0:05	0:13	0:08	LOAD CHANGE OVER
618	14-Apr-22	BENGALURU	66	BANASHANKARI - SUBRAMANYAPURA 220	BANASHANKARI	5:44	5:50	0:06	LOAD CHANGE OVER
619	14-Apr-22	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	14:25	14:34	0:09	LINE FAULT
620	14-Apr-22	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	17:42	17:51	0:09	LINE FAULT
621	14-Apr-22	BENGALURU	66	EXORA - VIKAS TECH PARK 220	EXORA	19:30	19:50	0:20	MAIN SUPPLY FAILURE
622	14-Apr-22	BENGALURU	66	EXORA - VIKAS TECH PARK 220	EXORA	20:40	20:50	0:10	MAIN SUPPLY FAILURE
623	14-Apr-22	BENGALURU	66	GOKULA - SRS PEENYA 220	GOKULA, BEL (EHT), HMT (EHT)	1:15	1:25	0:10	LOAD CHANGE OVER
624	14-Apr-22	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	9:58	10:31	0:33	LINE FAULT
625	14-Apr-22	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	17:35	18:00	0:25	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
626	14-Apr-22	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	6:28	6:37	0:09	LINE FAULT
627	14-Apr-22	BENGALURU	66	HOSKOTE 220 - VIDYANAGARA	GRINDWELL(EHT), HOSKOTE 66	19:36	19:55	0:19	LINE FAULT
628	14-Apr-22	BENGALURU	66	HOSKOTE 220 - VIDYANAGARA	GRINDWELL(EHT), HOSKOTE 66	21:08	21:18	0:10	LINE FAULT
629	14-Apr-22	BENGALURU	66	HV1	BANASAWADI	19:12	19:20	0:08	MAIN SUPPLY FAILURE
630	14-Apr-22	BENGALURU	66	HV1	BANASAWADI	20:46	20:50	0:04	LOAD CHANGE OVER
631	14-Apr-22	BENGALURU	66	HV1	MANYATHA TECH PARK 220	19:13	20:02	0:49	LINE CLEAR AVAILED
632	14-Apr-22	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	16:30	17:55	1:25	TRANSFORMER FAULT
633	14-Apr-22	BENGALURU	66	HV1	M GOLLAHALLI	14:18	14:28	0:10	LINE CLEAR AVAILED
634	14-Apr-22	BENGALURU	66	HV1	SIRIGIRIPURA	13:17	13:26	0:09	TRANSFORMER FAULT
635	14-Apr-22	BENGALURU	66	HV1	GOWRIBIDANUR 220	0:40	1:02	0:22	TRANSFORMER FAULT
636	14-Apr-22	BENGALURU	66	HV1	GOWRIBIDANUR 220	15:15	15:20	0:05	TRANSFORMER FAULT
637	14-Apr-22	BENGALURU	66	HV1	THONDEBHAVI	10:20	10:40	0:20	TRANSFORMER FAULT
638	14-Apr-22	BENGALURU	66	HV2	MANYATHA TECH PARK 220	19:13	20:02	0:49	LINE CLEAR AVAILED
639	14-Apr-22	BENGALURU	66	HV2	TK HALLI 220	8:03	8:19	0:16	TRANSFORMER FAULT
640	14-Apr-22	BENGALURU	66	HV2	TK HALLI 220	9:55	10:02	0:07	TRANSFORMER FAULT
641	14-Apr-22	BENGALURU	66	HV2	TK HALLI 220	11:13	11:22	0:09	LINE CLEAR AVAILED
642	14-Apr-22	BENGALURU	66	HV2	GUNDAMGERE	12:01	12:25	0:23	TRANSFORMER FAULT
643	14-Apr-22	BENGALURU	66	HV2	GUNDAMGERE	12:31	12:46	0:15	TRANSFORMER FAULT
644	14-Apr-22	BENGALURU	66	HV2	KODIHALLI CHINTAMANI	9:33	9:45	0:11	LINE CLEAR AVAILED
645	14-Apr-22	BENGALURU	66	HV2	IRGAMPALLI	15:20	16:34	1:14	TRANSFORMER FAULT
646	14-Apr-22	BENGALURU	66	HV2	IRGAMPALLI	15:35	16:34	0:58	TRANSFORMER FAULT
647	14-Apr-22	BENGALURU	66	HV3	BANASAWADI	19:12	19:20	0:08	MAIN SUPPLY FAILURE
648	14-Apr-22	BENGALURU	66	HV3	BANASAWADI	20:46	20:50	0:04	LOAD CHANGE OVER
649	14-Apr-22	BENGALURU	66	HV3	YARANDANAHALLI 220	20:20	20:30	0:10	TRANSFORMER FAULT
650	14-Apr-22	BENGALURU	66	HV3	KGF	6:40	9:05	2:25	TRANSFORMER FAULT
651	14-Apr-22	BENGALURU	66	HV4	MANYATHA TECH PARK 220	19:13	20:02	0:49	LINE CLEAR AVAILED
652	14-Apr-22	BENGALURU	66	IISc - HEBBALA 220	IISc	19:13	19:27	0:14	MAIN SUPPLY FAILURE
653	14-Apr-22	BENGALURU	66	IISc - NRS 220	IISc	22:12	22:18	0:06	LOAD CHANGE OVER
654	14-Apr-22	BENGALURU	66	JIGANI 66 - BG ROAD	JIGANI 66	6:15	6:24	0:09	LOAD CHANGE OVER
655	14-Apr-22	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	22:42	22:52	0:10	LINE FAULT
656	14-Apr-22	BENGALURU	66	Kengeri SATELLITE TOWN - KUMBALAGODU	Kengeri SATELLITE TOWN	0:00	0:08	0:08	LOAD CHANGE OVER
657	14-Apr-22	BENGALURU	66	KOLAR 220 - AVANI	NO STATION AFFECTED	19:20:00(14/04/2022)			LINE OPEN:LINE FAULT
658	14-Apr-22	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	19:20	20:32	1:12	LINE FAULT
659	14-Apr-22	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA, HONDA(EHT), K & C VALLEY(EHT)	19:25	20:35	1:10	LINE FAULT
660	14-Apr-22	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	18:13	18:23	0:10	LINE FAULT
661	14-Apr-22	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	19:20	20:23	1:03	LINE CLEAR AVAILED
662	14-Apr-22	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	19:20	20:27	1:07	LINE CLEAR AVAILED
663	14-Apr-22	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	18:43	18:54	0:11	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
664	14-Apr-22	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	19:15	19:20	0:05	LINE FAULT
665	14-Apr-22	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	19:20	20:34	1:14	LINE CLEAR AVAILED
666	14-Apr-22	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	19:20	20:25	1:05	LINE CLEAR AVAILED
667	14-Apr-22	BENGALURU	66	KOMBODI - NANGLI	NO STATION AFFECTED	19:15	20:40	1:25	LINE FAULT
668	14-Apr-22	BENGALURU	66	KUMBALAGODU - SOMANAHALLI 220	KUMBALAGODU, CHANDRAPPA CIRCLE	23:45	23:59	0:14	MAIN SUPPLY FAILURE
669	14-Apr-22	BENGALURU	66	LAKSHMIPURA - ADDGAL	ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	10:48	10:56	0:08	LINE FAULT
670	14-Apr-22	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	6:21	6:31	0:10	LOAD CHANGE OVER
671	14-Apr-22	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	11:05	23:45	12:40	MAIN SUPPLY FAILURE
672	14-Apr-22	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	7:12	7:20	0:08	LINE FAULT
673	14-Apr-22	BENGALURU	66	MALUR 220 - KGF 1	TEKAL, BUDIKOTE, TORLAKKI	11:05	17:43	6:38	MAIN SUPPLY FAILURE
674	14-Apr-22	BENGALURU	66	MALUR 220 - LAKKUR	DEVANGONDHI, LAKKUR	11:05	13:57	2:52	MAIN SUPPLY FAILURE
675	14-Apr-22	BENGALURU	66	MALUR 220 - LAKKUR	DEVANGONDHI, LAKKUR	21:50	23:45	1:55	LOAD CHANGE OVER
676	14-Apr-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI	11:05	23:46	12:41	MAIN SUPPLY FAILURE
677	14-Apr-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI	3:22	3:29	0:06	LINE FAULT
678	14-Apr-22	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	11:05(14-4-2022)			LINE CLEAR AVAILED
679	14-Apr-22	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL (EHT)	11:05	13:56	2:51	MAIN SUPPLY FAILURE
680	14-Apr-22	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL (EHT)	21:50(14-4-2022)			LINE CLEAR AVAILED
681	14-Apr-22	BENGALURU	66	MANYATHA TECH PARK 220 - MANYATHA TECH PARK 66	MANYATHA TECH PARK 66	19:13	20:02	0:49	LINE CLEAR AVAILED
682	14-Apr-22	BENGALURU	66	MATHIKERE - HEBBALA 220	MATHIKERE	1:30	1:34	0:04	LOAD CHANGE OVER
683	14-Apr-22	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	5:49	5:58	0:09	LOAD CHANGE OVER
684	14-Apr-22	BENGALURU	66	PATHPALYA - SOMANATHPURA	THIMMAMPALLI	22:46	23:34	0:48	LINE FAULT
685	14-Apr-22	BENGALURU	66	PATHPALYA - SOMANATHPURA	THIMMAMPALLI	23:44(14-4-2022)			LINE OPEN :LINE CLEAR AVAILED
686	14-Apr-22	BENGALURU	66	PRIMAL - VIKAS TECH PARK 220	PRIMAL	19:32	20:28	0:56	MAIN SUPPLY FAILURE
687	14-Apr-22	BENGALURU	66	RMV - HEBBALA 220	RMV, TATA INSTITUTE (EHT)	1:30	1:35	0:05	LOAD CHANGE OVER
688	14-Apr-22	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	19:32	20:23	0:51	MAIN SUPPLY FAILURE
689	14-Apr-22	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	19:32	20:23	0:51	MAIN SUPPLY FAILURE
690	14-Apr-22	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	19:32	20:25	0:53	MAIN SUPPLY FAILURE
691	14-Apr-22	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, CHANDRAPPA CIRCLE	23:45	23:59	0:14	LINE FAULT
692	14-Apr-22	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	20:02	21:38	1:36	LINE FAULT
693	14-Apr-22	BENGALURU	66	T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	19:26	20:29	1:03	LINE FAULT
694	14-Apr-22	BENGALURU	66	T GOLLAHALLI 220 - H GOLLAHALLI	H GOLLAHALLI, MUDIYANUR	19:21	20:27	1:06	LINE FAULT
695	14-Apr-22	BENGALURU	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	19:31	20:31	1:00	LINE FAULT
696	14-Apr-22	BENGALURU	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	19:21	20:32	1:11	LINE FAULT
697	14-Apr-22	BENGALURU	66	TADIGOLU - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	11:07	11:13	0:06	LINE FAULT
698	14-Apr-22	BENGALURU	66	TEKAL - BUDIKOTE	TORLAKKI, BUDIKOTE	18:15	19:55	1:40	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
699	14-Apr-22	BENGALURU	66	TEKAL - BUDIKOTE	TEKAL, BUDIKOTE, TORLAKKI	10:10	11:00	0:50	LOAD CHANGE OVER
700	14-Apr-22	BENGALURU	66	TELECOM ALYOUT - NRS 2 220	TELECOM LAYOUT	6:57	7:04	0:07	LOAD CHANGE OVER
701	14-Apr-22	BENGALURU	66	YARANDANAHALLI 220 - JIGANI 66	JIGANI 66	3:15	3:30	0:15	LINE FAULT
702	14-Apr-22	BENGALURU	220	HEBBALA 220 - MANYATHA TECH PARK 220	HEBBALA 220	19:13	20:16	1:03	MAIN SUPPLY FAILURE
703	14-Apr-22	BENGALURU	220	HV1	MALUR 220	11:08	21:29	10:20	TRANSFORMER FAULT
704	14-Apr-22	BENGALURU	220	HV2	MALUR 220	11:06	13:51	2:45	TRANSFORMER FAULT
705	14-Apr-22	BENGALURU	220	HV3	KOLAR 220	19:20	20:19	0:59	TRANSFORMER FAULT
706	14-Apr-22	BENGALURU	220	KOLAR 220 - MALUR 1 220	MALUR 220	11:06	15:40	4:34	LINE FAULT
707	14-Apr-22	BENGALURU	220	MALUR 220 - SOMANHALLI 1 O/G	SARIAPURA 220, VIKAS TECH PARK 220	19:32	20:23	0:51	LINE FAULT
708	14-Apr-22	BENGALURU	220	MANYATHA TECH PARK 220 - YELAHANKA 220	MANYATHA TECH PARK 220	19:13	20:02	0:49	MAIN SUPPLY FAILURE
709	14-Apr-22	BENGALURU	220	NELAMANGALA 400 - SRS PEENYA 1	SRS PEENYA 220	16:29(13-4-2022)	0:32(14-4-2022)	8:02	LINE FAULT
710	14-Apr-22	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 1 220	NO STATION AFFECTED	16:29(13/04/2022)	00:32(14/04/2022)	8:03HRS	LINE CHARGED
711	14-Apr-22	BENGALURU	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	19:32	20:25	0:53	MAIN SUPPLY FAILURE
712	14-Apr-22	BENGALURU	220	YELAHANKA 220 - MANYATHA TEC PARK 220	MANYATHA TECH PARK 220	19:13	20:30	1:17	LINE FAULT
713	14-Apr-22	BENGALURU	220	YELAHANKA 220 - YCCP 1	NO STATION AFFECTED	19:13:21(14-4-2022)			LINE OPEN:LINE FAULT
714	14-Apr-22	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	16:20	16:35	0:15	LINE FAULT
715	14-Apr-22	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	16:45	16:50	0:05	MAIN SUPPLY FAILURE
716	14-Apr-22	GULBARGA	66	HV3	HALAVAGALI_66	11:10	11:50	0:40	LINE CLEAR AVAILED
717	14-Apr-22	GULBARGA	66	ITTAGI-HUVINAHADAGALI	HUVINAHADGALI_66,HOLAGUNDI_66	16:25	18:35	2:10	LOAD CURTAILMENT
718	14-Apr-22	GULBARGA	66	ITTAGI-HUVINAHADAGALI	HUVINAHADGALI_66,HOLAGUNDI_66	11:05	11:15	0:10	LOAD CURTAILMENT
719	14-Apr-22	GULBARGA	110	AURAD-DONGARGAON	DONGARGAON_110	17:30	17:35	0:05	LINE FAULT
720	14-Apr-22	GULBARGA	110	AURAD-SANTHPUR	AURAD_110,DONGARGAON_110	17:55	18:15	0:20	MAIN SUPPLY FAILURE
721	14-Apr-22	GULBARGA	110	CHINCHOLI-SEDAM	CHINCHOLI_110	17:32	17:35	0:03	LINE CLEAR AVAILED
722	14-Apr-22	GULBARGA	110	CHINCHOLI-SEDAM	CHINCHOLI_110	17:37	17:50	0:13	LINE CLEAR AVAILED
723	14-Apr-22	GULBARGA	110	DUBALGUNDI-HUMNABAD	DUBALGUNDI_110	15:45	15:55	0:10	MAIN SUPPLY FAILURE
724	14-Apr-22	GULBARGA	110	HALBARGA-SANTAPUR	SANTAPUR_110,DONGARGAON_110,DIGGI_110	17:56	18:15	0:19	LINE FAULT
725	14-Apr-22	GULBARGA	110	HUMNABAD-HALBARGA	HALBARGA_110	15:46	16:03	0:17	LINE FAULT
726	14-Apr-22	GULBARGA	110	HV2	YAKATPUR_110	9:15	9:55	0:40	TRANSFORMER FAULT
727	14-Apr-22	GULBARGA	110	HV3	CHINCHOLI_110	17:08	17:13	0:05	TRANSFORMER FAULT
728	14-Apr-22	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	11:43	11:49	0:06	LINE FAULT
729	14-Apr-22	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_220	22:34	22:41	0:07	LOAD CURTAILMENT
730	14-Apr-22	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	15:50	17:35	1:45	LINE FAULT
731	14-Apr-22	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	21:22	21:27	0:05	LINE FAULT
732	14-Apr-22	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	22:07	22:14	0:07	LINE FAULT
733	14-Apr-22	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	22:53	22:59	0:06	LINE FAULT
734	14-Apr-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN :LINE CLEAR AVAILED
735	14-Apr-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN :LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
736	14-Apr-22	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110, SIRIGUPPA_110,DHADESUGUR_1 10,SIRIGERA CROSS_110,NSL SUGAR_IPP,VOORA_IPP	6:10	6:20	0:10	LINE FAULT
737	14-Apr-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
738	14-Apr-22	GULBARGA	220	HV2	RAICHUR_220	9:35	14:30	4:55	LINE CLEAR AVAILED
739	14-Apr-22	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	13:52	14:08	0:16	LINE FAULT
740	14-Apr-22	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	14:45	15:00	0:15	LINE FAULT
741	14-Apr-22	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	15:15	16:22	1:07	LINE CLEAR AVAILED
742	14-Apr-22	HASSAN	66	HV1	MOSALEHOSALLI_66	11:15	11:43	0:28	TRANSFORMER FAULT
743	14-Apr-22	HASSAN	66	HV1	MOSALEHOSALLI_66	12:10	12:30	0:20	MAIN SUPPLY FAILURE
744	14-Apr-22	HASSAN	66	HV1	MOSALEHOSALLI_66	12:33	13:40	1:07	TRANSFORMER FAULT
745	14-Apr-22	HASSAN	66	HV1	MOSALEHOSALLI_66	16:15	17:01	0:46	HAND TRIPPED
746	14-Apr-22	HASSAN	66	HV2	UDAYAPURA_66	17:51(13.04.2022)	10:33 (14.04.2022)	16:41 hrs	TRANSFORMER CHARGED
747	14-Apr-22	HASSAN	66	HV2	UDAYAPURA_66	13:58	14:02	0:04	TRANSFORMER FAULT
748	14-Apr-22	HASSAN	66	MOSALEH-BIOMASS	MOSALEHOSALLI_66	13:03	13:39	0:36	LINE FAULT
749	14-Apr-22	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSALLI_66	12:10	17:00	4:50	LINE CLEAR AVAILED
750	14-Apr-22	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN :LINE CLEAR AVAILED
751	14-Apr-22	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	10:28	18:11	7:43	LINE CLEAR AVAILED
752	14-Apr-22	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	10:28	18:11	7:43	LINE CLEAR AVAILED
753	14-Apr-22	HASSAN	66	UDDURKO-SUZLON1	UDDURKOPPLU_66	18:57 (13.04.2022)	11:22 (14.04.2022)	16:24 hrs	LINE CHARGED
754	14-Apr-22	HASSAN	110	ANANDASHIMOGA	ANADPURA_110	13:51	15:30	1:39	NFBC ISSUED
755	14-Apr-22	HASSAN	110	GAJNUR-SHIMOGA IC LINE	GAJNUR_110	21:30(13.04.2022)	11:13(14.04.2022)	13:42 hrs	LINE CHARGED
756	14-Apr-22	HASSAN	110	HV1	JAVAGAL_110	2:35	9:26	6:51	TRANSFORMER FAULT
757	14-Apr-22	HASSAN	110	HV1	JOG_110	14:21	17:40	3:19	LINE CLEAR AVAILED
758	14-Apr-22	HASSAN	110	HV2	JOG_110	11:01	14:04	3:03	LINE CLEAR AVAILED
759	14-Apr-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN : LINE CLEAR AVAILED
760	14-Apr-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN :LINE CLEAR AVAILED
761	14-Apr-22	HASSAN	110	KAVOOR-BAIKAMPADY	KAVOOR_220	17:10	18:05	0:55	LINE FAULT
762	14-Apr-22	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	22:18(13.04.2022)	3:03(14.04.2022)	4:44 hrs	LINE CHARGED
763	14-Apr-22	HASSAN	110	LPH-MGHE 1	lph_gen	20:31 (10.04.2022)			LINE OPEN :LINE CLEAR AVAILED
764	14-Apr-22	HASSAN	110	MANIPAL-NITTUR	MANIPAL_110	12:45	12:54	0:09	LINE FAULT
765	14-Apr-22	HASSAN	110	MRSSHM-GAJNUR	MRSMG_220	21:28(13.04.2022)	8:11(14.02.2022)	1052 hrs	LINE CHARGED
766	14-Apr-22	HASSAN	110	MRSSHM-SS2	MRSMG_220	13:51	15:30	1:39	LINE CLEAR AVAILED
767	14-Apr-22	HASSAN	110	NANDIKU-BELMAN	NANDIKUR_110	12:43	12:55	0:12	LINE FAULT
768	14-Apr-22	HASSAN	220	KAVOOR-KB2	KAVOOR_220	20:10(13.04.2022)	11:00(14.03.2022)	14:49 hrs	LINE CHARGED
769	14-Apr-22	HASSAN	220	KEMAR-Varahi2	KEMAR_220	21:14(13.04.2022)			LINE OPEN :LINE CLEAR AVAILED
770	14-Apr-22	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	21:12(13.04.2022)	16:13(14.04.2022)	19:00 hrs	LINE CHARGED
771	14-Apr-22	HASSAN	220	MRSSHM-VARAH12	MRSMG_220	15:45	19:07	3:22	LINE FAULT
772	14-Apr-22	HASSAN	220	MRSSHM-VARAH13	MRSMG_220	21:16(13.04.2022)	9:33(14.04.2022)	12:16 hrs	LINE CHARGED
773	14-Apr-22	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	20:03 (13.04.2022)	10:58 (14.04.2022)	14:54 hrs	LINE CHARGED
774	14-Apr-22	HASSAN	220	SHRAVITY-SHIMOGA4	gen-sharavthy	21:12(13.04.2022)	16:13(14.04.2022)	18:00 hrs	LINE CHARGED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
775	14-Apr-22	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	9:49(12.04.2022)			LINE OPEN :LINE CLEAR AVAILED
776	14-Apr-22	HASSAN	220	VARAHI-KEMAR2	gen_varahi	21:14(13.04.2022)			LINE OPEN :LINE CLEAR AVAILED
777	14-Apr-22	HASSAN	220	VARAHI-SHIMOGA2	gen_varahi	15:45	19:07	3:22	LINE FAULT
778	14-Apr-22	HASSAN	220	VARAHI-SHMG3	gen_varahi	21:14(13.04.2022)	9:33(14.04.2022)	12:18 hrs	LINE CHARGED
779	14-Apr-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN :LINE CLEAR AVAILED
780	14-Apr-22	MYSURU	66	ADDIHALLI-B G NAGARA	ADICHUNCHANAGIRI_66 BGNAGARA_66 KADABALLY_66 VADERALLI_66	21:58	22:06	0:08	LINE FAULT
781	14-Apr-22	MYSURU	66	C R NAGARA-HONGANURU	NO STATIONS EFFECTED	6:43	6:56	0:13	LINE FAULT
782	14-Apr-22	MYSURU	66	D B HALLY-TUBINAKERE	DODDABYADARAHALLI_66	17:10	17:20	0:10	LINE FAULT
783	14-Apr-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (8/12/2021)			LINE OPEN :LINE CLEAR AVAILED
784	14-Apr-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	16:58:00 (13/12/2021)			LINE OPEN :LINE CLEAR AVAILED
785	14-Apr-22	MYSURU	66	HOOTAGALLI-BARC1	NO STATIONS EFFECTED	17:25	12:09:00 PM (14.04.2022)	18:44	LINE FAULT
786	14-Apr-22	MYSURU	66	HOOTAGALLY-BARC 2	NO STATIONS EFFECTED	9:46	12:09	2:23	LINE CLEAR AVAILED
787	14-Apr-22	MYSURU	66	HV 3	HOOTAGALLY_220	15:52	16:13	0:21	MAIN SUPPLY FAILURE
788	14-Apr-22	MYSURU	66	HV1	YARAHALLI HANDPOST_66	18:10	18:15	0:05	TRANSFORMER FAULT
789	14-Apr-22	MYSURU	66	HV1	VYASRAJPURA_66	23:45	23:50	0:05	TRANSFORMER FAULT
790	14-Apr-22	MYSURU	66	HV1	HOSURGATE_66	15:25	15:40	0:15	TRANSFORMER FAULT
791	14-Apr-22	MYSURU	66	HV1	MADIKERI_66	12:26	15:20	2:54	LINE CLEAR AVAILED
792	14-Apr-22	MYSURU	66	HV1	TERAKANAMBE_66	12:20	14:15	1:54	LINE CLEAR AVAILED
793	14-Apr-22	MYSURU	66	HV1	SANIVARASANTHE_66	15:29:47 (11.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
794	14-Apr-22	MYSURU	66	HV2	SHEELUNERE_66	16:20	16:30	0:10	TRANSFORMER FAULT
795	14-Apr-22	MYSURU	66	HV2	KOLLEGALA_66	11:24	15:13	3:48	LINE CLEAR AVAILED
796	14-Apr-22	MYSURU	66	KR PETE 220-KR PETE 2	AKKHEBBAL_66 KIKKERI_66 KRPET_66	16:25	4:00:00 AM (14.04.2022)	11:35	LINE FAULT
797	14-Apr-22	MYSURU	66	KUNTHUR-D R PETE	JANNUR_66 MUGUR_66 TNARASIPURA_66 THAYURU_66 SANTHEMARAHALLI_66	6:00	6:05	0:05	LINE FAULT
798	14-Apr-22	MYSURU	66	KUSHALANAGARA- RAMANATHAPURA 1	ALUR SIDDAPUR_66 KANAGAL_66	9:08	14:47	5:39	LINE FAULT
799	14-Apr-22	MYSURU	66	KUSHALANAGARA- RAMANATHAPURA 1	ALUR SIDDAPUR_66 KANAGAL_66	14:50	15:03	0:13	HAND TRIPPED
800	14-Apr-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN :LINE CLEAR AVAILED
801	14-Apr-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN :LINE CLEAR AVAILED
802	14-Apr-22	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	15:52	16:26	0:34	LINE FAULT
803	14-Apr-22	TUMKUR	66	KUNDUR- SUZLON_IPP_66	SUZLON_IPP_66	22:17	22:42	0:25	MAIN SUPPLY FAILURE
804	14-Apr-22	TUMKUR	66	MATHOD- PANCHANAHALLI	GARAGA_66,PANCHANAHALLI_6 6	17:20	18:20	1:00	LINE CLEAR AVAILED
805	14-Apr-22	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	3:04	4:09	1:05	LINE FAULT
806	14-Apr-22	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110, TALKERE_110,KADEHALLI_110,	22:00	22:54	0:53	MAIN SUPPLY FAILURE
807	14-Apr-22	TUMKUR	110	TR-1	KBCROSS_220	22:00	22:55	0:55	MAIN SUPPLY FAILURE

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
808	14-Apr-22	TUMKUR	220	ANTHRASANAHALI 220KV- NELAMANGALA(KBCROSS 220)	ANTHRASANAHALI_220	22:00	22:55	0:55	LINE FAULT
809	14-Apr-22	TUMKUR	220	KB CROSS 220KV- NELAMANGALA	KBCROSS_220	22:00	22:51	0:51	LINE FAULT
810	15-Apr-22	BAGALKOT	110	110/11KV, HV1	NIDAGUNDI_110	12:13	12:18	0:05	TRANSFORMER FAULT
811	15-Apr-22	BAGALKOT	110	110/11KV,HV1	HIEMASALI_110	0:02	0:12	0:10	TRANSFORMER FAULT
812	15-Apr-22	BAGALKOT	110	110/11KV,HV1(HV4)	GOPANAKOPPA_110	23:04 (14.04.2022)	12:04 (15.04.2022)	13:00	TRANSFORMER CHARGED
813	15-Apr-22	BAGALKOT	110	110/11KV,HV2	YARAGATTI_110	7:58	8:00	0:02	MAIN SUPPLY FAILURE
814	15-Apr-22	BAGALKOT	110	110/11KV,HV2	YARAGATTI_110	9:57	10:26	0:29	TRANSFORMER FAULT
815	15-Apr-22	BAGALKOT	110	110/11KV,HV2	SHIRAGUPPI_110	16:45	17:30	0:45	LINE CLEAR AVAILED
816	15-Apr-22	BAGALKOT	110	110/11KV,HV2	RAMADURGA_110	12:45	14:00	1:15	LINE CLEAR AVAILED
817	15-Apr-22	BAGALKOT	110	110/11KV,HV2(HV3)	GOPANAKOPPA_110	11:01	12:07	1:06	LINE CLEAR AVAILED
818	15-Apr-22	BAGALKOT	110	110/11KV,HV2A	JAMAKHANDI_110	13:03	14:01	0:58	LINE CLEAR AVAILED
819	15-Apr-22	BAGALKOT	110	110/33KV,HV2	KLE_33,SADASHIVANAGAR_33,P ORT_33,RN2_33,SHRINAR GIS_33BELGAUM_110	18:19	18:33	0:14	TRANSFORMER FAULT
820	15-Apr-22	BAGALKOT	110	AMBEWADI-NK-1	STATION NOT AFFECTED AMBEWADI_220	19:52 (14.04.2022)	11:21 (15.04.2022)	15:39	LINE FAULT
821	15-Apr-22	BAGALKOT	110	ANKOLA-KUMTA	STATION NOT AFFECTED ANKOLA_110	1:39	11:46	10:07	LINE FAULT
822	15-Apr-22	BAGALKOT	110	BAGEWADI2(RAMBAPUR)-KIADB BIJAPUR	STATION NOT AFFECTED KIADB BIJAPUR_110	20:30	20:50	0:20	HAND TRIPPED
823	15-Apr-22	BAGALKOT	110	BAGEWADI2(RAMBAPUR)-KIADB BIJAPUR	STATION NOT AFFECTED KIADB BIJAPUR_110	21:58 (15.04.2022)			LINE OPEN :LINE CLEAR AVAILED
824	15-Apr-22	BAGALKOT	110	BELGAUM220- HUKKERI(UCHAGOAN)	UCHAGOAN_110, UDYAMBAG_110, HONAGA_110	17:38	19:19	1:41	LINE FAULT
825	15-Apr-22	BAGALKOT	110	BIJAPUR220- KIADB2	STATION NOT AFFECTED BIJAPUR_220	19:41	21:57	2:16	LINE FAULT
826	15-Apr-22	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN :LINE CLEAR AVAILED
827	15-Apr-22	BAGALKOT	110	HALIYAL-KAWALWADA	STATION NOT AFFECTED HALIYAL_110	17:56 (07.04.2022)			LINE OPEN:LINE FAULT
828	15-Apr-22	BAGALKOT	110	KULIGOD-GAMESHA	STATION NOT AFFECTED KULIGOD_110	22:21	22:32	0:11	HAND TRIPPED
829	15-Apr-22	BAGALKOT	110	M L PURA(RANNBELAGALI)- UTTUR	UTTUR_110	21:54 (14.04.2022)			LINE OPEN:LINE FAULT
830	15-Apr-22	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	STATION NOT AFFECTED HIDIKAL_110	1:49	9:59	8:10	LINE CLEAR AVAILED
831	15-Apr-22	BAGALKOT	110	MK HUBLI-MK HUBLI1	STATION NOT AFFECTED MK HUBLI_220	10:59 (31.03.2022)			LINE OPEN :LINE CLEAR AVAILED
832	15-Apr-22	BAGALKOT	110	MUGALKHOD- KULIGOD	STATION NOT AFFECTED MUGALKHOD_220	22:02	22:19	0:17	LINE FAULT
833	15-Apr-22	BAGALKOT	110	NAVALAGI-F1(JKD)	NAVALAGI_110	19:54:00 (14.04.2022)	6:26 (15.04.2022)	10:32	LINE FAULT
834	15-Apr-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN :LINE CLEAR AVAILED
835	15-Apr-22	BAGALKOT	110	SAVALAGI- AIGALI(YELLAMANAWADI)	SAVALAGI_110	21:14 (14.04.2022)			LINE OPEN :LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
836	15-Apr-22	BAGALKOT	110	TARHAL(NARENDRA220)-TADASINKOPPA	STATION NOT AFFECTED TADASINKOPPA_110	16:06 (10.04.2022)			LINE CLEAR AVALIED
837	15-Apr-22	BAGALKOT	110	UDAYMBAG-MACHE	STATION NOT AFFECTED UDAYMBAG_110	10:10 (10.04.2022)			LINE OPEN :LINE CLEAR AVALIED
838	15-Apr-22	BAGALKOT	110	YLWD-F2 Cbreaker(SAVALAGI)	SAVALAGI_110	19:22:00 (14.04.2022)	20:31 (15.04.2022)	25:09 hrs	LINE CHARGED
839	15-Apr-22	BAGALKOT	220	ATHANI-RVIURJA(KAKAMARI1)	STATION NOT AFFECTED ATHANI_220	16:34 (09.04.2022)			LINE OPEN:LINE FAULT
840	15-Apr-22	BAGALKOT	220	ATHANI-RVIURJA(KAKAMARI2)	STATION NOT AFFECTED ATHANI_220	16:34 (09.04.2022)			LINE OPEN:LINE FAULT
841	15-Apr-22	BAGALKOT	220	BELGAUM- CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	17:48	20:21	2:33	LINE FAULT
842	15-Apr-22	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	18:12 (14.04.2022)	17:09 (15.04.2022)	22:57	LINE FAULT
843	15-Apr-22	BAGALKOT	220	CHIKKODI- BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	17:48	20:21	2:33	LINE FAULT
844	15-Apr-22	BAGALKOT	220	CHIKKODI- MUGALKOD1	STATION NOT AFFECTED CHIKKODI_220	20:27	21:05	0:38	LINE FAULT
845	15-Apr-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN :LINE CLEAR AVALIED
846	15-Apr-22	BAGALKOT	220	GHATAPRABHA- MUGALKOD2	STATION NOT AFFECTED GHATAPRABHA_220	20:26	21:14	0:48	LINE FAULT
847	15-Apr-22	BAGALKOT	220	KUDAGI1- VAJRAMATTI	STATION NOT AFFECTED VAJRAMATTI_220	0:56	2:57	2:01	LINE FAULT
848	15-Apr-22	BAGALKOT	220	KUDAGI1(KUDAGI2)- VAJRAMATTI	STATION NOT AFFECTED VAJRAMATTI_220	7:10 (15.04.2022)			LINE OPEN :LINE CLEAR AVALIED
849	15-Apr-22	BAGALKOT	220	KUDAGI2- VAJRAMATTI	STATION NOT AFFECTED VAJRAMATTI_220	0:56	3:13	2:17	LINE FAULT
850	15-Apr-22	BAGALKOT	220	SIRSI- SHARAVATHY1	SSTATION NOT AFFECTED SIRSI_220	3:11 (15.04.2022)			LINE OPEN :LINE CLEAR AVALIED
851	15-Apr-22	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	3:13 (15.04.2022)			LINE OPEN :LINE CLEAR AVALIED
852	15-Apr-22	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	17:30 (31.03.2022)	3:11 (15.04.2022)	345:41 hrs	LINE CHARGED
853	15-Apr-22	BAGALKOT	220	SIRSI-SHUBLI1	SIRSI_220	13:24 (12.04.2022)	3:11 (15.04.2022)	61:47 hrs	LINE CHARGED
854	15-Apr-22	BAGALKOT	220	SOUDATTI- BIDNAL	STATION NOT AFFECTED SOUDATTI_220	18:13 (14.04.2022)	17:08 (15.04.2022)	11:27	LINE FAULT
855	15-Apr-22	BENGALURU	66	BEGUR 220 - BIAL 2	AIRPORT	19:15	19:39	0:24	MAIN SUPPLY FAILURE
856	15-Apr-22	BENGALURU	66	BEGUR 220 - ITC (EHT)	ITC (EHT)	19:15	19:55	0:40	MAIN SUPPLY FAILURE
857	15-Apr-22	BENGALURU	66	BEGUR 220 - VIDYANAGAR	VIDYANAGAR, HENNUR CROSS	19:15	19:57	0:42	MAIN SUPPLY FAILURE
858	15-Apr-22	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 2	NO STATION AFFECTED	23:38	23:50	0:12	LINE FAULT
859	15-Apr-22	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	19:15	19:36	0:21	MAIN SUPPLY FAILURE
860	15-Apr-22	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	19:15	19:36	0:21	MAIN SUPPLY FAILURE
861	15-Apr-22	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	19:15	19:36	0:21	MAIN SUPPLY FAILURE
862	15-Apr-22	BENGALURU	66	EXORA - VIKAS TECH PARK 220	EXORA	7:55	8:05	0:10	MAIN SUPPLY FAILURE

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
863	15-Apr-22	BENGALURU	66	EXORA - VIKAS TECH PARK 220	EXORA	8:25	8:30	0:05	MAIN SUPPLY FAILURE
864	15-Apr-22	BENGALURU	66	EXORA - VIKAS TECH PARK 220	EXORA	11:20	12:05	0:45	MAIN SUPPLY FAILURE
865	15-Apr-22	BENGALURU	66	HV1	BOODIGERE	20:30	21:15	0:45	TRANSFORMER FAULT
866	15-Apr-22	BENGALURU	66	HV1	EPID 220	8:58	9:13	0:15	TRANSFORMER FAULT
867	15-Apr-22	BENGALURU	66	HV1	GUDIGERE	20:30	21:55	1:25	TRANSFORMER FAULT
868	15-Apr-22	BENGALURU	66	HV1	THONDEBHAVI	9:40	9:50	0:10	TRANSFORMER FAULT
869	15-Apr-22	BENGALURU	66	HV1	DODDABELAVANGALA	22:18	22:27	0:09	TRANSFORMER FAULT
870	15-Apr-22	BENGALURU	66	HV2	CHATRA	13:02	13:36	0:34	LINE CLEAR AVAILED
871	15-Apr-22	BENGALURU	66	HV2	CHANDAPURA	7:39	7:54	0:15	TRANSFORMER FAULT
872	15-Apr-22	BENGALURU	66	HV2	SADALI	4:02	5:05	1:02	TRANSFORMER FAULT
873	15-Apr-22	BENGALURU	66	HV2	DODDABELAVANGALA	9:30	9:35	0:05	TRANSFORMER FAULT
874	15-Apr-22	BENGALURU	66	HV2	DODDABELAVANGALA	9:50	11:31	1:41	TRANSFORMER FAULT
875	15-Apr-22	BENGALURU	66	HV2	DODDABELAVANGALA	20:23	20:43	0:19	LINE CLEAR AVAILED
876	15-Apr-22	BENGALURU	66	HV2	DODDABELAVANGALA	22:45	22:55	0:10	TRANSFORMER FAULT
877	15-Apr-22	BENGALURU	66	HV3	NELAMANGALA 66	10:54	11:09	0:15	TRANSFORMER FAULT
878	15-Apr-22	BENGALURU	66	KENGERI SATELLITE TOWN - KUMBALAGODU	KENGERI SATELLITE TOWN	0:00	0:03	0:03	MAIN SUPPLY FAILURE
879	15-Apr-22	BENGALURU	66	KUMBALAGODU - KENGERI SATELLITE TOWN	KUMBALAGODU, CHANDRAPPA CIRCLE	1:04	1:07	0:03	LOAD CHANGE OVER
880	15-Apr-22	BENGALURU	66	KUMBALAGODU - SOMANAHALLI 220	KUMBALAGODU, CHANDRAPPA CIRCLE	0:07	0:25	0:18	LOAD CHANGE OVER
881	15-Apr-22	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	11:05(14-4-2022)	0:40(15-4-2022)	13:34	MAIN SUPPLY FAILURE
882	15-Apr-22	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL (EHT)	21:50(14-4-2022)	0:29(15-4-2022)	2:39	MAIN SUPPLY FAILURE
883	15-Apr-22	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	NO STATION AFFECTED	17:48	19:34	1:45	LINE CLEAR AVAILED
884	15-Apr-22	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	18:31	18:36	0:05	LINE FAULT
885	15-Apr-22	BENGALURU	66	PATHPALYA - SOMANATHPURA	THIMMAMPALLI	17:49	17:55	0:06	LINE CLEAR AVAILED
886	15-Apr-22	BENGALURU	66	PATHPALYA - SOMANATHPURA	THIMMAMPALLI	18:29	18:34	0:04	LINE CLEAR AVAILED
887	15-Apr-22	BENGALURU	66	PATHPALYA - SOMANATHPURA	THIMMAMPALLI	23:44(14-4-2022)	1:55(15-4-2022)	2:10 hrs	LINE CHARGED
888	15-Apr-22	BENGALURU	66	PRIMAL - VIKAS TECH PARK 220	PRIMAL	7:55	8:19	0:24	MAIN SUPPLY FAILURE
889	15-Apr-22	BENGALURU	66	PRIMAL - VIKAS TECH PARK 220	PRIMAL	11:23	12:00	0:37	MAIN SUPPLY FAILURE
890	15-Apr-22	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	7:54	8:15	0:21	MAIN SUPPLY FAILURE
891	15-Apr-22	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	11:21	11:47	0:26	MAIN SUPPLY FAILURE
892	15-Apr-22	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	7:55	8:17	0:22	MAIN SUPPLY FAILURE
893	15-Apr-22	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	7:54	8:20	0:26	MAIN SUPPLY FAILURE
894	15-Apr-22	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	11:21	11:51	0:30	MAIN SUPPLY FAILURE
895	15-Apr-22	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, CHANDRAPPA CIRCLE	0:00	0:02	0:02	LINE FAULT
896	15-Apr-22	BENGALURU	66	TK HALLI 220 - SIMSHA	NO STATION AFFECTED	11:24	11:32	0:08	LINE FAULT
897	15-Apr-22	BENGALURU	66	VIDHURASHWATHA - GOWRIBIDANUR 220	VIDHURASHWATHA	15:45	15:50	0:05	LINE FAULT
898	15-Apr-22	BENGALURU	66	VIDHURASHWATHA - GOWRIBIDANUR 220	VIDHURASHWATHA	15:50	16:00	0:10	LINE FAULT
899	15-Apr-22	BENGALURU	66	VIDHURASHWATHA - GOWRIBIDANUR 220	VIDHURASHWATHA	16:00	16:15	0:15	LINE FAULT
900	15-Apr-22	BENGALURU	66	VIDHURASHWATHA - GUNDLU KOTTUR	GUNDLU KOTTUR	15:45	15:50	0:05	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
901	15-Apr-22	BENGALURU	66	VIDHURASHWATHA - GUNDLU KOTTUR	GUNDLU KOTTUR	15:50	16:10	0:20	LINE FAULT
902	15-Apr-22	BENGALURU	66	VIDHURASHWATHA - GUNDLU KOTTUR	GUNDLU KOTTUR	16:10	19:32	3:22	LINE FAULT
903	15-Apr-22	BENGALURU	220	BEGUR 220 - DB PURA 220	DB PURA 220	19:15	19:36	0:21	MAIN SUPPLY FAILURE
904	15-Apr-22	BENGALURU	220	HV2	BIAL BEGUR 220	19:15	19:38	0:23	TRANSFORMER FAULT
905	15-Apr-22	BENGALURU	220	HV2	DB PURA 220	19:15	19:36	0:21	MAIN SUPPLY FAILURE
906	15-Apr-22	BENGALURU	220	KIADB HARDWARE PARK 220 - BIAL BEGUR 220	BIAL BEGUR 220	19:14	19:52	0:38	LINE FAULT
907	15-Apr-22	BENGALURU	220	MALUR 220 - SOMANHALLI 1 O/G	SARIAPURA 220, VIKAS TECH PARK 220	7:54	8:15	0:21	LINE FAULT
908	15-Apr-22	BENGALURU	220	MALUR 220 - SOMANHALLI 1 O/G	SARIAPURA 220, VIKAS TECH PARK 220	11:21	11:47	0:26	LINE CLEAR AVAILED
909	15-Apr-22	BENGALURU	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	7:55	8:20	0:25	MAIN SUPPLY FAILURE
910	15-Apr-22	BENGALURU	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	11:23	12:00	0:37	MAIN SUPPLY FAILURE
911	15-Apr-22	BENGALURU	220	YELAHANKA 220 - YCCP 1	NO STATION AFFECTED	19:13:21(14-4-2022)	8:08:58(15-4-2022)	12:54 hrs	LINE CHARGED
912	15-Apr-22	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	19:00	19:10	0:10	LINE FAULT
913	15-Apr-22	GULBARGA	66	HV2	HALAVAGALU_66	7:15	7:20	0:05	TRANSFORMER FAULT
914	15-Apr-22	GULBARGA	66	ITTAGI-TAMBRAHALLI	HAMPASAGAR_66,MORGERE_66,TAMBRAHALLI_66	9:00	9:06	0:06	LINE FAULT
915	15-Apr-22	GULBARGA	66	MUNIRABAD-MHDLINE	VENKATAPUR_66,UPANAYAKAN AHALLI_66,HAGARIBOMMANAH ALLI_66,RR STEELS_IPP	18:56	19:08	0:12	LINE FAULT
916	15-Apr-22	GULBARGA	66	TELAGI-YARAGUNTA	YARAGUNTA_66	4:25	4:35	0:10	LINE FAULT
917	15-Apr-22	GULBARGA	110	ALIPUR-BELLARY NORTH	SOMASAMUDRA_110,BELLARY NORTH_110,MOKA_110,PD HALLI_110,BISIHALLI_110,JANAKI_IPP,BASAI STEELS	5:10	5:23	0:13	LINE FAULT
918	15-Apr-22	GULBARGA	110	ALIPUR-BELLARY NORTH	SOMASAMUDRA_110,BELLARY NORTH_110,MOKA_110,PD HALLI_110,BISIHALLI_110,JANAKI_IPP,BASAI STEELS	5:36	5:53	0:17	LINE FAULT
919	15-Apr-22	GULBARGA	110	BISILAHALLI-BELLARYNORTH	BISILAHALLI_110	5:10	5:24	0:14	MAIN SUPPLY FAILURE
920	15-Apr-22	GULBARGA	110	BISILAHALLI-BELLARYNORTH	BISILAHALLI_110	5:37	5:54	0:17	MAIN SUPPLY FAILURE
921	15-Apr-22	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	23:25	23:35	0:10	MAIN SUPPLY FAILURE
922	15-Apr-22	GULBARGA	110	HV1	NIRNA_110	9:13	9:19	0:06	TRANSFORMER FAULT
923	15-Apr-22	GULBARGA	110	HV1	MATAMARI_110	22:55	23:00	0:05	TRANSFORMER FAULT
924	15-Apr-22	GULBARGA	110	HV1	CHOWDAPUR_110	10:05	10:10	0:05	TRANSFORMER FAULT
925	15-Apr-22	GULBARGA	110	HV1	CHOWDAPUR_110	15:50	15:55	0:05	TRANSFORMER FAULT
926	15-Apr-22	GULBARGA	110	HV1	KADAGANCHI_110	19:15	19:30	0:15	TRANSFORMER FAULT
927	15-Apr-22	GULBARGA	110	HV1	YAKATPUR_110	12:15	13:00	0:45	LINE CLEAR AVAILED
928	15-Apr-22	GULBARGA	110	HV2	NIRNA_110	9:08	9:14	0:06	TRANSFORMER FAULT
929	15-Apr-22	GULBARGA	110	HV2	NIRNA_110	11:44	11:54	0:10	TRANSFORMER FAULT
930	15-Apr-22	GULBARGA	110	HV2	BELLARYSOUTH_110	10:10	10:47	0:37	LINE CLEAR AVAILED
931	15-Apr-22	GULBARGA	110	HV2	BELLARYSOUTH_110	11:13	12:07	0:54	LINE CLEAR AVAILED
932	15-Apr-22	GULBARGA	110	HV2	YAKATPUR_110	15:05	15:10	0:05	TRANSFORMER FAULT
933	15-Apr-22	GULBARGA	110	HV3	HATTI_110	8:42	12:08	3:26	LINE CLEAR AVAILED
934	15-Apr-22	GULBARGA	110	LV1	SHAHAPUR_220	23:20	23:35	0:15	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
935	15-Apr-22	GULBARGA	110	MALLAT-BYGWAT	BYAGWAT_110, VALKAMDINNI_110	22:29	22:39	0:10	LINE FAULT
936	15-Apr-22	GULBARGA	110	NANDUR-SHAHABAD	NANDUR_110	15:40	16:18	0:38	LINE FAULT
937	15-Apr-22	GULBARGA	110	NANDUR-SHAHABAD	NANDUR_110	15:40	15:50	0:10	LINE FAULT
938	15-Apr-22	GULBARGA	110	SEDAM-GURMITKAL	GURMITKAL_110,KONKAL_110	22:05	22:30	0:25	LINE FAULT
939	15-Apr-22	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	13:05	13:12	0:07	LINE CLEAR AVAILED
940	15-Apr-22	GULBARGA	110	SEDAM-KURKUNTA	KURKUNTA_110	14:12	14:40	0:28	LINE CLEAR AVAILED
941	15-Apr-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN :LINE CLEAR AVAILED
942	15-Apr-22	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGURS_IPP,ASKI_IPP,HUNSAGI 110	4:38	4:43	0:05	LINE FAULT
943	15-Apr-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110, WADAGERA_110,SANNATHI_IPP, COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN :LINE CLEAR AVAILED
944	15-Apr-22	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	5:37	5:43	0:06	LINE FAULT
945	15-Apr-22	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	5:37	5:43	0:06	LINE FAULT
946	15-Apr-22	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110,NALWAR_110	23:20(15.04.2022)			LINE OPEN:LINE FAULT
947	15-Apr-22	GULBARGA	220	ALIPUR-BTPS	ALIPUR_220	11:18:00 AM(15/04/2022)			LINE OPEN :LINE CLEAR AVAILED
948	15-Apr-22	GULBARGA	220	HV1,LV1	KAPNOOR_220	7:15	10:25	3:10	LINE CLEAR AVAILED
949	15-Apr-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
950	15-Apr-22	GULBARGA	220	HV2	SINDHANOOR_220	12:05	12:20	0:15	LINE CLEAR AVAILED
951	15-Apr-22	GULBARGA	220	HV2	SHAHAPUR_220	22:18	23:02	0:44	TRANSFORMER FAULT
952	15-Apr-22	GULBARGA	220	HV2	SHAHAPUR_220	23:20	23:41	0:21	TRANSFORMER FAULT
953	15-Apr-22	HASSAN	66	HV1 CB	NAGARTHI_66	12:00	12:15	0:15	LINE CLEAR AVAILED
954	15-Apr-22	HASSAN	66	HV1 CB	NAGARTHI_66	12:35	12:46	0:11	LINE CLEAR AVAILED
955	15-Apr-22	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	6:20	6:32	0:12	LINE FAULT
956	15-Apr-22	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN :LINE CLEAR AVAILED
957	15-Apr-22	HASSAN	66	SAKALE-IPCL1	SAKALESHPURA_66	11:00	15:37	4:37	LINE CLEAR AVAILED
958	15-Apr-22	HASSAN	66	SAKALE-IPCL2	SAKALESHPURA_66	11:00	15:37	4:37	LINE CLEAR AVAILED
959	15-Apr-22	HASSAN	110	BRAHMAV-MANIPAL	BRAHMAVARA_110	10:31	10:40	0:09	HAND TRIPPED
960	15-Apr-22	HASSAN	110	BRAHMAV-MANIPAL	BRAHMAVARA_110	11:44	11:50	0:06	HAND TRIPPED
961	15-Apr-22	HASSAN	110	HV1	BARANGI_110	11:19	11:21	0:02	HAND TRIPPED
962	15-Apr-22	HASSAN	110	HV1	BARANGI_110	12:03	12:10	0:07	HAND TRIPPED
963	15-Apr-22	HASSAN	110	HV2	BARANGI_110	11:18	11:21	0:03	HAND TRIPPED
964	15-Apr-22	HASSAN	110	HV2	SHIRALKOPPA_220	13:45	14:28	0:43	LINE CLEAR AVAILED
965	15-Apr-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN : LINE CLEAR AVAILED
966	15-Apr-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN :LINE CLEAR AVAILED
967	15-Apr-22	HASSAN	110	LPH-MGHE 1	lph_gen	20:31 (10.04.2022)			LINE OPEN :LINE CLEAR AVAILED
968	15-Apr-22	HASSAN	110	MANIPAL-NITTUR	MANIPAL_110	10:35	11:45	1:10	NFBC ISSUED
969	15-Apr-22	HASSAN	110	MRSSHM-MPM	MRSMG_220	10:48	11:56	1:08	LINE FAULT
970	15-Apr-22	HASSAN	110	PUTTUR-VITLA	PUTTUR_220	1:52	9:05	7:13	LINE FAULT
971	15-Apr-22	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	11:55	12:31	0:36	LINE FAULT
972	15-Apr-22	HASSAN	220	GERSOPA-TALGUPA2	gen_gerusoppa	16:04(15.04.2022)			LINE OPEN:LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
973	15-Apr-22	HASSAN	220	KEMAR-Varahi2	KEMAR_220	21:14(13.04.2022)			LINE OPEN :LINE CLEAR AVAILED
974	15-Apr-22	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	9:49(12.04.2022)			LINE OPEN :LINE CLEAR AVAILED
975	15-Apr-22	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	16:04(15.04.2022)			LINE OPEN:LINE FAULT
976	15-Apr-22	HASSAN	220	VARAHI-KEMAR2	gen_varahi	21:14(13.04.2022)			LINE OPEN :LINE CLEAR AVAILED
977	15-Apr-22	HASSAN	220	VARAHI-SHIMOGA1	gen_varahi	17:31	17:59	0:28	LINE FAULT
978	15-Apr-22	HASSAN	220	VARAHI-SHIMOGA2	gen_varahi	17:31	17:59	0:28	LINE FAULT
979	15-Apr-22	HASSAN	220	VARAHI-SHMG3	gen_varahi	17:31	17:59	0:28	LINE FAULT
980	15-Apr-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN :LINE CLEAR AVAILED
981	15-Apr-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (8/12/2021)			LINE OPEN :LINE CLEAR AVAILED
982	15-Apr-22	MYSURU	66	HEBBANI-TK HALLI	NO STATIONS EFFECTED	11:30	11:39	0:09	LINE FAULT
983	15-Apr-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	16:58:00 (13/12/2021)			LINE OPEN :LINE CLEAR AVAILED
984	15-Apr-22	MYSURU	66	HV1	ADICHUNCHANAGIRI_66	8:50	9:50	0:59	LINE CLEAR AVAILED
985	15-Apr-22	MYSURU	66	HV1	SANIVARASANTHE_66	15:29:47 (11.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
986	15-Apr-22	MYSURU	66	TUBINKERE-NAGMANGALA 2	SHIVALLY _66HARADANAHALI(JAK)_66	14:24	15:35	1:11	LINE CLEAR AVAILED
987	15-Apr-22	MYSURU	66	TUBINKERE-NAGMANGALA 2	SHIVALLY _66HARADANAHALI(JAK)_66KES LAGERE_66BASARALU_66	7:45	8:33	0:48	LINE CLEAR AVAILED
988	15-Apr-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN :LINE CLEAR AVAILED
989	15-Apr-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN :LINE CLEAR AVAILED
990	15-Apr-22	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	11:54	15:54	4:00	LINE CLEAR AVAILED
991	15-Apr-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	6:05	6:10	0:05	MAIN SUPPLY FAILURE
992	15-Apr-22	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	8:00	8:26	0:26	MAIN SUPPLY FAILURE
993	15-Apr-22	TUMKUR	66	PAVAGADA220- NAGALAMADIKE66	PAVAGADA_220	12:43	12:48	0:05	LINE CLEAR AVAILED
994	15-Apr-22	TUMKUR	66	RANGANATHAPURA- WLSPPNSOLAR1	WELSPUN_IPP_SOLAR_66 1	7:14	7:54	0:40	LINE FAULT
995	15-Apr-22	TUMKUR	66	RANGANATHAPURA- WLSPPNSOLAR2	WELSPUN_IPP_SOLAR_66 2	7:14	9:15	2:00	LINE FAULT
996	15-Apr-22	TUMKUR	66	THIPPUR66-ANCHEPALYA220	THIPPUR_66	17:10	17:30	0:20	LINE FAULT
997	15-Apr-22	TUMKUR	220	GUTTUR 400KV-DAVANAGERE2	DAVANGERE_SRS_220	1:57	7:34	5:36	LINE FAULT
998	16-Apr-22	BAGALKOT	110	110/11KV, HV1	SIRSI_220	8:28	8:33	0:05	MAIN SUPPLY FAILURE
999	16-Apr-22	BAGALKOT	110	110/11KV, HV2	SIRSI_220	8:28	8:33	0:05	MAIN SUPPLY FAILURE
1000	16-Apr-22	BAGALKOT	110	110/11KV, HV2	AMBEWADI_220	0:22	0:26	0:04	TRANSFORMER FAULT
1001	16-Apr-22	BAGALKOT	110	110/11KV, HV2	AMBEWADI_220	1:11	1:14	0:03	TRANSFORMER FAULT
1002	16-Apr-22	BAGALKOT	110	110/11KV, HV2	HALIYAL_110	16:52	17:00	0:08	TRANSFORMER FAULT
1003	16-Apr-22	BAGALKOT	110	110/11KV,HV1	BABALESHWAR_110	18:04 (16.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
1004	16-Apr-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	11:55	11:56	0:01	TRANSFORMER FAULT
1005	16-Apr-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	18:00	18:03	0:03	HAND TRIPPED
1006	16-Apr-22	BAGALKOT	110	110/11KV,HV2	RON_110	18:22	18:43	0:21	TRANSFORMER FAULT
1007	16-Apr-22	BAGALKOT	110	110/11KV,HV3	MUDHOL_110	10:25	18:31	8:06	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1008	16-Apr-22	BAGALKOT	110	110/33KV,HV2	BISANAL_110,TEGGI_33	18:54	19:08	0:14	TRANSFORMER FAULT
1009	16-Apr-22	BAGALKOT	110	110/33KV,HV2	BISANAL_110,TEGGI_33	20:13	20:33	0:20	TRANSFORMER FAULT
1010	16-Apr-22	BAGALKOT	110	220/110KV,HV3,LV3	STATION NOT AFFECTED MAHALINGAPUR_220	11:05	12:20	1:15	LINE CLEAR AVAILED
1011	16-Apr-22	BAGALKOT	110	AMBEWADI-NK-2	AMBEWADI_220	8:12	8:37	0:25	HAND TRIPPED
1012	16-Apr-22	BAGALKOT	110	AMBEWADI-NK-2	AMBEWADI_220	18:47	18:55	0:08	HAND TRIPPED
1013	16-Apr-22	BAGALKOT	110	AMBEWADI-NK-2	AMBEWADI_220	20:52	20:59	0:07	HAND TRIPPED
1014	16-Apr-22	BAGALKOT	110	BAGALKOT220- BAGALKOT2	BAGALKOT_220	9:46	10:39	0:53	LINE CLEAR AVAILED
1015	16-Apr-22	BAGALKOT	110	BAGALKOT220- BAGALKOT2	BAGALKOT_220	17:27	18:10	0:43	LINE CLEAR AVAILED
1016	16-Apr-22	BAGALKOT	110	BAGALKOT220-RAMDURG	BAGALKOT_220	16:32	16:37	0:05	LINE FAULT
1017	16-Apr-22	BAGALKOT	110	BAGEWADI2(RAMBAPUR)-KIADB BIJAPUR	STATION NOT AFFECTED KIADB BIJAPUR_110	21:58 (15.04.2022)	00:01 (16.04.2022)	2:03:00	LINE CHARGED
1018	16-Apr-22	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN :LINE CLEAR AVAILED
1019	16-Apr-22	BAGALKOT	110	HAVERI220- HANGAL(TILUVALLI)	STATION NOT AFFECTED HAVERI_220	5:57	6:10	0:13	LINE FAULT
1020	16-Apr-22	BAGALKOT	110	HIDIKAL	STATION NOT AFFECTED MAHALINGAPUR_220	11:05	19:05	8:00	LINE CLEAR AVAILED
1021	16-Apr-22	BAGALKOT	110	HUBLI- RAMANKOPPA	HUBLI_220	17:47	19:19	1:32	LINE FAULT
1022	16-Apr-22	BAGALKOT	110	HUBLI-RAMANAKOPPA	RAMANAKOPPA_110	17:15 (16.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1023	16-Apr-22	BAGALKOT	110	KAVALWADA- HALIYAL	HALIYAL_110	8:17	8:40	0:23	LINE FAULT
1024	16-Apr-22	BAGALKOT	110	KIRUVATTI-SIRSI(AMBEWADI)	STATION NOT AFFECTED KIRUVATTI_110	8:05	19:33	11:28	LINE CLEAR AVAILED
1025	16-Apr-22	BAGALKOT	110	KONNUR-NAVALGUND	KONNUR_110	13:15	13:31	0:16	LINE FAULT
1026	16-Apr-22	BAGALKOT	110	M L PURA(RANNBELAGALI)- UTTUR	UTTUR_110	21:54 (14.04.2022)			LINE OPEN:LINE FAULT
1027	16-Apr-22	BAGALKOT	110	MAHALINGAPUR-GSML1&2	STATION NOT AFFECTED MAHALINGAPUR_220	7:20	11:10	3:50	LINE CLEAR AVAILED
1028	16-Apr-22	BAGALKOT	110	MAMDAPUR-BABLESHWAR	MAMADAPUR_110	16:45	16:56	0:11	LINE FAULT
1029	16-Apr-22	BAGALKOT	110	MAMDAPUR-BABLESHWAR	MAMADAPUR_110	17:12	17:21	0:09	LINE FAULT
1030	16-Apr-22	BAGALKOT	110	MK HUBLI220- HIREBAGEWADI	MK HUBLI_220	16:39	17:15	0:36	LINE FAULT
1031	16-Apr-22	BAGALKOT	110	MK HUBLI-MK HUBLI1	STATION NOT AFFECTED MK HUBLI_220	10:59 (31.03.2022)			LINE OPEN :LINE CLEAR AVAILED
1032	16-Apr-22	BAGALKOT	110	MUGALKHOD- PG HUNSHYAL	MUGALKHOD_220	10:13	11:56	1:43	LINE CLEAR AVAILED
1033	16-Apr-22	BAGALKOT	110	NARENDRA- KUD DHARWAD	NARENDRA_220	11:00	12:30	1:30	LINE CLEAR AVAILED
1034	16-Apr-22	BAGALKOT	110	NARENDRA-KUD DHARWAD	STATION NOT AFFECTED KUD DHARWAD	10:56	12:30	1:34	LINE CLEAR AVAILED
1035	16-Apr-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN :LINE CLEAR AVAILED
1036	16-Apr-22	BAGALKOT	110	RABAKAVI	RABAKAVI_110	11:05	11:15	0:10	HAND TRIPPED
1037	16-Apr-22	BAGALKOT	110	SAVALAGI- AIGALI(YELLAMANAWADI)	SAVALAGI_110	21:14 (14.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1038	16-Apr-22	BAGALKOT	110	TARIHAL(NARENDRA220)- TADASINKOPPA	STATION NOT AFFECTED TADASINKOPPA_110	16:06 (10.04.2022)			LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1039	16-Apr-22	BAGALKOT	110	UDAYMBAG-MACHE	STATION NOT AFFECTED UDAYMBAG_110	10:10 (10.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1040	16-Apr-22	BAGALKOT	110	UMMACHAGI- KIRUVATTI	UMMACHAGI_110	17:05	17:31	0:26	HAND TRIPPED
1041	16-Apr-22	BAGALKOT	220	220/110KV, HV1	SIRSI_220	8:28	8:33	0:05	HAND TRIPPED
1042	16-Apr-22	BAGALKOT	220	ATHANI-RVIURJA(KAKAMARI1)	STATION NOT AFFECTED ATHANI_220	16:34 (09.04.2022)			LINE OPEN:LINE FAULT
1043	16-Apr-22	BAGALKOT	220	ATHANI-RVIURJA(KAKAMARI2)	STATION NOT AFFECTED ATHANI_220	16:34 (09.04.2022)			LINE OPEN:LINE FAULT
1044	16-Apr-22	BAGALKOT	220	BAGEWADI-NANDYAL1(BIJAPUR1)	BAGEWADI_220	8:54	19:00	10:06	NFBC ISSUED
1045	16-Apr-22	BAGALKOT	220	BAGEWADI-NANDYAL2(BIJAPUR2)	BAGEWADI_220	8:53	19:58	11:05	NFBC ISSUED
1046	16-Apr-22	BAGALKOT	220	BELGAUM- KANABARGI1(NARENDRA1)	STATION NOT AFFECTED BELGAUM_220	16:21	17:12	0:51	LINE FAULT
1047	16-Apr-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN :LINE CLEAR AVAILED
1048	16-Apr-22	BAGALKOT	220	HAVERI- GUTTUR1	HAVERI_220	8:25	18:58	10:33	LINE CLEAR AVALIED
1049	16-Apr-22	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	16:30 (16.04.2022)			LINE OPEN:LINE FAULT
1050	16-Apr-22	BAGALKOT	220	KARWAR- KADRA2	KARWAR_220	10:33	13:23	2:50	LINE CLEAR AVALIED
1051	16-Apr-22	BAGALKOT	220	KUDAGI1(KUDAGI2)- VAJRAMATTI	STATION NOT AFFECTED VAJRAMATTI_220	7:10 (15.04.2022)	14:01 (16.04.2022)	30:51 hrs	LINE CHARGED
1052	16-Apr-22	BAGALKOT	220	KUDAGI2 (KUDAGI1)- VAJRAMATTI	VAJRAMATTI_220	12:03	14:06	2:03	LINE CLEAR AVALIED
1053	16-Apr-22	BAGALKOT	220	KUDAGI2 (KUDAGI1)- VAJRAMATTI	VAJRAMATTI_220	12:03	14:06	2:03	LINE CLEAR AVALIED
1054	16-Apr-22	BAGALKOT	220	NARENDRA- BELGAUM1	NARENDRA_220	16:21	17:12	0:51	LINE FAULT
1055	16-Apr-22	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	10:03 (16.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1056	16-Apr-22	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	10:03 (16.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1057	16-Apr-22	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	3:11 (15.04.2022)	10:04 (16.04.2022)	30:53 hrs	LINE CHARGED
1058	16-Apr-22	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	3:13 (15.04.2022)	10:04 (16.04.2022)	30:51 hrs	LINE CHARGED
1059	16-Apr-22	BENGALURU	66	AMAR JYOTHI - ADUGODI 2	AMAR JYOTHI	14:22	14:44	0:22	LOAD CHANGE OVER
1060	16-Apr-22	BENGALURU	66	AMAR JYOTHI - LEELA VENTURE 2	AMAR JYOTHI	9:27	9:51	0:24	LOAD CHANGE OVER
1061	16-Apr-22	BENGALURU	66	BRIGADE MEADOWS - SHOBHA FOREST	SHOBHA FOREST	19:14	19:26	0:12	LINE FAULT
1062	16-Apr-22	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1	GANJIGUNTE, PALLICHERLU	18:15	18:54	0:38	LINE CLEAR AVALIED
1063	16-Apr-22	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 2	NO STATION AFFECTED	18:15	18:54	0:38	LINE CLEAR AVALIED
1064	16-Apr-22	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 2	NO STATION AFFECTED	18:37	18:48	0:11	LINE FAULT
1065	16-Apr-22	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	16:09	16:18	0:08	LOAD CHANGE OVER
1066	16-Apr-22	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	17:50	17:55	0:05	LOAD CHANGE OVER
1067	16-Apr-22	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	16:09	16:18	0:08	LOAD CHANGE OVER
1068	16-Apr-22	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	17:50	17:55	0:05	LOAD CHANGE OVER
1069	16-Apr-22	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	12:25	12:31	0:05	LOAD CHANGE OVER

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1070	16-Apr-22	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	17:50	17:55	0:05	LOAD CHANGE OVER
1071	16-Apr-22	BENGALURU	66	DODDABELAVANGALA - DB PURA 220	DODDABELAVANGALA	12:24	14:02	1:38	LINE CLEAR AVAILED
1072	16-Apr-22	BENGALURU	66	GOWRIBIDANUR 220 - AFTL SOLAR	AFTL SOLAR	15:23	16:11	0:48	LOAD CHANGE OVER
1073	16-Apr-22	BENGALURU	66	GOWRIBIDANUR 220 - AFTL SOLAR	AFTL SOLAR	16:46	17:02	0:16	LOAD CHANGE OVER
1074	16-Apr-22	BENGALURU	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSURU RAMAPURA, NITRALLI	15:23	16:11	0:48	LOAD CHANGE OVER
1075	16-Apr-22	BENGALURU	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSURU RAMAPURA, NITRALLI	16:46	17:02	0:16	LOAD CHANGE OVER
1076	16-Apr-22	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	ID HALLI, KODIGENAHALLI	15:23	16:11	0:48	LOAD CHANGE OVER
1077	16-Apr-22	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	ID HALLI, KODIGENAHALLI	16:46	17:02	0:16	LOAD CHANGE OVER
1078	16-Apr-22	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	D PALYA, GUDIBANDE, MANDIKAL, PERESANDRA	15:23	16:11	0:48	LOAD CHANGE OVER
1079	16-Apr-22	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	D PALYA, GUDIBANDE, MANDIKAL, PERESANDRA	16:46	17:02	0:16	LOAD CHANGE OVER
1080	16-Apr-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR)	GRINDWELL (EHT), HOSKOTE 66	11:14	11:29	0:15	LINE CLEAR AVAILED
1081	16-Apr-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR)	GRINDWELL (EHT), HOSKOTE 66	11:30	11:51	0:21	LINE CLEAR AVAILED
1082	16-Apr-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	BELL CERAMICS (EHT), KONDASPURA	22:58	23:12	0:13	LINE FAULT
1083	16-Apr-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	BELL CERAMICS (EHT), KONDASPURA	22:58	23:12	0:13	LINE FAULT
1084	16-Apr-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	BELL CERAMICS (EHT), KONDASPURA	23:12(16-4-2022)			LINE OPEN:LINE FAULT
1085	16-Apr-22	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	17:08	17:53	0:45	LINE FAULT
1086	16-Apr-22	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	17:08	17:53	0:45	LINE FAULT
1087	16-Apr-22	BENGALURU	66	HV1	RAJANUKUNTE	15:50	16:10	0:20	LINE CLEAR AVAILED
1088	16-Apr-22	BENGALURU	66	HV1	BANGARPETE	16:30	16:45	0:15	TRANSFORMER FAULT
1089	16-Apr-22	BENGALURU	66	HV1	DALASNUR	20:31	21:30	0:58	TRANSFORMER FAULT
1090	16-Apr-22	BENGALURU	66	HV1	DALASNUR	21:33	21:54	0:20	TRANSFORMER FAULT
1091	16-Apr-22	BENGALURU	66	HV1	CHINTAMANI 66	11:07	11:12	0:05	LINE CLEAR AVAILED
1092	16-Apr-22	BENGALURU	66	HV2	CHATRA	12:40	12:57	0:17	LINE CLEAR AVAILED
1093	16-Apr-22	BENGALURU	66	HV2	HAL 220	6:31	6:43	0:12	LOAD CHANGE OVER
1094	16-Apr-22	BENGALURU	66	HV2	HOSUR RAMAPURA	23:27	23:39	0:12	TRANSFORMER FAULT
1095	16-Apr-22	BENGALURU	66	HV2	THAYALUR	3:00	3:14	0:13	TRANSFORMER FAULT
1096	16-Apr-22	BENGALURU	66	HV2	THAYALUR	7:17	7:35	0:17	TRANSFORMER FAULT
1097	16-Apr-22	BENGALURU	66	HV2	THAYALUR	12:45	13:45	1:00	LINE CLEAR AVAILED
1098	16-Apr-22	BENGALURU	66	HV2	HUKUNDA	18:20	18:29	0:09	TRANSFORMER FAULT
1099	16-Apr-22	BENGALURU	66	HV2	CHANDAPURA	21:37	21:54	0:17	TRANSFORMER FAULT
1100	16-Apr-22	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	20:46	20:56	0:10	LINE FAULT
1101	16-Apr-22	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	23:56(16-4-2022)			LINE OPEN :LINE CLEAR AVAILED
1102	16-Apr-22	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	21:02	21:36	0:34	LINE FAULT
1103	16-Apr-22	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	21:54	22:28	0:33	LINE FAULT
1104	16-Apr-22	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	9:28	9:43	0:14	LINE FAULT
1105	16-Apr-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI	21:37	22:29	0:52	LINE FAULT
1106	16-Apr-22	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	16:20	17:40	1:20	LINE CLEAR AVAILED
1107	16-Apr-22	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	17:46	18:01	0:14	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1108	16-Apr-22	BENGALURU	66	MANYATHA TECH PARK 220 - HOSKOTE 1	MANYATHA TECH PARK 66	12:50	13:23	0:33	LINE CLEAR AVAILED
1109	16-Apr-22	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	NO STATION AFFECTED	11:06	11:21	0:14	LINE CLEAR AVAILED
1110	16-Apr-22	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	17:31	17:37	0:06	LINE FAULT
1111	16-Apr-22	BENGALURU	66	T G HALLI - MAGADI 220	V G DODDI, TAVARAKERE	13:31	14:22	0:50	LINE CLEAR AVAILED
1112	16-Apr-22	BENGALURU	66	TADIGOLU - CHINTAMANI 220	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	21:20	21:25	0:05	LINE FAULT
1113	16-Apr-22	BENGALURU	66	VIDYANAGAR - HOSKOTE 220	GRINDWELL (EHT)	8:15	12:37	4:22	LINE FAULT
1114	16-Apr-22	BENGALURU	220	DABUSPET 220 - KADUR 220	NO STATION AFFECTED	10:48	16:03	5:15	LOAD CURTAILMENT
1115	16-Apr-22	BENGALURU	220	GOWRIBIDANUR 220 - SIRA 2	NO STATION AFFECTED	12:15	15:30	3:15	LINE CLEAR AVAILED
1116	16-Apr-22	BENGALURU	220	HV1	JIGANI 220	12:35(16-4-2022)			TRANSFORMER OPEN : LINE CLEAR AVAILED
1117	16-Apr-22	BENGALURU	220	HV3	GOWRIBIDANUR 220	15:03	16:38	1:35	LINE CLEAR AVAILED
1118	16-Apr-22	BENGALURU	220	LV3	GOWRIBIDANUR 220	15:03	16:45	1:42	LINE CLEAR AVAILED
1119	16-Apr-22	BENGALURU	220	VRISHABHAVATHI 220 - KUMBALAGODU 220	NO STATION AFFECTED	20:48:00(16/04/2022)			LINE OPEN:LINE FAULT
1120	16-Apr-22	GULBARGA	66	HV1	KOGALI_66	19:20	19:30	0:10	TRANSFORMER FAULT
1121	16-Apr-22	GULBARGA	66	HV2	TAMBRAHALLI_66	7:37	8:07	0:30	LINE CLEAR AVAILED
1122	16-Apr-22	GULBARGA	66	HV2	KOGALI_66	8:40	8:55	0:15	TRANSFORMER FAULT
1123	16-Apr-22	GULBARGA	66	HV2	BENNEHALLI_66	21:21	21:31	0:10	TRANSFORMER FAULT
1124	16-Apr-22	GULBARGA	66	HV3	HALVAGALU_66	17:45	18:35	0:50	TRANSFORMER FAULT
1125	16-Apr-22	GULBARGA	66	ITTAGI-BENNEHALLI	KOTTUR_66,UJJAINI_66,BENNEHALLI_66	17:55	18:01	0:06	LINE FAULT
1126	16-Apr-22	GULBARGA	66	ITTAGI-TAMBRAHALLI	HAMPASAGAR_66,MORGERE_66,TAMBRAHALLI_66	20:53	22:58	2:05	LINE FAULT
1127	16-Apr-22	GULBARGA	66	KUDLIGI-BANVIKAL	BANVIKAL_66	19:50	20:40	0:50	LINE FAULT
1128	16-Apr-22	GULBARGA	66	MAGALA-HIREHADAGALI	MAGALA_66	18:40	18:50	0:10	LINE FAULT
1129	16-Apr-22	GULBARGA	66	MUNIRABAD-MHDLIN	VENKATAPUR_66,UPANAYAKANAHALLI_66,HAGARIBOMMANAHALLI_66,RR STEELS_IPP	20:01	20:05	0:04	LINE FAULT
1130	16-Apr-22	GULBARGA	110	ALIPUR-BELLARY NORTH	SOMASAMUDRA_110,BELLARY NORTH_110,MOKA_110,PDHALLI_110,BISHIHALI_110,JANAKI_IPP,BASAI STEELS	5:55	6:12	0:17	LINE FAULT
1131	16-Apr-22	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURUGOD_110,SHATVAHANA_IPP,AGARWAL_IPP,SUZLON_IPP,KAMLAPUR_110,METRI_110,RBNS FACTORY	20:01	20:18	0:17	LINE FAULT
1132	16-Apr-22	GULBARGA	110	ALIPUR-SOUTH2	BELLARY SOUTH_110,HALKUNDI_110	18:11	18:36	0:25	HAND TRIPPED
1133	16-Apr-22	GULBARGA	110	BISILAALLI-BELLARYNORTH	BISILAHALLI_110	5:55	6:15	0:20	MAIN SUPPLY FAILURE
1134	16-Apr-22	GULBARGA	110	CHINCHOLI-SEDAM	CHINCHOLI_110	15:15	16:30	1:15	LINE CLEAR AVAILED
1135	16-Apr-22	GULBARGA	110	HALAKUN DI-ALIPUR	HALAKUNDI_110	18:11	18:36	0:25	MAIN SUPPLY FAILURE
1136	16-Apr-22	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	23:25	23:45	0:20	MAIN SUPPLY FAILURE
1137	16-Apr-22	GULBARGA	110	HV1	YAKATPUR_110	11:20	11:45	0:25	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1138	16-Apr-22	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110,HIREGONN AGAR_110,HANUMANAL_110	10:18	13:40	3:22	LINE CLEAR AVAILED
1139	16-Apr-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	0:20	0:28	0:08	LINE FAULT
1140	16-Apr-22	GULBARGA	110	MUDDAPUR-SINDHNOOR	MUDDAPUR_110	2:28	2:36	0:08	LINE FAULT
1141	16-Apr-22	GULBARGA	110	NALWAR-SHAHPUR	NALWAR_110,SHAHAPUR_110	11:00	12:00	1:00	LINE CLEAR AVAILED
1142	16-Apr-22	GULBARGA	110	NALWAR-SHAHPUR	NALWAR_110,SHAHAPUR_110	11:25	11:30	0:05	LINE FAULT
1143	16-Apr-22	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	15:49	15:57	0:08	LINE FAULT
1144	16-Apr-22	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	16:49	17:21	0:32	LINE FAULT
1145	16-Apr-22	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLAPUR_1 10,MANVI_110	5:05	5:12	0:07	LINE FAULT
1146	16-Apr-22	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	15:14	16:28	1:14	LINE CLEAR AVAILED
1147	16-Apr-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN :LINE CLEAR AVAILED
1148	16-Apr-22	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	12:48	14:48	2:00	LINE CLEAR AVAILED
1149	16-Apr-22	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGURS_IPP,ASKI_IPP,HUNSAGI _110	3:41	3:50	0:09	LINE FAULT
1150	16-Apr-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110, WADAGERA_110,SANNATHI_IPP, COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1151	16-Apr-22	GULBARGA	110	SHAHAPUR-SHAHAPUR-1	SHAHAPUR_110	11:03	11:10	0:07	LINE CLEAR AVAILED
1152	16-Apr-22	GULBARGA	110	SHAHAPUR-SHAHAPUR-1	SHAHAPUR_110	16:54	18:00	1:06	LINE CLEAR AVAILED
1153	16-Apr-22	GULBARGA	110	SHAHAPUR-SHAHAPUR2	NALWAR_110,SHAHAPUR_110	23:20(15.04.2022)	01:15(16.04.2022)	01:55HRS	LINE CHARGED
1154	16-Apr-22	GULBARGA	110	SHAHAPUR-SHAHAPUR2	NALWAR_110	0:30	1:18	0:48	LINE CLEAR AVAILED
1155	16-Apr-22	GULBARGA	110	SHAHAPUR-SHAHAPUR-2	NALWAR_110	11:03	14:28	3:25	LINE CLEAR AVAILED
1156	16-Apr-22	GULBARGA	110	SHAHAPUR-SHAHAPUR-2	NALWAR_110	16:54	18:00	1:06	LINE CLEAR AVAILED
1157	16-Apr-22	GULBARGA	110	SINDHANOOR- ADVAMARESHWARA	JEWALAGERA_110,ADAVIAMARE SHWARA_110	1:55	2:05	0:10	LINE FAULT
1158	16-Apr-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YE RDONA_110,SRNAGAR_110,MAL LAPURA_110	20:25(16.04.2022)			LINE OPEN:LINE FAULT
1159	16-Apr-22	GULBARGA	110	TEKKALKOTE-SHAHI SLR	TEKKALKOTE_110	20:35	22:55	2:20	LINE FAULT
1160	16-Apr-22	GULBARGA	220	ALIPUR-BTPS	ALIPUR_220	18:11	18:31	0:20	HAND TRIPPED
1161	16-Apr-22	GULBARGA	220	BTPS-LINGAPUR	LINGAPUR_220	18:20	18:30	0:10	LINE CLEAR AVAILED
1162	16-Apr-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
1163	16-Apr-22	GULBARGA	220	NEELAGUNA-GUTTUR	GUTTUR_220	1:42	6:58	5:16	LINE FAULT
1164	16-Apr-22	GULBARGA	220	SINDHANOOR-SULEKAL	SULEKAL_220	13:29	13:43	0:14	LINE FAULT
1165	16-Apr-22	HASSAN	66	BALLUPE-SAKLESPURA	BALLUPETE_66	19:05	20:00	0:55	MAIN SUPPLY FAILURE
1166	16-Apr-22	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	13:18	13:30	0:12	LINE FAULT
1167	16-Apr-22	HASSAN	66	CRPATNA-SBELAGULA	CHANNARAYAPATNA_66	18:16	18:51	0:35	LINE FAULT
1168	16-Apr-22	HASSAN	66	HASSN22-ARAKALGUD1	HASSAN_220	19:00	20:50	1:50	LINE FAULT
1169	16-Apr-22	HASSAN	66	HASSN22-SKPURA1	HASSAN_220	19:03	19:55	0:52	LINE FAULT
1170	16-Apr-22	HASSAN	66	HASSN22-SKPURA2	HASSAN_220	19:03	19:55	0:52	LINE FAULT
1171	16-Apr-22	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	20:35	22:35	2:00	LINE CLEAR AVAILED
1172	16-Apr-22	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	18:28	18:48	0:20	LINE FAULT
1173	16-Apr-22	HASSAN	66	HV1	BALLUPETE_66	12:40	13:05	0:25	LINE CLEAR AVAILED
1174	16-Apr-22	HASSAN	66	HV1	HOLALUR_66	22:00	22:18	0:18	TRANSFORMER FAULT
1175	16-Apr-22	HASSAN	66	HV1	MATTANAVILE_66	18:55	20:25	1:30	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1176	16-Apr-22	HASSAN	66	HV1	MOSALEHOSALLI_66	15:37	15:50	0:13	LINE CLEAR AVAILED
1177	16-Apr-22	HASSAN	66	HV1	MOSALEHOSALLI_66	18:40	18:55	0:15	LINE CLEAR AVAILED
1178	16-Apr-22	HASSAN	66	HV1	MOSALEHOSALLI_66	22:45	22:50	0:05	HAND TRIPPED
1179	16-Apr-22	HASSAN	66	HV1	YESLUR_66	19:00	20:57	1:57	MAIN SUPPLY FAILURE
1180	16-Apr-22	HASSAN	66	KANDLI-HASSAN	KANDLI_66	18:55	20:00	1:05	MAIN SUPPLY FAILURE
1181	16-Apr-22	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	18:55	20:00	1:05	MAIN SUPPLY FAILURE
1182	16-Apr-22	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN :LINE CLEAR AVAILED
1183	16-Apr-22	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAR_66	16:45	17:25	0:40	MAIN SUPPLY FAILURE
1184	16-Apr-22	HASSAN	66	SAKALE-HASSAN	SAKALESHPURA_66	19:00	20:05	1:05	MAIN SUPPLY FAILURE
1185	16-Apr-22	HASSAN	66	SAKLAE-IPCL1	SAKALESHPURA_66	19:00	20:20	1:20	LINE FAULT
1186	16-Apr-22	HASSAN	66	SAKLAE-IPCL2	SAKALESHPURA_66	19:00	20:20	1:20	LINE FAULT
1187	16-Apr-22	HASSAN	66	SHANTHI-RMSWRNGR	SHANTHIGRAMA_66	16:45	17:20	0:35	LINE FAULT
1188	16-Apr-22	HASSAN	110	BAIKAM-KAVOOR	BAIKAMPADI_110	16:46	17:15	0:29	MAIN SUPPLY FAILURE
1189	16-Apr-22	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	15:30	17:30	2:00	LINE FAULT
1190	16-Apr-22	HASSAN	110	HV1	BAIKAMPADI_110	10:11	16:16	6:05	LINE CLEAR AVAILED
1191	16-Apr-22	HASSAN	110	HV1	BARANGI_110	18:00	19:14	1:14	TRANSFORMER FAULT
1192	16-Apr-22	HASSAN	110	HV1	JOG_110	11:35	13:25	1:50	LINE CLEAR AVAILED
1193	16-Apr-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN : LINE CLEAR AVAILED
1194	16-Apr-22	HASSAN	110	HV4	MRSMSG_220	9:13	13:15	4:02	LINE CLEAR AVAILED
1195	16-Apr-22	HASSAN	110	HV4	KAVOOR_220	9:33	19:01	9:28	LINE CLEAR AVAILED
1196	16-Apr-22	HASSAN	110	JOG110-LPH	JOG_110	15:45(16.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1197	16-Apr-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN :LINE CLEAR AVAILED
1198	16-Apr-22	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	16:47	16:50	0:03	LINE CLEAR AVAILED
1199	16-Apr-22	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	16:50	16:58	0:08	LINE FAULT
1200	16-Apr-22	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	16:58	17:15	0:17	LINE FAULT
1201	16-Apr-22	HASSAN	110	LPH-MGHE 1	lph_gen	20:31 (10.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1202	16-Apr-22	HASSAN	110	NANDIKU-KEMAR1	NANDIKUR_110	10:23	12:56	2:33	LINE CLEAR AVAILED
1203	16-Apr-22	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	18:05(16.04.2022)			LINE OPEN:LINE FAULT
1204	16-Apr-22	HASSAN	110	SHRLKP-SHRLKP	SHIRALKOPPA_220	18:12	19:04	0:52	LINE FAULT
1205	16-Apr-22	HASSAN	220	GERSOPA-TALGUPA2	gen_gerusoppa	16:04(15.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1206	16-Apr-22	HASSAN	220	HV1	KEMAR_220	10:48	12:07	1:19	LINE CLEAR AVAILED
1207	16-Apr-22	HASSAN	220	KEMAR-Varahi2	KEMAR_220	21:14(13.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1208	16-Apr-22	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	15:41(16.04.2022)			LINE OPEN:LINE FAULT
1209	16-Apr-22	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	19:26	19:43	0:17	LINE FAULT
1210	16-Apr-22	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	15:31	17:38	2:07	LINE FAULT
1211	16-Apr-22	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	9:49(12.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1212	16-Apr-22	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	16:04(15.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1213	16-Apr-22	HASSAN	220	VARAHI-KEMAR1	gen_varahi	17:54	18:18	0:24	LINE FAULT
1214	16-Apr-22	HASSAN	220	VARAHI-KEMAR2	gen_varahi	21:14(13.04.2022)			LINE OPEN :LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1215	16-Apr-22	HASSAN	220	VARAHI-SHMG3	gen_varahi	15:28	18:17	2:49	LINE FAULT
1216	16-Apr-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN :LINE CLEAR AVAILED
1217	16-Apr-22	MYSURU	66	AKKI HEBBAL-KAVERI HYDRO	NO STATIONS INTERRUPTED	17:21	17:49	0:27	LINE FAULT
1218	16-Apr-22	MYSURU	66	HANNUR-MADHUVANAHALLI 1	NO STATIONS INTERRUPTED	23:25	23:30	0:05	LINE FAULT
1219	16-Apr-22	MYSURU	66	HEBBANI-MADHUVANAHALLI	NO STATIONS EFFECTED	15:16:00 (8/12/2021)			LINE OPEN :LINE CLEAR AVAILED
1220	16-Apr-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	16:58:00 (13/12/2021)			LINE OPEN :LINE CLEAR AVAILED
1221	16-Apr-22	MYSURU	66	HV1	SANIVARASANTHE_66	15:29:47 (11.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
1222	16-Apr-22	MYSURU	66	HV2	KIKKERI_66	13:00	15:31	2:30	LINE CLEAR AVAILED
1223	16-Apr-22	MYSURU	66	K.HONALGERE-IGGLUR	K_HONNALGERE_66 MADDUR_66 SOMANAHALLI KIADB_66	14:45	14:55	0:10	MAIN SUPPLY FAILURE
1224	16-Apr-22	MYSURU	66	K.HONALGERE-MADDUR	MADDUR_66 SOMANAHALLI KIADB_66	14:59	15:19	0:20	MAIN SUPPLY FAILURE
1225	16-Apr-22	MYSURU	66	MADDUR-K.HONALGERE	SOMANAHALLI KIADB_66	7:04	7:14	0:10	LINE FAULT
1226	16-Apr-22	MYSURU	66	MADDUR-KIADB MANDYA	MADDUR_66 SOMANAHALLI KIADB_66	13:05	14:40	1:35	LINE CLEAR AVAILED
1227	16-Apr-22	MYSURU	66	MADDUR-KIADB MANDYA	MADDUR_66 SOMANAHALLI KIADB_66	14:41	15:29	0:48	LINE CLEAR AVAILED
1228	16-Apr-22	MYSURU	66	MADHUVANAHALLI-HANNUR1	NO STATIONS INTERRUPTED	23:25	23:30	0:04	LINE FAULT
1229	16-Apr-22	MYSURU	66	MALAVALLI-SHIMSHA	MALAVALLI_66 HADLI_66	11:44	11:49	0:05	MAIN SUPPLY FAILURE
1230	16-Apr-22	MYSURU	66	MALAVALLI-SHIMSHA	MALAVALLI_66 HADLI_66	11:52	12:00	0:08	MAIN SUPPLY FAILURE
1231	16-Apr-22	MYSURU	66	NANJANGUDU-SINDUVALLI	NO STATIONS INTERRUPTED	11:11	15:10	3:59	LINE CLEAR AVAILED
1232	16-Apr-22	MYSURU	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY_66 HARADANAHALLI(JAK)_66 KESLAGERE_66 BASARALU_66	12:04	12:24	0:20	HAND TRIPPED
1233	16-Apr-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN :LINE CLEAR AVAILED
1234	16-Apr-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN :LINE CLEAR AVAILED
1235	16-Apr-22	MYSURU	220	HV1	TUBINAKERE_220	15:59	16:31	0:32	HAND TRIPPED
1236	16-Apr-22	TUMKUR	66	BHARAMAGIRI66-MATHOD66	BHARAMAGIRI_66	15:33	15:39	0:06	LINE FAULT
1237	16-Apr-22	TUMKUR	66	BHARAMAGIRI66-MATHOD66	BHARAMAGIRI_66	15:57	16:05	0:08	LINE FAULT
1238	16-Apr-22	TUMKUR	66	BRAHMASANDRA-SIRA(ANKASANDRA)	BRAHMASANDRA_66	16:36	17:16	0:40	LINE FAULT
1239	16-Apr-22	TUMKUR	66	BRAHMASANDRA-SIRA(ANKASANDRA)	BRAHMASANDRA_66	18:33	18:53	0:19	LINE FAULT
1240	16-Apr-22	TUMKUR	66	BRAHMASANDRA-THOVINKERE(KORA)	THOVINAKERE_66, KORA_66	16:36	18:34	1:57	LINE FAULT
1241	16-Apr-22	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66,KADAJJI_66,M ELEKATTE_66	1:47	2:20	0:33	HAND TRIPPED
1242	16-Apr-22	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	1:47	2:20	0:33	HAND TRIPPED
1243	16-Apr-22	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	1:47	2:20	0:33	HAND TRIPPED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1244	16-Apr-22	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:00	11:31	0:31	LINE FAULT
1245	16-Apr-22	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	1:47	2:20	0:32	HAND TRIPPED
1246	16-Apr-22	TUMKUR	66	DAVANGERE SRS- YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJIHALLI_66	1:47	2:20	0:33	HAND TRIPPED
1247	16-Apr-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	0:28	0:39	0:11	LINE FAULT
1248	16-Apr-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	5:19	5:22	0:03	LINE FAULT
1249	16-Apr-22	TUMKUR	66	NAYAKANAHATTI66- HIREMALLANAHOLE66	NAYAKANHATTI_66, HIREMALLANAHOLE_66	5:03	5:15	0:11	LINE FAULT
1250	16-Apr-22	TUMKUR	66	TR-1	HIRIYUR_66	8:21	8:55	0:33	TRANSFORMER FAULT
1251	16-Apr-22	TUMKUR	66	TR-1	HIRIYUR_66	17:08	17:56	0:47	TRANSFORMER FAULT
1252	16-Apr-22	TUMKUR	66	TR-1	HOLALKERE_66	22:06	22:09	0:03	TRANSFORMER FAULT
1253	16-Apr-22	TUMKUR	66	TR-1	DAVANAGERE_220	1:47	2:21	0:34	HAND TRIPPED
1254	16-Apr-22	TUMKUR	66	TR-2	BEVINAHALLI_66	14:15	15:10	0:54	LINE CLEAR AVAILED
1255	16-Apr-22	TUMKUR	66	TR-2	BHARAMAGIRI_66	14:15	14:20	0:05	TRANSFORMER FAULT
1256	16-Apr-22	TUMKUR	66	TR-2	BHARAMAGIRI_66	14:40	14:45	0:05	TRANSFORMER FAULT
1257	16-Apr-22	TUMKUR	110	TR-1	SHETTYKERE_110	8:18	10:19	2:00	TRANSFORMER FAULT
1258	16-Apr-22	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	1:39	2:37	0:57	LINE FAULT
1259	16-Apr-22	TUMKUR	220	NITTUR 220-NELAMANGALA	NITTUR_220	10:51	15:39	4:48	LINE CLEAR AVAILED
1260	17-Apr-22	BAGALKOT	110	110/11KV, HV2	RAMDURGA_110	17:05	17:25	0:20	TRANSFORMER FAULT
1261	17-Apr-22	BAGALKOT	110	110/11KV,HV1	BABALESHWAR_110	18:04 (16.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
1262	17-Apr-22	BAGALKOT	110	110/11KV,HV1	HIREMASALI_110	15:54	16:00	0:06	TRANSFORMER FAULT
1263	17-Apr-22	BAGALKOT	110	110/11KV,HV2	RON_110	21:43	22:02	0:19	TRANSFORMER FAULT
1264	17-Apr-22	BAGALKOT	110	110/11KV,HV4	KERUR_110	17:36	18:02	0:26	LINE CLEAR AVAILED
1265	17-Apr-22	BAGALKOT	110	110/33KV,HV2	BISANAL_110, TEGGI_33	20:26	20:41	0:15	TRANSFORMER FAULT
1266	17-Apr-22	BAGALKOT	110	110/33KV,HV2	HUNGUND_110 & KARADI,AMINGAD,MAITRA SOLAR_33	16:54	17:03	0:09	TRANSFORMER FAULT
1267	17-Apr-22	BAGALKOT	110	110/33KV,HV3	KANABARGI LAY OUT_110 & GARISSON,BALEKUNDRI_33	19:00	20:02	1:02	LINE CLEAR AVAILED
1268	17-Apr-22	BAGALKOT	110	AMBEWADI-NK-2	STATION NOT AFFECTED AMBEWADI_220	16:31	17:14	0:43	LINE FAULT
1269	17-Apr-22	BAGALKOT	110	AMBEWADI-NK-2(KAVALWADA)	AMBEWADI_220	14:29	14:32	0:03	HAND TRIPPED
1270	17-Apr-22	BAGALKOT	110	AMBEWADI-NK-2(KAVALWADA)	AMBEWADI_220	18:48	18:53	0:05	HAND TRIPPED
1271	17-Apr-22	BAGALKOT	110	AMBEWADI-SUPA1	AMBEWADI_220	22:16	22:26	0:10	LINE FAULT
1272	17-Apr-22	BAGALKOT	110	BAGEWADI-ATRIA	BAGEWADI_220	16:48	17:20	0:32	LINE FAULT
1273	17-Apr-22	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN :LINE CLEAR AVAILED
1274	17-Apr-22	BAGALKOT	110	HUBLI- RAMANKOPPA	HUBLI_220	19:54	20:43	0:49	LINE FAULT
1275	17-Apr-22	BAGALKOT	110	HUBLI-RAMANAKOPPA	RAMANAKOPPA_110	17:15 (16.04.2022)	12:28 (17.04.2022)	19:13 hrs	LINE CHARGED
1276	17-Apr-22	BAGALKOT	110	HUNGUND-KUDALASANGAM	KUDAL SANGAM_110	16:55	17:04	0:09	LINE FAULT
1277	17-Apr-22	BAGALKOT	110	HUNGUND-KUDALASANGAM	KUDAL SANGAM_110	17:06	17:22	0:16	LINE FAULT
1278	17-Apr-22	BAGALKOT	110	JAMBAGI- HALAKI	JAMBAGI_110	12:30	12:40	0:10	MAIN SUPPLY FAILURE

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1279	17-Apr-22	BAGALKOT	110	KIRUVATTI-SIRSI	STATION NOT AFFECTEDKIRUVATTI_110	6:39	14:49	8:10	LINE CLEAR AVAILED
1280	17-Apr-22	BAGALKOT	110	KIRUVATTI-SIRSI	STATION NOT AFFECTEDKIRUVATTI_110	17:03	18:23	1:20	NFBC ISSUED
1281	17-Apr-22	BAGALKOT	110	KONNUR-NAVALGUND	KONNUR_110	13:31	13:36	0:05	LINE FAULT
1282	17-Apr-22	BAGALKOT	110	KONNUR-NAVALGUND	KONNUR_110	13:47 (17.04.2022)			LINE OPEN:LINE FAULT
1283	17-Apr-22	BAGALKOT	110	KULIGERE CROSS-KONNUR	KULIGERE CROSS_110	13:37	13:44	0:07	LINE FAULT
1284	17-Apr-22	BAGALKOT	110	KULIGERE CROSS-MRN SUGARS	STATION NOT AFFECTED KULIGERE CROSS_110	13:31	13:35	0:04	LINE FAULT
1285	17-Apr-22	BAGALKOT	110	KULIGERE CROSS-MRN SUGARS	STATION NOT AFFECTED KULIGERE CROSS_110	13:37	14:06	0:29	LINE FAULT
1286	17-Apr-22	BAGALKOT	110	KULIGERE CROSS-MRN SUGARS	STATION NOT AFFECTED KULIGERE CROSS_110	16:24	16:28	0:04	LINE FAULT
1287	17-Apr-22	BAGALKOT	110	LAKAMANAHALLI-KUD DHARWAD	STATION NOT AFFECTED KUD DHARWAD	19:46	19:47	0:01	HAND TRIPPED
1288	17-Apr-22	BAGALKOT	110	M L PURA(RANNBELAGALI)-UTTUR	UTTUR_110	21:54 (14.04.2022)	11:33 (17.04.2022)	50:06 hrs	LINE CHARGED
1289	17-Apr-22	BAGALKOT	110	MAHALINGAPUR-BANAHATTI	BANAHATTI_110	11:34	11:53	0:19	LINE FAULT
1290	17-Apr-22	BAGALKOT	110	MAHALINGAPUR-GSML2	MAHALINGAPUR_220	5:30 (17.04.2022)			LINE OPEN:LINE FAULT
1291	17-Apr-22	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110 (STATION NOT AFFECTED)	11:27	19:08	7:41	LINE CLEAR AVAILED
1292	17-Apr-22	BAGALKOT	110	MAMDAPUR-BABLESHWAR	MAMADAPUR_110	15:26	15:33	0:07	LINE FAULT
1293	17-Apr-22	BAGALKOT	110	MK HUBLI-MK HUBLI1	STATION NOT AFFECTED MK HUBLI_220	10:59 (31.03.2022)			LINE OPEN :LINE CLEAR AVAILED
1294	17-Apr-22	BAGALKOT	110	NARENDRA- KUD DHARWAD	NARENDRA_220	19:08	19:44	0:36	LINE FAULT
1295	17-Apr-22	BAGALKOT	110	NARGUND-BPCL	NARGUND_110	18:39	18:51	0:12	HAND TRIPPED
1296	17-Apr-22	BAGALKOT	110	NAVALGUND-KONNUR	STATION NOT AFFECTED NAVALGUND_110	14:20	18:36	4:16	LINE FAULT
1297	17-Apr-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN :LINE CLEAR AVAILED
1298	17-Apr-22	BAGALKOT	110	RAMANKOPPA-MUNDGOD	MUNDGOD_110	20:49	20:55	0:06	HAND TRIPPED
1299	17-Apr-22	BAGALKOT	110	SAVALAGI-AIGALI(YELLAMANAWADI)	SAVALAGI_110	21:14 (14.04.2022)	19:02 (17.04.2022)	45:48 hrs	LINE CHARGED
1300	17-Apr-22	BAGALKOT	110	SODATTI220- MMCL	SODATTI_220	17:43	18:50	1:07	LINE FAULT
1301	17-Apr-22	BAGALKOT	110	TARIHAL(NARENDRA220)-TADASINKOPPA	STATION NOT AFFECTED TADASINKOPPA_110	16:06 (10.04.2022)			LINE CLEAR AVAILED
1302	17-Apr-22	BAGALKOT	110	UDAYMBAG-MACHE	STATION NOT AFFECTED UDAYMBAG_110	10:10 (10.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1303	17-Apr-22	BAGALKOT	110	VAJRAMATTI220- JAMBAGI	VAJRAMATTI_220	12:30	12:40	0:10	NFBC ISSUED
1304	17-Apr-22	BAGALKOT	110	VAJRAMATTI-JAMBAGI	JAMBAGI_110	11:15	12:48	1:33	LINE CLEAR AVAILED
1305	17-Apr-22	BAGALKOT	220	ATHANI-RVIURJA(KAKAMARI1)	STATION NOT AFFECTED ATHANI_220	16:34 (09.04.2022)			LINE OPEN:LINE FAULT
1306	17-Apr-22	BAGALKOT	220	ATHANI-RVIURJA(KAKAMARI2)	STATION NOT AFFECTED ATHANI_220	16:34 (09.04.2022)			LINE OPEN:LINE FAULT
1307	17-Apr-22	BAGALKOT	220	BIDNAL-HARTI2	BIDNAL_220	18:45	21:19	2:34	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1308	17-Apr-22	BAGALKOT	220	BIDNAL-HAVERI	BIDNAL_220	19:42 (17.04.2022)			LINE OPEN:LINE FAULT
1309	17-Apr-22	BAGALKOT	220	BIDNAL-SOUDATTI	BIDNAL_220	17:54	20:22	2:28	LINE FAULT
1310	17-Apr-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN :LINE CLEAR AVAILED
1311	17-Apr-22	BAGALKOT	220	HAVERI- NARENDRA1(BIDNAL)	STATION NOT AFFECTED HAVERI_220	19:42 (17.04.2022)			LINE OPEN:LINE FAULT
1312	17-Apr-22	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	16:30 (16.04.2022)	9:32 (17.04.2022)	17:02 hrs	LINE CHARGED
1313	17-Apr-22	BAGALKOT	220	NARENDRA- HUBLI1	NARENDRA_220	19:16 (17.04.2022)			LINE OPEN:LINE FAULT
1314	17-Apr-22	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	10:03 (16.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1315	17-Apr-22	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	10:03 (16.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1316	17-Apr-22	BAGALKOT	220	SIRSI- SHARAVATHY1	SIRSI_220	9:40	10:47	1:07	LINE FAULT
1317	17-Apr-22	BAGALKOT	220	SOUDATTI- BIDNAL	SOUDATTI_220	17:52	20:22	2:30	LINE FAULT
1318	17-Apr-22	BENGALURU	66	HENNUR CROSS - HBR LAYOUT 220	HENNUR CROSS	12:11	12:14	0:03	LOAD CHANGE OVER
1319	17-Apr-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	BELL CERAMICS (EHT)	1:23	2:53	1:30	LINE FAULT
1320	17-Apr-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	BELL CERAMICS (EHT)	1:23	2:53	1:30	LINE FAULT
1321	17-Apr-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	BELL CERAMICS (EHT)	11:57	12:03	0:06	LINE CLEAR AVAILED
1322	17-Apr-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	BELL CERAMICS (EHT)	15:21	15:36	0:15	LINE FAULT
1323	17-Apr-22	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	BELL CERAMICS (EHT)	23:12(16-4-2022)	1:23(17-4-2022)	2:13	LINE FAULT
1324	17-Apr-22	BENGALURU	66	HV1	KADUGODI	23:28	23:55	0:27	TRANSFORMER FAULT
1325	17-Apr-22	BENGALURU	66	HV1	MAHALAKSHMI LAYOUT	17:40	18:05	0:25	TRANSFORMER FAULT
1326	17-Apr-22	BENGALURU	66	HV1	BRINDAVANA 66	9:56	10:18	0:22	LINE CLEAR AVAILED
1327	17-Apr-22	BENGALURU	66	HV1	CHANDAPURA	16:08	16:13	0:04	TRANSFORMER FAULT
1328	17-Apr-22	BENGALURU	66	HV2	KODIGEHALI	16:05	16:10	0:05	LINE CLEAR AVAILED
1329	17-Apr-22	BENGALURU	66	HV2	KODIGEHALI	16:35	16:40	0:05	LOAD CHANGE OVER
1330	17-Apr-22	BENGALURU	66	HV2	VIJAYANAGARA	12:00	12:04	0:04	LOAD CHANGE OVER
1331	17-Apr-22	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE, BIJJALALLI	16:56	17:03	0:07	LINE FAULT
1332	17-Apr-22	BENGALURU	66	Kengeri SATELLITE TOWN - SIR MV LAYOUT	Kengeri SATELLITE TOWN	11:44	12:35	0:51	LINE CLEAR AVAILED
1333	17-Apr-22	BENGALURU	66	KOLAR 220 - BANGARPET 1	NO STATION AFFECTED	0:41	0:59	0:17	LINE CLEAR AVAILED
1334	17-Apr-22	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPETE	0:40	0:59	0:18	LINE CLEAR AVAILED
1335	17-Apr-22	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	1:35	4:14	2:39	LINE FAULT
1336	17-Apr-22	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	23:56(16-4-2022)	1:35(17-4-2022)	1:39	LINE CHARGED
1337	17-Apr-22	BENGALURU	66	KONDASPURA - EPIP 220	KONDASPURA	16:58	17:03	0:05	LOAD CHANGE OVER
1338	17-Apr-22	BENGALURU	66	MAGADI 220 - T G HALLI	V G DODDI, T G HALLI, TAVARAKERE	15:03	15:35	0:32	LINE FAULT
1339	17-Apr-22	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	17:40	18:05	0:25	MAIN SUPPLY FAILURE
1340	17-Apr-22	BENGALURU	66	MALUR 220 - KGF 1	TEKAL, BUDIKOTE, TORLAKKI	0:14	1:12	0:57	LINE CLEAR AVAILED
1341	17-Apr-22	BENGALURU	66	NRS 220 - REMCO MYSORE 1	VIJAYANAGARA	11:38	11:43	0:05	LINE CLEAR AVAILED
1342	17-Apr-22	BENGALURU	66	PALLICHERLU - ACME SOLAR IPP	NO STATION AFFECTED	18:37	18:57	0:20	LINE FAULT
1343	17-Apr-22	BENGALURU	66	SHOBHA FOREST - SUBRAMANYAPURA 220	SHOBHA FOREST	15:49	17:02	1:13	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1344	17-Apr-22	BENGALURU	66	SRS PEENYA 220 - NRS 2	MAHALAKSHMI LAYOUT	17:40	18:05	0:25	LINE FAULT
1345	17-Apr-22	BENGALURU	66	T G HALLI - MAGADI 220	T G HALLI	15:03	15:36	0:33	LINE FAULT
1346	17-Apr-22	BENGALURU	66	T G HALLI - MAGADI 220	V G DODDI, TAVARAKERE	15:03	15:40	0:37	LINE FAULT
1347	17-Apr-22	BENGALURU	220	HV1	JIGANI 220	12:35(16-4-2022)			TRANSFORMER OPEN : LINE CLEAR AVAILED
1348	17-Apr-22	BENGALURU	220	VRISHABHAVATHI 220 - KUMBALAGODU 220	NO STATION AFFECTED	20:48:00(16/04/2022)	10:35:00(17/04/2022)	14:27HRS	LINE CHARGED
1349	17-Apr-22	GULBARGA	66	HV1	BENNEHALLI_66	22:00	22:15	0:15	TRANSFORMER FAULT
1350	17-Apr-22	GULBARGA	66	HV1	TELALI_66	2:15	2:25	0:10	TRANSFORMER FAULT
1351	17-Apr-22	GULBARGA	66	HV2	HALVAGALU_66	9:00	9:05	0:05	TRANSFORMER FAULT
1352	17-Apr-22	GULBARGA	66	HV2	HALVAGALU_66	17:15	17:20	0:05	TRANSFORMER FAULT
1353	17-Apr-22	GULBARGA	66	HV2	HALVAGALU_66	17:40	20:50	3:10	TRANSFORMER FAULT
1354	17-Apr-22	GULBARGA	66	HV2	TAMBRAHALLI_66	17:05	17:10	0:05	TRANSFORMER FAULT
1355	17-Apr-22	GULBARGA	66	HV2	TAMBRAHALLI_66	21:20	21:30	0:10	TRANSFORMER FAULT
1356	17-Apr-22	GULBARGA	66	ITTAGI-BENNEHALLI	KOTTUR_66,UJJAINI_66,BENNEHALLI_66	21:59	22:11	0:12	LINE FAULT
1357	17-Apr-22	GULBARGA	66	ITTAGI-HUVINAHADAGALI	HUVINAHADGALI_66,HOLAGUNDI_66	20:03	20:15	0:12	LINE FAULT
1358	17-Apr-22	GULBARGA	66	SHAHAPUR-YADGIR	SAIDAPUR_110,YADGIR_110,KHANAPUR_110	2:30	2:35	0:05	LINE FAULT
1359	17-Apr-22	GULBARGA	66	SHAHAPUR-YADGIR	SAIDAPUR_110,YADGIR_110,KHANAPUR_110	3:24	3:28	0:04	LINE FAULT
1360	17-Apr-22	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURUGOD_110,SHATVAHANA_IPP,AGARWAL_IPP,SUZLON_IPP,KANAPUR_110,METRI_110,RBNS FACTORY	4:50	4:56	0:06	LINE FAULT
1361	17-Apr-22	GULBARGA	110	CHILKUMUKHI-BEVOOR	CHILKUMUKHI_110	19:37	20:02	0:25	MAIN SUPPLY FAILURE
1362	17-Apr-22	GULBARGA	110	HV1	CHINCHOLI_110	17:50	18:09	0:19	TRANSFORMER FAULT
1363	17-Apr-22	GULBARGA	110	HV1	YAKATPUR_110	7:40	8:10	0:30	LINE CLEAR AVAILED
1364	17-Apr-22	GULBARGA	110	HV1&2	MYLAR_110	11:35	12:05	0:30	LINE CLEAR AVAILED
1365	17-Apr-22	GULBARGA	110	HV2	YAKATPUR_110	11:25	11:35	0:10	TRANSFORMER FAULT
1366	17-Apr-22	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110,NSL SUGARS FACTORY	11:30	11:47	0:17	LINE FAULT
1367	17-Apr-22	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110,HIREGONNAGAR_110,HANUMANAL_110	18:39 (17.04.2022)			LINE OPEN:LINE FAULT
1368	17-Apr-22	GULBARGA	110	KUSTAGI-VAJRABANDI	VAJRABANDI_110	19:37	19:51	0:14	LINE FAULT
1369	17-Apr-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	5:08	5:15	0:07	LINE FAULT
1370	17-Apr-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	5:47	6:02	0:15	LINE FAULT
1371	17-Apr-22	GULBARGA	110	MYLAR-GUTTAL	MYLAR_110	6:40	6:55	0:15	MAIN SUPPLY FAILURE
1372	17-Apr-22	GULBARGA	110	NALWAR-SHAHPUR	NALWAR_110,SHAHAPUR_110	17:25	17:30	0:05	LINE FAULT
1373	17-Apr-22	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	19:46	19:51	0:05	LINE FAULT
1374	17-Apr-22	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	11:38	11:41	0:03	LINE FAULT
1375	17-Apr-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN :LINE CLEAR AVAILED
1376	17-Apr-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1377	17-Apr-22	GULBARGA	110	SHAHAPUR-SHAHPUR-2	NALWAR_110	17:23	17:29	0:06	LINE FAULT
1378	17-Apr-22	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SR NAGAR_110	1:47	3:29	1:42	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1379	17-Apr-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YE RDONA_110,SRNAGAR_110,MAL LAPURA_110	20:25(16.04.2022)	03:29(17.04.2022)	07:04HRS	LINE CHARGED
1380	17-Apr-22	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YE RDONA_110,SRNAGAR_110,MAL LAPURA_110	8:20	11:40	3:20	LINE CLEAR AVAILED
1381	17-Apr-22	GULBARGA	110	TEKKALKOTE-SHAHI SLR	TEKKALKOTE_110	19:48(17.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1382	17-Apr-22	GULBARGA	220	HV1	KUSTAGI_220	19:37	20:03	0:26	TRANSFORMER FAULT
1383	17-Apr-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
1384	17-Apr-22	GULBARGA	220	HV2	KUSTAGI_220	19:37	19:49	0:12	TRANSFORMER FAULT
1385	17-Apr-22	GULBARGA	400	RTPS-BTPS	RTPS_400	4:03	11:03	7:00	LINE FAULT
1386	17-Apr-22	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	3:18	8:35	5:17	LINE FAULT
1387	17-Apr-22	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	14:58	15:08	0:10	LINE FAULT
1388	17-Apr-22	HASSAN	66	HV1	MATTANAVILE_66	10:30	11:50	1:20	LINE CLEAR AVAILED
1389	17-Apr-22	HASSAN	66	HV1	MATTANAVILE_66	12:00	12:55	0:55	TRANSFORMER FAULT
1390	17-Apr-22	HASSAN	66	HV1	MATTANAVILE_66	13:05	13:25	0:20	LINE CLEAR AVAILED
1391	17-Apr-22	HASSAN	66	HV1	MATTANAVILE_66	16:30	17:00	0:30	LINE CLEAR AVAILED
1392	17-Apr-22	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN :LINE CLEAR AVAILED
1393	17-Apr-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN : LINE CLEAR AVAILED
1394	17-Apr-22	HASSAN	110	JOG110-LPH	JOG_110	15:45(16.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1395	17-Apr-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN :LINE CLEAR AVAILED
1396	17-Apr-22	HASSAN	110	LPH-MGHE 1	lph_gen	20:31 (10.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1397	17-Apr-22	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	18:05(16.04.2022)	11:53(17.04.2022)	17:49 hrs	LINE CHARGED
1398	17-Apr-22	HASSAN	220	GESOPA-TALGUPA2	gen_gerusoppa	16:04(15.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1399	17-Apr-22	HASSAN	220	KEMAR-Varahi2	KEMAR_220	21:14(13.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1400	17-Apr-22	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	15:41(16.04.2022)	13:22(17.04.2022)	21:40 hrs	LINE CHARGED
1401	17-Apr-22	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	3:05	18:40	15:35	LINE FAULT
1402	17-Apr-22	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	9:49(12.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1403	17-Apr-22	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	16:04(15.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1404	17-Apr-22	HASSAN	220	VARAHI-KEMAR1	gen_varahi	7:44	18:30	10:46	LINE CLEAR AVAILED
1405	17-Apr-22	HASSAN	220	VARAHI-KEMAR2	gen_varahi	21:14(13.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1406	17-Apr-22	HASSAN	220	VARAHI-SHIMOGA2	gen_varahi	3:05	18:40	15:35	LINE FAULT
1407	17-Apr-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN :LINE CLEAR AVAILED
1408	17-Apr-22	MYSURU	66	BEGUR 220-SARAGURU	NO STATIONS EFFECTED	16:58	17:08	0:10	LINE FAULT
1409	17-Apr-22	MYSURU	66	DB HALLI-TUBINAKERE	DODDABYADARAHALLI_66	10:49	11:28	0:38	LINE FAULT
1410	17-Apr-22	MYSURU	66	HANNUR-KOTHANURU	NO STATIONS EFFECTED	21:26	21:39	0:13	LINE FAULT
1411	17-Apr-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (8/12/2021)			LINE OPEN :LINE CLEAR AVAILED
1412	17-Apr-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	16:58:00 (13/12/2021)			LINE OPEN :LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1413	17-Apr-22	MYSURU	66	HV1	ARAKERE_66	11:47	11:56	0:09	LINE CLEAR AVAILED
1414	17-Apr-22	MYSURU	66	HV1	BEGUR_66	17:10	17:33	0:23	TRANSFORMER FAULT
1415	17-Apr-22	MYSURU	66	HV1	BEGUR_66	21:44	21:51	0:07	TRANSFORMER FAULT
1416	17-Apr-22	MYSURU	66	HV1	NAGAMANGALA_66	5:54	6:02	0:07	TRANSFORMER FAULT
1417	17-Apr-22	MYSURU	66	HV1	SANIVARASANTHE_66	15:29:47 (11.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
1418	17-Apr-22	MYSURU	66	KUNTHUR-D R PETE	JANNUR_66 MUGUR_66 SANTHEMARAHALLI_66 THAYURU_66 TNARASIPURA_66	12:45	12:52	0:07	LINE FAULT
1419	17-Apr-22	MYSURU	66	KUNTHUR-D R PETE	NO STATIONS EFFECTED	18:29	18:35	0:05	LINE FAULT
1420	17-Apr-22	MYSURU	66	MUGUR-CLEAN SOLAR	NO STATIONS EFFECTED	18:29	18:42	0:13	LINE FAULT
1421	17-Apr-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN :LINE CLEAR AVAILED
1422	17-Apr-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN :LINE CLEAR AVAILED
1423	17-Apr-22	MYSURU	220	MADHUVANAHALLI-HEBBANI 1	NO STATIONS EFFECTED	5:42	6:44	1:01	LINE FAULT
1424	17-Apr-22	TUMKUR	66	BEVINAHALLI- AFTL SOLAR_IPP_66	AFTL SOLAR_IPP_66	9:30	10:22	0:52	LINE FAULT
1425	17-Apr-22	TUMKUR	66	CHITRADURGA 66KV- PANDARAHALLI 1	CHITRADURGA_66 OLD MUSS,PANDARAHALLI_66,CHITR AHALLI_66,HDPURA_66,HOLALK ERE_66,RAMGIRI_66	5:59	6:51	0:52	LINE FAULT
1426	17-Apr-22	TUMKUR	66	HAGALWADI66-ANCHEPALYA220	HAGALWADI_66	11:01	12:04	1:03	LINE CLEAR AVAILED
1427	17-Apr-22	TUMKUR	66	HANAGAL-ASEP_SLR	ASEP_SLR_66	16:59	18:00	1:01	LINE CLEAR AVAILED
1428	17-Apr-22	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	9:15	9:20	0:04	LINE FAULT
1429	17-Apr-22	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	16:55	18:04	1:09	LINE FAULT
1430	17-Apr-22	TUMKUR	66	NAYAKANAHATTI66- HIREMALLANAHOLE66	NAYAKANHATTI_66, HIREMALLANAHOLE 66	18:01	18:25	0:23	LINE FAULT
1431	17-Apr-22	TUMKUR	66	PAVAGADA220-SHYLAPURA66	SHYLAPURA_66	4:13	4:32	0:18	LINE FAULT
1432	17-Apr-22	TUMKUR	66	TR-1	HAGALWADI_66	11:01	12:04	1:02	LINE CLEAR AVAILED
1433	17-Apr-22	TUMKUR	66	TR-1	LOKIKERE_66	20:13	20:15	0:02	TRANSFORMER FAULT
1434	17-Apr-22	TUMKUR	66	TR-1(LV SIDE)	PAVAGADA_220	4:13	4:24	0:10	TRANSFORMER FAULT
1435	17-Apr-22	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	15:33	20:34	5:00	LINE FAULT
1436	17-Apr-22	TUMKUR	220	TR-1	PAVAGADA_220	4:13	4:28	0:14	TRANSFORMER FAULT
1437	17-Apr-22	TUMKUR	220	TR-2	PAVAGADA_220	4:13	4:52	0:38	TRANSFORMER FAULT
1438	18-Apr-22	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED LOKAPUR_110	10:18	10:24	0:06	TRANSFORMER FAULT
1439	18-Apr-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MAMADAPUR(B)_110	12:53	13:00	0:07	TRANSFORMER FAULT
1440	18-Apr-22	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED LAXMESHWAR_110	10:56	12:10	1:14	TRANSFORMER FAULT
1441	18-Apr-22	BAGALKOT	110	110/11KV,HV1	BABALESHWAR_110	18:04 (16.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
1442	18-Apr-22	BAGALKOT	110	110/11KV,HV1	HIREMASALI_110	1:01	1:06	0:05	TRANSFORMER FAULT
1443	18-Apr-22	BAGALKOT	110	110/11KV,HV1	HIREMASALI_110	1:29	08:03	6:34	TRANSFORMER FAULT
1444	18-Apr-22	BAGALKOT	110	110/11KV,HV1	110/11KV,HV1	14:12	14:53	0:41	LINE CLEAR AVAILED
1445	18-Apr-22	BAGALKOT	110	110/11KV,HV1	SIRSI_220	11:02	13:34	2:32	LINE CLEAR AVAILED
1446	18-Apr-22	BAGALKOT	110	110/11KV,HV1	MANTUR_110	18:19	18:55	0:36	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1447	18-Apr-22	BAGALKOT	110	110/11KV,HV1	MAHALINGAPUR_220	18:20	18:50	0:30	TRANSFORMER FAULT
1448	18-Apr-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	2:35	2:43	0:08	TRANSFORMER FAULT
1449	18-Apr-22	BAGALKOT	110	110/11KV,HV2	ALMEL_110	19:19	19:24	0:05	TRANSFORMER FAULT
1450	18-Apr-22	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	18:38	18:44	0:06	TRANSFORMER FAULT
1451	18-Apr-22	BAGALKOT	110	110/11KV,HV2	STATION NOT AFFECTED RANEBENNUUR_220	20:52	21:02	0:10	TRANSFORMER FAULT
1452	18-Apr-22	BAGALKOT	110	110/11KV,HV2	SIRSI_220	11:02	13:38	2:36	LINE CLEAR AVALIED
1453	18-Apr-22	BAGALKOT	110	110/11KV,HV2	SHIROL_110	14:30	14:35	0:05	TRANSFORMER FAULT
1454	18-Apr-22	BAGALKOT	110	110/11KV,HV2	MAHALINGAPUR_220	18:20	19:14	0:54	TRANSFORMER FAULT
1455	18-Apr-22	BAGALKOT	110	110/33KV, HV2	HALLUR_33, MASUR_33 STATION NOT AFFECTED RATTIHALI_110	13:42	14:12	0:30	LINE CLEAR AVALIED
1456	18-Apr-22	BAGALKOT	110	110/33KV,HV1	HALLUR_110,JAGADAL_110,MAH ALINGAPUR_220	18:20	19:13	0:53	TRANSFORMER FAULT
1457	18-Apr-22	BAGALKOT	110	110/33KV,HV2	DEMPDAIRY_33,MALALI_33,M AHALINGAPUR_220	18:20	19:13	0:53	TRANSFORMER FAULT
1458	18-Apr-22	BAGALKOT	110	BAGALKOT-RAMDURG	STATION NOT AFFECTED BAGALKOT_220	16:32	16:37	0:05	LINE FAULT
1459	18-Apr-22	BAGALKOT	110	BIJAPUR220-KIADB2	KIADB BIJAPUR_110	18:04	18:07	0:03	HAND TRIPPED
1460	18-Apr-22	BAGALKOT	110	DRGMR-F1 CB(SHIRABUR)	DEVARGENNUR_110	17:20	18:57	1:37	MAIN SUPPLY FAILURE
1461	18-Apr-22	BAGALKOT	110	DRGMR-F2 CB(MAMADAPUR(B))	DEVARGENNUR_110	17:20	18:57	1:37	MAIN SUPPLY FAILURE
1462	18-Apr-22	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVKID(NARAGUND)	STATION NOT AFFECTED GOPANKOPPA_110	18:15 (24.06.2021)			LINE OPEN :LINE CLEAR AVALIED
1463	18-Apr-22	BAGALKOT	110	HIREMASALI-ATHARGA	HIREMASALI_110	1:01	1:06	0:05	LINE FAULT
1464	18-Apr-22	BAGALKOT	110	HIREMASALI-ATHARGA	HIREMASALI_110	1:29	8:03	6:34	LINE FAULT
1465	18-Apr-22	BAGALKOT	110	INDI220-HIREMASALI	HIREMASALI_110	1:01	1:06	0:05	LINE FAULT
1466	18-Apr-22	BAGALKOT	110	INDI220-HIREMASALI	HIREMASALI_110	1:29	08:03	6:34	LINE FAULT
1467	18-Apr-22	BAGALKOT	110	JAMBAGI-MUDHOL	MUDHOL_110	19:16	19:29	0:13	HAND TRIPPED
1468	18-Apr-22	BAGALKOT	110	JAMBAGI-VAJJRAMATTI220	JAMBAGI_110	19:16	19:19	0:03	HAND TRIPPED
1469	18-Apr-22	BAGALKOT	110	KIRUVATTI-AMBEWADI(SIRSI)	STATION NOT AFFECTED KIRUVATTI_110	6:30	18:39	12:09	LINE CLEAR AVALIED
1470	18-Apr-22	BAGALKOT	110	KONNUR-NAVALGUND	STATION NOT AFFECTED KONNUR_110	13:47 (17.04.2022)			LINE OPEN:LINE FAULT
1471	18-Apr-22	BAGALKOT	110	MAHALINGAPUR-DAVALESHWAR	DAVALESHWAR_110	18:20	19:17	0:57	LINE FAULT
1472	18-Apr-22	BAGALKOT	110	MAHALINGAPUR-GSML1	STATION NOT AFFECTED MAHALINGAPUR_220	18:20	19:20	1:00	LINE FAULT
1473	18-Apr-22	BAGALKOT	110	MAHALINGAPUR-GSML2	STATION NOT AFFECTED MAHALINGAPUR_220	5:30 (17.04.2022)	19:21 (18.04.2022)	37:51 hrs	LINE CHARGED
1474	18-Apr-22	BAGALKOT	110	MAHALINGAPUR-RANNABELAGALI	RANNABELAGALI_110	19:39	23:00	3:21	LINE FAULT
1475	18-Apr-22	BAGALKOT	110	MAHALINGAPUR-TERDAL	TERDAL_110	18:20	19:36	1:16	LINE FAULT
1476	18-Apr-22	BAGALKOT	110	MK HUBLI-MK HUBLI1	STATION NOT AFFECTED MK HUBLI_220	10:59 (31.03.2022)			LINE OPEN :LINE CLEAR AVALIED
1477	18-Apr-22	BAGALKOT	110	MUGALKHOD-HIDIKAL	MUGALKHOD_220	23:56 (18.04.2022)			LINE OPEN:LINE FAULT
1478	18-Apr-22	BAGALKOT	110	PG HUNSHYAL-MUDALAGI (NAGANUR)	STATION NOT AFFECTED PG HUNSHYAL_110	16:13 (04.03.2022)			LINE OPEN :LINE CLEAR AVALIED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1479	18-Apr-22	BAGALKOT	110	RANEENNUUR-(RATTIHALLI)TUMMINAKATTI	STATION NOT AFFECTED RANEENNUUR_220	23:09	23:22	0:13	LINE FAULT
1480	18-Apr-22	BAGALKOT	110	RANNABELAGALI-UTTUR	UTTUR_110	18:20	19:40	1:20	LINE FAULT
1481	18-Apr-22	BAGALKOT	110	RANNABELAGALI-UTTUR	RANNABELAGALI_110	18:30	19:40	1:10	LINE FAULT
1482	18-Apr-22	BAGALKOT	110	SAVALAGI-AIGALI	STATION NOT AFFECTED SAVALAGI_110	8:37	18:26	9:49	NFBC ISSUED
1483	18-Apr-22	BAGALKOT	110	SHIRAGUPPI-BILAGI	VAJRAMATTI_220,BILAGI_110,GI RISAGAR_110,TOLAMATTI_110 & BISNAL_110	17:30	19:15	1:45	LINE FAULT
1484	18-Apr-22	BAGALKOT	110	SIRSI- KUMATA2	STATION NOT AFFECTED SIRSI_110	9:08	18:47	9:39	LINE CLEAR AVAILED
1485	18-Apr-22	BAGALKOT	110	SIRSI220-UMMACHAGI	UMMACHAGI_110	11:01	13:35	2:34	LINE CLEAR AVAILED
1486	18-Apr-22	BAGALKOT	110	SIRSI-SIRSI1	SIRSI_110	10:06	18:22	8:16	NFBC ISSUED
1487	18-Apr-22	BAGALKOT	110	SIRSI-SIRSI2	SIRSI_110	10:06	18:22	8:16	NFBC ISSUED
1488	18-Apr-22	BAGALKOT	110	SOUDATTI110- ENERCON1	STATION NOT AFFECTED ENERCON_110 SOUDATTI_110	5:52	8:41	2:49	LINE FAULT
1489	18-Apr-22	BAGALKOT	110	SOUDATTI-MMCL	SOUNDATTI_220	4:58	5:46	0:48	LINE FAULT
1490	18-Apr-22	BAGALKOT	110	UDAYMBAG-MACHE	STATION NOT AFFECTED UDAYMBAG_110	10:10 (10.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1491	18-Apr-22	BAGALKOT	110	VAJRAMATTI-SIRAGUPPI	STATION NOT AFFECTED VAJRAMATTI_220	17:35	19:15	1:40	LINE FAULT
1492	18-Apr-22	BAGALKOT	220	220/110KV,HV1 & LV1	BIJAPUR_220	18:25	18:30	0:05	HAND TRIPPED
1493	18-Apr-22	BAGALKOT	220	220/110KV,HV1,LV1	SIRSI_220	11:02	13:29	2:27	LINE CLEAR AVAILED
1494	18-Apr-22	BAGALKOT	220	220/110KV,HV1,LV1	MAHALINGAPUR_220	18:20	18:44	0:24	TRANSFORMER FAULT
1495	18-Apr-22	BAGALKOT	220	220/110KV,HV2 & LV2	BIJAPUR_220	17:49	18:11	0:22	HAND TRIPPED
1496	18-Apr-22	BAGALKOT	220	220/110KV,LV2	MAHALINGAPUR_220	18:20	18:44	0:24	TRANSFORMER FAULT
1497	18-Apr-22	BAGALKOT	220	ATHANI-RVIURJA(KAKAMARI1)	STATION NOT AFFECTED ATHANI_220	16:34 (09.04.2022)			LINE OPEN:LINE FAULT
1498	18-Apr-22	BAGALKOT	220	ATHANI-RVIURJA(KAKAMARI2)	STATION NOT AFFECTED ATHANI_220	16:34 (09.04.2022)			LINE OPEN:LINE FAULT
1499	18-Apr-22	BAGALKOT	220	BIDNAL-HAVERI	STATION NOT AFFECTED BIDNAL_220	19:42 (17.04.2022)	9:17 (18.04.2022)	13:35 hrs	LINE CHARGED
1500	18-Apr-22	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:13 (03.03.2022)			LINE OPEN :LINE CLEAR AVAILED
1501	18-Apr-22	BAGALKOT	220	HAVERI- NARENDRA1(BIDNAL)	STATION NOT AFFECTED HAVERI_220	19:42 (17.04.2022)	9:17 (18.04.2022)	13:35 hrs	LINE CHARGED
1502	18-Apr-22	BAGALKOT	220	HAVERI-GUTTUR2	STATION NOT AFFECTED HAVERI_220	20:27 (18.04.2022)			LINE OPEN:LINE FAULT
1503	18-Apr-22	BAGALKOT	220	HUBLI-NAGJIHARI2	STATION NOT AFFECTED HUBLI_220	13:26	16:56	3:30	LINE CLEAR AVAILED
1504	18-Apr-22	BAGALKOT	220	HUBLI-NARENDRA2	STATION NOT AFFECTED HUBLI_220	11:48	17:36	5:48	LINE CLEAR AVAILED
1505	18-Apr-22	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	12:22	13:57	1:35	LINE CLEAR AVAILED
1506	18-Apr-22	BAGALKOT	220	NARENDRA- HUBLI1	NARENDRA_220	19:16 (17.04.2022)	19:40 (18.04.2022)	24:24 hrs	LINE CHARGED
1507	18-Apr-22	BAGALKOT	220	NARENDRA- HUBLI2	STATION NOT AFFECTED NARENDRA_220	11:48	19:35	7:47	LINE CLEAR AVAILED

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1508	18-Apr-22	BAGALKOT	220	RANEENNUR-BALLIGAVI	STATION NOT AFFECTED RANEENNUUR_220	14:57	22:27	7:30	LINE CLEAR AVAILED
1509	18-Apr-22	BAGALKOT	220	RANEENNUR-GUTTUR	STATION NOT AFFECTED RANEENNUUR_220	10:52	13:12	2:20	MAIN SUPPLY FAILURE
1510	18-Apr-22	BAGALKOT	220	RANEENNUR-GUTTUR	RANEENNUUR_220	22:35 (18.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1511	18-Apr-22	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	10:03 (16.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1512	18-Apr-22	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	10:03 (16.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1513	18-Apr-22	BAGALKOT	220	VAJRAMATTI-KUDAGI2	STATION NOT AFFECTED VAJARMATTI_220	17:56	18:35	0:39	LINE FAULT
1514	18-Apr-22	BENGALURU	66	BEGUR 220 - BIAL 1	NO STATION AFFECTED	20:15	20:57	0:42	LINE FAULT
1515	18-Apr-22	BENGALURU	66	BEGUR 220 - BIAL 2	AIRPORT	20:15	20:35	0:20	LINE FAULT
1516	18-Apr-22	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	20:15	21:01	0:46	LINE FAULT
1517	18-Apr-22	BENGALURU	66	BEGUR 220 - HOSKOTE	NO STATION AFFECTED	20:15(18-4-2022)			LINE OPEN:LINE FAULT
1518	18-Apr-22	BENGALURU	66	BEGUR 220 - ITC (EHT)	ITC (EHT)	20:15	20:35	0:20	LINE FAULT
1519	18-Apr-22	BENGALURU	66	BG ROAD - JIGANI LINK ROAD	JIGANI LINK ROAD	6:00	6:20	0:20	LINE FAULT
1520	18-Apr-22	BENGALURU	66	BOODIGERE - BEGUR 220	BOODIGERE	20:16	21:00	0:44	MAIN SUPPLY FAILURE
1521	18-Apr-22	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	VANDARGUPPE, CHANNAPATNA, SHIVANAHALLI	16:16	17:12	0:56	LINE FAULT
1522	18-Apr-22	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	18:01	18:34	0:32	LINE FAULT
1523	18-Apr-22	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	BOMMEPALLIC CROSS	18:48	19:04	0:16	LINE FAULT
1524	18-Apr-22	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	20:54	21:12	0:18	LINE FAULT
1525	18-Apr-22	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	20:54	21:26	0:31	LINE FAULT
1526	18-Apr-22	BENGALURU	66	DALSANUR - KOLAR 220	DALSANUR - YELDUR	14:25	14:35	0:10	LINE FAULT
1527	18-Apr-22	BENGALURU	66	GLOBAL TECH PARK - DEVARABISANAHALLI	GLOBAL TECH PARK	16:46	16:56	0:10	LOAD CHANGE OVER
1528	18-Apr-22	BENGALURU	66	HOODY 220 - HAL 1	BAGMANE WORLD TECH PARK	15:35	15:44	0:09	LINE FAULT
1529	18-Apr-22	BENGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	20:55	21:01	0:06	LOAD CHANGE OVER
1530	18-Apr-22	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	23:08	23:24	0:16	LINE FAULT
1531	18-Apr-22	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	23:29(18-4-2022)			LINE OPEN :LINE CLEAR AVAILED
1532	18-Apr-22	BENGALURU	66	HV1	BOODIGERE	13:00	13:03	0:03	LINE CLEAR AVAILED
1533	18-Apr-22	BENGALURU	66	HV1	MAHALAKSHMI LAYOUT	16:45	16:50	0:05	LOAD CHANGE OVER
1534	18-Apr-22	BENGALURU	66	HV1	BIAL BEGUR 220	20:15	21:19	1:04	TRANSFORMER FAULT
1535	18-Apr-22	BENGALURU	66	HV1	GANIJGUNTE	18:22	18:27	0:05	TRANSFORMER FAULT
1536	18-Apr-22	BENGALURU	66	HV1	CB PURA URBAN	10:06	10:15	0:08	LINE CLEAR AVAILED
1537	18-Apr-22	BENGALURU	66	HV1	CHAKAVELU	15:16	17:15	1:59	LINE CLEAR AVAILED
1538	18-Apr-22	BENGALURU	66	HV1	DALASNUR	10:17	14:32	4:15	LINE CLEAR AVAILED
1539	18-Apr-22	BENGALURU	66	HV1	MALLANAYAKANA HALLI	16:02	19:04	3:02	LINE CLEAR AVAILED
1540	18-Apr-22	BENGALURU	66	HV1	THAYALUR	14:10	14:34	0:24	LINE CLEAR AVAILED
1541	18-Apr-22	BENGALURU	66	HV2	KADUGODI	9:44	10:40	0:56	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1542	18-Apr-22	BENGALURU	66	HV2	RR NAGAR	10:38	10:42	0:04	LOAD CHANGE OVER
1543	18-Apr-22	BENGALURU	66	HV2	REMC0	10:35	10:38	0:03	LOAD CHANGE OVER
1544	18-Apr-22	BENGALURU	66	HV2	BIAL BEGUR 220	20:15	20:40	0:25	TRANSFORMER FAULT
1545	18-Apr-22	BENGALURU	66	HV2	CB PURA URBAN	12:45	12:50	0:05	TRANSFORMER FAULT
1546	18-Apr-22	BENGALURU	66	HV2	CHAKAVELU	14:33	15:00	0:26	LINE CLEAR AVAILED
1547	18-Apr-22	BENGALURU	66	HV2	HUKUNDA	17:41	17:49	0:08	TRANSFORMER FAULT
1548	18-Apr-22	BENGALURU	66	HV2	MALLASANDRA	11:34	12:12	0:37	LINE CLEAR AVAILED
1549	18-Apr-22	BENGALURU	66	HV2	THAYALUR	13:59	14:20	0:20	LINE CLEAR AVAILED
1550	18-Apr-22	BENGALURU	66	HV3	BANASHANKARI	12:12	12:15	0:03	LINE CLEAR AVAILED
1551	18-Apr-22	BENGALURU	66	HV3	BANASHANKARI	15:53	15:57	0:04	LOAD CHANGE OVER
1552	18-Apr-22	BENGALURU	66	JAGANI 220 - JIGANI 66	JIGANI 66	15:26	15:45	0:19	MAIN SUPPLY FAILURE
1553	18-Apr-22	BENGALURU	66	JAGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI, BAGANDODDI	15:26	16:06	0:40	MAIN SUPPLY FAILURE
1554	18-Apr-22	BENGALURU	66	KODIGEHALLI - SRS PEENYA 220	KODIGEHALLI	19:35	20:52	1:17	LINE FAULT
1555	18-Apr-22	BENGALURU	66	KOLAR 220 - MULBAGLU	NO STATION AFFECTED	19:20:00(14/04/2022)			LINE OPEN:LINE FAULT
1556	18-Apr-22	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	19:59	20:09	0:10	LINE FAULT
1557	18-Apr-22	BENGALURU	66	LV2	MALUR 220	12:09	13:00	0:51	MAIN SUPPLY FAILURE
1558	18-Apr-22	BENGALURU	66	MAGADI 220 - MAGADI 66	MAGADI 66, GUDEMARANAHALLI, HOSPALYA CIRCLE	19:08	19:33	0:24	LINE FAULT
1559	18-Apr-22	BENGALURU	66	MALUR 220 - HOSKOTE 1	NO STATION AFFECTED	19:07	19:58	0:51	LINE FAULT
1560	18-Apr-22	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	12:08	13:00	0:51	MAIN SUPPLY FAILURE
1561	18-Apr-22	BENGALURU	66	MALUR 220 - KGF 1	TEKAL, BUDIKOTE, TORLAKKI	12:08	13:00	0:52	MAIN SUPPLY FAILURE
1562	18-Apr-22	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT), KGF, KAMASAMUDRA	12:08	13:00	0:52	MAIN SUPPLY FAILURE
1563	18-Apr-22	BENGALURU	66	MALUR 220 - LAKKUR	DEVANGONDHI, LAKKUR	12:09	13:01	0:52	MAIN SUPPLY FAILURE
1564	18-Apr-22	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI	12:09	13:01	0:52	MAIN SUPPLY FAILURE
1565	18-Apr-22	BENGALURU	66	RMZ - VIKAS TECH PARK 220	RMZ	15:35	15:45	0:10	MAIN SUPPLY FAILURE
1566	18-Apr-22	BENGALURU	66	SRS PEENYA 220 - T G HALLI	BYDRAHALLI, KODIGEHALLI, SRIGANDAKAVALLU	18:02	19:36	1:34	LINE FAULT
1567	18-Apr-22	BENGALURU	66	TADIGOLU - CHINTAMANI 220	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	18:00	18:35	0:35	LINE FAULT
1568	18-Apr-22	BENGALURU	66	TALAGAWARA - Y HUNSENAHALLI	Y HUNSENAHALLI, CHEEMANGALA	18:44	19:14	0:30	LINE FAULT
1569	18-Apr-22	BENGALURU	66	TK HALLI 220 - SIMSHA	NO STATION AFFECTED	7:07	7:32	0:25	LINE FAULT
1570	18-Apr-22	BENGALURU	220	BUS COUPLER	BIAL BEGUR 220	20:15	20:33	0:18	LINE FAULT
1571	18-Apr-22	BENGALURU	220	HV1	BIAL BEGUR 220	20:15	20:34	0:19	TRANSFORMER FAULT
1572	18-Apr-22	BENGALURU	220	HV1	JIGANI 220	12:35(16-4-2022)			TRANSFORMER OPEN : LINE CLEAR AVAILED
1573	18-Apr-22	BENGALURU	220	HV2	MALUR 220	12:09	13:00	0:51	LINE CLEAR AVAILED
1574	18-Apr-22	BENGALURU	220	HV2	JIGANI 220	15:26	16:06	0:40	LINE CLEAR AVAILED
1575	18-Apr-22	GULBARGA	66	HV1	TAMBRAHALLI_66	8:55	9:00	0:05	TRANSFORMER FAULT
1576	18-Apr-22	GULBARGA	66	HV1	TAMBRAHALLI_66	8:50	9:00	0:10	TRANSFORMER FAULT
1577	18-Apr-22	GULBARGA	66	HV2	PUNABGHATA_66	14:50	16:50	2:00	LINE CLEAR AVAILED
1578	18-Apr-22	GULBARGA	66	KUDLIGI_220-KUDLIGI_66	HANSI_66,KUDLIGI_66	21:00	22:05	1:05	LINE CLEAR AVAILED
1579	18-Apr-22	GULBARGA	66	KUDLIGI-BANVIKAL	BANVIKAL_66	23:20	0:00	0:40	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1580	18-Apr-22	GULBARGA	66	KUDLIGI-GUDEKOTE	GUDEKOTE_66,CJ HALLI_66,HOSAHALLI_66	23:15	0:00	0:45	LINE FAULT
1581	18-Apr-22	GULBARGA	66	NEELAGUNDA-PUNABGHATTA	PUNABGHATTA_66,UCHCHANGI DURGA_66	16:10	16:18	0:08	LINE FAULT
1582	18-Apr-22	GULBARGA	66	NEELGUNDA-HALAVAGALU	HALAVAGALU_66	20:20	20:31	0:11	MAIN SUPPLY FAILURE
1583	18-Apr-22	GULBARGA	66	NEELGUNDA-HALAVAGALU	HALAVAGALU_66	21:10	21:24	0:14	MAIN SUPPLY FAILURE
1584	18-Apr-22	GULBARGA	66	TELAGI-KURUBARARHALLI	KURUBARARHALLI_66	21:25	21:35	0:10	MAIN SUPPLY FAILURE
1585	18-Apr-22	GULBARGA	66	TELAGI-YARAGUNTA	YARAGUNTA_66	20:15	20:40	0:25	MAIN SUPPLY FAILURE
1586	18-Apr-22	GULBARGA	110	BISILAHALLI-BELLARYNORTH	BISILAHALLI_110,PDHALLI_110	10:41	11:02	0:21	MAIN SUPPLY FAILURE
1587	18-Apr-22	GULBARGA	110	BISILAHALLI-BELLARYNORTH	BISILAHALLI_110,PDHALLI_110	11:09	14:15	3:06	MAIN SUPPLY FAILURE
1588	18-Apr-22	GULBARGA	110	HV1	YAKATPUR_110	13:50	14:25	0:35	LINE CLEAR AVAILED
1589	18-Apr-22	GULBARGA	110	HV2	KUSTAGI_220	15:08	15:13	0:05	TRANSFORMER FAULT
1590	18-Apr-22	GULBARGA	110	HV2	KUSTAGI_220	15:18	15:33	0:15	TRANSFORMER FAULT
1591	18-Apr-22	GULBARGA	110	HV2	KUSTAGI_220	16:19	16:28	0:09	TRANSFORMER FAULT
1592	18-Apr-22	GULBARGA	110	HV2	KUSTAGI_220	17:35	18:30	0:55	TRANSFORMER FAULT
1593	18-Apr-22	GULBARGA	110	HV2	BISILAHALLI_110	22:01	22:06	0:05	TRANSFORMER FAULT
1594	18-Apr-22	GULBARGA	110	HV2	YAKATPUR_110	12:45	13:00	0:15	TRANSFORMER FAULT
1595	18-Apr-22	GULBARGA	110	HV2	YAKATPUR_110	13:20	13:30	0:10	TRANSFORMER FAULT
1596	18-Apr-22	GULBARGA	110	HV2	SHAHAPUR_220	18:10	18:19	0:09	TRANSFORMER FAULT
1597	18-Apr-22	GULBARGA	110	HV4	YELBURGA_110	6:48	7:16	0:28	TRANSFORMER FAULT
1598	18-Apr-22	GULBARGA	110	KAPNOOR-GULBARGA WEST1	GULBARGA WEST_110,GULBARGA SOUTH_110	9:30	13:46	4:16	LINE CLEAR AVAILED
1599	18-Apr-22	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110,NSL SUGARS FACTORY	11:28	11:42	0:14	LINE FAULT
1600	18-Apr-22	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110,NSL SUGARS FACTORY	11:56	12:15	0:19	LINE FAULT
1601	18-Apr-22	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110,HIREGONN AGAR_110,HANUMANAL_110	18:39 (17.04.2022)	12:00 (18.04.2022)	17:21 HRS	LINE CHARGED
1602	18-Apr-22	GULBARGA	110	LINGASUGUR-HATTI	HATTI_110,MASKI_110,KAVITHA L_110,SOMANMARDI_IPP,GAME SHA_IPP	14:52	18:28	3:36	LINE CLEAR AVAILED
1603	18-Apr-22	GULBARGA	110	LINGASUGUR-HATTI	HATTI_110,MASKI_110,KAVITHA L_110,SOMANMARDI_IPP,GAME SHA_IPP	21:12(17.04.2022)	12:16(18.04.2022)	15:04HRS	LINE CHARGED
1604	18-Apr-22	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	1:18	1:26	0:08	LINE FAULT
1605	18-Apr-22	GULBARGA	110	RAICHUR-SHAHPUR1	GABBUR_110	20:11	21:08	0:57	LINE FAULT
1606	18-Apr-22	GULBARGA	110	RAICHUR-SHAHPUR1	GABBUR_110	22:30	22:44	0:14	LINE FAULT
1607	18-Apr-22	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	11:58	12:06	0:08	LINE FAULT
1608	18-Apr-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN :LINE CLEAR AVAILED
1609	18-Apr-22	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN :LINE CLEAR AVAILED
1610	18-Apr-22	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110, WADAGERA_110,SANNATHI_IPP, COREGREENSUGARS_IPP	10:55 (11.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1611	18-Apr-22	GULBARGA	110	TEKKALKOTE-AGNISOLAR_IPP	TEKKALKOTE_110	21:10	21:30	0:20	LINE FAULT
1612	18-Apr-22	GULBARGA	110	TEKKALKOTE-SHAHI SLR	TEKKALKOTE_110	19:48(17.04.2022)	0:20(18.04.2022)	4:55 hrs	LINE CHARGED
1613	18-Apr-22	GULBARGA	110	TEKKALKOTE-SHAHI SLR	TEKKALKOTE_110	1:00	2:20	1:20	LINE FAULT
1614	18-Apr-22	GULBARGA	110	TEKKALKOTE-SHAHI SLR	TEKKALKOTE_110	21:10	21:30	0:20	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1615	18-Apr-22	GULBARGA	110	TEKKALKOTE-SHAHI SLR	TEKKALKOTE_110	23:20(18.04.2022)			LINE OPEN:LINE FAULT
1616	18-Apr-22	GULBARGA	110	TEKKALKOTE-SHAHI SLR	TEKKALKOTE_110	23:20(18.04.2022)	2:35(19.04.2022)	3:15HRS	LINE CHARGED
1617	18-Apr-22	GULBARGA	220	HV1 LV1,HV2 LV2	LINGASUGUR_220	19:35	19:54	0:19	TRANSFORMER FAULT
1618	18-Apr-22	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
1619	18-Apr-22	GULBARGA	220	LINGASUGUR-SINDHANOOR	LINGASUGUR_220	17:44	18:25	0:41	LINE FAULT
1620	18-Apr-22	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	5:15	5:50	0:35	LINE FAULT
1621	18-Apr-22	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	6:03	8:03	2:00	LINE CLEAR AVAILED
1622	18-Apr-22	GULBARGA	220	SINDHANOOR-SULEKAL	SINDHANOOR_220	17:44	18:13	0:29	LINE FAULT
1623	18-Apr-22	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	19:40	20:30	0:50	LINE FAULT
1624	18-Apr-22	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	15:05	16:35	1:30	LINE FAULT
1625	18-Apr-22	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	15:05	16:32	1:27	LINE FAULT
1626	18-Apr-22	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	15:05	16:30	1:25	LINE FAULT
1627	18-Apr-22	HASSAN	66	HV1	MATTANAVILE_66	11:50	12:10	0:20	HAND TRIPPED
1628	18-Apr-22	HASSAN	66	HV1	MATTANAVILE_66	15:20	17:15	1:55	LINE CLEAR AVAILED
1629	18-Apr-22	HASSAN	66	MRSSHM-BD-1	MRSMG_220	15:05	16:30	1:25	LINE FAULT
1630	18-Apr-22	HASSAN	66	MRSSHM-BD-2	MRSMG_220	15:05	16:29	1:24	LINE FAULT
1631	18-Apr-22	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	12:41(11.03.2022)			LINE OPEN :LINE CLEAR AVAILED
1632	18-Apr-22	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	11:55	14:25	2:30	LINE CLEAR AVAILED
1633	18-Apr-22	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	11:55	14:25	2:30	LINE CLEAR AVAILED
1634	18-Apr-22	HASSAN	66	SHANTI-RMSWRNGR	SHANTHIGRAMA_66	6:05	6:10	0:05	LINE FAULT
1635	18-Apr-22	HASSAN	110	ARSK2-GANDASI	ARASIKERE_220	18:20 (18.04.2022)			LINE OPEN:LINE FAULT
1636	18-Apr-22	HASSAN	110	HV1	JOG_110	13:40	16:45	3:05	LINE CLEAR AVAILED
1637	18-Apr-22	HASSAN	110	HV2	JOG_110	13:40	16:45	3:05	LINE CLEAR AVAILED
1638	18-Apr-22	HASSAN	110	HV3	JOG_110	10:55(05.04.2022)			TRANSFORMER OPEN : LINE CLEAR AVAILED
1639	18-Apr-22	HASSAN	110	HV4	KAVOOR_220	9:13	17:40	8:27	LINE CLEAR AVAILED
1640	18-Apr-22	HASSAN	110	JOG110-AMBTR1	JOG_110	13:45	17:15	3:30	LINE CLEAR AVAILED
1641	18-Apr-22	HASSAN	110	JOG110-AMBTR2	JOG_110	13:45	17:15	3:30	LINE CLEAR AVAILED
1642	18-Apr-22	HASSAN	110	JOG110-LPH	JOG_110	15:45(16.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1643	18-Apr-22	HASSAN	110	JOG110-MGHE	JOG_110	13:45	16:40	2:55	LINE CLEAR AVAILED
1644	18-Apr-22	HASSAN	110	JOG-NK2	mghejog_gen	17:05(28.03.2022)			LINE OPEN :LINE CLEAR AVAILED
1645	18-Apr-22	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	10:36	12:42	2:06	LINE CLEAR AVAILED
1646	18-Apr-22	HASSAN	110	LPH-MGHE 1	lph_gen	20:31 (10.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1647	18-Apr-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	10:42	11:00	0:18	LINE FAULT
1648	18-Apr-22	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	23:09	23:16	0:07	LINE FAULT
1649	18-Apr-22	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	10:42	10:59	0:17	LINE FAULT
1650	18-Apr-22	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	23:09	23:16	0:07	LINE FAULT
1651	18-Apr-22	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	10:40	11:05	0:25	LINE FAULT
1652	18-Apr-22	HASSAN	220	ARSK2-HSN	ARASIKERE_220	18:20 (18.04.2022)			LINE OPEN:LINE FAULT
1653	18-Apr-22	HASSAN	220	GESOPA-TALGUPA2	gen_gerusoppa	16:04(15.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1654	18-Apr-22	HASSAN	220	HV1	SHIRALKOPPA_220	10:42	10:55	0:13	TRANSFORMER FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1655	18-Apr-22	HASSAN	220	HV2	SHIRALKOPPA_220	10:42	10:57	0:15	TRANSFORMER FAULT
1656	18-Apr-22	HASSAN	220	MRSSHM-STRP1	MRSMG_220	15:11	15:43	0:32	LINE FAULT
1657	18-Apr-22	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	16:04(15.04.2022)			LINE OPEN :LINE CLEAR AVAILED
1658	18-Apr-22	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:15 (29.03.2022)			LINE OPEN :LINE CLEAR AVAILED
1659	18-Apr-22	MYSURU	66	BG NAGAR-YEDIYUR	ADICHUNCHANAGIRI_66 VADERALLI_66	21:00	21:04	0:04	LINE FAULT
1660	18-Apr-22	MYSURU	66	CHUNCHUNKATTE-RAVANDUR	NO STATIONS EFFECTED	18:16	21:23	3:07	LINE FAULT
1661	18-Apr-22	MYSURU	66	CR NAGAR-GUNDLUPETE	NO STATIONS EFFECTED	19:39	19:49	0:09	LINE FAULT
1662	18-Apr-22	MYSURU	66	CR NAGAR-KABBALLI	NO STATIONS EFFECTED	19:39	19:50	0:10	LINE FAULT
1663	18-Apr-22	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16:00 (8/12/2021)			LINE OPEN :LINE CLEAR AVAILED
1664	18-Apr-22	MYSURU	66	HEBBANI-SFC 8	NO STATIONS EFFECTED	5:56	6:17	0:21	LINE FAULT
1665	18-Apr-22	MYSURU	66	HEBBANI-SHIMSHA	MALAVALLI_66 HADLI_66	7:07	7:14	0:07	LINE FAULT
1666	18-Apr-22	MYSURU	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	16:58:00 (13/12/2021)			LINE OPEN :LINE CLEAR AVAILED
1667	18-Apr-22	MYSURU	66	HV1	HAMPAPURA_66	10:27	13:21	2:53	LINE CLEAR AVAILED
1668	18-Apr-22	MYSURU	66	HV1	HANGALA_66	12:41	13:43	1:02	LINE CLEAR AVAILED
1669	18-Apr-22	MYSURU	66	HV1	KIADB SOMANAHALLI_66	9:35	10:55	1:20	LINE CLEAR AVAILED
1670	18-Apr-22	MYSURU	66	HV1	SANIVARASANTHE_66	15:29:47 (11.04.2022)			TRANSFORMER OPEN: TRANSFORMER FAULT
1671	18-Apr-22	MYSURU	66	HV2	HANGALA_66	13:43	14:52	1:09	LINE CLEAR AVAILED
1672	18-Apr-22	MYSURU	66	HV2	HUNSUR_66	16:06	16:16	0:10	LINE CLEAR AVAILED
1673	18-Apr-22	MYSURU	66	JAKKANAHALLI-NAGMANGLA	G MALLIGERE_66	19:48	20:07	0:18	LINE FAULT
1674	18-Apr-22	MYSURU	66	KR PETE 220-CR PATNA	ANEGOLAL_66 KRISHNAPURA_66	13:45	13:56	0:11	LINE FAULT
1675	18-Apr-22	MYSURU	66	KR PETE 220-CR PATNA	ANEGOLAL_66 KRISHNAPURA_66	19:53	20:09	0:16	LINE FAULT
1676	18-Apr-22	MYSURU	66	KR PETE 220-KR PETE1	NO STATIONS EFFECTED	13:45	13:54	0:08	LINE FAULT
1677	18-Apr-22	MYSURU	66	KR PETE 220-KR PETE1	NO STATIONS EFFECTED	19:54	20:13	0:19	LINE FAULT
1678	18-Apr-22	MYSURU	66	KR PETE-HUYGONALLY2	KRPETE_66 AKKIHEBBAL_66 KIKKERI_66	13:45	13:56	0:10	LINE FAULT
1679	18-Apr-22	MYSURU	66	KR PETE-HUYGONALLY2	KRPETE_66 AKKIHEBBAL_66 KIKKERI_66	19:54	20:15	0:21	LINE FAULT
1680	18-Apr-22	MYSURU	66	KUSHALNAGARA-BETTADAPURA	BETTADHAPURA_66 KITTUR_66 RAVANDUR_66 CHUNCHUNKATTE_66	17:10	17:49	0:39	LINE FAULT
1681	18-Apr-22	MYSURU	66	KUSHALNAGARA-MYSORE1	BILIKERE_66 KRNAGARA_66GGVUDI_66DMG _HALLI_66 MIRLE_66	17:17	17:57	0:39	LINE FAULT
1682	18-Apr-22	MYSURU	66	LOKKANAHALLY-P G PALYA	PG PALYA_66	18:30	18:35	0:05	LINE FAULT
1683	18-Apr-22	MYSURU	66	MUGUR-THAYURU	THAYURU_66 TNARASIPURA_66	5:03	5:08	0:05	LINE FAULT
1684	18-Apr-22	MYSURU	66	NAGAMANGALA-NAGMANGLA1	NO STATIONS EFFECTED	15:22	16:08	0:46	LINE CLEAR AVAILED
1685	18-Apr-22	MYSURU	66	NAGAMANGALA-NAGMANGLA2	NAGAMANGALA_66	13:58	14:35	0:37	LINE CLEAR AVAILED
1686	18-Apr-22	MYSURU	66	NAGAMANGALA-TUBINKERE2	NO STATIONS EFFECTED	13:58	14:35	0:37	LINE CLEAR AVAILED
1687	18-Apr-22	MYSURU	66	SFC SIVA-PGL	NO STATIONS EFFECTED	5:57	6:10	0:12	LINE FAULT

SL NO	Dinanka	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REMARKS
1688	18-Apr-22	MYSURU	66	SFC SIVA-PGL	NO STATIONS EFFECTED	7:07	7:14	0:07	LINE FAULT
1689	18-Apr-22	MYSURU	66	SRIRANGAPATNA-GUKKADA	SRIRANGAPATNA_66	6:24	17:42	11:18	LINE CLEAR AVAILED
1690	18-Apr-22	MYSURU	66	TUBINKERE-GUKKADA	SRIRANGAPATNA_66 G UKKADA 66	23:08	23:14	0:05	LINE FAULT
1691	18-Apr-22	MYSURU	220	HEBBANI-T K HALLI 1	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN :LINE CLEAR AVAILED
1692	18-Apr-22	MYSURU	220	HEBBANI-T K HALLI 2	NO STATIONS EFFECTED	14:37:00 (20.03.2022)			LINE OPEN :LINE CLEAR AVAILED
1693	18-Apr-22	MYSURU	220	NAGAMANGALA 220kV- ANCHEPALYA 1	NAGAMANGALA_66 GUDDENAHALLI_66 BOGADHI_66 KOPPA_66 BESAGARAHALLI_66 DUNDANAHALLI_66	13:10	14:02	0:52	HAND TRIPPED
1694	18-Apr-22	MYSURU	220	NAGAMANGALA 220kV- ANCHEPALYA 2	NO STATIONS EFFECTED	13:10	14:02	0:52	HAND TRIPPED
1695	18-Apr-22	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	19:17	19:24	0:07	LINE FAULT
1696	18-Apr-22	TUMKUR	220	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE 66	19:51	20:29	0:38	LINE FAULT
1697	18-Apr-22	TUMKUR	220	ANCHEPALYA 220kV- KUNIGAL66	YEDIYUR_66,THIPPUR_,JIDDEGER E 66	19:52	20:31	0:39	LINE FAULT
1698	18-Apr-22	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA 2(MAGADI)	ANCHEPALYA_220	13:41	14:02	0:21	LINE FAULT
1699	18-Apr-22	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA-1	ANCHEPALYA_220	13:41	14:01	0:20	LINE FAULT
1700	18-Apr-22	TUMKUR	220	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66,KADAJJI_66,M ELEKATTE 66	20:06	21:04	0:58	LINE FAULT
1701	18-Apr-22	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	20:07	23:59	3:52	LINE FAULT
1702	18-Apr-22	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	21:00(18.4.22)			LINE OPEN:LINE FAULT
1703	18-Apr-22	TUMKUR	220	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	20:06	21:04	0:58	LINE FAULT
1704	18-Apr-22	TUMKUR	220	NITTUR 220-ARASIKERE	NITTUR_220	18:20	23:59	5:39	LINE CLEAR AVAILED
1705	18-Apr-22	TUMKUR	220	TR1	ANCHEPALYA 220	13:12	13:57	0:45	LINE CLEAR AVAILED
1706	18-Apr-22	TUMKUR	220	TR1	ANCHEPALYA 220	20:31	21:04	0:33	TRANSFORMER FAULT
1707	18-Apr-22	TUMKUR	220	TR2	ANCHEPALYA 220	13:35	13:51	0:16	LINE CLEAR AVAILED
1708	18-Apr-22	TUMKUR	220	TRI	DAVANGERE_SRS_220	20:05			TRANSFORMER OPEN : LINE CLEAR AVAILED
1709	18-Apr-22	TUMKUR	400	TR1	JAGLUR_400	9:53	18:31	8:38	LINE CLEAR AVAILED