

400/220/110/66 kV TRANSMISSION OUTAGES: 11.08.2020 to 17.08.2020

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	11-Aug-20	BAGALKOT	66	HONNALLI(BANUVALLI-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020)			LINE OPEN:LINE CLEAR AVAILED
2	11-Aug-20	BAGALKOT	110	110/11KV, HV1	SAIDAPUR_110	3:55	9:31	5:36	TRANSFORMER FAULT
3	11-Aug-20	BAGALKOT	110	110/11KV, HV2	TIKOTA_110	12:52	13:01	0:09	TRANSFORMER FAULT
4	11-Aug-20	BAGALKOT	110	110/11KV, HV2	SHIROL_110	12:01	14:05	2:04	LINE CLEAR AVAILED
5	11-Aug-20	BAGALKOT	110	110/11KV, HV2	MUKARTIHAL_110	13:58	14:11	0:13	TRANSFORMER FAULT
6	11-Aug-20	BAGALKOT	110	110/11KV,HV 4	BELGAUM_110	11:52	13:54	2:02	LINE CLEAR AVAILED
7	11-Aug-20	BAGALKOT	110	110/11KV,HV1	BEDI_110	11:43	15:13	3:30	LINE CLEAR AVAILED
8	11-Aug-20	BAGALKOT	110	110/33KV,HV4	GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
9	11-Aug-20	BAGALKOT	110	220/110KV, LV2	MKHUBLI_220	20:00 (11.08.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
10	11-Aug-20	BAGALKOT	110	AMBEWADI-(NK2)KAVALWADA	KAVALWADA_110	6:30	13:46	7:16	LINE FAULT
11	11-Aug-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN:LINE CLEAR AVAILED
12	11-Aug-20	BAGALKOT	110	BELLATTI-AB SOLAR	BELLATTI_110	5:59	19:10	13:11	LINE CLEAR AVAILED
13	11-Aug-20	BAGALKOT	110	BELLATTI-ENERCON 2	BELLATTI_110	5:58	19:36	13:38	LINE CLEAR AVAILED
14	11-Aug-20	BAGALKOT	110	GADAG-BETAGERI	BETAGERI_110, NAREGAL_110	13:41	14:04	0:23	LINE FAULT
15	11-Aug-20	BAGALKOT	110	GADAG-SHIRAHATTI & LAXMESWAR	SHIRAHATTI_110 LAXMESWAR_110	6:00	18:22	12:22	LINE CLEAR AVAILED
16	11-Aug-20	BAGALKOT	110	GAJENDRAGAD-KUSTAGI	STATION NOT AFFECTED GAJENDRAGAD_110	7:40 19.07.2020)			LINE OPEN:LINE CLEAR AVAILED
17	11-Aug-20	BAGALKOT	110	GAMESHA- RON	RON_110	14:16	14:29	0:13	HAND TRIPPED
18	11-Aug-20	BAGALKOT	110	GMR SUGARS- HALIYAL	HALIYAL_110	7:16	8:06	0:50	LINE CLEAR AVAILED
19	11-Aug-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN:LINE CLEAR AVAILED
20	11-Aug-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:0 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
21	11-Aug-20	BAGALKOT	110	HAVERI220- SAVANUR	SAVANUR_110	11:35	13:23	1:48	LINE CLEAR AVAILED
22	11-Aug-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
23	11-Aug-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
24	11-Aug-20	BAGALKOT	110	NAREGAL- RON	RON_110	13:48	14:01	0:13	HAND TRIPPED
25	11-Aug-20	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
26	11-Aug-20	BAGALKOT	110	SIRSI 220-SIRSI2	SIRSI_220	15:50 (10.08.2020)			LINE OPEN:LINE CLEAR AVAILED
27	11-Aug-20	BAGALKOT	110	SIRSI-KUMATA2	STATION NOT AFFECTED SIRSI_110	17:07 (07.08.2020)			LINE OPEN:LINE FAULT
28	11-Aug-20	BAGALKOT	110	SIRSI-KUMATA2	SIRSI_110	11:45:00 AM (10.08.2020)	12:06 (11.08.2020)	24:21hrs	LINE CHARGED
29	11-Aug-20	BAGALKOT	110	TODALBAGI-JAMAKHANDI	JAMAKHANDI_110	6:25	7:06	0:41	LINE FAULT
30	11-Aug-20	BAGALKOT	110	TODALBAGI-JAMAKHANDI	JAMAKHANDI_110	11:24	13:33	2:09	LINE CLEAR AVAILED
31	11-Aug-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
32	11-Aug-20	BAGALKOT	220	220/110KV,HV 1,&LV 1	GADAG_220	11:26	17:47	6:21	LINE CLEAR AVAILED
33	11-Aug-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN:LINE FAULT
34	11-Aug-20	BAGALKOT	220	BAGEWADI-ATRIA 2	BAGEWADI_220	17:00 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
35	11-Aug-20	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	17:26 (24.07.2020)			LOAD CURTAILMENT
36	11-Aug-20	BAGALKOT	220	BELGAUM- NARENDRA2 (KANABARGI2)	BELGAUM_220	22:18 (04.08.2020)			LINE OPEN:LINE CLEAR AVAILED
37	11-Aug-20	BAGALKOT	220	BELGAUM-CHIKKODI 2	BELGAUM_220	23:05 (10.8.2020)	9:30 (11.08.2020)	10:25hrs	LINE CHARGED
38	11-Aug-20	BAGALKOT	220	BIDNAL-HARTI1	BIDNAL_220	9:11:00 AM (7.8.2020)			LOAD CURTAILMENT
39	11-Aug-20	BAGALKOT	220	BIDNAL-HARTI2	BIDNAL_220	16:22 (7.8.2020)			LOAD CURTAILMENT
40	11-Aug-20	BAGALKOT	220	GADAG-HARTI1	GADAG_220	15:00 (10.8.2020)			LINE OPEN:LINE CLEAR AVAILED
41	11-Aug-20	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	16:57 (10.08.2020)			LINE OPEN:LINE CLEAR AVAILED
42	11-Aug-20	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	18:35 (07.08.2020)			LINE OPEN:LINE FAULT
43	11-Aug-20	BAGALKOT	220	SHARAVATY 2-SIRSI	SIRSI_220	5:24:00 PM (10.8.2020)			LOAD CURTAILMENT
44	11-Aug-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
45	11-Aug-20	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	08:52	09:05	00:13	LINE FAULT
46	11-Aug-20	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	16:32	16:36	00:04	LINE FAULT
47	11-Aug-20	BENGALURU	66	HV1	KANAKAPURA 66	12:40	12:45	00:05	LINE CLEAR AVAILED
48	11-Aug-20	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN:LINE FAULT
49	11-Aug-20	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)	17:17(11/08/2020)	1018:27H RS	TRANSFORMER CHARGED
50	11-Aug-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN:LINE FAULT
51	11-Aug-20	GULBARGA	66	HV1	HANASI_66	09:40	09:45	00:05	LINE CLEAR AVAILED
52	11-Aug-20	GULBARGA	66	HV1	HANASI_66	10:15	10:25	00:10	LINE CLEAR AVAILED
53	11-Aug-20	GULBARGA	66	HV1	HANASI_66	12:45	13:30	00:45	LINE CLEAR AVAILED
54	11-Aug-20	GULBARGA	110	GURUMITKAL-KONKAL_110	KONKAL_110	05:10	05:25	00:15	LINE FAULT
55	11-Aug-20	GULBARGA	110	HV1	KOLHAR_110	15:35	16:10	00:35	LINE CLEAR AVAILED
56	11-Aug-20	GULBARGA	110	HV1	KOLHAR_110	17:30	18:55	01:25	LINE CLEAR AVAILED
57	11-Aug-20	GULBARGA	110	HV2	SHORAPUR_110	19:42	20:06	00:24	TRANSFORMER FAULT
58	11-Aug-20	GULBARGA	110	HV2	SHORAPUR_110	23:12	23:36	00:24	TRANSFORMER FAULT
59	11-Aug-20	GULBARGA	110	HV2	YEDRAMI_110	18:35	19:10	00:35	TRANSFORMER FAULT
60	11-Aug-20	GULBARGA	110	SHAHPUR-KHANAPUR	KHANAPUR_110, SAIDAPUR_110, WADAGERA_110, SANNATI_110, NALWAR_110	02:25	02:35	00:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
61	11-Aug-20	GULBARGA	110	SHAHPUR-SHAHPUR1	NO STATION AFFECTED	12:15(5.8.2020)			LINE OPEN:LINE CLEAR AVAILED
62	11-Aug-20	GULBARGA	110	SHAHPUR-SHORAPUR	SHORAPUR_110	19:40	19:50	00:10	LINE FAULT
63	11-Aug-20	GULBARGA	110	SHAHPUR-SHORAPUR	SHORAPUR_110	23:10	23:21	00:11	LINE FAULT
64	11-Aug-20	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SIDHANOOR_220	00:36	00:41	00:05	LINE FAULT
65	11-Aug-20	GULBARGA	110	SINDHANOOR-SIRUGUPPA	DHADESUGUR_110, SIRUGUPPA_110, TEKKALKOTE_110, NSLSUGARS_IPP	17:30	17:45	00:15	LINE FAULT
66	11-Aug-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN:LINE CLEAR AVAILED
67	11-Aug-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN:LINE FAULT
68	11-Aug-20	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	10:42(11/8/2020)			LINE OPEN:LINE CLEAR AVAILED
69	11-Aug-20	HASSAN	66	HASSN220-HSN66	HASSAN_220	10:19	10:25	00:06	HAND TRIPPED
70	11-Aug-20	HASSAN	66	HV1	MAGGE_66	13:40	14:10	00:30	MAIN SUPPLY FAILURE
71	11-Aug-20	HASSAN	66	HV2	HOLALUR_66	09:50	12:13	02:23	LINE CLEAR AVOIDED
72	11-Aug-20	HASSAN	66	HV2	MAGGE_66	13:40	14:10	00:30	MAIN SUPPLY FAILURE
73	11-Aug-20	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	13:40	14:00	00:20	HAND TRIPPED
74	11-Aug-20	HASSAN	66	SAKALE-HASSAN	SAKLESHPURA_66	13:40	14:00	00:20	HAND TRIPPED
75	11-Aug-20	HASSAN	66	TAVAREC-HONNALLI	TAVARECHANAHALLI_66	11:13	11:55	00:42	LINE FAULT
76	11-Aug-20	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	14:11	14:20	00:09	LINE FAULT
77	11-Aug-20	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	10:38	13:02	02:24	LINE CLEAR AVOIDED
78	11-Aug-20	HASSAN	110	HV1	KAVOOR_220	06:15	06:24	00:09	HAND TRIPPED
79	11-Aug-20	HASSAN	110	HV1	SAGARA_110	12:00	12:10	00:10	LINE CLEAR AVOIDED
80	11-Aug-20	HASSAN	110	HV2	HOSANGADI_110	11:59	12:44	00:45	LINE CLEAR AVOIDED
81	11-Aug-20	HASSAN	110	HV2	KARAYA_110	07:39	13:05	05:26	TRANSFORMER FAULT
82	11-Aug-20	HASSAN	110	HV2	NAVUNDA_110	09:16	10:05	00:49	LINE CLEAR AVOIDED
83	11-Aug-20	HASSAN	110	JOG-JLT4	mghejog_gen	0:33 (10.08.2020)	12:35 (11.08.2020)	13:08hrs	LINE CHARGED
84	11-Aug-20	HASSAN	110	JOG-NK2	mghejog_gen	23:36 (7.08.2020)			LINE OPEN:LINE CLEAR AVAILED
85	11-Aug-20	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	10:38	13:02	02:24	LINE CLEAR AVOIDED
86	11-Aug-20	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	08:32	08:45	00:13	LINE FAULT
87	11-Aug-20	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	12:22	15:51	03:29	LINE CLEAR AVOIDED
88	11-Aug-20	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	14:41	16:00	01:19	LINE CLEAR AVOIDED
89	11-Aug-20	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	14:25 (10.08.2020)			LINE OPEN:LINE CLEAR AVAILED
90	11-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:06 (10.08.2020)	9:23 (11.08.2020)	10:17hrs	LINE CHARGED
91	11-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:17 (11.08.2020)			LINE OPEN:LINE CLEAR AVAILED
92	11-Aug-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:56 (7.08.2020)			LINE OPEN:LINE CLEAR AVAILED
93	11-Aug-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	16:21 (5.08.2020)			LINE OPEN:LINE CLEAR AVAILED
94	11-Aug-20	MYSURU	66	DEVNUR(N'GUD)-KADAKOLA	DEVANOORNGUDU_66	11:17	18:39	7:22	LINE CLEAR AVOIDED
95	11-Aug-20	MYSURU	66	HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	2:47 (06.08.2020)			LINE OPEN:LINE FAULT
96	11-Aug-20	MYSURU	66	HEBBANI-VADKEPURA	KIRUGAVALU_66 VADKEPURA_66	13:47	14:03	0:16	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
97	11-Aug-20	MYSURU	66	HV1	HANNUR_66	15:36	15:41	0:05	LINE CLEAR AVAILED
98	11-Aug-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
99	11-Aug-20	MYSURU	66	HV2	HANAGODU_66	16:18	17:29	1:10	LINE CLEAR AVAILED
100	11-Aug-20	MYSURU	66	KUSHALNAGARA 220-SUNTIKOPPA	NO STATIONS EFFECTED	10:43 (07.08.2020)			LINE OPEN:LINE CLEAR AVAILED
101	11-Aug-20	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS INTERRUPTED	13:50	13:55	0:05	LINE FAULT
102	11-Aug-20	MYSURU	66	SINDUVALLY-KADKOLA	NO STATIONS EFFECTED	7:40 (09.08.2020)			LINE OPEN:LINE CLEAR AVAILED
103	11-Aug-20	MYSURU	66	SUNTIKOPPA-KUSHALNAGAR	NO STATIONS EFFECTED	23:10 (06.08.2020)			LINE OPEN:LINE CLEAR AVAILED
104	11-Aug-20	MYSURU	66	SUTTUR-DEVNUR(N'GUD)	SUTTUR_66	10:09	17:31	7:22	LINE CLEAR AVAILED
105	11-Aug-20	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66 MANDYA_66	16:25	16:55	0:30	LINE CLEAR AVAILED
106	11-Aug-20	MYSURU	66	TUBINKERE-MC-2	CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66 KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADII_66 MANDYA_66	12:40	12:50	0:10	LINE FAULT
107	11-Aug-20	MYSURU	66	TUBINKERE-MC-4	CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66 KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADII_66 MANDYA_66	12:40	12:50	0:10	LINE FAULT
108	11-Aug-20	MYSURU	220	HOOTAGALLI-BASTIPURA 2	NO STATIONS EFFECTED	11:57	14:15	2:18	LINE CLEAR AVAILED
109	11-Aug-20	MYSURU	220	HOOTAGALLI-VAJMANGALA	NO STATIONS EFFECTED	9:55	14:15	4:19	LINE CLEAR AVAILED
110	11-Aug-20	MYSURU	220	HV 1	CRNAGAR_220	12:10	12:25	0:15	HAND TRIPPED
111	11-Aug-20	MYSURU	220	HV 2	CRNAGAR_220	12:28	12:32	0:04	HAND TRIPPED
112	11-Aug-20	MYSURU	220	KADAKOLA-CR NAGARA 1	NO STATIONS EFFECTED	11:43	17:52	6:09	NFBC ISSUED
113	11-Aug-20	TUMKUR	66	ANCHEPALYA 220kV- ANCHEPALYA1	ANCHEPALYA_66, BHAKTHARAHALLI_66, THIMMASANDRA_66	14:55	15:32	0:36	LINE FAULT
114	11-Aug-20	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	4:34	4:50	0:15	LINE FAULT
115	11-Aug-20	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	6:09	6:11	0:01	LINE FAULT
116	11-Aug-20	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66,SOKKE_66	18:46	18:59	0:12	LINE FAULT
117	11-Aug-20	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)	19:52(11.08.2020)	1707:36hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
118	11-Aug-20	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	11:43	11:47	0:04	LINE FAULT
119	11-Aug-20	TUMKUR	66	NEELAGUNDA220KV- HARAPANAHALLI-1	HARAPPANAHALLI_66	18:38	18:47	0:08	LINE FAULT
120	11-Aug-20	TUMKUR	66	RANGENAHALLI- DYVARANAHALLI	RANGENAHALLI_66	7:40	17:36	9:55	LINE CLEAR AVAILED
121	11-Aug-20	TUMKUR	66	SIRA- KALLAMBELLA	SIRA_66	4:34	4:46	0:12	LINE FAULT
122	11-Aug-20	TUMKUR	66	SIRA- KALLAMBELLA	SIRA_66	5:45	6:06	0:21	LINE FAULT
123	11-Aug-20	TUMKUR	66	SIRA- MADHUGIRI 2	SIRA_66	4:34	4:46	0:11	LINE FAULT
124	11-Aug-20	TUMKUR	66	SIRA- MADHUGIRI 2	SIRA_66	5:45	6:06	0:20	LINE FAULT
125	11-Aug-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
126	11-Aug-20	TUMKUR	66	TR-2	BRAHMASANDRA_66	18:22	19:17	0:54	LINE CLEAR AVAILED
127	11-Aug-20	TUMKUR	66	TR-2	HOSADURGA_66	12:01	12:39	0:37	LINE CLEAR AVAILED
128	11-Aug-20	TUMKUR	66	TR-2	SANIKERE_66	17:38	17:44	0:05	TRANSFORMER FAULT
129	11-Aug-20	TUMKUR	110	TR-1	KGTEMPLE_110	11:43	12:29	0:45	LINE CLEAR AVAILED
130	11-Aug-20	TUMKUR	110	TR-1(LV SIDE)	KBCROSS_220	11:15	12:19	1:03	LINE CLEAR AVAILED
131	11-Aug-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN:TRANSFORMER FAULT
132	11-Aug-20	TUMKUR	110	TR-2(LV SIDE)	KBCROSS_220	12:19	15:47	3:27	LINE CLEAR AVAILED
133	11-Aug-20	TUMKUR	220	ANTHRASANAHALLI 220KV- VASANTHNARASAPURA 2	ANTHRASANAHALLI_220	9:57	16:43	6:45	LINE CLEAR AVAILED
134	11-Aug-20	TUMKUR	220	TR-1	KBCROSS_220	11:15	12:19	1:03	LINE CLEAR AVAILED
135	11-Aug-20	TUMKUR	220	TR-2	KBCROSS_220	12:20	15:47	3:27	LINE CLEAR AVAILED
136	12-Aug-20	BAGALKOT	66	HONNALLI(BANUVALLI-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020)			LINE OPEN:LINE CLEAR AVAILED
137	12-Aug-20	BAGALKOT	110	110/11KV, HV1	BANAHATTI_110	14:05	14:26	0:21	LINE CLEAR AVAILED
138	12-Aug-20	BAGALKOT	110	110/11KV,HV2	NAVANAGAR(B)_110	15:44	15:55	0:11	LINE CLEAR AVAILED
139	12-Aug-20	BAGALKOT	110	110/33KV, HV3	NIPPANI_110, BENADI_33, JATRAT_33	15:49	16:35	0:46	LINE CLEAR AVAILED
140	12-Aug-20	BAGALKOT	110	110/33KV,HV4	GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
141	12-Aug-20	BAGALKOT	110	220/110KV, LV2	MKHUBLI_220	20:00 (11.08.2020)	8:26 (12.08.2020)	12:26hrs	LINE CHARGED
142	12-Aug-20	BAGALKOT	110	BAGEWADI- MUDDEBIHAL	MUDDEBIHAL_110	12:19	13:50	1:31	LINE CLEAR AVAILED
143	12-Aug-20	BAGALKOT	110	BALAJISUGARS- MUDDEBIHAL	MUDDEBIHAL_110	12:18	13:50	1:32	LINE CLEAR AVAILED
144	12-Aug-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN:LINE CLEAR AVAILED
145	12-Aug-20	BAGALKOT	110	GAJENDRAGAD-KUSTAGI	STATION NOT AFFECTED GAJENDRAGAD_110	7:40 (19.07.2020)			LINE OPEN:LINE CLEAR AVAILED
146	12-Aug-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN:LINE CLEAR AVAILED
147	12-Aug-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:0 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
148	12-Aug-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
149	12-Aug-20	BAGALKOT	110	KNM SOLAR- MUDDEBIHAL	MUDDEBIHAL_110	12:18	13:50	1:32	LINE CLEAR AVAILED
150	12-Aug-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
151	12-Aug-20	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
152	12-Aug-20	BAGALKOT	110	SIRSI 220-SIRSI2	SIRSI_220	15:50 (10.08.2020)			LINE OPEN:LINE CLEAR AVAILED
153	12-Aug-20	BAGALKOT	110	SIRSI-KUMATA2	STATION NOT AFFECTED SIRSI_110	17:07 (07.08.2020)	11:45 (11.08.2020)	90:38hrs	LINE CHARGED
154	12-Aug-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
155	12-Aug-20	BAGALKOT	220	ATHANI- MAHALINGAPUR	MAHALINGAPUR_220	4:35	11:10	6:35	LINE FAULT
156	12-Aug-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN:LINE FAULT
157	12-Aug-20	BAGALKOT	220	BAGEWADI-ATRIA 2	BAGEWADI_220	17:00 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
158	12-Aug-20	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	17:26 (24.07.2020)			LOAD CURTAILMENT
159	12-Aug-20	BAGALKOT	220	BELGAUM- CHIKKODI2	BELGAUM_220	22:23 (12.08.2020)			LINE OPEN:LINE CLEAR AVAILED
160	12-Aug-20	BAGALKOT	220	BELGAUM- NARENDRA2 (KANABARGI2)	BELGAUM_220	22:18 (04.08.2020)			LINE OPEN:LINE CLEAR AVAILED
161	12-Aug-20	BAGALKOT	220	BIDNAL-HARTI1	BIDNAL_220	9:11:00 AM (7.8.2020)	16:06 (12.08.2020)	126:55hrs	LINE CHARGED
162	12-Aug-20	BAGALKOT	220	BIDNAL-HARTI2	BIDNAL_220	16:22 (7.8.2020)	16:06 (12.08.2020)	119:44hrs	LINE CHARGED
163	12-Aug-20	BAGALKOT	220	GADAG- BAGALKOT1	GADAG_220	8:54	17:29	8:35	LINE CLEAR AVOIDED
164	12-Aug-20	BAGALKOT	220	GADAG- BAGALKOT2	GADAG_220	8:54	15:59	7:05	LINE CLEAR AVOIDED
165	12-Aug-20	BAGALKOT	220	GADAG- BAGALKOT2	GADAG_220	17:29 (12.08.2020)			LINE OPEN:LINE CLEAR AVAILED
166	12-Aug-20	BAGALKOT	220	GADAG-HARTI1	GADAG_220	15:00 (10.8.2020)	14:39 (12.08.2020)	47:39hrs	LINE CHARGED
167	12-Aug-20	BAGALKOT	220	HARTI1- GADAG	GADAG_220	17:12	17:24	0:12	HAND TRIPPED
168	12-Aug-20	BAGALKOT	220	HARTI2- GADAG	GADAG_220	17:25	17:42	0:17	HAND TRIPPED
169	12-Aug-20	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	16:57 (10.08.2020)			LINE OPEN:LINE CLEAR AVAILED
170	12-Aug-20	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	18:35 (07.08.2020)			LINE OPEN:LINE FAULT
171	12-Aug-20	BAGALKOT	220	SHARAVATY 2-SIRSI	SIRSI_220	5:24:00 PM (10.8.2020)			LOAD CURTAILMENT
172	12-Aug-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
173	12-Aug-20	BENGALURU	66	BTM 4TH PHASE - KHODAYS 220	BTM 4TH PHASE	10:30	10:38	00:08	LOAD CHANGE OVER
174	12-Aug-20	BENGALURU	66	BTM 4TH PHASE - SOUTH CITY	BTM 4TH PHASE	13:28	13:34	00:06	LOAD CHANGE OVER
175	12-Aug-20	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	06:56	07:18	00:22	LINE FAULT
176	12-Aug-20	BENGALURU	66	CHINTAMANI 66 - CHINTAMANI 220	CHINTAMANI 66	09:18	10:41	01:23	LINE CLEAR AVOIDED
177	12-Aug-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	05:58	06:11	00:13	LINE FAULT
178	12-Aug-20	BENGALURU	66	HV1	CHELUR	17:00	17:44	00:44	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
179	12-Aug-20	BENGALURU	66	HV1	ELECTRONIC CITY PH-2 SEC-2	10:45	10:50	00:05	TRANSFORMER FAULT
180	12-Aug-20	BENGALURU	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	10:24	10:37	00:13	LINE CLEAR AVAILED
181	12-Aug-20	BENGALURU	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	13:31	13:34	00:03	LINE CLEAR AVAILED
182	12-Aug-20	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN:LINE FAULT
183	12-Aug-20	BENGALURU	220	HV2	CHINTAMANI	06:56	07:17	00:21	TRANSFORMER FAULT
184	12-Aug-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN:LINE FAULT
185	12-Aug-20	GULBARGA	66	HV1	TABRAHALLI_66	10:20	10:50	00:30	LINE CLEAR AVAILED
186	12-Aug-20	GULBARGA	66	HV1	TABRAHALLI_66	11:40	16:55	05:15	LINE CLEAR AVAILED
187	12-Aug-20	GULBARGA	66	HV1	TABRAHALLI_66	17:35	18:25	00:50	LINE CLEAR AVAILED
188	12-Aug-20	GULBARGA	66	HV2	TABRAHALLI_66	10:20	18:25	08:05	LINE CLEAR AVAILED
189	12-Aug-20	GULBARGA	66	TAMBRAHALLI-ITTAGGI	TABRAHALLI_66	11:50	16:50	05:00	LINE CLEAR AVAILED
190	12-Aug-20	GULBARGA	110	HV2	SHORAPUR_110	01:39	02:05	00:26	TRANSFORMER FAULT
191	12-Aug-20	GULBARGA	110	HV3	GULBARGAWEST_110	10:15	12:55	02:40	LINE CLEAR AVAILED
192	12-Aug-20	GULBARGA	110	SHAHNUR-KEMBHAVI2	KBJNL_IPP	09:50	12:10	02:20	LINE CLEAR AVAILED
193	12-Aug-20	GULBARGA	110	SHAHNUR-KHANAPUR	KHANAPUR_110, SAIDAPUR_110, WADAGERA_110, SANNATI_110, NALWAR_110	09:45	11:55	02:10	LINE CLEAR AVAILED
194	12-Aug-20	GULBARGA	110	SHAHNUR-SHAHNUR1	NO STATION AFFECTED	12:15(5.8.2020)			LINE OPEN:LINE CLEAR AVAILED
195	12-Aug-20	GULBARGA	110	SHAHNUR-SHORAPUR	SHORAPUR_110	01:38	01:50	00:12	LINE FAULT
196	12-Aug-20	GULBARGA	110	SINDHANUR-NIRLOOTI_IPP	SIDHANUR_220	05:50	06:05	00:15	LINE FAULT
197	12-Aug-20	GULBARGA	220	KAPNUR-SHAHNUR	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN:LINE CLEAR AVAILED
198	12-Aug-20	GULBARGA	220	KAPNUR-SHAHNUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN:LINE FAULT
199	12-Aug-20	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	10:42(11/8/2020)			LINE OPEN:LINE CLEAR AVAILED
200	12-Aug-20	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	09:41	11:07	01:26	LINE CLEAR AVAILED
201	12-Aug-20	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	00:10	00:30	00:20	MAIN SUPPLY FAILURE
202	12-Aug-20	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	09:41	11:07	01:26	LINE CLEAR AVAILED
203	12-Aug-20	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADANUR_66	05:30	05:45	00:15	LINE FAULT
204	12-Aug-20	HASSAN	66	HASSN220-CHIKKAMAGLUR2	HASSAN_220	13:35	13:45	00:10	LINE FAULT
205	12-Aug-20	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	05:34	05:43	00:09	LINE FAULT
206	12-Aug-20	HASSAN	66	HV1	CHIKMAGALUR_66	14:08	14:30	00:22	HAND TRIPPED
207	12-Aug-20	HASSAN	66	HV1	DODDAKADANUR_66	05:30	05:45	00:15	MAIN SUPPLY FAILURE
208	12-Aug-20	HASSAN	66	HV1	MOSALEHOSAHALLI_66	10:37	10:48	00:11	TRANSFORMER FAULT
209	12-Aug-20	HASSAN	66	HV1	SOMANAHALLI_66	13:25	13:47	00:22	LINE CLEAR AVAILED
210	12-Aug-20	HASSAN	66	HV2	CHIKMAGALUR_66	14:08	14:31	00:23	HAND TRIPPED
211	12-Aug-20	HASSAN	66	HV2	RAMNATHPURA_66	07:17	10:16	02:59	TRANSFORMER FAULT
212	12-Aug-20	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	09:43	10:46	01:03	NFBC ISSUED
213	12-Aug-20	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	09:40	10:52	01:12	LINE CLEAR AVAILED
214	12-Aug-20	HASSAN	110	HV1	BARANGI_110	12:11	13:04	00:53	LINE CLEAR AVAILED
215	12-Aug-20	HASSAN	110	HV2	KONAJE_110	00:55	01:09	00:14	MAIN SUPPLY FAILURE
216	12-Aug-20	HASSAN	110	JOG-JST1	mghejog_gen	10:15	12:20	02:05	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
217	12-Aug-20	HASSAN	110	JOG-NK2	NO STN AFFECTED	23:36 (7.08.2020)			LINE OPEN:LINE CLEAR AVAILED
218	12-Aug-20	HASSAN	110	LV1	KADUR_220	10:08	13:06	02:58	LINE CLEAR AVALIED
219	12-Aug-20	HASSAN	110	SAGARA-JST1	SAGARA_110	10:15	12:20	02:05	LINE CLEAR AVALIED
220	12-Aug-20	HASSAN	110	SAGARA-LST4	SAGARA_110	12:40	14:40	02:00	LINE CLEAR AVALIED
221	12-Aug-20	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	20:54	21:03	00:09	HAND TRIPPED
222	12-Aug-20	HASSAN	220	HV1	KADUR_220	10:08	13:03	02:55	LINE CLEAR AVALIED
223	12-Aug-20	HASSAN	220	SHRAVTY-SIRISI 2	NO STN AFFECTED	14:25 (10.08.2020)			LINE OPEN:LINE CLEAR AVAILED
224	12-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:17 (11.08.2020)	19:05 (12.08.2020)	19:47hrs	LINE CHARGED
225	12-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:32 (12.08.2020)			LINE OPEN:LINE CLEAR AVAILED
226	12-Aug-20	HASSAN	400	UPCL-HASSAN1	NO STN AFFECTED	21:56 (7.08.2020)			LINE OPEN:LINE CLEAR AVAILED
227	12-Aug-20	HASSAN	400	UPCL-HASSAN2	NO STN AFFECTED	16:21 (5.08.2020)			LINE OPEN:LINE CLEAR AVAILED
228	12-Aug-20	MYSURU	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS INTERRUPTED	10:00	16:55	6:54	NFBC ISSUED
229	12-Aug-20	MYSURU	66	HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	2:47 (06.08.2020)	10:45	151:58 HRS	LINE CHARGED
230	12-Aug-20	MYSURU	66	HOOTAGALLI-ELWALA	NO STATIONS INTERRUPTED	9:41	12:45	3:03	LINE CLEAR AVALIED
231	12-Aug-20	MYSURU	66	HOOTAGALLI-HUNSUR	NO STATIONS INTERRUPTED	9:41	12:45	3:03	LINE CLEAR AVALIED
232	12-Aug-20	MYSURU	66	HOOTAGALLI-KHB	NO STATIONS INTERRUPTED	9:43	12:58	3:15	LINE CLEAR AVALIED
233	12-Aug-20	MYSURU	66	HV 1	THALAKADU_66	9:15	16:40	7:24	LINE CLEAR AVALIED
234	12-Aug-20	MYSURU	66	HV 1	JAKKANAHALLY_66	13:25	13:45	0:20	LINE CLEAR AVALIED
235	12-Aug-20	MYSURU	66	HV 2	GUDDENAHALLI_66	11:40	12:05	0:25	LINE CLEAR AVALIED
236	12-Aug-20	MYSURU	66	HV1	ARAKERE_66	12:12	13:05	0:52	LINE CLEAR AVALIED
237	12-Aug-20	MYSURU	66	HV1	HALAGUR_66	3:26	3:54	0:27	TRANSFORMER FAULT
238	12-Aug-20	MYSURU	66	HV1	MADIKERI_66	15:53	16:30	0:36	HAND TRIPPED
239	12-Aug-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
240	12-Aug-20	MYSURU	66	HV2	HOOTAGALLY_220	8:31	9:25	0:54	TRANSFORMER FAULT
241	12-Aug-20	MYSURU	66	HV2	KMDODDI_66	12:06	13:35	1:29	LINE CLEAR AVALIED
242	12-Aug-20	MYSURU	66	HV2	THALAKADU_66	9:15	16:40	7:24	LINE CLEAR AVALIED
243	12-Aug-20	MYSURU	66	JYOTHINAGARA-FTS	JYOTHINAGARA_66	10:39	17:18	6:39	LINE CLEAR AVALIED
244	12-Aug-20	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66 SUTTUR_66	8:58	9:04	0:06	LINE FAULT
245	12-Aug-20	MYSURU	66	KADAKOLA-SARGUR-1	ANTHARSANTHE_66 HAMPAPURA(K)_66 HDKOTE_66 JAIPUR_66	11:40	11:45	0:05	LINE FAULT
246	12-Aug-20	MYSURU	66	KADAKOLA-SARGUR-2	DOORA_66 HURA_66 HULLAHALLI_66,	13:49	16:12	2:23	NFBC ISSUED
247	12-Aug-20	MYSURU	66	KUSHALNAGARA 220-SUNTIKOPPA	NO STATIONS EFFECTED	10:43 (07.08.2020)	12:30	121:47 HRS	LINE CHARGED
248	12-Aug-20	MYSURU	66	KUSHALNAGARA-SUNTIKOPPA	SUNTIKOPPA_66	10:35	12:30	1:55	LINE CLEAR AVALIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
249	12-Aug-20	MYSURU	66	MADIKERI-KUSHALNAGARA	MADIKERI_66	10:33	12:30	1:57	NFBC ISSUED
250	12-Aug-20	MYSURU	66	MADIKERI-SUNTIKOPPA	NO STATIONS INTERRUPTED	14:24	15:53	1:28	LINE CLEAR AVAILED
251	12-Aug-20	MYSURU	66	SINDUVALLY-KADKOLA	NO STATIONS EFFECTED	7:40 (09.08.2020)			LINE OPEN:LINE CLEAR AVAILED
252	12-Aug-20	MYSURU	66	SUNTIKOPPA-KUSHALNAGAR	NO STATIONS EFFECTED	23:10 (06.08.2020)	12:30	133:20 HRS	LINE CHARGED
253	12-Aug-20	MYSURU	66	TALKADU-CHANDALLI	NO STATIONS INTERRUPTED	13:00	16:40	3:40	LINE CLEAR AVAILED
254	12-Aug-20	MYSURU	66	TALKADU-PARINAMIPURA	THALAKADU_66	13:00	17:35	4:35	LINE CLEAR AVAILED
255	12-Aug-20	MYSURU	66	VAJMANGALA-BANNUR	NO STATIONS INTERRUPTED	11:58	15:50	3:52	LINE CLEAR AVAILED
256	12-Aug-20	MYSURU	66	VAJMANGALA-JYOTHINAGARA	JYOTHINAGARA_66	10:39	15:31	4:51	NFBC ISSUED
257	12-Aug-20	MYSURU	220	HOOTAGALLI-HV3	NO STATIONS INTERRUPTED	9:56	12:40	2:43	LINE CLEAR AVAILED
258	12-Aug-20	TUMKUR	66	BELADADARA- ANTHRASANAHALLI	BELADARA_66	10:22	19:22	9:00	LINE CLEAR AVAILED
259	12-Aug-20	TUMKUR	66	H D PURA- SUZLON	SUZLON-IPP	12:46	14:00	1:13	LINE CLEAR AVAILED
260	12-Aug-20	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	8:54	9:06	0:12	LINE FAULT
261	12-Aug-20	TUMKUR	66	I D HALLI- KODIGENAHALLI	IDHALLY_66	11:13	18:41	7:28	LINE CLEAR AVAILED
262	12-Aug-20	TUMKUR	66	RANGENAHALLI- DYVARANAHALLI	RANGENAHALLI_66	7:03	17:35	10:32	LINE CLEAR AVAILED
263	12-Aug-20	TUMKUR	66	THALLAK 220kv- CHALLAKERE-2	CHALLAKERE_66, SANIKERE_66	8:13	13:38	5:24	LINE CLEAR AVAILED
264	12-Aug-20	TUMKUR	66	TR-1	DEVARAHALLI_66	12:14	12:26	0:11	LINE CLEAR AVAILED
265	12-Aug-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
266	12-Aug-20	TUMKUR	66	TR-2	LINGDHALLI_66	12:19	13:42	1:23	LINE CLEAR AVAILED
267	12-Aug-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
268	12-Aug-20	TUMKUR	110	TR-1	SHETYKERE_110	12:40	14:27	1:47	LINE CLEAR AVAILED
269	12-Aug-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN:TRANSFORMER FAULT
270	12-Aug-20	TUMKUR	110	TR-2	HULIYAR_110	14:37	16:15	1:38	LINE CLEAR AVAILED
271	12-Aug-20	TUMKUR	110	TR-2	SHETYKERE_110	13:41	14:27	0:46	LINE CLEAR AVAILED
272	12-Aug-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN:TRANSFORMER FAULT
273	13-Aug-20	BAGALKOT	66	HONNALLI(BANUVALLI-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020)			LINE OPEN:LINE CLEAR AVAILED
274	13-Aug-20	BAGALKOT	110	110/11KV, HV1	KANABARGI LAYOUT_110	10:35	11:35	1:00	LINE CLEAR AVAILED
275	13-Aug-20	BAGALKOT	110	110/11KV,HV1	BAGALKOT_110	10:20	18:07	7:47	LINE CLEAR AVAILED
276	13-Aug-20	BAGALKOT	110	110/33KV, HV3&HV4	GOPPANAKOPPA_110, KUSUGAL_33, KMC_33	10:00	20:54	10:54	LINE CLEAR AVAILED
277	13-Aug-20	BAGALKOT	110	110/33KV, HV4	KANABARGI LAYOUT_110, KAKTI_33, SUZLON_33	11:32	17:31	5:59	LINE CLEAR AVAILED
278	13-Aug-20	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
279	13-Aug-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
280	13-Aug-20	BAGALKOT	110	GAJENDRAGAD-KUSTAGI	STATION NOT AFFECTED GAJENDRAGAD_110	7:40 19.07.2020)			LINE OPEN:LINE CLEAR AVAILED
281	13-Aug-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN:LINE CLEAR AVAILED
282	13-Aug-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:0 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
283	13-Aug-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
284	13-Aug-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
285	13-Aug-20	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
286	13-Aug-20	BAGALKOT	110	SIRSI 220-SIRSI2	STATION NOT AFFECTED SIRSI_220	15:50 (10.08.2020)			LINE OPEN:LINE CLEAR AVAILED
287	13-Aug-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
288	13-Aug-20	BAGALKOT	220	AMBEWADI-NARENDRA 1	STATION NOT AFFECTED AMBEWADI_220	21:22 (13.08.2020)			LINE OPEN:LINE CLEAR AVAILED
289	13-Aug-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN:LINE FAULT
290	13-Aug-20	BAGALKOT	220	BAGEWADI-ATRIA 2	STATION NOT AFFECTED BAGEWADI_220	17:00 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
291	13-Aug-20	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	17:26 (24.07.2020)			LOAD CURTAILMENT
292	13-Aug-20	BAGALKOT	220	BELGAUM- CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	22:23 (12.08.2020)	8:32 (13.08.2020)	10:05hrs	LINE CHARGED
293	13-Aug-20	BAGALKOT	220	BELGAUM- CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	18:02 (13.08.2020)			LINE OPEN:LINE CLEAR AVAILED
294	13-Aug-20	BAGALKOT	220	BELGAUM- NARENDRA2 (KANABARGI2)	STATION NOT AFFECTED BELGAUM_220	22:18 (04.08.2020)			LINE OPEN:LINE CLEAR AVAILED
295	13-Aug-20	BAGALKOT	220	GADAG- BAGALKOT1	GADAG_220	11:36	18:16	6:40	LINE CLEAR AVOIDED
296	13-Aug-20	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	17:29 (12.08.2020)	11:35 (13.08.2020)	18:06hrs	LINE CHARGED
297	13-Aug-20	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	16:57 (10.08.2020)			LINE OPEN:LINE CLEAR AVAILED
298	13-Aug-20	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	18:35 (07.08.2020)			LINE OPEN:LINE FAULT
299	13-Aug-20	BAGALKOT	220	NAGJHARI 1&2-AMBEWADI	AMBEWADI_220	10:15	16:32	6:17	LINE CLEAR AVOIDED
300	13-Aug-20	BAGALKOT	220	SHARAVATY 2-SIRSI	STATION NOT AFFECTED SIRSI_220	5:24:00 PM (10.8.2020)			LOAD CURTAILMENT
301	13-Aug-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
302	13-Aug-20	BENGALURU	66	HV1	KYLANUR	11:30	11:35	00:05	LINE CLEAR AVOIDED
303	13-Aug-20	BENGALURU	66	HV1	NIMHANS	13:28	15:45	02:17	TRANSFORMER FAULT
304	13-Aug-20	BENGALURU	66	HV2	KYLANUR	13:25	13:30	00:05	LINE CLEAR AVOIDED
305	13-Aug-20	BENGALURU	66	HV2	KYLANUR	16:00	16:40	00:40	LINE CLEAR AVOIDED
306	13-Aug-20	BENGALURU	66	HV3	A STATION 66	03:03	03:20	00:17	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
307	13-Aug-20	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	01:07	01:18	00:11	LINE FAULT
308	13-Aug-20	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN:LINE FAULT
309	13-Aug-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN:LINE FAULT
310	13-Aug-20	GULBARGA	66	ITTAGI-BENNEHALLI	BENNEHALLI_66, KOTTUR_66,UJJAINI_66	09:05	09:10	00:05	LINE FAULT
311	13-Aug-20	GULBARGA	66	ITTAGI-HIREHADAGALI1	HIREHADAGLI_66	16:27	18:00	01:33	LINE CLEAR AVAILED
312	13-Aug-20	GULBARGA	66	KOTTUR-UJJAINI	UJJAINI_110	09:05	09:10	00:05	LINE FAULT
313	13-Aug-20	GULBARGA	110	GURUMITAKAL-SEDAM	GURUMITAKAL_110, KONKAL_110	02:35	03:10	00:35	LINE FAULT
314	13-Aug-20	GULBARGA	110	GURUMITAKAL-SEDAM	GURUMITAKAL_110, KONKAL_110	05:00	05:15	00:15	LINE FAULT
315	13-Aug-20	GULBARGA	110	HV1	KURKUNTA_110	04:05	04:30	00:25	TRANSFORMER FAULT
316	13-Aug-20	GULBARGA	110	HV2	SHORAPUR_110	05:10	05:27	00:17	TRANSFORMER FAULT
317	13-Aug-20	GULBARGA	110	KAPNOOR-ALAND	ALAND_110	11:32	12:03	00:31	LINE CLEAR AVAILED
318	13-Aug-20	GULBARGA	110	RAICHUR-SHAHPUR1	GABUR_110, DEODURGA_110	07:43	07:49	00:06	LINE FAULT
319	13-Aug-20	GULBARGA	110	RAICHUR-SHAHPUR1	GABUR_110, DEODURGA_110	08:14	08:31	00:17	LINE FAULT
320	13-Aug-20	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	18:05	18:29	00:24	LINE FAULT
321	13-Aug-20	GULBARGA	110	SEDAM-VICATSAGARCEMENTS	VICATSAGAR_CEMENTS	03:15	03:20	00:05	LINE FAULT
322	13-Aug-20	GULBARGA	110	SEDAM-VICATSAGARCEMENTS	VICATSAGAR_CEMENTS	06:00	09:58	03:58	LINE FAULT
323	13-Aug-20	GULBARGA	110	SHAHPUR-KEMBHAVI2	KBJNL_110	20:45	21:21	00:36	LINE FAULT
324	13-Aug-20	GULBARGA	110	SHAHPUR-SHAHPUR1	NO STATION AFFECTED	12:15(5.8.2020)			LINE OPEN:LINE CLEAR AVAILED
325	13-Aug-20	GULBARGA	110	SHAHPUR-SHORAPUR	SHORAPUR_110	05:10	05:21	00:11	LINE FAULT
326	13-Aug-20	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_11 0,BTPSWATERWORKS	22:20	22:30	00:10	LINE FAULT
327	13-Aug-20	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	05:30	05:40	00:10	LINE FAULT
328	13-Aug-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN:LINE CLEAR AVAILED
329	13-Aug-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN:LINE FAULT
330	13-Aug-20	GULBARGA	220	RAICHUR- JURALA2	RAICHUR_220	22:58	23:58	01:00	LINE FAULT
331	13-Aug-20	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	10:42(11/8/2020)			LINE OPEN:LINE CLEAR AVAILED
332	13-Aug-20	GULBARGA	220	SEDAM-SHAHPUR	SEDAM_220	20:33	20:57	00:24	LINE FAULT
333	13-Aug-20	GULBARGA	220	SHAHPUR-SHAHBAD	SHAHABAD_220	20:38	20:50	00:12	LINE FAULT
334	13-Aug-20	HASSAN	66	BALLUPEOKANDLI	BALLUPETE_66	17:41	17:56	00:15	LINE FAULT
335	13-Aug-20	HASSAN	66	CHANNARA-HIRESAVE	CHANNARAYAPATNA_66	20:47	20:59	00:12	LINE FAULT
336	13-Aug-20	HASSAN	66	HANUBAL-SAKLESPUR	HANUBAL_66	12:26	13:24	00:58	MAIN SUPPLY FAILURE
337	13-Aug-20	HASSAN	66	HASSN220-CHIKAMAGLUR2	HASSAN_220	12:44	13:02	00:18	LINE FAULT
338	13-Aug-20	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	09:49	14:11	04:22	LINE CLEAR AVAILED
339	13-Aug-20	HASSAN	66	HV1	AREHALLI_HSN_66	12:28	13:24	00:56	MAIN SUPPLY FAILURE
340	13-Aug-20	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	10:20	10:40	00:20	MAIN SUPPLY FAILURE
341	13-Aug-20	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	13:45	14:27	00:42	MAIN SUPPLY FAILURE
342	13-Aug-20	HASSAN	66	HV1	MALALI_66	09:50	14:41	04:51	MAIN SUPPLY FAILURE
343	13-Aug-20	HASSAN	66	HV1	MALLAPURA_66	12:18	13:20	01:02	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
344	13-Aug-20	HASSAN	66	HV2	MALLAPURA_66	13:27	13:47	00:20	HAND TRIPPED
345	13-Aug-20	HASSAN	66	MALALI-CRPATNA	MALALI_66	09:50	14:40	04:50	MAIN SUPPLY FAILURE
346	13-Aug-20	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGAR_66	10:10	13:41	03:31	LINE CLEAR AVAILED
347	13-Aug-20	HASSAN	66	SAKALE-HANBAL	SAKLESHPURA_66	12:24	13:24	01:00	LINE CLEAR AVAILED
348	13-Aug-20	HASSAN	66	SHANTHI-UDYAPURA	SHANTHIGRAMMA_66	10:08	10:22	00:14	MAIN SUPPLY FAILURE
349	13-Aug-20	HASSAN	66	SHANTHI-UDYAPURA	SHANTHIGRAMMA_66	10:38	11:32	00:54	MAIN SUPPLY FAILURE
350	13-Aug-20	HASSAN	110	HALADY11-HIRIYADKA	HALADY_110	11:09	14:00	02:51	LINE CLEAR AVAILED
351	13-Aug-20	HASSAN	110	HIRIYA-HALADY	HIRIYADKA_110	11:16	13:51	02:35	NFBC ISSUED
352	13-Aug-20	HASSAN	110	HV1	HALADY_110	15:21	16:16	00:55	LINE CLEAR AVAILED
353	13-Aug-20	HASSAN	110	HV1	KULASHEKARA_110	10:02	17:15	07:13	LINE CLEAR AVAILED
354	13-Aug-20	HASSAN	110	HV1	NANDIKUR_110	10:20	16:18	05:58	LINE CLEAR AVAILED
355	13-Aug-20	HASSAN	110	HV2	KONAJE_110	03:05	04:08	01:03	MAIN SUPPLY FAILURE
356	13-Aug-20	HASSAN	110	HV2	NANDIKUR_110	10:18	12:00	01:42	LINE CLEAR AVAILED
357	13-Aug-20	HASSAN	110	HV4	MRSMSG_220	11:41	14:48	03:07	TRANSFORMER FAULT
358	13-Aug-20	HASSAN	110	JOG-NK2	NO STN AFFECTED	23:36 (7.08.2020)			LINE OPEN:LINE CLEAR AVAILED
359	13-Aug-20	HASSAN	110	KADUR-YGTI	KADUR_220	09:49	13:34	03:45	LINE CLEAR AVAILED
360	13-Aug-20	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	13:14	13:27	00:13	HAND TRIPPED
361	13-Aug-20	HASSAN	110	LV1	SHIRALKOPPA_220	12:43	13:21	00:38	LINE CLEAR AVAILED
362	13-Aug-20	HASSAN	110	LV2	SHIRALKOPPA_220	11:22	12:38	01:16	LINE CLEAR AVAILED
363	13-Aug-20	HASSAN	110	LV2	KADUR_220	10:19	12:44	02:25	LINE CLEAR AVAILED
364	13-Aug-20	HASSAN	110	MNANDIKU-ISTRIL	NANDIKUR_110	10:20	15:54	05:34	LINE CLEAR AVAILED
365	13-Aug-20	HASSAN	110	NANDIKU-KEMAR1	NANDIKUR_110	10:20	16:00	05:40	LINE CLEAR AVAILED
366	13-Aug-20	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	10:20	12:00	01:40	LINE CLEAR AVAILED
367	13-Aug-20	HASSAN	110	NANDIKU-NDKR-SUZLON	NANDIKUR_110	10:19	15:46	05:27	LINE CLEAR AVAILED
368	13-Aug-20	HASSAN	220	HV1	SHIRALKOPPA_220	12:43	13:21	00:38	LINE CLEAR AVAILED
369	13-Aug-20	HASSAN	220	HV2	KADUR_220	10:19	12:44	02:25	LINE CLEAR AVAILED
370	13-Aug-20	HASSAN	220	HV2	SHIRALKOPPA_220	11:22	12:37	01:15	LINE CLEAR AVAILED
371	13-Aug-20	HASSAN	220	KEMAR-Varahi1	KEMAR_220	21:25 (13.08.2020)			LINE OPEN:LINE FAULT
372	13-Aug-20	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	12:02	14:02	02:00	LINE CLEAR AVAILED
373	13-Aug-20	HASSAN	220	SHRAVTY-SIRISI 2	NO STN AFFECTED	14:25 (10.08.2020)			LINE OPEN:LINE CLEAR AVAILED
374	13-Aug-20	HASSAN	220	VARAHI-KEMAR1	varahi_gen	21:25 (13.08.2020)			LINE OPEN:LINE FAULT
375	13-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:17 (11.08.2020)	6:28 (13.08.2020)	31:10 hrs	LINE CHARGED
376	13-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	20:16 (13.08.2020)			LINE OPEN:LINE CLEAR AVAILED
377	13-Aug-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:56 (7.08.2020)	8:20 (13.08.2020)	130:23 hrs	LINE CHARGED
378	13-Aug-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	17:38 (13.08.2020)			LINE OPEN:LINE CLEAR AVAILED
379	13-Aug-20	HASSAN	400	UPCL-HASSAN2	NO STN AFFECTED	16:21 (5.08.2020)			LINE OPEN:LINE CLEAR AVAILED
380	13-Aug-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
381	13-Aug-20	MYSURU	66	HV2	COWDALLI_66	18:01	18:35	0:33	TRANSFORMER FAULT
382	13-Aug-20	MYSURU	66	HV2	HEBBAL_66	11:27	13:37	2:10	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
383	13-Aug-20	MYSURU	66	KADAKOLA-SARGUR-1	ANTHARSANTHE_66 HAMPAPURA(K)_66 HDKOTE 66 JAIPUR 66	8:52	8:57	0:05	LINE FAULT
384	13-Aug-20	MYSURU	66	MADHUVANAHALLI- DODDINADUVADI	NO STATIONS INTERRUPTED	13:19	13:50	0:31	HAND TRIPPED
385	13-Aug-20	MYSURU	66	SINDUVALLY-KADKOLA	NO STATIONS EFFECTED	7:40 (09.08.2020)			LINE OPEN:LINE CLEAR AVAILED
386	13-Aug-20	MYSURU	220	HV 2	TUBINAKERE 220	10:20	10:33	0:13	TRANSFORMER FAULT
387	13-Aug-20	TUMKUR	66	ANTHRASANAHALI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	10:39	15:03	4:23	LINE CLEAR AVAILED
388	13-Aug-20	TUMKUR	66	BALENAHALI-CHITRADURGA	BALENAHALI 66	15:46	16:12	0:26	LINE CLEAR AVAILED
389	13-Aug-20	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE 66	5:56	6:30	0:34	LINE FAULT
390	13-Aug-20	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR 66	5:56	6:28	0:32	LINE FAULT
391	13-Aug-20	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI 66	7:32	7:43	0:10	LINE FAULT
392	13-Aug-20	TUMKUR	66	RANGENAHALI- DYVARANAHALI	RANGENAHALI 66	7:51	17:47	9:55	LINE CLEAR AVAILED
393	13-Aug-20	TUMKUR	66	TR-1	DEVARAHALLI 66	11:01	11:17	0:16	LINE CLEAR AVAILED
394	13-Aug-20	TUMKUR	66	TR-1	KALAMARANAHALLI_66	12:39	12:58	0:19	LINE CLEAR AVAILED
395	13-Aug-20	TUMKUR	66	TR-1	PAVAGADA 220	11:06	11:08	0:01	TRANSFORMER FAULT
396	13-Aug-20	TUMKUR	66	TR-1	TUMKUR_66	14:15	15:05	0:50	HAND TRIPPED
397	13-Aug-20	TUMKUR	66	TR-1	TUMKUR_66	17:45	17:49	0:03	HAND TRIPPED
398	13-Aug-20	TUMKUR	66	TR-1	BALENAHALI 66	14:46	16:12	1:25	LINE CLEAR AVAILED
399	13-Aug-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
400	13-Aug-20	TUMKUR	66	TR-2	ANTHRASANAHALI 220	9:11	9:59	0:48	LINE CLEAR AVAILED
401	13-Aug-20	TUMKUR	66	TR-2	ANTHRASANAHALI 220	19:55	21:14	1:19	LINE CLEAR AVAILED
402	13-Aug-20	TUMKUR	66	TR-2	SANIKERE 66	14:26	15:43	1:17	TRANSFORMER FAULT
403	13-Aug-20	TUMKUR	66	TR-2	TUMKUR_66	14:15	15:05	0:50	HAND TRIPPED
404	13-Aug-20	TUMKUR	66	TR-2	TUMKUR_66	17:45	17:48	0:03	HAND TRIPPED
405	13-Aug-20	TUMKUR	66	TR-2	BALENAHALI_66	15:24	16:13	0:48	LINE CLEAR AVAILED
406	13-Aug-20	TUMKUR	66	URDIGERE-ANTHRASANAHALI	URDIGERE 66	10:39	14:27	3:48	NFBC ISSUED
407	13-Aug-20	TUMKUR	66	URDIGERE-KOLALA	URDIGERE 66	10:40	11:24	0:44	NFBC ISSUED
408	13-Aug-20	TUMKUR	66	URDIGERE-KOLALA	URDIGERE 66	14:12	15:14	1:02	NFBC ISSUED
409	13-Aug-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN:TRANSFORMER FAULT
410	13-Aug-20	TUMKUR	220	TR-1	MADHUGIRI 220	10:48	17:48	6:59	LINE CLEAR AVAILED
411	14-Aug-20	BAGALKOT	66	HONNALLI(BANUVALLI-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	18:46 (19.07.0.2020)			LINE OPEN:LINE CLEAR AVAILED
412	14-Aug-20	BAGALKOT	110	110/11KV, HV1	DAVALESHWAR 110	12:13	13:59	01:46	LINE CLEAR AVAILED
413	14-Aug-20	BAGALKOT	110	110/11KV, HV2 & HV3	TIKOTA 110	14:00	14:37	00:37	LINE CLEAR AVAILED
414	14-Aug-20	BAGALKOT	110	110/11KV,HV1,HV2&HV3	RANEENNUR 220	11:55	12:00	00:05	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
415	14-Aug-20	BAGALKOT	110	110/33KV, HV1	TIKOTA_110, BIJJARGI_33	14:00	14:37	00:37	LINE CLEAR AVAILED
416	14-Aug-20	BAGALKOT	110	110/33KV, HV4	KANABARGA_110, KAKATI_33 & SUZALON_33	17:10	18:04	00:54	LINE CLEAR AVAILED
417	14-Aug-20	BAGALKOT	110	110/33KV,HV1	RANEBENNUR_220,KUPPELL UR_33,RSNG_33	11:55	12:00	00:05	HAND TRIPPED
418	14-Aug-20	BAGALKOT	110	110/33KV,HV2	RANEBENNUR_220GUDGUR MAIDUR_33,HALIGERI_33	11:55	12:00	00:05	HAND TRIPPED
419	14-Aug-20	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
420	14-Aug-20	BAGALKOT	110	220/110KV,LV1	STATION NOT AFFECTED MK HUBLI_220	21:13 (14.80.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
421	14-Aug-20	BAGALKOT	110	220/110KV,LV2	STATION NOT AFFECTED MK HUBLI_220	17:09 (14.08.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
422	14-Aug-20	BAGALKOT	110	AMBEWADI- NK2 (HALIYAL)	HALIYAL_110	22:45	22:53	00:08	HAND TRIPPED
423	14-Aug-20	BAGALKOT	110	ATHARGA-KN SOLAR	ATHARGA_110	18:57	19:58	01:01	LINE FAULT
424	14-Aug-20	BAGALKOT	110	BAGALKOT-NAVANAGR(B)2	NAVANAGAR(B)_110	12:03	17:06	05:03	LINE CLEAR AVAILED
425	14-Aug-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN:LINE CLEAR AVAILED
426	14-Aug-20	BAGALKOT	110	GAJENDRAGAD-KUSTAGI	STATION NOT AFFECTED GAJENDRAGAD_110	7:40 (19.07.2020)			LINE OPEN:LINE CLEAR AVAILED
427	14-Aug-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN:LINE CLEAR AVAILED
428	14-Aug-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:0 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
429	14-Aug-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
430	14-Aug-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
431	14-Aug-20	BAGALKOT	110	NAVLGUND-KONNUR	KONNUR_110	09:15	18:21	09:06	LINE CLEAR AVAILED
432	14-Aug-20	BAGALKOT	110	RANEBENNUR-TUMMINAKATTI	TUMMINAKATTI_110	11:35	12:15	00:40	HAND TRIPPED
433	14-Aug-20	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
434	14-Aug-20	BAGALKOT	110	SIRSI 220-SIRSI2	STATION NOT AFFECTED SIRSI_220	15:50 (10.08.2020)			LINE OPEN:LINE CLEAR AVAILED
435	14-Aug-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
436	14-Aug-20	BAGALKOT	220	220/110KV,HV1,LV1,HV2.LV2	RANEBENNUR_220	12:45	18:29	05:44	LINE CLEAR AVAILED
437	14-Aug-20	BAGALKOT	220	AMBEWADI- NAGJHARI1	AMBEWADI_220	10:21	15:14	04:53	LINE CLEAR AVAILED
438	14-Aug-20	BAGALKOT	220	AMBEWADI- NAGJHARI1	STATION NOT AFFECTED AMBEWADI_220	21:46 (14.08.2020)			LOAD CURTAILMENT
439	14-Aug-20	BAGALKOT	220	AMBEWADI- NAGJHARI2	AMBEWADI_220	10:21	15:13	04:52	LINE CLEAR AVAILED
440	14-Aug-20	BAGALKOT	220	AMBEWADI-NARENDRA 1	STATION NOT AFFECTED AMBEWADI_220	21:22 (13.08.2020)	7:41 (14.08.2020)	10:19	LINE CHARGED
441	14-Aug-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN:LINE FAULT
442	14-Aug-20	BAGALKOT	220	BAGEWADI-ATRIA 2	STATION NOT AFFECTED BAGEWADI_220	17:00 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
443	14-Aug-20	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI 220	17:26 (24.07.2020)			LOAD CURTAILMENT
444	14-Aug-20	BAGALKOT	220	BALLIGAVI-RANEENNUR	RANEENNUR 220	11:55	18:15	06:20	LINE CLEAR AVOIDED
445	14-Aug-20	BAGALKOT	220	BELGAUM- CHIKKODI2	STATION NOT AFFECTED BELGAUM 220	18:02 (13.08.2020)	7:33 (14.08.2020)	13:31	LINE CHARGED
446	14-Aug-20	BAGALKOT	220	BELGAUM- NARENDRA2 (KANABARGI2)	STATION NOT AFFECTED BELGAUM 220	22:18 (04.08.2020)			LINE OPEN:LINE CLEAR AVOIDED
447	14-Aug-20	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM 220	17:02 (14.08.2020)			LINE OPEN:LINE CLEAR AVOIDED
448	14-Aug-20	BAGALKOT	220	GADAG-HARTHI1	GADAG 220	13:20	13:24	00:04	HAND TRIPPED
449	14-Aug-20	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG 220	13:22 (14.08.2020)			LOAD CURTAILMENT
450	14-Aug-20	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI 220	16:57 (10.08.2020)			LINE OPEN:LINE CLEAR AVOIDED
451	14-Aug-20	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI 220	18:35 (07.08.2020)			LINE OPEN:LINE FAULT
452	14-Aug-20	BAGALKOT	220	NAGJHARI1- HUBLI	STATION NOT AFFECTED HUBLI 220	21:43 (14.08.2020)			LINE OPEN:LINE CLEAR AVOIDED
453	14-Aug-20	BAGALKOT	220	NAGJHARI3- HUBLI	STATION NOT AFFECTED HUBLI 220	21:42 (14.08.2020)			LINE OPEN:LINE CLEAR AVOIDED
454	14-Aug-20	BAGALKOT	220	NARENDRA-AMBEWADI1	NARENDRA 220	15:14	15:33	00:19	LINE FAULT
455	14-Aug-20	BAGALKOT	220	NARENDRA-AMBEWADI1	NARENDRA 220	17:44	17:58	00:14	HAND TRIPPED
456	14-Aug-20	BAGALKOT	220	SHARAVATY 2-SIRSI	STATION NOT AFFECTED SIRSI 220	5:24:00 PM (10.8.2020)	17:23 (14.08.2020)	95:55 hrs	LINE CHARGED
457	14-Aug-20	BENGALURU	66	APPAREL PARK - KIADB	APPAREL PARK	23:38	23:43	00:05	LOAD CHANGE OVER
458	14-Aug-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
459	14-Aug-20	BENGALURU	66	DB PURA 220 - DG 1	AIR (EHT)	22:17	22:53	00:36	LINE FAULT
460	14-Aug-20	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	22:17	22:53	00:36	LINE FAULT
461	14-Aug-20	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	23:16	23:44	00:28	LINE FAULT
462	14-Aug-20	BENGALURU	66	HOODY 220 - BMRL (EHT)	BMRL (EHT)	13:09	15:44	02:34	LINE FAULT
463	14-Aug-20	BENGALURU	66	HV1	TUBUGERE	12:10	12:50	00:40	LINE CLEAR AVOIDED
464	14-Aug-20	BENGALURU	66	HV1	VIJAYAPURA	10:30	10:55	00:25	LINE CLEAR AVOIDED
465	14-Aug-20	BENGALURU	66	HV1	MEI LAYOUT	10:18	10:20	00:02	LOAD CHANGE OVER
466	14-Aug-20	BENGALURU	66	HV1	MEI LAYOUT	11:40	11:42	00:02	LOAD CHANGE OVER
467	14-Aug-20	BENGALURU	66	HV2	TUBUGERE	15:35	16:10	00:35	LINE CLEAR AVOIDED
468	14-Aug-20	BENGALURU	66	HV2	VIJAYAPURA	10:35	10:50	00:15	LINE CLEAR AVOIDED
469	14-Aug-20	BENGALURU	66	HV2	VIJAYAPURA	13:25	13:50	00:25	LINE CLEAR AVOIDED
470	14-Aug-20	BENGALURU	66	HV2	MEI LAYOUT	11:42	11:45	00:03	LOAD CHANGE OVER
471	14-Aug-20	BENGALURU	66	HV2	MEI LAYOUT	12:40	12:42	00:02	LOAD CHANGE OVER
472	14-Aug-20	BENGALURU	66	HV2	PADMANBHANAGAR	10:25	10:26	00:01	LINE CLEAR AVOIDED
473	14-Aug-20	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN:LINE FAULT
474	14-Aug-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN:LINE FAULT
475	14-Aug-20	GULBARGA	110	HV2	SHORAPUR 110	20:28	21:40	01:12	TRANSFORMER FAULT
476	14-Aug-20	GULBARGA	110	HV2	SHORAPUR 110	22:11	22:26	00:15	TRANSFORMER FAULT
477	14-Aug-20	GULBARGA	110	HV2	SHORAPUR 110	22:32	23:01	00:29	TRANSFORMER FAULT
478	14-Aug-20	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110, MANVI 110	23:51	23:59	00:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
479	14-Aug-20	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	20:28	20:52	00:24	LINE FAULT
480	14-Aug-20	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	22:11	22:19	00:08	LINE FAULT
481	14-Aug-20	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	22:32	23:03	00:31	LINE FAULT
482	14-Aug-20	GULBARGA	110	SHAHPUR-KHANAPUR	KHANAPUR_110, SAIDAPUR_110, WADAGERA_110, SANNATI_110, NALWAR_110	19:37	19:47	00:10	LINE FAULT
483	14-Aug-20	GULBARGA	110	SHAHPUR-KHANAPUR	KHANAPUR_110, SAIDAPUR_110, WADAGERA_110, SANNATI_110, NALWAR_110	21:14	21:28	00:14	LINE FAULT
484	14-Aug-20	GULBARGA	220	HV2	SIDHANOOR_220	00:25	00:55	00:30	TRANSFORMER FAULT
485	14-Aug-20	GULBARGA	220	SEDAM-SHAHPUR	SEDAM_220	05:49	06:03	00:14	LINE FAULT
486	14-Aug-20	GULBARGA	220	SINDHANOOR-LINGAPUR	SIDHANOOR_220	00:25	00:45	00:20	LINE FAULT
487	14-Aug-20	HASSAN	66	HV1	DUDDA_66	11:08	11:25	00:17	LINE CLEAR AVAILED
488	14-Aug-20	HASSAN	66	HV1	DUDDA_66	13:45	16:15	02:30	LINE CLEAR AVAILED
489	14-Aug-20	HASSAN	66	HV1	KANDLI_66	11:29	11:52	00:23	LINE CLEAR AVAILED
490	14-Aug-20	HASSAN	110	HV1	KONAJE_110	13:03	13:54	00:51	LINE CLEAR AVAILED
491	14-Aug-20	HASSAN	110	HV1	MRSMSG_220	15:41	17:30	01:49	LINE CLEAR AVAILED
492	14-Aug-20	HASSAN	110	JOG-NK2	NO STN AFFECTED	23:36 (7.08.2020)			LINE OPEN:LINE CLEAR AVAILED
493	14-Aug-20	HASSAN	110	KEMAR-Manipal1	KEMAR_220	18:32	20:23	01:51	LINE FAULT
494	14-Aug-20	HASSAN	110	KEMAR-Manipal2	KEMAR_220	18:32	19:06	00:34	LINE FAULT
495	14-Aug-20	HASSAN	110	KEMAR-Manipal2	KEMAR_220	19:16	19:20	00:04	HAND TRIPPED
496	14-Aug-20	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	18:35	19:31	00:56	MAIN SUPPLY FAILURE
497	14-Aug-20	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	18:23	20:24	02:01	MAIN SUPPLY FAILURE
498	14-Aug-20	HASSAN	110	NANDIKU-KEMAR1	NANDIKUR_110	11:53	14:00	02:07	LINE CLEAR AVAILED
499	14-Aug-20	HASSAN	110	NITUR11-MANIPAL	NITTUR_110	18:47	19:24	00:37	MAIN SUPPLY FAILURE
500	14-Aug-20	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	11:22	12:13	00:51	NFBC ISSUED
501	14-Aug-20	HASSAN	220	KEMAR-UPCL1	KEMAR_220	09:47	14:35	04:48	LINE CLEAR AVAILED
502	14-Aug-20	HASSAN	220	KEMAR-Varahi1	KEMAR_220	21:25 (13.08.2020)	10:37 (14.08.2020)	13:11 hrs	LINE CHARGED
503	14-Aug-20	HASSAN	220	KEMAR-Varahi1	KEMAR_220	10:38	15:51	05:13	LINE CLEAR AVAILED
504	14-Aug-20	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	11:59	15:08	03:09	LINE FAULT
505	14-Aug-20	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	11:59	15:08	03:09	LINE FAULT
506	14-Aug-20	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	14:25 (10.08.2020)	17:28 (14.08.2020)	99:02 hrs	LINE CHARGED
507	14-Aug-20	HASSAN	220	UPCL-KEMAR1	upcl_gen	08:10	14:35	06:25	LINE FAULT
508	14-Aug-20	HASSAN	220	VARAHI-KEMAR1	varahi_gen	21:25 (13.08.2020)	15:52 (14.08.2020)	42:26 hrs	LINE CHARGED
509	14-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	20:16 (13.08.2020)	6:30 (14.08.2020)	10:13 hrs	LINE CHARGED
510	14-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	22:37 (14.08.2020)			LINE OPEN:LINE CLEAR AVAILED
511	14-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	16:03	16:55	00:52	LINE FAULT
512	14-Aug-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	17:38 (13.08.2020)	6:54 (14.08.2020)	13:17 hrs	LINE CHARGED
513	14-Aug-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:14 (14.08.2020)			LINE OPEN:LINE CLEAR AVAILED
514	14-Aug-20	HASSAN	400	UPCL-HASSAN2	NO STN AFFECTED	16:21 (5.08.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
515	14-Aug-20	MYSURU	66	BOOKANAKERE-PANDAPURA	CHINAKURALI_66 BANANGADI_66	16:55	17:05	00:10	LINE FAULT
516	14-Aug-20	MYSURU	66	DK MAIDANA-JYOTHINAGARA	DKMAIDANA_66	10:01	16:27	06:26	LINE CLEAR AVAILED
517	14-Aug-20	MYSURU	66	HV1	HONNALLY_MYS_66	13:07	13:26	00:18	TRANSFORMER FAULT
518	14-Aug-20	MYSURU	66	HV1	SHIVALLY_66	14:21	15:26	01:04	LINE CLEAR AVAILED
519	14-Aug-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
520	14-Aug-20	MYSURU	66	HV2	FTS_66	11:45	13:14	01:29	LINE CLEAR AVAILED
521	14-Aug-20	MYSURU	66	KADAKOLA-DK MAIDANA	NO STATIONS INTERRUPTED	10:16	17:39	07:23	NFBC ISSUED
522	14-Aug-20	MYSURU	66	MYSORE SOUTH-GIS	MYSORESOUTH_66	10:07	15:53	05:46	LINE CLEAR AVAILED
523	14-Aug-20	MYSURU	66	MYSORE SOUTH-KADKOLA	MYSORESOUTH_66	10:06	15:53	05:46	LINE CLEAR AVAILED
524	14-Aug-20	MYSURU	66	SINDUVALLY-KADKOLA	NO STATIONS EFFECTED	7:40 (09.08.2020)			LINE OPEN:LINE CLEAR AVAILED
525	14-Aug-20	MYSURU	66	TUBINKERE-PANDAVAPURA	DODDABYADARAHALLI_66 BELAGOLA_66 PANDAVAPURA_66	07:01	07:12	00:11	LINE FAULT
526	14-Aug-20	MYSURU	66	TUBINKERE-PANDAVAPURA	GARUDANAUKADDA_66 SRIRANGAPATNA_66	07:01	07:12	00:11	LINE FAULT
527	14-Aug-20	TUMKUR	66	BHAKTHARA HALLI -ANCHEPALYA	BHAKTHARAHALLI_66	13:26	14:50	01:24	LINE CLEAR AVAILED
528	14-Aug-20	TUMKUR	66	HARAPPANAHALLI-SUZLON 1	SUZLON_IPP_66	12:15	15:00	02:45	LINE FAULT
529	14-Aug-20	TUMKUR	66	RANGENAHALLI- DYVARANAHALLI	RANGENAHALLI_66	08:00	17:43	09:42	LINE CLEAR AVAILED
530	14-Aug-20	TUMKUR	66	TR-1	BHAKTHARAHALLI_66	12:55	15:20	02:24	LINE CLEAR AVAILED
531	14-Aug-20	TUMKUR	66	TR-1	CHALLAKERE_66	11:00	11:25	00:25	HAND TRIPPED
532	14-Aug-20	TUMKUR	66	TR-1	CHIKKABANAGERE_66	17:08	17:52	00:43	LINE CLEAR AVAILED
533	14-Aug-20	TUMKUR	66	TR-1	DAVANAGERE_66	10:29	12:47	02:17	LINE CLEAR AVAILED
534	14-Aug-20	TUMKUR	66	TR-1	RANGANATHAPURA_66	07:45	08:27	00:41	LINE CLEAR AVAILED
535	14-Aug-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
536	14-Aug-20	TUMKUR	66	TR-2	HARIYABBE_66	17:14	17:17	00:03	LINE CLEAR AVAILED
537	14-Aug-20	TUMKUR	110	KB CROSS 220kv- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_11 0, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	13:27	13:58	00:30	LINE CLEAR AVAILED
538	14-Aug-20	TUMKUR	110	TR-1(LV SIDE)	KBCROSS_220	12:23	12:58	00:34	LINE CLEAR AVAILED
539	14-Aug-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN:TRANSFORMER FAULT
540	14-Aug-20	TUMKUR	110	TR-2	HULIYAR_110	14:06	15:45	01:39	LINE CLEAR AVAILED
541	14-Aug-20	TUMKUR	110	TR-2(LV SIDE)	KBCROSS_220	12:59	13:26	00:27	LINE CLEAR AVAILED
542	14-Aug-20	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	07:49	18:05	10:15	LINE CLEAR AVAILED
543	14-Aug-20	TUMKUR	220	CHITRADURGA 220kv- THALLAK 220	CHITRADURGA_220	07:52	17:49	09:56	LINE CLEAR AVAILED
544	14-Aug-20	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	07:53	18:05	10:12	NFBC ISSUED
545	14-Aug-20	TUMKUR	220	NITTUR 220kv- NELAMANGALA	NITTUR_220	10:49	13:35	02:45	NFBC ISSUED
546	14-Aug-20	TUMKUR	220	THALLAK 220kv-CHITRADURGA	THALLAKK_220	08:00	17:50	09:49	NFBC ISSUED
547	14-Aug-20	TUMKUR	220	TR-1	KBCROSS_220	12:23	12:57	00:34	LINE CLEAR AVAILED
548	14-Aug-20	TUMKUR	220	TR-2	CHITRADURGA_220	17:50	18:41	00:50	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
549	14-Aug-20	TUMKUR	220	TR-2	KBCROSS_220	12:59	13:26	00:26	LINE CLEAR AVAILED
550	15-Aug-20	BAGALKOT	66	HONNALLI(BANUVALLI-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020)			LINE OPEN:LINE CLEAR AVAILED
551	15-Aug-20	BAGALKOT	110	110/11KV, HV1	LOKAPUR_110	18:54	23:59	05:05	TRANSFORMER FAULT
552	15-Aug-20	BAGALKOT	110	110/11KV,HV1	RATTIHALLI_110	10:00	12:10	02:10	LINE CLEAR AVAILED
553	15-Aug-20	BAGALKOT	110	110/33KV, HV4	HIDAKAL_110, ALAGAWADI_33	18:10	19:03	00:53	TRANSFORMER FAULT
554	15-Aug-20	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
555	15-Aug-20	BAGALKOT	110	220/110KV,LV1	STATION NOT AFFECTED MK HUBLI_220	21:13 (14.80.2020)	7:33 (15.08.2020)	10:20	TRANSFORMER CHARGED
556	15-Aug-20	BAGALKOT	110	220/110KV,LV1	STATION NOT AFFECTED MK HUBLI_220	15:21 (15.08.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
557	15-Aug-20	BAGALKOT	110	220/110KV,LV2	STATION NOT AFFECTED MK HUBLI_220	17:09 (14.08.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
558	15-Aug-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN:LINE CLEAR AVAILED
559	15-Aug-20	BAGALKOT	110	GAJENDRAGAD-KUSTAGI	STATION NOT AFFECTED GAJENDRAGAD_110	7:40 19.07.2020)			LINE OPEN:LINE CLEAR AVAILED
560	15-Aug-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN:LINE CLEAR AVAILED
561	15-Aug-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:0 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
562	15-Aug-20	BAGALKOT	110	ITNAL-RAIBAG1&2	RAIBAG_110	18:29	20:17	01:48	LINE CLEAR AVAILED
563	15-Aug-20	BAGALKOT	110	JOG2- SIRSI	SIRSI_110	10:02	13:41	03:39	LINE CLEAR AVAILED
564	15-Aug-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
565	15-Aug-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
566	15-Aug-20	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
567	15-Aug-20	BAGALKOT	110	SIRSI 220-SIRSI2	STATION NOT AFFECTED SIRSI_220	15:50 (10.08.2020)	10:47 (15.08.2020)	114:57 hrs	LINE CHARGED
568	15-Aug-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
569	15-Aug-20	BAGALKOT	220	220/11KV,HV1&LV1	CHIKKODI_220	10:29	10:44	00:15	HAND TRIPPED
570	15-Aug-20	BAGALKOT	220	AMBEWADI- NAGJHARI1	AMBEWADI_220	21:46 (14.08.2020)	6:23 (15.08.2020)	08:37	LOAD CURTAILMENT
571	15-Aug-20	BAGALKOT	220	AMBEWADI- NAGJHARI1	STATION NOT AFFECTED AMBEWADI_220	6:29 (15.08.2020)			LINE OPEN:LINE CLEAR AVAILED
572	15-Aug-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN:LINE FAULT
573	15-Aug-20	BAGALKOT	220	BAGEWADI-ATRIA 2	STATION NOT AFFECTED BAGEWADI_220	17:00 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
574	15-Aug-20	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	17:26 (24.07.2020)			LOAD CURTAILMENT
575	15-Aug-20	BAGALKOT	220	BELGAUM- NARENDRA2 (KANABARGI2)	STATION NOT AFFECTED BELGAUM_220	22:18 (04.08.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
576	15-Aug-20	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	17:02 (14.08.2020)			LINE OPEN:LINE CLEAR AVAILED
577	15-Aug-20	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:22 (14.08.2020)			LOAD CURTAILMENT
578	15-Aug-20	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	16:57 (10.08.2020)			LINE OPEN:LINE CLEAR AVAILED
579	15-Aug-20	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	18:35 (07.08.2020)			LINE OPEN:LINE FAULT
580	15-Aug-20	BAGALKOT	220	MK HUBLI220-NARENDRA1	MK HUBLI_220	03:10	06:16	03:06	LOAD CURTAILMENT
581	15-Aug-20	BAGALKOT	220	MK HUBLI220-NARENDRA1	STATION NOT AFFECTED MK HUBLI_220	22:57 (15.08.2020)			LOAD CURTAILMENT
582	15-Aug-20	BAGALKOT	220	NAGJHARI1- HUBLI	STATION NOT AFFECTED HUBLI_220	21:43 (14.08.2020)	6:19 (15.08.2020)	08:36	LINE CHARGED
583	15-Aug-20	BAGALKOT	220	NAGJHARI3- HUBLI	STATION NOT AFFECTED HUBLI_220	21:42 (14.08.2020)	6:21 (15.08.2020)	08:39	LINE CHARGED
584	15-Aug-20	BAGALKOT	220	NARENDRA1-MAHALINGAPUR	MAHALINGAPUR_220	03:06	06:32	03:26	LINE CLEAR AVOID
585	15-Aug-20	BENGALURU	66	APPAREL PARK - NRS 220	APPAREL PARK	15:00	15:05	00:05	LOAD CHANGE OVER
586	15-Aug-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
587	15-Aug-20	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	15:03	15:13	00:10	LINE CLEAR AVOID
588	15-Aug-20	BENGALURU	66	GUNDLU KOTTUR - GOWRIBIDANUR 220	GUNDLU KOTTUR	10:00	10:55	00:55	LINE CLEAR AVOID
589	15-Aug-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	09:35	09:48	00:13	LINE CLEAR AVOID
590	15-Aug-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS	12:38	12:46	00:08	LINE CLEAR AVOID
591	15-Aug-20	BENGALURU	66	HV1	HAROBEL	08:40	09:31	00:51	LINE CLEAR AVOID
592	15-Aug-20	BENGALURU	66	HV2	KODIHALLI	09:21	09:26	00:05	TRANSFORMER FAULT
593	15-Aug-20	BENGALURU	66	NIMHANS 220 - BMT	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN:LINE FAULT
594	15-Aug-20	BENGALURU	220	HOODY 220 - YELAHANKA 220	NO STATION AFFECTED	16:6 (15.08.20)			LINE OPEN:LINE FAULT
595	15-Aug-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN:LINE FAULT
596	15-Aug-20	GULBARGA	110	HV1	GULBARGA WEST_110	21:06	21:15	00:09	TRANSFORMER FAULT
597	15-Aug-20	GULBARGA	110	HV1	MADIYAL_110	06:08	06:15	00:07	TRANSFORMER FAULT
598	15-Aug-20	GULBARGA	110	HV2	ALIPUR_220	09:20	10:10	00:50	TRANSFORMER FAULT
599	15-Aug-20	GULBARGA	110	HV2	KAMPLI_110_GLB	05:36	15:35	09:59	TRANSFORMER FAULT
600	15-Aug-20	GULBARGA	110	HV2	SINDHANOR_110	10:45	10:56	00:11	TRANSFORMER FAULT
601	15-Aug-20	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	22:50	22:55	00:05	LINE FAULT
602	15-Aug-20	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGWAT_110	19:51	19:58	00:07	LINE FAULT
603	15-Aug-20	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGWAT_110	22:10	22:15	00:05	LINE FAULT
604	15-Aug-20	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	23:40	23:45	00:05	LINE FAULT
605	15-Aug-20	GULBARGA	110	RAICHUR-SHAHPUR1	GABUR_110, DEODURGA_110	23:52(15.8.2020)			LINE OPEN:LINE FAULT
606	15-Aug-20	GULBARGA	110	RAICHUR-SINDHANOR2	KURDICROSS_110	15:51	15:57	00:06	LINE FAULT
607	15-Aug-20	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	21:10	21:22	00:12	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
608	15-Aug-20	GULBARGA	110	SHAHPUR-KHANAPUR	KHANAPUR_110, SAIDAPUR_110, WADAGERA_110, SANNATI_110, NALWAR_110	05:50	05:58	00:08	LINE FAULT
609	15-Aug-20	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	07:32	07:51	00:19	LINE FAULT
610	15-Aug-20	HASSAN	66	HV1	HOLALUR_66	15:24	19:43	04:19	MAIN SUPPLY FAILURE
611	15-Aug-20	HASSAN	66	HV2	HOLALUR_66	15:24	19:42	04:18	MAIN SUPPLY FAILURE
612	15-Aug-20	HASSAN	66	HV2	TAVARECHANAHALLI_66	13:21	14:27	01:06	TRANSFORMER FAULT
613	15-Aug-20	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	18:37 (15.08.2020)			LINE OPEN:LINE CLEAR AVAILED
614	15-Aug-20	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	18:37 (15.08.2020)			LINE OPEN:LINE CLEAR AVAILED
615	15-Aug-20	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	12:26	13:09	00:43	LINE CLEAR AVAILED
616	15-Aug-20	HASSAN	66	TAVAREC-IDLE	TAVARECHANAHALLI_66	13:21	19:40	06:19	LINE CLEAR AVAILED
617	15-Aug-20	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	08:34	09:11	00:37	LINE CLEAR AVAILED
618	15-Aug-20	HASSAN	110	HV1	BAIKAMPADI_110	16:40	17:24	00:44	MAIN SUPPLY FAILURE
619	15-Aug-20	HASSAN	110	JOG-NK1	mghejog_gen	10:42	13:15	02:33	LINE CLEAR AVAILED
620	15-Aug-20	HASSAN	110	JOG-NK2	NO STN AFFECTED	23:36 (7.08.2020)			LINE OPEN:LINE CLEAR AVAILED
621	15-Aug-20	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	16:32	17:21	00:49	LINE FAULT
622	15-Aug-20	HASSAN	110	KEMAR-Manipal1	KEMAR_220	00:22	09:36	09:14	LINE CLEAR AVAILED
623	15-Aug-20	HASSAN	110	LV2	SHIRALKOPPA_220	14:59	15:52	00:53	LINE CLEAR AVAILED
624	15-Aug-20	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	00:22	09:36	09:14	LINE FAULT
625	15-Aug-20	HASSAN	110	MSEZ-KAVOOR	MSEZ_220	15:37	16:31	00:54	HAND TRIPPED
626	15-Aug-20	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	10:56	14:13	03:17	LINE CLEAR AVAILED
627	15-Aug-20	HASSAN	220	HV2	SHIRALKOPPA_220	15:00	15:50	00:50	LINE CLEAR AVAILED
628	15-Aug-20	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	23:44 (15.08.2020)			LINE OPEN:LINE FAULT
629	15-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	22:37 (14.08.2020)			LINE OPEN:LINE CLEAR AVAILED
630	15-Aug-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:14 (14.08.2020)			LINE OPEN:LINE CLEAR AVAILED
631	15-Aug-20	HASSAN	400	UPCL-HASSAN2	NO STN AFFECTED	16:21 (5.08.2020)			LINE OPEN:LINE CLEAR AVAILED
632	15-Aug-20	MYSURU	66	CHIK MANDYA-HAMPAPURA	NO STATIONS INTERRUPTED	08:34	09:21	00:47	HAND TRIPPED
633	15-Aug-20	MYSURU	66	HUNSUR-ELWALA	GAVADAGERE_66	02:46	02:58	00:11	LINE FAULT
634	15-Aug-20	MYSURU	66	HUNSUR-HOOTAGALLI	HOSURGATE_66	09:48	09:55	00:07	LINE FAULT
635	15-Aug-20	MYSURU	66	HV1	DEVANOORMYS_66	09:53	10:26	00:32	TRANSFORMER FAULT
636	15-Aug-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
637	15-Aug-20	MYSURU	66	MYSORE SOUTH-KADAKOLA	NO STATIONS INTERRUPTED	11:28	18:37	07:08	NFBC ISSUED
638	15-Aug-20	MYSURU	66	RK NAGARA-KADAKOLA	NO STATIONS INTERRUPTED	11:44	18:46	07:02	LINE CLEAR AVAILED
639	15-Aug-20	MYSURU	66	SINDUVALLY-KADKOLA	NO STATIONS EFFECTED	7:40 (09.08.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
640	15-Aug-20	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	13:24	13:29	00:05	LINE FAULT
641	15-Aug-20	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	14:12	14:17	00:04	LINE FAULT
642	15-Aug-20	MYSURU	66	TUBINKERE-MANDYA 4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADII_66	08:02	08:09	00:07	LINE FAULT
643	15-Aug-20	MYSURU	66	TUBINKERE-MANDYA 4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADII_66	08:22	08:29	00:07	LINE FAULT
644	15-Aug-20	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	17:39	17:40	00:01	HAND TRIPPED
645	15-Aug-20	TUMKUR	66	NEELAGUNDA220KV- HARAPANAHALLI-1	HARAPPANAHALLI_66	18:52	19:05	00:13	LINE FAULT
646	15-Aug-20	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66	10:37	10:46	00:08	MAIN SUPPLY FAILURE
647	15-Aug-20	TUMKUR	66	TR-1	MANGALWADA_66	11:54	11:57	00:03	TRANSFORMER FAULT
648	15-Aug-20	TUMKUR	66	TR-1	MYLANAHALLI_66	08:09	08:21	00:11	TRANSFORMER FAULT
649	15-Aug-20	TUMKUR	66	TR-1	RANGANATHAPURA_66	07:12	08:14	01:01	LINE CLEAR AVAILED
650	15-Aug-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
651	15-Aug-20	TUMKUR	66	TR-2	HALURAMESHWARA_66	12:11	14:08	01:56	LINE CLEAR AVAILED
652	15-Aug-20	TUMKUR	66	TR-2	HALURAMESHWARA_66	16:34	17:52	01:18	LINE CLEAR AVAILED
653	15-Aug-20	TUMKUR	66	TR-2	LINGADAHALLI_TMK2_66	13:56	14:45	00:49	LINE CLEAR AVAILED
654	15-Aug-20	TUMKUR	66	TR-2	SANIKERE_66	15:03	15:09	00:05	TRANSFORMER FAULT
655	15-Aug-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN:TRANSFORMER FAULT
656	15-Aug-20	TUMKUR	110	TR-3	GUBBI_110	10:16	10:44	00:28	LINE CLEAR AVAILED
657	16-Aug-20	BAGALKOT	66	HONNALLI(BANUVALLI-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	18:46 (19.07.0.2020)			LINE OPEN:LINE CLEAR AVAILED
658	16-Aug-20	BAGALKOT	110	110/11KV,HV1	NARAGAL_110	04:25	04:50	00:25	TRANSFORMER FAULT
659	16-Aug-20	BAGALKOT	110	110/11KV,HV2	PG HUNSHYAL_110	10:30	11:58	01:28	LINE CLEAR AVAILED
660	16-Aug-20	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG_110	15:54 (04.08.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
661	16-Aug-20	BAGALKOT	110	220/110KV,LV1	STATION NOT AFFECTED MK HUBLI_220	15:21 (15.08.2020)	9:13 (16.08.2020)	17:52	TRANSFORMER CHARGED
662	16-Aug-20	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	17:09 (14.08.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
663	16-Aug-20	BAGALKOT	110	BAGEWADI1-MAMADAPUR	MAMADAPUR_110	01:58	02:33	00:35	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
664	16-Aug-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN:LINE CLEAR AVAILED
665	16-Aug-20	BAGALKOT	110	BELLATTI-ENERCON2&AB SOLAR	BELLATTI_110	04:08	04:30	00:22	HAND TRIPPED
666	16-Aug-20	BAGALKOT	110	GAJENDRAGAD-KUSTAGI	STATION NOT AFFECTED GAJENDRAGAD_110	7:40 (19.07.2020)	18:38 (16.08.2020)	682:58 hrs	LINE CHARGED
667	16-Aug-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN:LINE CLEAR AVAILED
668	16-Aug-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:0 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
669	16-Aug-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
670	16-Aug-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
671	16-Aug-20	BAGALKOT	110	LAXMESHWER-BELLATTI	BELLATTI_110	03:45	04:20	00:35	LINE FAULT
672	16-Aug-20	BAGALKOT	110	MAHALINGAPUR-DAVALESHWAR	DAVALESHWAR_110	06:30	06:42	00:12	LINE FAULT
673	16-Aug-20	BAGALKOT	110	MAHALINGAPUR-GSML1	MAHALINGAPUR_220	18:08	18:44	00:36	LINE FAULT
674	16-Aug-20	BAGALKOT	110	MAMADAPUR(B)-DEVARAGENNNUR	DEVARAGENNNUR_110	02:32	02:47	00:15	HAND TRIPPED
675	16-Aug-20	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL_110 (STATION NOT EFFECTED)	18:30 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
676	16-Aug-20	BAGALKOT	110	SOUDATTI220- RAMDURGA1	RAMDURGA_110	02:47	03:15	00:28	LINE FAULT
677	16-Aug-20	BAGALKOT	110	SOUDATTI220- RAMDURGA1	RAMDURGA_110	03:01	09:34	06:33	LINE FAULT
678	16-Aug-20	BAGALKOT	110	SOUDATTI220- RAMDURGA2	RAMDURGA_110	02:47	03:01	00:14	LINE FAULT
679	16-Aug-20	BAGALKOT	110	SOUDATTI220- RAMDURGA2	RAMDURGA_110	03:01	03:27	00:26	LINE FAULT
680	16-Aug-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
681	16-Aug-20	BAGALKOT	220	AMBEWADI- NAGJHARI1	STATION NOT AFFECTED AMBEWADI_220	6:29 (15.08.2020)	17:07 (16.08.2020)	34:38 hrs	LINE CHARGED
682	16-Aug-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN:LINE FAULT
683	16-Aug-20	BAGALKOT	220	BAGEWADI-ATRIA 2	STATION NOT AFFECTED BAGEWADI_220	17:00 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
684	16-Aug-20	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI_220	17:26 (24.07.2020)			LOAD CURTAILMENT
685	16-Aug-20	BAGALKOT	220	BELGAUM- NARENDRA2 (KANABARGI2)	STATION NOT AFFECTED BELGAUM_220	22:18 (04.08.2020)			LINE OPEN:LINE CLEAR AVAILED
686	16-Aug-20	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	17:02 (14.08.2020)	11:23 (16.08.2020)	42:21 hrs	LINE CHARGED
687	16-Aug-20	BAGALKOT	220	BIDNAL-HARTI 1	BIDNAL_220	08:49	10:14	01:25	LINE FAULT
688	16-Aug-20	BAGALKOT	220	GADAG-HARTHI2	STATION NOT AFFECTED GADAG_220	13:22 (14.08.2020)	9:10 (16.08.2020)	43:52 hrs	LINE CHARGED
689	16-Aug-20	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	16:57 (10.08.2020)			LINE OPEN:LINE CLEAR AVAILED
690	16-Aug-20	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	18:35 (07.08.2020)			LINE OPEN:LINE FAULT
691	16-Aug-20	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI1	VAJRAMATTI_220	18:08	19:12	01:04	LINE FAULT
692	16-Aug-20	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI2	VAJRAMATTI_220	18:08	19:12	01:04	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
693	16-Aug-20	BAGALKOT	220	MK HUBLI220-NARENDRA1	STATION NOT AFFECTED MK HUBLI_220	22:57 (15.08.2020)			LOAD CURTAILMENT
694	16-Aug-20	BAGALKOT	400	DHONI-GUDDADAHALLI	DHONI_400	3:25 (16.08.2020)			LINE OPEN:LINE FAULT
695	16-Aug-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
696	16-Aug-20	BENGALURU	66	HV1	MITTEMARI	08:55	10:30	01:35	LINE CLEAR AVAILED
697	16-Aug-20	BENGALURU	66	NIMHANS 220 - BMTc	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN:LINE FAULT
698	16-Aug-20	BENGALURU	220	HOODY 220 - YELAHANKA 220	NO STATION AFFECTED	16:6 (15.08.20)	00:47	08:40	LINE CHARGED
699	16-Aug-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN:LINE FAULT
700	16-Aug-20	GULBARGA	66	HV1	HANASI_66	11:05	11:45	00:40	LINE CLEAR AVAILED
701	16-Aug-20	GULBARGA	66	KOGALI-ITTAGI	KOGALI_66	12:36	12:43	00:07	LINE FAULT
702	16-Aug-20	GULBARGA	110	HV1	KAMPLI_110_GLB	5:55(16.8.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
703	16-Aug-20	GULBARGA	110	HV1	SHAHAPUR_220	16:36	16:47	00:11	TRANSFORMER FAULT
704	16-Aug-20	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHPUR_110	17:42	17:48	00:06	LINE FAULT
705	16-Aug-20	GULBARGA	110	KAPNOOR-GULBARGANORTH2	GULBARGANORTH_110,GUL BARGASOUTH_110,GUL_UNI 110	06:29	06:55	00:26	LINE FAULT
706	16-Aug-20	GULBARGA	110	LINGASUGUR-MUDGAL	MUDGAL_110	06:25	15:05	08:40	LINE FAULT
707	16-Aug-20	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	01:10	01:20	00:10	LINE FAULT
708	16-Aug-20	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	02:12	02:20	00:08	LINE FAULT
709	16-Aug-20	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110, VADAVATTI_110	03:35	03:44	00:09	LINE FAULT
710	16-Aug-20	GULBARGA	110	RAICHUR-SHAHPUR1	GABUR_110, DEODURGA_110	23:52(15.8.2020)	00:01(16.8.2020)	00:09 hrs	LINE CHARGED
711	16-Aug-20	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110, KORWARTEMPLE_110 RAJSHREE CEMENTS	05:28	11:53	06:25	LINE CLEAR AVAILED
712	16-Aug-20	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110, KORWARTEMPLE_110 RAJSHREE CEMENTS	22:29(16.8.2020)			LINE OPEN:LINE FAULT
713	16-Aug-20	GULBARGA	110	SEDAM-VICATSAGARCEMENTS	VICATSAGAR CEMENTS_1PP	21:10	21:40	00:30	LINE FAULT
714	16-Aug-20	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	20:15	20:25	00:10	LINE FAULT
715	16-Aug-20	GULBARGA	110	SIRWAR-MALLAT	SIRWAR_110	08:45	10:30	01:45	LINE CLEAR AVAILED
716	16-Aug-20	GULBARGA	220	HUMNABAD-HALBURGA	HALBURGA_220	23:04(15.8.2020)			LINE OPEN:LINE CLEAR AVALIED
717	16-Aug-20	GULBARGA	220	HV1	KUSTAGI_220	03:10	04:47	01:37	TRANSFORMER FAULT
718	16-Aug-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN:LINE CLEAR AVALIED
719	16-Aug-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN:LINE FAULT
720	16-Aug-20	GULBARGA	220	KUSTAGI-LINGASUGUR	KUSTAGI_220	06:25	07:00	00:35	LINE FAULT
721	16-Aug-20	GULBARGA	220	MALLAT-LINGASUGUR	LINGASUGUR_220	06:25	06:30	00:05	LINE FAULT
722	16-Aug-20	GULBARGA	220	MALLAT-RTPS3	MALLAT_220	23:45(16.8.2020)			LINE OPEN:LINE FAULT
723	16-Aug-20	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	10:42(11.8.2020)			LINE OPEN:LINE CLEAR AVALIED
724	16-Aug-20	GULBARGA	220	SINDHANOOR-LINGASUGUR	SIDHANOOR_220	03:15	03:25	00:10	LINE FAULT
725	16-Aug-20	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	13:27	13:36	00:09	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
726	16-Aug-20	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	13:27	13:36	00:09	HAND TRIPPED
727	16-Aug-20	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	13:27	13:36	00:09	HAND TRIPPED
728	16-Aug-20	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	13:27	13:36	00:09	HAND TRIPPED
729	16-Aug-20	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	13:28	13:37	00:09	HAND TRIPPED
730	16-Aug-20	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	13:28	13:37	00:09	HAND TRIPPED
731	16-Aug-20	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	13:27	13:36	00:09	HAND TRIPPED
732	16-Aug-20	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	13:27	13:36	00:09	HAND TRIPPED
733	16-Aug-20	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	13:30	13:41	00:11	MAIN SUPPLY FAILURE
734	16-Aug-20	HASSAN	66	HV1	HOLENARASIPURA_220	10:27	13:36	03:09	LINE CLEAR AVAILED
735	16-Aug-20	HASSAN	66	HV1	HNPURA_66	13:31	13:38	00:07	MAIN SUPPLY FAILURE
736	16-Aug-20	HASSAN	66	HV1	MALALI_66	13:30	13:38	00:08	MAIN SUPPLY FAILURE
737	16-Aug-20	HASSAN	66	HV1	MOSALEHOSAHALLI_66	13:29	13:37	00:08	MAIN SUPPLY FAILURE
738	16-Aug-20	HASSAN	66	HV2	HNPURA_66	13:30	13:38	00:08	MAIN SUPPLY FAILURE
739	16-Aug-20	HASSAN	66	JNPR2-HNPR1	HOLENARASIPURA_220	13:28	13:36	00:08	HAND TRIPPED
740	16-Aug-20	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	18:37 (15.08.2020)	0:50 (16.08.2020)	6:12 hrs	LINE CHARGED
741	16-Aug-20	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	12:09	17:24	05:15	LINE CLEAR AVAILED
742	16-Aug-20	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	18:37 (15.08.2020)	0:50 (16.08.2020)	6:12 hrs	LINE CHARGED
743	16-Aug-20	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	03:19	17:24	14:05	LINE FAULT
744	16-Aug-20	HASSAN	110	HV1	SHIRALKOPPA_110	03:05	09:55	06:50	TRANSFORMER FAULT
745	16-Aug-20	HASSAN	110	HV2	BIRUR_110	18:20 (16.08.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
746	16-Aug-20	HASSAN	110	JOG-NK1	mghejog_gen	07:47	14:13	06:26	LINE FAULT
747	16-Aug-20	HASSAN	110	JOG-NK2	NO STN AFFECTED	23:36 (7.08.2020)			LINE OPEN:LINE CLEAR AVAILED
748	16-Aug-20	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	23:44 (15.08.2020)	12:16 (16.08.2020)	12:31 hrs	LINE CHARGED
749	16-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	22:37 (14.08.2020)			LINE OPEN:LINE CLEAR AVAILED
750	16-Aug-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:14 (14.08.2020)			LINE OPEN:LINE CLEAR AVAILED
751	16-Aug-20	HASSAN	400	UPCL-HASSAN2	NO STN AFFECTED	16:21 (5.08.2020)			LINE OPEN:LINE CLEAR AVAILED
752	16-Aug-20	MYSURU	66	CR NAGARA-CHANDAKAWADI	CHANDAKAVADI_66	10:09	16:41	06:31	LINE CLEAR AVAILED
753	16-Aug-20	MYSURU	66	CR NAGARA-GUNDLUPETE	TERAKANAMBE_66	09:11	12:39	03:27	LINE CLEAR AVAILED
754	16-Aug-20	MYSURU	66	CR NAGARA-KABBALLI	KABHALLY_66 HARVEY_66	10:12	12:53	02:41	LINE CLEAR AVAILED
755	16-Aug-20	MYSURU	66	CR NAGARA-KABBALLI	GUNDLPET_66 TERAKANAMBE_66	09:15	14:02	04:47	LINE CLEAR AVAILED
756	16-Aug-20	MYSURU	66	CR NAGARA-YALANDUR	NO STATIONS INTERRUPTED	14:39	16:21	01:42	LINE CLEAR AVAILED
757	16-Aug-20	MYSURU	66	GUNDLUPETE-BEGUR	BEGUR_66	08:40	13:20	04:40	NFBC ISSUED
758	16-Aug-20	MYSURU	66	GUNDLUPETE-BOMMALAPURA	BOMMALAPURA_66	09:15	15:40	06:25	LINE CLEAR AVAILED
759	16-Aug-20	MYSURU	66	GUNDLUPETE-CR NAGARA	GUNDLUPETE & TERAKANAMBI	09:15	14:02	04:47	LINE CLEAR AVAILED
760	16-Aug-20	MYSURU	66	GUNDLUPETE-HANGALA	HANGLA_66 BHARGI_66	09:11	13:45	04:33	LINE CLEAR AVAILED
761	16-Aug-20	MYSURU	66	HANNUR-AMP SOLAR	NO STATIONS INTERRUPTED	18:35	18:54	00:19	LINE FAULT
762	16-Aug-20	MYSURU	66	HANNUR-KOTHANUR	KOTTANUR_66	16:40	17:20	00:40	NFBC ISSUED
763	16-Aug-20	MYSURU	66	HANNUR-MADHUVANAHALLI 1	NO STATIONS INTERRUPTED	18:35	18:52	00:17	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
764	16-Aug-20	MYSURU	66	HV1	MADHUVANAHALLI_220	13:50	14:49	00:59	LINE CLEAR AVAILED
765	16-Aug-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
766	16-Aug-20	MYSURU	66	HV2	MADHUVANAHALLI_220	12:40	14:55	02:15	LINE CLEAR AVAILED
767	16-Aug-20	MYSURU	66	MADHUVANAHALLI-KOLLEGALA	KOLLEGALA_66	10:30	15:54	05:24	NFBC ISSUED
768	16-Aug-20	MYSURU	66	MADHUVANAHALLI-KUNTHUR	KUNTHUR_66	09:55	15:51	05:56	NFBC ISSUED
769	16-Aug-20	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	10:20	16:00	05:40	NFBC ISSUED
770	16-Aug-20	MYSURU	66	RAMAPURA-COWDALLI	RAMAPURA_MYS_66	10:30	17:30	07:00	LINE CLEAR AVAILED
771	16-Aug-20	MYSURU	66	RK NAGARA-KADKOLA	NO STATIONS INTERRUPTED	08:46	18:38	09:52	NFBC ISSUED
772	16-Aug-20	MYSURU	66	SINDUVALLY-KADKOLA	NO STATIONS EFFECTED	7:40 (09.08.2020)			LINE OPEN:LINE CLEAR AVAILED
773	16-Aug-20	MYSURU	66	TUBINKERE-MANDYA4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADII_66 MANDYA_66	07:42	07:54	00:12	LINE FAULT
774	16-Aug-20	MYSURU	66	TUBINKERE-MANDYA4	CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADII_66 MANDYA_66	08:02	08:09	00:07	LINE FAULT
775	16-Aug-20	TUMKUR	66	BANUVALLI- NANDUGUDI	BANUVALLI_66	15:42	15:53	00:10	LINE FAULT
776	16-Aug-20	TUMKUR	66	BELADADARA- ANTHRASANAHALLI	BELADARA_66	10:26	10:31	00:05	HAND TRIPPED
777	16-Aug-20	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	14:10	15:40	01:30	LINE CLEAR AVAILED
778	16-Aug-20	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	18:36	18:54	00:18	LINE FAULT
779	16-Aug-20	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	19:54	21:14	01:19	LINE FAULT
780	16-Aug-20	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	13:30	13:45	00:14	LINE FAULT
781	16-Aug-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:00	12:18	00:18	LINE FAULT
782	16-Aug-20	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	12:00	12:10	00:10	LINE FAULT
783	16-Aug-20	TUMKUR	66	MAYAKONDA- DAVANAGERE SRS 220KV	MAYAKONDA_66	05:59	06:10	00:10	LINE FAULT
784	16-Aug-20	TUMKUR	66	TR-1	BANUVALLI_66	16:59	17:50	00:51	LINE CLEAR AVAILED
785	16-Aug-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
786	16-Aug-20	TUMKUR	66	TR-2	HALURAMESHWARA_66	10:30	15:21	04:50	LINE CLEAR AVAILED
787	16-Aug-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN:TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
788	17-Aug-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	18:46 (19.07.0.2020)			LINE OPEN:LINE CLEAR AVAILED
789	17-Aug-20	BAGALKOT	110	110/11KV,HV1	VAJRAMATTI 110	13:59	19:45	5:46	LINE CLEAR AVOIDED
790	17-Aug-20	BAGALKOT	110	110/11KV,HV1,HV2	VAJRAMATTI 110	8:31	13:47	5:16	LINE CLEAR AVOIDED
791	17-Aug-20	BAGALKOT	110	110/33KV, HV3	MUDDEBIHAL 110, NALATWAD, DAVALAGI & TANGADAGI 33	15:40	16:05	0:25	LINE CLEAR AVOIDED
792	17-Aug-20	BAGALKOT	110	110/33KV,HV4	STATION NOT AFFECTED GADAG 110	15:54 (04.08.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
793	17-Aug-20	BAGALKOT	110	220/110KV,LV2	MK HUBLI 220	17:09 (14.08.2020)	10:36 (17.08.2020)	65:27hrs	TRANSFORMER CHARGED
794	17-Aug-20	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	KAVALWADA 110	13:52	14:01	0:09	HAND TRIPPED
795	17-Aug-20	BAGALKOT	110	B.BAGEWADI-MUDDEBIHAL	MUDDEBIHAL 110	15:56	16:02	0:06	LINE CLEAR AVOIDED
796	17-Aug-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM 110	15:16 (20.06.2020)			LINE OPEN:LINE CLEAR AVAILED
797	17-Aug-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA 110	18:28 (30.05.2020)			LINE OPEN:LINE CLEAR AVAILED
798	17-Aug-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:0 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
799	17-Aug-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
800	17-Aug-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR 110	18:26 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
801	17-Aug-20	BAGALKOT	110	MUDDEBIHAL-BALAJI SUGARS & KNM SOLAR	BALAJI SUGARS & KNM SOLAR 110	15:57	16:00	0:03	LINE CLEAR AVOIDED
802	17-Aug-20	BAGALKOT	110	SHIROL-JAMAKHANDI	SHIROL 110 (STATION NOT EFFECTED)	18:30 (01.08.2020)			LINE OPEN:LINE CLEAR AVAILED
803	17-Aug-20	BAGALKOT	110	SIRSI220-UMMACHAGI	UMMACHAGI 110	16:06	16:23	0:17	LINE FAULT
804	17-Aug-20	BAGALKOT	110	SIRSI-KUMTA2	STATION NOT AFFECTED KUMTA 110	11:38 (16.08.2020)	12:44 (17.08.2020)	25:06hrs	LINE CHARGED
805	17-Aug-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR 110	21:11 (29.05.2020)			LINE OPEN:LINE CLEAR AVAILED
806	17-Aug-20	BAGALKOT	110	VAJRAMATTI220-MANTUR1	MANTUR 110	14:39	17:44	3:05	LINE CLEAR AVOIDED
807	17-Aug-20	BAGALKOT	110	VAJRAMATTI220-VAJRAMATTI	VAJRAMATTI 110	8:31	13:46	5:15	LINE CLEAR AVOIDED
808	17-Aug-20	BAGALKOT	110	VAJRAMATTI220-VAJRAMATTI	VAJRAMATTI 110	14:44	14:50	0:06	LINE CLEAR AVOIDED
809	17-Aug-20	BAGALKOT	110	VAJRAMATTI220-VAJRAMATTI	VAJRAMATTI 110	18:41	18:46	0:05	LINE CLEAR AVOIDED
810	17-Aug-20	BAGALKOT	220	220/110KV,HV2,LV2	VAJRAMATTI 220	18:21 (16.08.2020)	12:45 (17.08.2020)	18:24hrs	LINE CHARGED
811	17-Aug-20	BAGALKOT	220	AMBEWADI- NARENDRA2	AMBEWADI 220	10:03	10:22	0:19	LINE FAULT
812	17-Aug-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT 220	9:16 (30.04.2020)			LINE OPEN:LINE FAULT
813	17-Aug-20	BAGALKOT	220	BAGEWADI-ATRIA 2	STATION NOT AFFECTED BAGEWADI 220	17:00 (01.08.2020)	15:57 (17.08.2020)	406:57hrs	LINE CHARGED
814	17-Aug-20	BAGALKOT	220	BAGEWADI-ATRIA 2	STATION NOT AFFECTED BAGEWADI 220	16:26 (17.08.2020)			LINE OPEN:LINE CLEAR AVAILED
815	17-Aug-20	BAGALKOT	220	BAGEWADI-BIJAPUR1 (NANDIHAL1)	STATION NOT AFFECTED BAGEWADI 220	17:26 (24.07.2020)			LOAD CURTAILMENT
816	17-Aug-20	BAGALKOT	220	BELGAUM- CHIKKODI2	BELGAUM 220	21:12 (17.08.2020)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
817	17-Aug-20	BAGALKOT	220	BELGAUM- NARENDRA2 (KANABARGI2)	STATION NOT AFFECTED BELGAUM_220	22:18 (04.08.2020)			LINE OPEN:LINE CLEAR AVAILED
818	17-Aug-20	BAGALKOT	220	GADAG-HARTHI1	GADAG_220	12:19 (17.08.2020)			LOAD CURTAILMENT
819	17-Aug-20	BAGALKOT	220	HUBLI 1-SIRSI	STATION NOT AFFECTED SIRSI_220	16:57 (10.08.2020)			LINE OPEN:LINE CLEAR AVAILED
820	17-Aug-20	BAGALKOT	220	HUBLI 2-SIRSI	STATION NOT AFFECTED SIRSI_220	18:35 (07.08.2020)			LINE OPEN:LINE FAULT
821	17-Aug-20	BAGALKOT	220	MK HUBLI220-NARENDRA1	STATION NOT AFFECTED MK HUBLI_220	22:57 (15.08.2020)			LOAD CURTAILMENT
822	17-Aug-20	BAGALKOT	400	DHONI-GUDDADAHALLI	DHONI_400	3:25 (16.08.2020)			LOAD CURTAILMENT
823	17-Aug-20	BENGALURU	66	BAGEPALLI - GOWRIBIDANUR 1 & 2	NO STATION AFFECTED	10:16(17/08/2020)			LINE OPEN:LINE CLEAR AVAILED
824	17-Aug-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN:LINE FAULT
825	17-Aug-20	BENGALURU	66	CHINTAMANI 220 - IRAGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	13:21	14:01	00:40	LINE CLEAR AVOID
826	17-Aug-20	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	11:39	13:49	02:10	LINE CLEAR AVOID
827	17-Aug-20	BENGALURU	66	HV1	SADLI	15:46	16:15	00:28	LINE CLEAR AVOID
828	17-Aug-20	BENGALURU	66	HV1	DALASNUR	11:39	11:50	00:10	LINE CLEAR AVOID
829	17-Aug-20	BENGALURU	66	HV2	ISRO LAYOUT	13:05	13:08	00:03	LINE CLEAR AVOID
830	17-Aug-20	BENGALURU	66	HV2	KHODAYS 220	16:43	16:47	00:04	LINE CLEAR AVOID
831	17-Aug-20	BENGALURU	66	HV2	SADLI	10:30	10:50	00:20	LINE CLEAR AVOID
832	17-Aug-20	BENGALURU	66	HV2	DALASNUR	14:00	14:05	00:05	LINE CLEAR AVOID
833	17-Aug-20	BENGALURU	66	HV3	ADUGODI	13:11	14:20	01:09	LINE CLEAR AVOID
834	17-Aug-20	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	15:49	16:20	00:31	LINE CLEAR AVOID
835	17-Aug-20	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	16:25	16:30	00:05	LINE FAULT
836	17-Aug-20	BENGALURU	66	NIMHANS 220 - BMTc	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN:LINE FAULT
837	17-Aug-20	BENGALURU	66	TK HALLI 220 - SHIMSHA 1	T K HALLI 220	06:04	06:23	00:19	LINE FAULT
838	17-Aug-20	BENGALURU	66	TK HALLI 220 - SHIMSHA 1	T K HALLI 220	11:04	16:12	05:08	LINE FAULT
839	17-Aug-20	BENGALURU	220	NRS 220 - A STATION 220	NO STATION AFFECTED	14:26(29-07-2020)			LINE OPEN:LINE FAULT
840	17-Aug-20	GULBARGA	66	HV1	HANASI_66	16:15	16:46	00:31	LINE CLEAR AVOID
841	17-Aug-20	GULBARGA	66	KOGALI-ITTAGI	KOGALI_66	09:18	09:34	00:16	LINE FAULT
842	17-Aug-20	GULBARGA	110	HV1	KAMPLI_110_GLB	5:55(16.8.2020)	15:21(17.8.2020)	33:26HRS	TRANSFORMER FAULT
843	17-Aug-20	GULBARGA	110	HV2	DEODURGA_110	12:38	12:45	00:07	TRANSFORMER FAULT
844	17-Aug-20	GULBARGA	110	HV2	HATTI_110	09:07	09:12	00:05	TRANSFORMER FAULT
845	17-Aug-20	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110, KORWARTEMPLE_110 RAJSHREE CEMENTS	22:29(16.8.2020)	8:45(17.8.2020)	10:16HRS	LINE CHARGED
846	17-Aug-20	GULBARGA	110	SEDAM-VICATSAGAR CEMENTS	VICATSAGAR CEMENTS IPP KEMBHAVI_110,	06:10	07:00	00:50	LINE FAULT
847	17-Aug-20	GULBARGA	110	SHAHPUR-KEMBHAVI1	UGARSUGARS_IPP,ASKI_110, HUNASGI_110	05:36	05:46	00:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
848	17-Aug-20	GULBARGA	110	SHAHPUR-KHANAPUR	KHANAPUR_110, SAIDAPUR_110, WADAGERA_110, SANNATI_110, NALWAR_110	18:22	18:42	00:20	LINE FAULT
849	17-Aug-20	GULBARGA	220	HUMNABAD-HALBURGA	HALBURGA_220	23:04(15.8.2020)	10:48(17.8.2020)	35:44HRS	LINE CHARGED
850	17-Aug-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN:LINE CLEAR AVALIED
851	17-Aug-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN:LINE FAULT
852	17-Aug-20	GULBARGA	220	MALLAT-RTPS3	MALLAT_220	23:45(16.8.2020)	00:39(17.8.2020)	00:54HRS	LINE CHARGED
853	17-Aug-20	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	14:05	16:46	02:41	LINE CLEAR AVALIED
854	17-Aug-20	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	18:20(17.8.2020)			LINE OPEN:LINE CLEAR AVALIED
855	17-Aug-20	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	10:42(11.8.2020)	17:08(17.8.2020)	150:26HRS	LINE CHARGED
856	17-Aug-20	GULBARGA	220	SEDAM-SHAHPUR	SEDAM_220	05:56	06:19	00:23	LINE FAULT
857	17-Aug-20	HASSAN	66	DODDAKA-KRNAGARA	DODDAKADANUR_66	06:40	09:02	02:22	MAIN SUPPLY FAILURE
858	17-Aug-20	HASSAN	66	DODDAKA-HNPURA	DODDAKADANUR_66	06:40	08:38	01:58	NFBC ISSUED
859	17-Aug-20	HASSAN	66	DODDAKA-HNPURA	DODDAKADANUR_66	13:57	15:07	01:10	NFBC ISSUED
860	17-Aug-20	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	06:37	09:00	02:23	LINE CLEAR AVALIED
861	17-Aug-20	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	13:54	15:15	01:21	LINE CLEAR AVALIED
862	17-Aug-20	HASSAN	66	HV1	DODDAKADANUR_66	06:40	09:01	02:21	MAIN SUPPLY FAILURE
863	17-Aug-20	HASSAN	66	HV1	DODDAKADANUR_66	13:56	15:17	01:21	MAIN SUPPLY FAILURE
864	17-Aug-20	HASSAN	110	HV1	KONAJE_110	10:39	11:25	00:46	LINE CLEAR AVALIED
865	17-Aug-20	HASSAN	110	HV1	SAGARA_110	08:14	09:11	00:57	TRANSFORMER FAULT
866	17-Aug-20	HASSAN	110	HV2	BIRUR_110	18:20 (16.08.2020)	12:01 (17.08.2020)	17:40 hrs	LINE CHARGED
867	17-Aug-20	HASSAN	110	HV3	PUTTUR_110	16:04	16:16	00:12	TRANSFORMER FAULT
868	17-Aug-20	HASSAN	110	JOG-NK2	NO STN AFFECTED	23:36 (7.08.2020)			LINE OPEN:LINE CLEAR AVALIED
869	17-Aug-20	HASSAN	110	LV2	SHIRALKOPPA_220	11:34	14:16	02:42	LINE CLEAR AVALIED
870	17-Aug-20	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	11:55	12:03	00:08	LINE FAULT
871	17-Aug-20	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	10:18	12:18	02:00	LINE CLEAR AVALIED
872	17-Aug-20	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	10:19	12:19	02:00	NFBC ISSUED
873	17-Aug-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	22:37 (14.08.2020)			LINE OPEN:LINE CLEAR AVALIED
874	17-Aug-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:14 (14.08.2020)	7:10 (17.08.2020)	33:55 hrs	LINE CHARGED
875	17-Aug-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	16:42 (17.08.2020)			LINE OPEN:LINE CLEAR AVALIED
876	17-Aug-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	16:21 (5.08.2020)	14:30 (17.08.2020)	296:08 hrs	LINE CHARGED
877	17-Aug-20	MYSURU	66	BESAGRALLI-KOPPA	NO STATIONS INTERRUPTED	14:26	15:55	1:28	LINE CLEAR AVALIED
878	17-Aug-20	MYSURU	66	DODDARAYAPETE-CR NAGARA 1	DODDARAYAPET_66	13:16	17:43	4:27	LINE CLEAR AVALIED
879	17-Aug-20	MYSURU	66	DODDARAYAPETE-CR NAGARA 2	DODDARAYAPET_66	13:16	17:43	4:27	LINE CLEAR AVALIED
880	17-Aug-20	MYSURU	66	DODDARAYAPETE-KUNTHUR	DODDARAYAPET_66	15:15	18:43	3:28	LINE CLEAR AVALIED
881	17-Aug-20	MYSURU	66	FTS-JYOTHINAGARA	NO STATIONS INTERRUPTED	14:42	18:20	3:38	LINE CLEAR AVALIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
882	17-Aug-20	MYSURU	66	FTS-RAJEEV NAGARA	NO STATIONS INTERRUPTED	14:42	18:20	3:38	LINE CLEAR AVAILED
883	17-Aug-20	MYSURU	66	HANAGODU-PONNAMPETE	NO STATIONS INTERRUPTED	15:45	16:01	0:15	HAND TRIPPED
884	17-Aug-20	MYSURU	66	HANAGODU-PONNAMPETE	NO STATIONS INTERRUPTED	16:01	18:02	2:00	LINE CLEAR AVAILED
885	17-Aug-20	MYSURU	66	HOOTAGALLI-BOGADHI	BOGADHI_66 KALAMANDIRA_66 MYSORESOUTH_66	13:00	13:21	0:20	HAND TRIPPED
886	17-Aug-20	MYSURU	66	HOOTAGALLI-DATTAGALLI	DATTAGALLY_66 MANDAKALLI_66 RKNAGARA_66	13:00	18:31	5:31	LINE CLEAR AVAILED
887	17-Aug-20	MYSURU	66	HOOTAGALLI-VIJAYANAGARA	VAJMANGALA BANNIMANTAP	12:26 (17/08/2020)			LINE OPEN:LINE FAULT
888	17-Aug-20	MYSURU	66	HV1	AKKIHEBBAL_66	15:21	16:33	1:11	LINE CLEAR AVAILED
889	17-Aug-20	MYSURU	66	HV1	DKMAIDANA_66	15:45	16:06	0:21	LINE CLEAR AVAILED
890	17-Aug-20	MYSURU	66	HV1	KRNAGARA_66	11:57	12:18	0:21	LINE CLEAR AVAILED
891	17-Aug-20	MYSURU	66	HV1	KRPET_66	13:52	15:20	1:27	LINE CLEAR AVAILED
892	17-Aug-20	MYSURU	66	HV1	METAGALLY_66	12:34	12:37	0:02	TRANSFORMER FAULT
893	17-Aug-20	MYSURU	66	HV1	METAGALLY_66	12:54	12:58	0:03	TRANSFORMER FAULT
894	17-Aug-20	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
895	17-Aug-20	MYSURU	66	HV2	BGPURA_66	15:19	15:54	0:34	LINE CLEAR AVAILED
896	17-Aug-20	MYSURU	66	HV2	HDKOTE_66	15:45	16:00	0:15	LINE CLEAR AVAILED
897	17-Aug-20	MYSURU	66	HV2	KRPET_66	10:18	12:15	1:57	LINE CLEAR AVAILED
898	17-Aug-20	MYSURU	66	HV3	KRPET_66	11:15	13:45	2:30	LINE CLEAR AVAILED
899	17-Aug-20	MYSURU	66	KADAKOLA-DK MAIDANA	NO STATIONS INTERRUPTED	9:31	16:12	6:41	LINE CLEAR AVAILED
900	17-Aug-20	MYSURU	66	KADAKOLA-RK NAGARA	NO STATIONS INTERRUPTED	10:26	13:32	3:05	LINE CLEAR AVAILED
901	17-Aug-20	MYSURU	66	KUNTHUR-DODDRAIPETE	TNARASIPURA_66 MUGUR_66 SANTHEMARAHALLI_66 JANNUR_66 THAYURU_66 DODDARAYAPET_66	6:09	6:21	0:12	LINE FAULT
902	17-Aug-20	MYSURU	66	KUSHALNAGARA 220- RAMANTHAPURA 1	ALUR SIDDAPUR_66	12:09	12:17	0:08	LINE FAULT
903	17-Aug-20	MYSURU	66	MANDGERE-HOLENARSIPURA	MANDGERE_66	6:38	16:41	10:03	LINE CLEAR AVAILED
904	17-Aug-20	MYSURU	66	MEGALAPURA-SFC	THUMBLA_66 GARGESHWARI_66 VYASRAJPURA_66 CHIDRAVALLI_66 BGPURA_66	5:41	5:59	0:18	LINE FAULT
905	17-Aug-20	MYSURU	66	MYSORE SOUTH-KADAKOLA	NO STATIONS INTERRUPTED	10:51	13:25	2:34	NFBC ISSUED
906	17-Aug-20	MYSURU	66	RAVANDUR-KITTUR	RAVANDUR_66	13:50	14:11	0:20	LINE FAULT
907	17-Aug-20	MYSURU	66	SFC SIVA-PGL	NO STATIONS INTERRUPTED	6:04	6:06	0:02	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
908	17-Aug-20	MYSURU	66	SFC SIVA-PGL	NO STATIONS INTERRUPTED	11:05	11:15	0:10	LINE FAULT
909	17-Aug-20	MYSURU	66	SINDUVALLY-KADKOLA	NO STATIONS INTERRUPTED	7:40 (09.08.2020)			LINE OPEN:LINE CLEAR AVAILED
910	17-Aug-20	MYSURU	220	HV2	HOOTAGALLY_220	13:03	14:26	1:22	LINE CLEAR AVAILED
911	17-Aug-20	TUMKUR	66	BALENAHALLI-CHITRADURGA	BALENAHALLI_66	7:20	7:23	0:02	HAND TRIPPED
912	17-Aug-20	TUMKUR	66	BANUVALLI- HONNALLI	BANUVALLI_66	11:50	11:55	0:05	LINE FAULT
913	17-Aug-20	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	13:57	19:02	5:04	LINE CLEAR AVAILED
914	17-Aug-20	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL EHT_66	11:50	12:00	0:10	LINE FAULT
915	17-Aug-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	3:01	3:19	0:17	LINE FAULT
916	17-Aug-20	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	3:01	3:12	0:11	LINE FAULT
917	17-Aug-20	TUMKUR	66	TR-1	BADDIHALLI_66	11:55	12:14	0:18	LINE CLEAR AVAILED
918	17-Aug-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN:TRANSFORMER FAULT
919	17-Aug-20	TUMKUR	66	TR-2	BADDIHALLI_66	12:17	12:35	0:18	LINE CLEAR AVAILED
920	17-Aug-20	TUMKUR	66	TR-2	BEVINAHALLI_66	11:00	11:55	0:55	LINE CLEAR AVAILED
921	17-Aug-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN:TRANSFORMER FAULT
922	17-Aug-20	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	6:30	17:51	11:20	LINE CLEAR AVAILED
923	17-Aug-20	TUMKUR	220	MADHUGIRI 220kv- GOWRIBIDANUR220	MADHUGIRI 220kv	11:47	16:38	4:51	LOAD CURTAILMENT
924	17-Aug-20	TUMKUR	220	THALLAK 220KV-CHITRADURGA	THALLAKK_220	6:54	17:49	10:55	LINE CLEAR AVAILED