

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 06.10.2020 TO 12.10.2020

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	06-Oct-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVALIED
2	06-Oct-20	BAGALKOT	110	110/11KV, HV1	MUNDUGANUR 110	18:00	18:10	00:10	LOAD CURTAILMENT
3	06-Oct-20	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL 110	14:14 (16.09.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
4	06-Oct-20	BAGALKOT	110	110/11KV,HV1	HANAGAL 110	17:38	17:50	00:12	LOAD CURTAILMENT
5	06-Oct-20	BAGALKOT	110	110/11KV,HV1	KUDAL SANGAM 110	17:37	17:53	00:16	LOAD CURTAILMENT
6	06-Oct-20	BAGALKOT	110	110/11KV,HV2	AINAPUR 110	17:37	17:47	00:10	LOAD CURTAILMENT
7	06-Oct-20	BAGALKOT	110	110/11KV,HV3	HIDIKALL 110	17:37	17:42	00:05	LOAD CURTAILMENT
8	06-Oct-20	BAGALKOT	110	110/33KV, HV4	HARIHAR HOSPET 66	17:30	17:40	00:10	LOAD CURTAILMENT
9	06-Oct-20	BAGALKOT	110	110/33KV, HV4	HARIHAR HOSPET 66	18:20	18:35	00:15	LOAD CURTAILMENT
10	06-Oct-20	BAGALKOT	110	110/33KV,HV2	ANKOLA_110,MASTIKATTA_3 3,SEA BIRD 33	08:15	08:20	00:05	TRANSFORMER FAULT
11	06-Oct-20	BAGALKOT	110	BAGALKOT220-LOKAPUR	STATION NOT AFFECTED LOKAPUR 110	22:47 (06.10.2020)			LINE OPEN : LINE FAULT
12	06-Oct-20	BAGALKOT	110	BELGAUM220-ANKALAGI	STATION NOT AFFECTED ANKALAGI 110	09:31	16:30	06:59	NFBC ISSUED
13	06-Oct-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM 110	13:05 (19.08.2020)			LINE OPEN: LINE CLEAR AVALIED
14	06-Oct-20	BAGALKOT	110	BIJAPUR-ENERCON	BIJAPUR_220 (STATION NOT AFFECTED)	08:04	08:12	00:08	LINE FAULT
15	06-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA 110	19:05 (31.08.2020)			LINE OPEN: LINE CLEAR AVALIED
16	06-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA 110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVALIED
17	06-Oct-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL 110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVALIED
18	06-Oct-20	BAGALKOT	110	KAVALLWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA 110	15:34 (13.09.2020)			LINE OPEN: LINE CLEAR AVALIED
19	06-Oct-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR 110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
20	06-Oct-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR 110	16:02 (28.09.2020)			LINE OPEN: LINE CLEAR AVALIED
21	06-Oct-20	BAGALKOT	110	MANTUR-SHIROL	STATION NOT AFFECTED SHIROL 110	9:39 (29.09.2020)			LINE OPEN: LINE CLEAR AVALIED
22	06-Oct-20	BAGALKOT	110	SIRSI- KUMTA2	SIRSI 110	14:54	14:56	00:02	HAND TRIPPED
23	06-Oct-20	BAGALKOT	110	SUARNASOUDA- MACHE	MACHE 110	14:45	17:37	02:52	LINE FAULT
24	06-Oct-20	BAGALKOT	110	VAJJARAMATTI220-BILAGI(SHIRGUPPI)	BILAGI_110,SHIRGUPPI_110,B ISNAL_110,GIRISAGAR_110, TOLMATTI_110, TEGGI 33,ANAGAWADI 33	08:32	17:34	09:02	LINE CLEAR AVALIED
25	06-Oct-20	BAGALKOT	110	VAJJRAMATTI220-KATARAKI	STATION NOT AFFECTED KATARAKI 110	18:38 (04.10.2020)	18:05(06.10.2 020)	23:27 hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
26	06-Oct-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR 110	21:11 (29.05.2020)	23:22(06.10.2020)	5592:10 hrs	LINE CHARGED
27	06-Oct-20	BAGALKOT	220	220/110KV, HV1&LV1	MK HUBLI 220	14:48	17:31	02:43	LINE CLEAR AVAILED
28	06-Oct-20	BAGALKOT	220	220/110KV, HV2&LV2	MK HUBLI 220	14:48	18:22	03:34	LINE CLEAR AVAILED
29	06-Oct-20	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI 220	16:28 (16.09.2020)			LINE OPEN: LINE CLEAR AVAILED
30	06-Oct-20	BAGALKOT	220	CHIKKODI220-MUDASHINGI	STATION NOT AFFECTED CHIKKODI 220	08:18	20:10	11:52	NFBC ISSUED
31	06-Oct-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI 220	10:29 (21.09.2020)			LINE OPEN: LINE CLEAR AVAILED
32	06-Oct-20	BAGALKOT	220	MKHUBLI- NARENDRA1	MK HUBLI 220	12:57	16:47	03:50	LINE FAULT
33	06-Oct-20	BAGALKOT	220	MKHUBLI- NARENDRA2	MK HUBLI 220	14:07	20:34	06:27	LINE FAULT
34	06-Oct-20	BAGALKOT	220	NARENDRA- HUBLI2	STATION NOT AFFECTED NARENDRA 220	15:46 (05.10.2020)			LINE OPEN : LINE FAULT
35	06-Oct-20	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI 220	22:53 (02.10.2020)			LOAD CURTAILMENT
36	06-Oct-20	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI 220	22:53 (02.10.2020)			LOAD CURTAILMENT
37	06-Oct-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN : LINE FAULT
38	06-Oct-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	10:03	10:49	00:46	LINE FAULT
39	06-Oct-20	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	13:16	13:40	00:24	LINE CLEAR AVAILED
40	06-Oct-20	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	16:08	16:47	00:39	LINE CLEAR AVAILED
41	06-Oct-20	BENGALURU	66	HSR LAYOUT 220 - JAKKASANDRA	JAKKASANDRA	16:08	16:48	00:40	LINE CLEAR AVAILED
42	06-Oct-20	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	13:16	13:38	00:22	LINE CLEAR AVAILED
43	06-Oct-20	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	16:08	16:36	00:28	LINE CLEAR AVAILED
44	06-Oct-20	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	13:16	13:40	00:24	LINE CLEAR AVAILED
45	06-Oct-20	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS	16:08	16:37	00:29	LINE CLEAR AVAILED
46	06-Oct-20	BENGALURU	66	HV1	HSR LAYOUT 220	13:16	13:41	00:25	LINE CLEAR AVAILED
47	06-Oct-20	BENGALURU	66	HV1	HSR LAYOUT 220	16:08	16:35	00:27	LINE CLEAR AVAILED
48	06-Oct-20	BENGALURU	66	HV1	NIMHANS	14:10	14:12	00:02	LINE CLEAR AVAILED
49	06-Oct-20	BENGALURU	66	HV1	KGF	13:24	16:10	02:45	LINE CLEAR AVAILED
50	06-Oct-20	BENGALURU	66	HV1	YELAHANKA	10:49(5/10/2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
51	06-Oct-20	BENGALURU	66	HV2	HSR LAYOUT 220	13:16	13:41	00:25	LINE CLEAR AVAILED
52	06-Oct-20	BENGALURU	66	HV2	HSR LAYOUT 220	16:08	16:35	00:27	LINE CLEAR AVAILED
53	06-Oct-20	BENGALURU	66	HV2	KGF	13:24	16:10	02:45	LINE CLEAR AVAILED
54	06-Oct-20	BENGALURU	66	HV2	HOSKOTE 66	12:22	12:55	00:32	LINE CLEAR AVAILED
55	06-Oct-20	BENGALURU	66	HV3	HSR LAYOUT 220	13:16	13:41	00:25	LINE CLEAR AVAILED
56	06-Oct-20	BENGALURU	66	HV3	HSR LAYOUT 220	16:08	16:35	00:27	LINE CLEAR AVAILED
57	06-Oct-20	BENGALURU	66	HV3	KGF	13:24	16:10	02:45	LINE CLEAR AVAILED
58	06-Oct-20	BENGALURU	66	KGF - KAMASAMUDRA	KAMASAMUDRA	13:24	16:09	02:45	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
59	06-Oct-20	BENGALURU	66	KGF - KYASAMBALLI	KYASAMBALLI	13:24	13:36	00:11	LINE CLEAR AVAILED
60	06-Oct-20	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	18:50	19:20	00:30	LOAD CURTAILMENT
61	06-Oct-20	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	18:30	18:58	00:28	LOAD CURTAILMENT
62	06-Oct-20	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	18:20	18:30	00:10	LOAD CURTAILMENT
63	06-Oct-20	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	19:20	19:45	00:25	LOAD CURTAILMENT
64	06-Oct-20	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	18:20	18:50	00:30	LOAD CURTAILMENT
65	06-Oct-20	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	19:00	19:20	00:20	LOAD CURTAILMENT
66	06-Oct-20	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	19:20	19:45	00:25	LOAD CURTAILMENT
67	06-Oct-20	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	06:33	06:43	00:10	LINE FAULT
68	06-Oct-20	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	13:42	13:52	00:10	LINE FAULT
69	06-Oct-20	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	13:42	16:28	02:46	LINE FAULT
70	06-Oct-20	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 2	HONNIGANAHALLI	13:42	13:52	00:10	LINE FAULT
71	06-Oct-20	BENGALURU	220	HOODY 400 - HSR LAYOUT 220	HSR LAYOUT 220	13:16	14:22	01:06	LINE FAULT
72	06-Oct-20	BENGALURU	220	HSR LAYOUT 220 - HOODY 400	HSR LAYOUT 220	13:16	13:35	00:19	MAIN SUPPLY FAILURE
73	06-Oct-20	BENGALURU	220	HSR LAYOUT 220 - SOMANAHALLI 220	HSR LAYOUT 220	16:08	16:34	00:26	MAIN SUPPLY FAILURE
74	06-Oct-20	BENGALURU	220	HV1	HSR LAYOUT 220	16:08	16:34	00:26	LINE CLEAR AVAILED
75	06-Oct-20	BENGALURU	220	HV2	HSR LAYOUT 220	16:08	16:46	00:38	TRANSFORMER FAULT
76	06-Oct-20	BENGALURU	220	HV3	HSR LAYOUT 220	16:08(06/10/2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
77	06-Oct-20	BENGALURU	220	SOMANAHALLI 220 - HSR LAYOUT 220	HSR LAYOUT 220	16:07	16:50	00:43	LINE FAULT
78	06-Oct-20	GULBARGA	66	HV1	KUDLIGI_66	17:45	17:55	00:10	TRANSFORMER FAULT
79	06-Oct-20	GULBARGA	110	HV1	CHINCHOLLI_110	19:00	19:10	00:10	LINE CLEAR AVAILED
80	06-Oct-20	GULBARGA	110	HV2	CHINCHOLLI_110	17:28	17:35	00:07	LINE CLEAR AVAILED
81	06-Oct-20	GULBARGA	110	HV2	CHINCHOLLI_110	18:01	18:10	00:09	LINE CLEAR AVAILED
82	06-Oct-20	GULBARGA	110	HV2	KOLHAR_110	19:25	19:40	00:15	TRANSFORMER FAULT
83	06-Oct-20	GULBARGA	110	KOLHAR-HALBURGA1	KOLHAR_110	14:00	14:05	00:05	LINE FAULT
84	06-Oct-20	GULBARGA	110	KOLHAR-SHAHI_SLR_IPP	KOLHAR_110	12:15	12:20	00:05	LOAD CURTAILMENT
85	06-Oct-20	GULBARGA	110	KOLHAR-SHAHI_SLR_IPP	KOLHAR_110	14:00	14:15	00:15	LINE FAULT
86	06-Oct-20	GULBARGA	110	MALLAT- MADLAPUR	MADLAPUR_110	21:51	21:55	00:04	LINE FAULT
87	06-Oct-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN: LINE CLEAR AVAILED
88	06-Oct-20	GULBARGA	110	RAICHUR-SHAHAPUR	SHAHAPUR_110	17:53	20:00	02:07	LOAD CURTAILMENT
89	06-Oct-20	GULBARGA	110	RAICHUR-SHAHAPUR	MATAMAARI_110	17:53	19:06	01:13	LOAD CURTAILMENT
90	06-Oct-20	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	11:47	13:50	02:03	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
91	06-Oct-20	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	11:47	13:50	02:03	LINE CLEAR AVAILED
92	06-Oct-20	GULBARGA	110	SINDHANOOR-RAICHUR2	MASKI_110,MUDDAPUR_110	12:50(25.9.2020)			LINE OPEN: LINE CLEAR AVAILED
93	06-Oct-20	GULBARGA	110	SINDHANOOR-SUZLON1	SIDHANOOR_220	00:35	00:52	00:17	LINE FAULT
94	06-Oct-20	GULBARGA	110	SINDHANOOR-SUZLON1	SIDHANOOR_220	01:30	01:50	00:20	LINE FAULT
95	06-Oct-20	GULBARGA	110	SINDNOOR-NIRLOOTI IPP	SINDHANOOR_220	19:15	19:40	00:25	LINE FAULT
96	06-Oct-20	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTYHALLI_66	12:47	12:50	00:03	HAND TRIPPED
97	06-Oct-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:40 (11.09.2020)			LINE OPEN: LINE CLEAR AVAILED
98	06-Oct-20	HASSAN	66	CHANNARA-CRPATNA1	CHANNARAYAPATNA_66	10:59	17:54	06:55	LINE CLEAR AVAILED
99	06-Oct-20	HASSAN	66	CHANNARA-CRPATNA2	CHANNARAYAPATNA_66	10:59	17:15	06:16	LINE CLEAR AVAILED
100	06-Oct-20	HASSAN	66	CHANNARA-HIRESAVE	CHANNARAYAPATNA_66	10:59	17:32	06:33	LINE CLEAR AVAILED
101	06-Oct-20	HASSAN	66	CHANNARA-UDAYAPURA	CHANNARAYAPATNA_66	10:58	19:36	08:38	LINE CLEAR AVAILED
102	06-Oct-20	HASSAN	66	HV1	ALDUR_66	15:23	15:51	00:28	LINE CLEAR AVAILED
103	06-Oct-20	HASSAN	66	HV1	CHANNARAYAPATNA_66	10:57	17:18	06:21	LINE CLEAR AVAILED
104	06-Oct-20	HASSAN	66	HV1	KANDLI_66	11:05	11:38	00:33	LINE CLEAR AVAILED
105	06-Oct-20	HASSAN	66	HV2	CHANNARAYAPATNA_66	10:57	17:18	06:21	LINE CLEAR AVAILED
106	06-Oct-20	HASSAN	66	HV2	RAMESHWARNAGAR_66	17:36	17:56	00:20	TRANSFORMER FAULT
107	06-Oct-20	HASSAN	66	HV2	SALAGAME_66	17:36	17:53	00:17	TRANSFORMER FAULT
108	06-Oct-20	HASSAN	66	SHANTHI-UDYAPURA	SHANTHIGRAMMA_66	07:37	08:22	00:45	LINE CLEAR AVAILED
109	06-Oct-20	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	19:04	19:40	00:36	HAND TRIPPED
110	06-Oct-20	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	19:04	19:40	00:36	HAND TRIPPED
111	06-Oct-20	HASSAN	110	HV1	MOODABIDRE_110	10:22	11:29	01:07	LINE CLEAR AVAILED
112	06-Oct-20	HASSAN	110	HV2	BAIKAMPADI_110	12:37	13:05	00:28	LINE CLEAR AVAILED
113	06-Oct-20	HASSAN	110	HV2	MSEZ_220	09:52	14:28	04:36	LINE CLEAR AVAILED
114	06-Oct-20	HASSAN	110	JOG-NK1	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
115	06-Oct-20	HASSAN	110	JOG-NK2	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
116	06-Oct-20	HASSAN	110	KADUR-NGNHL	KADUR_220	17:54	18:10	00:16	HAND TRIPPED
117	06-Oct-20	HASSAN	110	KADUR-TNGL	KADUR_220	17:53	18:19	00:26	HAND TRIPPED
118	06-Oct-20	HASSAN	110	KADUR-YGTI	KADUR_220	17:53	18:16	00:23	HAND TRIPPED
119	06-Oct-20	HASSAN	220	KEMAR-Varahi3	KEMAR_220	09:10	12:36	03:26	NFBC ISSUED
120	06-Oct-20	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	10:26	16:39	06:13	LINE CLEAR AVAILED
121	06-Oct-20	HASSAN	220	VARAHI-KEMAR3	varahi_gen	09:09	12:36	03:27	LINE CLEAR AVAILED
122	06-Oct-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:49 (29.09.2020)	6:35 (6.10.2020)	150:45 hrs	LINE CHARGED
123	06-Oct-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:46 (1.10.2020)	7:07 (6.10.2020)	104:20 hrs	LINE CHARGED
124	06-Oct-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:25 (6.10.2020)			LINE OPEN: LINE CLEAR AVAILED
125	06-Oct-20	MYSURU	66	CHIKKAMANDYA-HAMPAPURA	NO STATIONS EFFECTED	11:00	11:21	00:21	LINE CLEAR AVAILED
126	06-Oct-20	MYSURU	66	CHIKKAMANDYA-MANDYA	NO STATIONS EFFECTED	11:21	11:36	00:15	LINE CLEAR AVAILED
127	06-Oct-20	MYSURU	66	CR NAGARA-CHANDAKAWADI	CHANDAKAVADI_66	00:09	00:22	00:12	LINE FAULT
128	06-Oct-20	MYSURU	66	CR NAGARA-HONNALLI	ATTIGULIPURA_66 HONNALLY MYS 66	00:09	00:22	00:12	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
129	06-Oct-20	MYSURU	66	HV1	DODDINADUVADI_66	17:30	17:36	00:06	LOAD CURTAILMENT
130	06-Oct-20	MYSURU	66	HV1	DODDABYADARAHALLI_66	16:09	16:35	00:25	LINE CLEAR AVAILED
131	06-Oct-20	MYSURU	66	HV1	HANGALA-	06:30	06:38	00:08	TRANSFORMER FAULT
132	06-Oct-20	MYSURU	66	HV2	KADAKOLA_220	09:29	09:31	00:02	HAND TRIPPED
133	06-Oct-20	MYSURU	66	HV2	RAMAPURA_MYS_66	13:43	14:41	00:58	LINE CLEAR AVAILED
134	06-Oct-20	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	NO STATIONS EFFECTED	09:29	09:30	00:01	HAND TRIPPED
135	06-Oct-20	MYSURU	66	KADAKOLA-MYSORE SOUTH	NO STATIONS EFFECTED	08:05	18:28	10:23	LINE CLEAR AVAILED
136	06-Oct-20	MYSURU	66	SANTHE SARGUR-KADKOLA 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66	12:10	12:21	00:10	LINE FAULT
137	06-Oct-20	MYSURU	66	SANTHE SARGUR-KADKOLA 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66	12:52	12:57	00:05	LINE FAULT
138	06-Oct-20	MYSURU	66	SANTHE SARGUR-KADKOLA 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66	13:45	13:55	00:10	LINE FAULT
139	06-Oct-20	MYSURU	66	SANTHE SARGUR-KADKOLA 1	ANTHARSANTHE_66, HAMPAPURA(K)_66, HDKOTE_66, JAIPUR_66	15:25	15:40	00:15	LINE FAULT
140	06-Oct-20	MYSURU	220	HV1	KADAKOLA_220	09:19	18:26	09:07	LINE CLEAR AVAILED
141	06-Oct-20	MYSURU	220	HV2	KADAKOLA_220	09:23	09:28	00:04	HAND TRIPPED
142	06-Oct-20	MYSURU	220	KADAKOLA-HOOTAGALLI	NO STATIONS EFFECTED	15:27	18:33	03:06	LINE CLEAR AVAILED
143	06-Oct-20	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	18:50	19:44	00:54	LINE CLEAR AVAILED
144	06-Oct-20	TUMKUR	66	ANTHRASANAHALI 220KV- KORA	KORA_66, THOVINAKERE_66, BRAHMASANDRA_66, KALLAMBELLA_66	10:45	12:02	01:17	LINE CLEAR AVAILED
145	06-Oct-20	TUMKUR	66	DEVARAHALLI- HONNALLI220	DEVARAHALLI_66	13:12	13:24	00:11	LINE CLEAR AVAILED
146	06-Oct-20	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	18:21	18:31	00:09	LINE FAULT
147	06-Oct-20	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	12:22	12:40	00:18	LINE FAULT
148	06-Oct-20	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	12:10	12:22	00:12	LINE FAULT
149	06-Oct-20	TUMKUR	66	KORA- ANTHRASANAHALI	KORA_66	10:05	12:07	02:01	LINE FAULT
150	06-Oct-20	TUMKUR	66	KORA- BRAHMASANDRA	KORA_66, BRAHMASANDRA_66, THOVINAKERE_66	12:01	12:12	00:10	HAND TRIPPED
151	06-Oct-20	TUMKUR	66	MEDIGESI- CLEANSOLAR IPP	CLEANSOLAR_IPP_66	11:03	11:13	00:10	HAND TRIPPED
152	06-Oct-20	TUMKUR	66	SASALUHALLA-CKJRKUTT	SASALUHALLA_66	12:59	13:04	00:04	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
153	06-Oct-20	TUMKUR	66	SASALUHALLA-MAYAKONDA	MAYAKONDA_66	12:59	13:02	00:03	LINE CLEAR AVAILED
154	06-Oct-20	TUMKUR	66	TR-1	BELADARA_66	12:32	12:47	00:15	LINE CLEAR AVAILED
155	06-Oct-20	TUMKUR	66	TR-1	BELADARA_66	12:54	13:03	00:09	LINE CLEAR AVAILED
156	06-Oct-20	TUMKUR	66	TR-1	DEVARAHALLI_66	10:33	10:36	00:03	LINE CLEAR AVAILED
157	06-Oct-20	TUMKUR	66	TR-1	DEVARAHALLI_66	12:36	13:24	00:48	LINE CLEAR AVAILED
158	06-Oct-20	TUMKUR	66	TR-1	KORA_66	11:46	12:09	00:23	HAND TRIPPED
159	06-Oct-20	TUMKUR	66	TR-1	SASALUHALLA_66	11:11	13:03	01:52	LINE CLEAR AVAILED
160	06-Oct-20	TUMKUR	66	TR-1	SASALUHALLA_66	16:38	16:47	00:09	LINE CLEAR AVAILED
161	06-Oct-20	TUMKUR	66	TR-2	HARAPPANAHALLI_66	06:20	06:41	00:20	TRANSFORMER FAULT
162	06-Oct-20	TUMKUR	66	TR-2	RANGANATHAPURA_66	07:24	08:25	01:00	LINE CLEAR AVAILED
163	06-Oct-20	TUMKUR	66	TR-2	SASALUHALLA_66	12:26	14:00	01:33	LINE CLEAR AVAILED
164	06-Oct-20	TUMKUR	66	TR-2(LV SIDE)	ANTHRASANAHALLI_220	15:27	15:51	00:23	LINE CLEAR AVAILED
165	06-Oct-20	TUMKUR	110	TR-1	AMMASANDRA_110	11:52	14:01	02:08	LINE CLEAR AVAILED
166	06-Oct-20	TUMKUR	110	TR-1	SHETYKERE_110	13:04	14:35	01:31	LINE CLEAR AVAILED
167	06-Oct-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT
168	06-Oct-20	TUMKUR	110	TR-3	AMMASANDRA_110	12:40	13:09	00:29	LINE CLEAR AVAILED
169	06-Oct-20	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	13:07	13:51	00:43	LINE FAULT
170	06-Oct-20	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	14:23	22:05	07:42	LINE FAULT
171	06-Oct-20	TUMKUR	220	TR-2	ANTHRASANAHALLI_220	15:28	15:50	00:22	LINE CLEAR AVAILED
172	7-Oct-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
173	7-Oct-20	BAGALKOT	110	110/11KV, HV1	NANADI_110	10:10	16:30	6:20	LINE CLEAR AVAILED
174	7-Oct-20	BAGALKOT	110	110/11KV, HV2	NANADI_110	10:10	17:17	7:07	LINE CLEAR AVAILED
175	7-Oct-20	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL_110	14:14 (16.09.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
176	7-Oct-20	BAGALKOT	110	110/11KV,HV3	LOKAPUR_110	21:05	21:15	0:10	TRANSFORMER FAULT
177	7-Oct-20	BAGALKOT	110	110/33KV, HV1	HUBLI_220, TAUSHI_33	17:02	17:43	0:41	LINE CLEAR AVAILED
178	7-Oct-20	BAGALKOT	110	110/33KV,HV4	LAKAMANAHALLI_110 & ALNAVAR_33	18:48	18:57	0:09	TRANSFORMER FAULT
179	7-Oct-20	BAGALKOT	110	BADAMI-HIREHAL	HIREHAL_110	14:05	15:21	1:16	LINE CLEAR AVAILED
180	7-Oct-20	BAGALKOT	110	BAGALKOT220-LOKAPUR	STATION NOT AFFECTED LOKAPUR_110	22:47 (06.10.2020)	11:00 (7.10.2020)	12:13hrs	LINE CHARGED
181	7-Oct-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN: LINE CLEAR AVAILED
182	7-Oct-20	BAGALKOT	110	BIJAPUR220-KIADB BIJAPUR 1	KIADB BIJAPUR_110	4:50	5:02	0:12	LINE FAULT
183	7-Oct-20	BAGALKOT	110	CHIKKODI220- NANADI	NANADI_110	10:12	14:00	3:48	LINE CLEAR AVAILED
184	7-Oct-20	BAGALKOT	110	GADAG-BETAGERI	BETAGERI_110	11:11	17:00	5:49	LINE CLEAR AVAILED
185	7-Oct-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN: LINE CLEAR AVAILED
186	7-Oct-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
187	7-Oct-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
188	7-Oct-20	BAGALKOT	110	KAVALLWADA(AMBEWADI)- KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	15:34 (13.09.2020)			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
189	7-Oct-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
190	7-Oct-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN: LINE CLEAR AVAILED
191	7-Oct-20	BAGALKOT	110	MANTUR-SHIROL	STATION NOT AFFECTED SHIROL_110	9:39 (29.09.2020)			LINE OPEN: LINE CLEAR AVAILED
192	7-Oct-20	BAGALKOT	110	SOUDATTI220- RAMDURGA1	STATION NOT AFFECTED RAMDURGA_110	13:10	14:10	1:00	LINE CLEAR AVAILED
193	7-Oct-20	BAGALKOT	110	SOUDATTI220- SOUDATTI2	STATION NOT AFFECTED SOUDATTI_110	12:15	14:22	2:07	LINE CLEAR AVAILED
194	7-Oct-20	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	16:28 (16.09.2020)			LINE OPEN: LINE CLEAR AVAILED
195	7-Oct-20	BAGALKOT	220	BIDNAL-HARTI2	BIDNAL_220	10:33	17:06	6:33	LINE CLEAR AVAILED
196	7-Oct-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN: LINE CLEAR AVAILED
197	7-Oct-20	BAGALKOT	220	NAGJHARI3- HUBLI	HUBLI_220	10:31	15:18	4:47	LINE CLEAR AVAILED
198	7-Oct-20	BAGALKOT	220	NARENDRA- HUBLI2	STATION NOT AFFECTED NARENDRA_220	15:46 (05.10.2020)	15:26 (7.10.2020)	47:40hrs	LINE CHARGED
199	7-Oct-20	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	22:53 (02.10.2020)			LOAD CURTAILMENT
200	7-Oct-20	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	22:53 (02.10.2020)			LOAD CURTAILMENT
201	7-Oct-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN : LINE FAULT
202	7-Oct-20	BENGALURU	66	HV1	KACHMARANAHALLI	11:45	12:20	00:35	LINE CLEAR AVAILED
203	7-Oct-20	BENGALURU	66	HV1	ATTIBELE	13:31	13:45	00:13	LINE CLEAR AVAILED
204	7-Oct-20	BENGALURU	66	HV1	YELAHANKA	10:49(5/10/2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
205	7-Oct-20	BENGALURU	66	HV2	SUBRAMANYAPURA 66	10:58	11:00	00:02	LINE CLEAR AVAILED
206	7-Oct-20	BENGALURU	66	HV2	M GOLLAHALLI	10:17	10:35	00:17	LINE CLEAR AVAILED
207	7-Oct-20	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU, GODURU	10:01	10:11	00:09	LINE CLEAR AVAILED
208	7-Oct-20	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU, GODURU	10:11	17:10	06:59	LINE CLEAR AVAILED
209	7-Oct-20	BENGALURU	66	MALLASANDRA - KOLAR 220	MALLASANDRA, DALASANUR, YELDUR	19:00	19:30	00:30	LOAD CURTAILMENT
210	7-Oct-20	BENGALURU	66	NRS 220 - MYSORE ROAD 1	VIJAYANAGARA	07:01	07:13	00:12	LINE FAULT
211	7-Oct-20	BENGALURU	66	NRS 220 - MYSORE ROAD 2	VIJAYANAGARA	10:34	15:36	05:02	LINE CLEAR AVAILED
212	7-Oct-20	BENGALURU	66	SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66	SUBRAMANYAPURA 66	10:25	11:02	00:37	LOAD CHANGE OVER
213	7-Oct-20	BENGALURU	66	SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66	SUBRAMANYAPURA 66	21:34	22:10	00:36	LINE CLEAR AVAILED
214	7-Oct-20	BENGALURU	66	TK HALLI 220 - SHIMSHA	NO STATION AFFECTED	07:29	07:44	00:15	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
215	7-Oct-20	BENGALURU	220	HV3	HSR LAYOUT 220	16:08(06/10/2020)	22:56	30:47hrs	TRANSFORMER CHARGED
216	7-Oct-20	GULBARGA	66	HV1 & HV2	GUDEKOTE_66	11:10	17:10	06:00	LINE CLEAR AVAILED
217	7-Oct-20	GULBARGA	66	KUDLIGI-GUDEKOTE	GUDEKOTE_66	10:05	17:30	07:25	LINE CLEAR AVAILED
218	7-Oct-20	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110, HIREGONNAGAR_110, HANUMANAL_110	01:36	02:14	00:38	LINE FAULT
219	7-Oct-20	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110	03:55	03:58	00:03	LINE FAULT
220	7-Oct-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN: LINE CLEAR AVAILED
221	7-Oct-20	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHNOOR_220	19:30	19:40	00:10	LINE FAULT
222	7-Oct-20	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHNOOR_220	19:53	20:20	00:27	LINE FAULT
223	7-Oct-20	GULBARGA	110	SINDHANOOR-RAICHUR2	MASKI_110,MUDDAPUR_110	12:50(25.9.2020)			LINE OPEN: LINE CLEAR AVAILED
224	7-Oct-20	GULBARGA	110	TEKKALKOTE-ABMN_SLR_IPP	TEKKALKOTE_110	03:12	03:20	00:08	LINE FAULT
225	7-Oct-20	GULBARGA	220	HV2	KUSTAGI_220	01:36	01:59	00:23	TRANSFORMER FAULT
226	7-Oct-20	GULBARGA	220	KUSHTAGI-LINGASUGUR	KUSHTAGI_220	20:40(07.10.2020)			LINE OPEN: LINE CLEAR AVAILED
227	7-Oct-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	16:40(11.09.2020)	16:57(07.10.2020)	624:16 hrs	LINE CHARGED
228	7-Oct-20	HASSAN	66	HV1	BYACHANAHALLI_66	15:45	16:50	01:05	TRANSFORMER FAULT
229	7-Oct-20	HASSAN	66	HV1	BYACHANAHALLI_66	17:37	17:40	00:03	TRANSFORMER FAULT
230	7-Oct-20	HASSAN	66	HV2	BYACHANAHALLI_66	20:45	20:55	00:10	TRANSFORMER FAULT
231	7-Oct-20	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	09:52	11:09	01:17	LINE FAULT
232	7-Oct-20	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	11:20	11:30	00:10	LINE CLEAR AVAILED
233	7-Oct-20	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	16:25	17:05	00:40	LINE CLEAR AVAILED
234	7-Oct-20	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	18:40	19:05	00:25	LINE CLEAR AVAILED
235	7-Oct-20	HASSAN	110	HV1	MRSMG_220	10:45	10:57	00:12	HAND TRIPPED
236	7-Oct-20	HASSAN	110	HV1	MRSMG_220	12:54	15:20	02:26	LINE CLEAR AVAILED
237	7-Oct-20	HASSAN	110	HV1	GERUMARA_110	11:05	11:40	00:35	LINE CLEAR AVAILED
238	7-Oct-20	HASSAN	110	HV1	GERUMARA_110	14:26	16:53	02:27	LINE CLEAR AVAILED
239	7-Oct-20	HASSAN	110	HV1	GURUVAYANAKERE_110	10:09	13:46	03:37	LINE CLEAR AVAILED
240	7-Oct-20	HASSAN	110	HV1	KULASHEKARA_110	10:03	21:49	11:46	LINE CLEAR AVAILED
241	7-Oct-20	HASSAN	110	HV1	MSEZ_220	10:03	14:24	04:21	LINE CLEAR AVAILED
242	7-Oct-20	HASSAN	110	HV2	MRSMG_220	10:45	10:57	00:12	HAND TRIPPED
243	7-Oct-20	HASSAN	110	HV2	MRSMG_220	12:54	15:21	02:27	LINE CLEAR AVAILED
244	7-Oct-20	HASSAN	110	HV2	GERUMARA_110	11:05	18:06	07:01	LINE CLEAR AVAILED
245	7-Oct-20	HASSAN	110	HV2	MSEZ_220	10:02	14:35	04:33	LINE CLEAR AVAILED
246	7-Oct-20	HASSAN	110	HV3	MRSMG_220	10:45	10:57	00:12	HAND TRIPPED
247	7-Oct-20	HASSAN	110	HV3	MRSMG_220	12:54	16:14	03:20	LINE CLEAR AVAILED
248	7-Oct-20	HASSAN	110	HV3	BHADRAVATHI_110	18:07	18:48	00:41	LINE CLEAR AVAILED
249	7-Oct-20	HASSAN	110	HV4	MRSMG_220	10:45	10:57	00:12	HAND TRIPPED
250	7-Oct-20	HASSAN	110	HV4	MRSMG_220	12:54	15:22	02:28	LINE CLEAR AVAILED
251	7-Oct-20	HASSAN	110	HV5	MRSMG_220	10:36	10:39	00:03	HAND TRIPPED
252	7-Oct-20	HASSAN	110	HV5	MRSMG_220	13:51	14:56	01:05	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
253	7-Oct-20	HASSAN	110	JOG-NK1	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
254	7-Oct-20	HASSAN	110	JOG-NK2	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
255	7-Oct-20	HASSAN	110	LV2	MRSMSG_220	11:05 (7.10.2020)			LINE OPEN: LINE CLEAR AVAILED
256	7-Oct-20	HASSAN	110	MRSSHM-BADRAVATY3	MRSMSG_220	06:04	06:08	00:04	HAND TRIPPED
257	7-Oct-20	HASSAN	110	MRSSHM-MPM	MRSMSG_220	13:21	15:34	02:13	LINE CLEAR AVAILED
258	7-Oct-20	HASSAN	110	MRSSHM-SS2	MRSMSG_220	11:46	12:49	01:03	LINE CLEAR AVAILED
259	7-Oct-20	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	20:11 (7.10.2020)			LINE OPEN: LINE CLEAR AVAILED
260	7-Oct-20	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	12:08	14:05	01:57	LINE FAULT
261	7-Oct-20	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	12:41	14:08	01:27	LINE FAULT
262	7-Oct-20	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	12:28	12:41	00:13	HAND TRIPPED
263	7-Oct-20	HASSAN	220	SHRAVITY-SMG1	sharavathy_gen	12:08	14:05	01:57	LINE FAULT
264	7-Oct-20	HASSAN	220	SHRAVITY-SMG4	sharavathy_gen	12:41	14:08	01:27	LINE FAULT
265	7-Oct-20	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	12:28	12:42	00:14	HAND TRIPPED
266	7-Oct-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:45 (7.10.2020)			LINE OPEN: LINE CLEAR AVAILED
267	7-Oct-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:25 (6.10.2020)	7:19 (7.10.2020)	7:53 hrs	LINE CHARGED
268	7-Oct-20	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	13:57	14:02	0:05	LINE FAULT
269	7-Oct-20	MYSURU	66	DUNDANAHALLI-HULIYURDURGA	DUNDANAHALLI_66	13:29	17:40	4:10	LINE CLEAR AVAILED
270	7-Oct-20	MYSURU	66	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	18:43	19:49	1:05	LINE FAULT
271	7-Oct-20	MYSURU	66	HV1	PANDAVAPURA_66	11:02	11:48	0:46	LINE CLEAR AVAILED
272	7-Oct-20	MYSURU	66	HV1	SATHEGALA_66	11:56	13:28	1:31	LINE CLEAR AVAILED
273	7-Oct-20	MYSURU	66	HV2	SATHEGALA_66	12:20	14:40	2:20	LINE CLEAR AVAILED
274	7-Oct-20	MYSURU	66	HV5	SFCSHIVA_66	17:17	18:03	0:45	TRANSFORMER FAULT
275	7-Oct-20	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66 SUTTUR_66	6:50	6:58	0:07	LINE FAULT
276	7-Oct-20	MYSURU	66	KIRUGAVALU-MALIYUR	NO STATIONS EFFECTED	8:41	8:55	0:14	LINE FAULT
277	7-Oct-20	MYSURU	66	PERIYAPATNA -HANGODU	PONNAMPET_66, VIRAJPET_66, HANAGODU_66	13:15	13:40	0:25	LINE FAULT
278	7-Oct-20	MYSURU	66	SATHEGALA-HEBBANI	SATHEGALA_66	12:47	13:27	0:40	LINE CLEAR AVAILED
279	7-Oct-20	MYSURU	66	SATHEGALA-KOLLEGALA	NO STATIONS EFFECTED	12:47	13:30	0:43	LINE CLEAR AVAILED
280	7-Oct-20	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	13:15	13:20	0:05	LINE FAULT
281	7-Oct-20	MYSURU	66	TUBINKERE-PANDAVAPURA	DODDABYADARAHALLI_66 PANDAVAPURA_66	17:18	17:25	0:06	LINE FAULT
282	7-Oct-20	MYSURU	220	HV2	KADAKOLA_220	7:20	14:05	6:45	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
283	7-Oct-20	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	10:43	12:13	1:30	LINE CLEAR AVAILED
284	7-Oct-20	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	19:00	20:01	1:00	LOAD CURTAILMENT
285	7-Oct-20	TUMKUR	66	ANTHRASANAHALI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	19:00	20:01	1:00	LOAD CURTAILMENT
286	7-Oct-20	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR	IMANGALA_66, RELIANCE_IPP_66, HIRIYUR_66	15:43	15:58	0:15	LINE FAULT
287	7-Oct-20	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	11:39	11:51	0:11	LINE FAULT
288	7-Oct-20	TUMKUR	66	TR-1	BELADARA_66	11:14	11:46	0:31	LINE CLEAR AVAILED
289	7-Oct-20	TUMKUR	66	TR-1	BENKIKERE_66	14:51	14:57	0:05	HAND TRIPPED
290	7-Oct-20	TUMKUR	66	TR-1	KALAMARANAHALLI_66	7:39	8:17	0:37	TRANSFORMER FAULT
291	7-Oct-20	TUMKUR	66	TR-2	HANAGAL_66	10:45	11:51	1:06	LINE CLEAR AVAILED
292	7-Oct-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT
293	7-Oct-20	TUMKUR	220	PAVAGADA220-MADHUGIRI 2	PAVAGADA_220	11:33	18:42	7:09	LINE CLEAR AVAILED
294	7-Oct-20	TUMKUR	220	PAVAGADA220-MADHUGIRI1	PAVAGADA_220	16:03	18:42	2:38	LINE CLEAR AVAILED
295	8-Oct-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
296	8-Oct-20	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL_110	14:14 (16.09.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
297	8-Oct-20	BAGALKOT	110	110/11KV,HV1	GOPANAKOPPA_110	10:01	16:00	05:59	LINE CLEAR AVAILED
298	8-Oct-20	BAGALKOT	110	110/11KV,HV1	GOPANAKOPPA_110	10:02	16:00	05:58	LINE CLEAR AVAILED
299	8-Oct-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN: LINE CLEAR AVAILED
300	8-Oct-20	BAGALKOT	110	BETAGERI- NAREGAL	NAREGAL_110	06:05	06:45	00:40	LINE FAULT
301	8-Oct-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN: LINE CLEAR AVAILED
302	8-Oct-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
303	8-Oct-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
304	8-Oct-20	BAGALKOT	110	KAWALWADA(AMBEWADI)- KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	15:34 (13.09.2020)			LINE OPEN: LINE CLEAR AVAILED
305	8-Oct-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
306	8-Oct-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN: LINE CLEAR AVAILED
307	8-Oct-20	BAGALKOT	110	KULIGOD-GAMESH	KULIGOD_110	06:24	06:25	00:01	HAND TRIPPED
308	8-Oct-20	BAGALKOT	110	MAHALINGAPUR- HIDIKAL	STATION NOT AFFECTED HIDIKAL_110	7:50 (08.10.2020)			LINE OPEN : LINE FAULT
309	8-Oct-20	BAGALKOT	110	MANTUR-SHIROL	STATION NOT AFFECTED SHIROL_110	9:39 (29.09.2020)			LINE OPEN: LINE CLEAR AVAILED
310	8-Oct-20	BAGALKOT	110	NAREGAL- RON	RON_110	06:05	06:55	00:50	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
311	8-Oct-20	BAGALKOT	110	PGHUNSHYAL- MUDALGI	MUDALGI_110, NAGNUR_110	06:05	06:19	00:14	LINE FAULT
312	8-Oct-20	BAGALKOT	110	VAJRAMATTI220- KATARKI	KATARKI_110	06:13	06:25	00:12	LINE FAULT
313	8-Oct-20	BAGALKOT	220	220/110KV, HV3&LV3	MAHALINGAPUR_220, HIDIKAL_110, ITANAL_110	07:50	08:08	00:18	TRANSFORMER FAULT
314	8-Oct-20	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	16:28 (16.09.2020)			LINE OPEN: LINE CLEAR AVAILED
315	8-Oct-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN: LINE CLEAR AVAILED
316	8-Oct-20	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	22:53 (02.10.2020)			LOAD CURTAILMENT
317	8-Oct-20	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	22:53 (02.10.2020)			LOAD CURTAILMENT
318	8-Oct-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN : LINE FAULT
319	8-Oct-20	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	10:05	15:25	05:19	LINE CLEAR AVAILED
320	8-Oct-20	BENGALURU	66	HV1	YELAHANKA	10:49(5/10/2020)	16:34	00:25	TRANSFORMER FAULT
321	8-Oct-20	BENGALURU	66	HV2	THAYALUR	09:59	10:04	00:05	TRANSFORMER FAULT
322	8-Oct-20	GULBARGA	110	ALIPUR-KUDITINI	KUDITINI_110	17:34	17:39	00:05	LINE FAULT
323	8-Oct-20	GULBARGA	110	ALIPUR-KUDITINI	KUDITINI_110	18:18	18:24	00:06	LINE FAULT
324	8-Oct-20	GULBARGA	110	HATTI-SOMMANAMARDI_IPP	HATTI_110	14:45	14:46	00:01	LINE FAULT
325	8-Oct-20	GULBARGA	110	HUMNABAD-BHALKI	BHALKI_110	11:08	11:37	00:29	LINE CLEAR AVAILED
326	8-Oct-20	GULBARGA	110	HV1	HATTI_110	12:09	12:20	00:11	TRANSFORMER FAULT
327	8-Oct-20	GULBARGA	110	HV2	HATTI_110	08:54	09:00	00:06	TRANSFORMER FAULT
328	8-Oct-20	GULBARGA	110	HV2	HATTI_110	09:50	12:32	02:42	LINE CLEAR AVAILED
329	8-Oct-20	GULBARGA	110	HV2	HATTI_110	12:09	12:20	00:11	TRANSFORMER FAULT
330	8-Oct-20	GULBARGA	110	HV2	HATTI_110	12:48	13:05	00:17	LINE CLEAR AVAILED
331	8-Oct-20	GULBARGA	110	HV2	HATTI_110	08:54	09:00	00:06	TRANSFORMER FAULT
332	8-Oct-20	GULBARGA	110	HV2	HATTI_110	09:50	12:32	02:42	LINE CLEAR AVAILED
333	8-Oct-20	GULBARGA	110	HV2	HATTI_110	12:48	13:05	00:17	LINE CLEAR AVAILED
334	8-Oct-20	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110, VALKAMDINNI _110	01:55	02:04	00:09	LINE FAULT
335	8-Oct-20	GULBARGA	110	MALLAT-LINGSUGUR	MALLAT_220	14:45	15:08	00:23	LINE FAULT
336	8-Oct-20	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110	17:58	18:08	00:10	LINE FAULT
337	8-Oct-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN: LINE CLEAR AVAILED
338	8-Oct-20	GULBARGA	110	SINDHANOOR-RAICHUR2	MASKI_110, MUDDAPUR_110	12:50(25.9.2020)			LINE OPEN: LINE CLEAR AVAILED
339	8-Oct-20	GULBARGA	220	KUSHTAGI-LINGASUGUR	KUSHTAGI_220	20:40(07.10.2020)	17:15(8.10.20 20)	20:35HRS	NFBC ISSUED
340	8-Oct-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	18:03	18:53	00:50	LINE CLEAR AVAILED
341	8-Oct-20	HASSAN	66	HV1	HOLALUR_66	10:21	17:31	07:10	LINE CLEAR AVAILED
342	8-Oct-20	HASSAN	66	HV2	HOLALUR_66	10:21	17:31	07:10	LINE CLEAR AVAILED
343	8-Oct-20	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	18:41	18:57	00:16	HAND TRIPPED
344	8-Oct-20	HASSAN	110	HV1	MRS MG_220	12:15	13:02	00:47	LINE CLEAR AVAILED
345	8-Oct-20	HASSAN	110	HV1	HOSANGADI_110	10:14	12:49	02:35	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
346	8-Oct-20	HASSAN	110	HV2	MRS MG_220	12:15	13:02	00:47	LINE CLEAR AVAILED
347	8-Oct-20	HASSAN	110	HV2	BAIKAMPADI_110	11:30	11:50	00:20	LINE CLEAR AVAILED
348	8-Oct-20	HASSAN	110	HV2	KONAJE_110	09:45	14:01	04:16	LINE CLEAR AVAILED
349	8-Oct-20	HASSAN	110	JOG-NK1	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
350	8-Oct-20	HASSAN	110	JOG-NK2	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
351	8-Oct-20	HASSAN	110	KADUR-NERLEKERE	KADUR_220	12:50	14:24	01:34	LINE FAULT
352	8-Oct-20	HASSAN	110	LV2	MRS MG_220	11:05 (7.10.2020)			LINE OPEN: LINE CLEAR AVAILED
353	8-Oct-20	HASSAN	110	MRSSH-M-BADRAVATY1	MRS MG_220	11:12	12:57	01:45	LINE CLEAR AVAILED
354	8-Oct-20	HASSAN	110	MRSSH-M-BADRAVATY3	MRS MG_220	08:52	10:45	01:53	LINE CLEAR AVAILED
355	8-Oct-20	HASSAN	110	MRSSH-M-SS1	MRS MG_220	11:08	12:13	01:05	LINE CLEAR AVAILED
356	8-Oct-20	HASSAN	110	PUTTUR-PUTUR 1	PUTTUR_220	10:01	15:13	05:12	LINE CLEAR AVAILED
357	8-Oct-20	HASSAN	110	PUTTUR-PUTUR 1	PUTTUR_220	16:55	17:15	00:20	LINE FAULT
358	8-Oct-20	HASSAN	220	ARSK2-HSN	ARASIKERE_220	14:46	16:11	01:25	LINE CLEAR AVAILED
359	8-Oct-20	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	17:12	17:36	00:24	HAND TRIPPED
360	8-Oct-20	HASSAN	220	KEMAR-Varahi2	KEMAR_220	12:33 (8.10.2020)			LINE OPEN: LINE CLEAR AVAILED
361	8-Oct-20	HASSAN	220	KEMAR-Varahi3	KEMAR_220	09:23	12:27	03:04	NFBC ISSUED
362	8-Oct-20	HASSAN	220	MRSSH-M-KBCRS	MRS MG_220	20:11 (7.10.2020)	12:44 (8.10.2020)	16:32 hrs	LINE CHARGED
363	8-Oct-20	HASSAN	220	MRSSH-M-SHARAVATHY4	MRS MG_220	14:01	15:26	01:25	LINE FAULT
364	8-Oct-20	HASSAN	220	MRSSH-M-SHARAVATHY4	MRS MG_220	19:14	21:06	01:52	LINE CLEAR AVAILED
365	8-Oct-20	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	19:15 (8.10.2020)			LINE OPEN: LINE CLEAR AVAILED
366	8-Oct-20	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	14:02	15:28	01:26	LINE FAULT
367	8-Oct-20	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	15:22	16:13	00:51	LINE CLEAR AVAILED
368	8-Oct-20	HASSAN	220	VARAHI-KEMAR2	varahi_gen	12:33 (8.10.2020)			LINE OPEN: LINE CLEAR AVAILED
369	8-Oct-20	HASSAN	220	VARAHI-KEMAR3	varahi_gen	09:14	12:27	03:13	LINE CLEAR AVAILED
370	8-Oct-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:45 (7.10.2020)	19:12 (8.10.2020)	19:26 hrs	LINE CHARGED
371	8-Oct-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	00:25	07:48	07:23	LINE CLEAR AVAILED
372	8-Oct-20	MYSURU	66	DEVNUR(N'GUD)-HERMERGALA	DEVANOORNGUDU_66 SUTTUR_66	13:05	18:25	05:20	NFBC ISSUED
373	8-Oct-20	MYSURU	66	DEVNUR(N'GUD)-HERMERGALA	DEVANOORNGUDU_66 SUTTUR_66	10:40	11:45	01:05	LINE CLEAR AVAILED
374	8-Oct-20	MYSURU	66	HV2	VAJAMANGALA_220	14:23	14:57	00:34	HAND TRIPPED
375	8-Oct-20	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66 SUTTUR_66	00:07	00:20	00:13	LINE FAULT
376	8-Oct-20	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66 SUTTUR_66	01:13	01:19	00:05	LINE FAULT
377	8-Oct-20	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66 SUTTUR_66	01:20	15:09	13:49	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
378	8-Oct-20	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66 SUTTUR 66	16:12	18:45	02:33	NFBC ISSUED
379	8-Oct-20	MYSURU	66	KADAKOLA-NANJANGUDU 1	NO STATIONS EFFECTED	21:49	22:08	00:19	LINE FAULT
380	8-Oct-20	MYSURU	66	KADAKOLA-NANJANGUDU 2	NO STATIONS EFFECTED	21:49	22:08	00:19	LINE FAULT
381	8-Oct-20	MYSURU	66	KADAKOLA-SARGUR 2	CHANDRAVADI_66, DOORA_66 , HURA_66, HULLAHALLI 66,	07:53	07:59	00:06	LINE FAULT
382	8-Oct-20	MYSURU	66	KUSHALNAGARA -PERIYAPATNA 1	NO STATIONS EFFECTED	13:50	13:59	00:09	LINE FAULT
383	8-Oct-20	MYSURU	66	TUBINKERE-M2	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66,BESAGARAH ALLI_66, KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI 66	22:45	22:55	00:10	LINE FAULT
384	8-Oct-20	MYSURU	66	TUBINKERE-M4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66,BESAGARAH ALLI_66, KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI 66	22:45	22:55	00:10	LINE FAULT
385	8-Oct-20	MYSURU	66	VAJMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI 66	01:50	01:59	00:09	LINE FAULT
386	8-Oct-20	MYSURU	66	VAJMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI 66	05:56	06:15	00:19	LINE FAULT
387	8-Oct-20	MYSURU	220	HOOTAGALLI-BASTIPURA 2	NO STATIONS EFFECTED	11:35	13:55	02:20	LINE CLEAR AVAILED
388	8-Oct-20	MYSURU	220	HV2	VAJAMANGALA_220	14:24	14:56	00:32	HAND TRIPPED
389	8-Oct-20	MYSURU	220	VAJMANGALA-HOOTAGALLI	NO STATIONS EFFECTED	10:09	17:35	07:26	LINE CLEAR AVAILED
390	8-Oct-20	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE 66	01:36	01:53	00:17	LINE FAULT
391	8-Oct-20	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR 66	12:14	14:29	02:15	LINE CLEAR AVAILED
392	8-Oct-20	TUMKUR	66	HIREGUNTANUR- CHITRADURGA	HIREGUNTANUR_66	16:00	16:10	00:09	HAND TRIPPED
393	8-Oct-20	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIR I_66, BASAVAPATNA 66	14:17	14:27	00:09	LINE FAULT
394	8-Oct-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR 66	11:12	11:22	00:09	LINE FAULT
395	8-Oct-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR 66	15:40	15:49	00:09	LINE FAULT
396	8-Oct-20	TUMKUR	66	NAYAKANAHATTI66- HIREMALLANHOLE	NAYAKANAHATTI_66	18:38	18:47	00:09	LINE FAULT
397	8-Oct-20	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR IPP_66	13:46	14:04	00:18	LOAD CURTAILMENT
398	8-Oct-20	TUMKUR	66	TR-1	BENNEHALLI_66	5:55:50 PM (08.10.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
399	8-Oct-20	TUMKUR	66	TR-1	BENNEHALLI_66	13:18	17:40	04:21	LINE CLEAR AVAILED
400	8-Oct-20	TUMKUR	66	TR-1	BHAKTHARAHALLI_66	09:43	18:21	08:37	LINE CLEAR AVAILED
401	8-Oct-20	TUMKUR	66	TR-1	DEVARAHALLI_66	10:59	12:19	01:19	LINE CLEAR AVAILED
402	8-Oct-20	TUMKUR	66	TR-1	GOWRASAMUDRA_66	12:47	13:33	00:45	TRANSFORMER FAULT
403	8-Oct-20	TUMKUR	66	TR-1	GOWRASAMUDRA_66	16:50	17:01	00:11	TRANSFORMER FAULT
404	8-Oct-20	TUMKUR	66	TR-1	HIREGUNTANUR_66	14:20	17:20	03:00	LINE CLEAR AVAILED
405	8-Oct-20	TUMKUR	66	TR-1	RANGANATHAPURA_66	08:01	08:25	00:23	HAND TRIPPED
406	8-Oct-20	TUMKUR	66	TR-2	HIREGUNTANUR_66	16:00	17:20	01:20	LINE CLEAR AVAILED
407	8-Oct-20	TUMKUR	66	TURUVANUR66-JAGALUR	JAGALUR_66,BIDARKERE_66,S OKKE_66	01:37	02:00	00:22	MAIN SUPPLY FAILURE
408	8-Oct-20	TUMKUR	110	HONNAVALI 110-ADAN SOLAR	ADAN SOLAR_IPP_66	16:05	16:08	00:02	HAND TRIPPED
409	8-Oct-20	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	11:06	12:11	01:05	LINE CLEAR AVAILED
410	8-Oct-20	TUMKUR	110	TR-1(LV SIDE)	NITTUR_220	15:59	16:17	00:17	LINE CLEAR AVAILED
411	8-Oct-20	TUMKUR	110	TR-1(LV SIDE)	NITTUR_220	17:10	17:29	00:19	LINE CLEAR AVAILED
412	8-Oct-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT
413	8-Oct-20	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	11:06	12:11	01:05	LINE CLEAR AVAILED
414	8-Oct-20	TUMKUR	110	TR-2(LV SIDE)	NITTUR_220	16:17	16:59	00:41	LINE CLEAR AVAILED
415	8-Oct-20	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	12:36	13:11	00:34	LINE FAULT
416	8-Oct-20	TUMKUR	220	GUTTUR 400KV- HAVERI 1	GUTUR_400	11:47	15:07	03:19	LINE FAULT
417	8-Oct-20	TUMKUR	220	NITTUR 220kv- HASSAN(ARASIKERE)	NITTUR_220	14:47	16:13	01:26	LINE CLEAR AVAILED
418	8-Oct-20	TUMKUR	220	TR-1(HV SIDE)	NITTUR_220	15:59	17:29	01:29	LINE CLEAR AVAILED
419	8-Oct-20	TUMKUR	220	TR-2(HV SIDE)	NITTUR_220	16:17	16:58	00:41	LINE CLEAR AVAILED
420	9-Oct-20	BAGALKOT	66	66/33KV,HV3	HARIHAR HOSPET_66	23:50 (09.10.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
421	9-Oct-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
422	9-Oct-20	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL_110	14:14 (16.09.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
423	9-Oct-20	BAGALKOT	110	BAGEWADI-MAMADAPUR1	STATION NOT AFFECTED MAMADAPUR(B)_110	20:12	20:36	0:24	LINE FAULT
424	9-Oct-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN: LINE CLEAR AVAILED
425	9-Oct-20	BAGALKOT	110	CHIKKODI-SADALAGA	SADALAGA_110	11:30	13:10	1:40	NFBC ISSUED
426	9-Oct-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN: LINE CLEAR AVAILED
427	9-Oct-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
428	9-Oct-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
429	9-Oct-20	BAGALKOT	110	KAVALLWADA(AMBEWADI)- KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	15:34 (13.09.2020)			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
430	9-Oct-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
431	9-Oct-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN: LINE CLEAR AVAILED
432	9-Oct-20	BAGALKOT	110	MAHALINGAPUR220- HIDIKAL/ITNAL	STATION NOT AFFECTED HIDIKAL_110	7:50 (08.10.2020)			LINE OPEN : LINE FAULT
433	9-Oct-20	BAGALKOT	110	MANTUR-SHIROL	STATION NOT AFFECTED SHIROL_110	9:39 (29.09.2020)	12:40 (08.10.2020)	219:01hrs	LINE CHARGED
434	9-Oct-20	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	16:28 (16.09.2020)			LINE OPEN: LINE CLEAR AVAILED
435	9-Oct-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN: LINE CLEAR AVAILED
436	9-Oct-20	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	22:53 (02.10.2020)	23:37 (9.10.2020)	168:44hrs	LINE CHARGED
437	9-Oct-20	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	22:53 (02.10.2020)	23:55 (09.10.2020)	169:02hrs	LINE CHARGED
438	9-Oct-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN : LINE FAULT
439	9-Oct-20	GULBARGA	66	HANASI-ITTAGGI	HANASI_66	09:05	12:45	03:40	LINE CLEAR AVOIDED
440	9-Oct-20	GULBARGA	66	HV1	HANASI_66	13:30	18:32	05:02	LINE CLEAR AVOIDED
441	9-Oct-20	GULBARGA	110	ALIPUR-BELLARYNORTH1	SOMASAMUDRA_110, BELLARYNORTH_110, MOKA_110, PDHALLI_110,BISIHALLI_110	12:22	13:44	01:22	LINE FAULT
442	9-Oct-20	GULBARGA	110	HALBURGA-SANTHAPUR	SANTHAPUR_110, DONGARGOA_110, KAMALNAGAR_110	05:40	06:01	00:21	LINE FAULT
443	9-Oct-20	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110,NIRNA_110	16:29	17:45	01:16	LINE CLEAR AVOIDED
444	9-Oct-20	GULBARGA	110	HUMNABAD-HALIKHED	HALIKHED_110	16:20	17:35	01:15	LINE CLEAR AVOIDED
445	9-Oct-20	GULBARGA	110	HUMNABAD-HUMNABAD2	HUMNABAD_110	16:20	17:35	01:15	LINE CLEAR AVOIDED
446	9-Oct-20	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	17:18	17:34	00:16	LINE CLEAR AVOIDED
447	9-Oct-20	GULBARGA	110	HV1	CHINCHOLI_110	10:35	17:21	06:46	LINE CLEAR AVOIDED
448	9-Oct-20	GULBARGA	110	HV1,HV2	HALIKHED_110	11:44	14:53	03:09	TRANSFORMER FAULT
449	9-Oct-20	GULBARGA	110	HV2	SHAHAPUR_220	03:20	20:10	16:50	TRANSFORMER FAULT
450	9-Oct-20	GULBARGA	110	HV2	CHINCHOLI_110	10:35	17:00	06:25	LINE CLEAR AVOIDED
451	9-Oct-20	GULBARGA	110	HV3	HALIKHED_110	10:02	14:53	04:51	TRANSFORMER FAULT
452	9-Oct-20	GULBARGA	110	LINGAPUR-HKT MINING	BMMISPAT_220	09:15	13:20	04:05	LINE CLEAR AVOIDED
453	9-Oct-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN: LINE CLEAR AVAILED
454	9-Oct-20	GULBARGA	110	SINDHANOOR-RAICHUR2	MASKI_110,MUDDAPUR_110	12:50(25.9.2020)			LINE OPEN: LINE CLEAR AVAILED
455	9-Oct-20	GULBARGA	220	ALIPUR-GOOTY	GOOTY_220	12:22	13:45	01:23	LINE CLEAR AVOIDED
456	9-Oct-20	GULBARGA	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	12:01	14:36	02:35	NFBC ISSUED
457	9-Oct-20	GULBARGA	220	SINDHNOOR-LINGSUGUR	SINDHNOOR_220	09:55	13:08	03:13	NFBC ISSUED
458	9-Oct-20	GULBARGA	400	JINDAL-BPS4	BPS_400	12:11(9.10.2020)			LINE OPEN : LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
459	9-Oct-20	HASSAN	66	BHADRA-SHMG2	bhadra_gen	10:55	12:07	01:12	NFBC ISSUED
460	9-Oct-20	HASSAN	66	HV1	BYACHANAHALLI_66	21:20	21:25	00:05	TRANSFORMER FAULT
461	9-Oct-20	HASSAN	66	HV1	BYACHANAHALLI_66	21:30	21:35	00:05	TRANSFORMER FAULT
462	9-Oct-20	HASSAN	66	HV1	BYACHANAHALLI_66	21:40	21:45	00:05	TRANSFORMER FAULT
463	9-Oct-20	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	11:28	11:32	00:04	LINE FAULT
464	9-Oct-20	HASSAN	66	MRSSHM-BD-2	MRSMG_220	10:55	12:05	01:10	NFBC ISSUED
465	9-Oct-20	HASSAN	110	GAJNUR-SHIMOGA IC LINE	GAJNUR_110	09:53	20:27	10:34	NFBC ISSUED
466	9-Oct-20	HASSAN	110	HV1	ARASIKERE_220	06:42	07:10	00:28	TRANSFORMER FAULT
467	9-Oct-20	HASSAN	110	HV1	BIRUR_110	10:22	11:03	00:41	LINE CLEAR AVAILED
468	9-Oct-20	HASSAN	110	HV1	SALATHUR_110	11:19	12:01	00:42	LINE CLEAR AVAILED
469	9-Oct-20	HASSAN	110	HV2	BIRUR_110	10:22	11:03	00:41	LINE CLEAR AVAILED
470	9-Oct-20	HASSAN	110	HV2	KONDENALU_110	04:09	04:25	00:16	TRANSFORMER FAULT
471	9-Oct-20	HASSAN	110	HV2	MSEZ_220	10:00	14:45	04:45	LINE CLEAR AVAILED
472	9-Oct-20	HASSAN	110	JOG-NK2	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
473	9-Oct-20	HASSAN	110	LV2	MRSMG_220	11:05 (7.10.2020)	16:35 (9.10.2020)	53:29 hrs	LINE CHARGED
474	9-Oct-20	HASSAN	110	MRSSHM-GAJNUR	MRSMG_220	09:41	20:23	10:42	LINE CLEAR AVAILED
475	9-Oct-20	HASSAN	110	MRSSHM-SS1	MRSMG_220	16:45	16:46	00:01	HAND TRIPPED
476	9-Oct-20	HASSAN	110	MRSSHM-SS2	MRSMG_220	16:45	16:46	00:01	HAND TRIPPED
477	9-Oct-20	HASSAN	220	KEMAR-Varahi2	KEMAR_220	12:33 (8.10.2020)	12:05 (9.10.2020)	23:31 hrs	NFBC ISSUED
478	9-Oct-20	HASSAN	220	MRSSHM-HSN4001	MRSMG_220	10:26	15:10	04:44	LINE CLEAR AVAILED
479	9-Oct-20	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	09:22	13:49	04:27	LINE CLEAR AVAILED
480	9-Oct-20	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	19:15 (8.10.2020)	13:49 (9.10.2020)	18:33 hrs	LINE CHARGED
481	9-Oct-20	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	09:20	13:49	04:29	LINE CLEAR AVAILED
482	9-Oct-20	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	23:30 (9.10.2020)			LINE OPEN: LINE CLEAR AVAILED
483	9-Oct-20	HASSAN	220	VARAHI-KEMAR2	varahi_gen	12:33 (8.10.2020)	12:05 (9.10.2020)	23:31 hrs	LINE CHARGED
484	9-Oct-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:06 (9.10.2020)			LINE OPEN: LINE CLEAR AVAILED
485	9-Oct-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	00:24	07:48	07:24	LINE CLEAR AVAILED
486	9-Oct-20	MYSURU	66	CR NAGARA-KABBALLI	NO STATIONS EFFECTED	14:44	15:22	0:38	LINE FAULT
487	9-Oct-20	MYSURU	66	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	14:07	14:13	0:05	LINE FAULT
488	9-Oct-20	MYSURU	66	HV1	KHBCOLONY_66	13:38	13:57	0:18	LINE CLEAR AVAILED
489	9-Oct-20	MYSURU	66	HV1	PANDAVAPURA_66	12:30	15:58	3:28	LINE CLEAR AVAILED
490	9-Oct-20	MYSURU	66	HV1	SUTTUR_66	14:40	16:41	2:00	LINE CLEAR AVAILED
491	9-Oct-20	MYSURU	66	HV2	DKMAIDANA_66	11:29	15:00	3:31	LINE CLEAR AVAILED
492	9-Oct-20	MYSURU	66	HV2	PANDAVAPURA_66	10:23	12:33	2:10	LINE CLEAR AVAILED
493	9-Oct-20	MYSURU	66	HV3	KUSHALNAGARA-	12:35	12:54	0:19	LINE CLEAR AVAILED
494	9-Oct-20	MYSURU	66	HV4	KUSHALNAGARA 220-	12:51	13:13	0:21	LINE CLEAR AVAILED
495	9-Oct-20	MYSURU	66	KOLLEGALA-SATHEGALA	SATHEGALA_66	17:38	17:49	0:10	LINE FAULT
496	9-Oct-20	MYSURU	66	KR PETE 220-KR PETE 1	AKKIHEBBAL_66 KIKKERI_66 KRPET_66	3:35	3:46	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
497	9-Oct-20	MYSURU	66	KR PETE 220-KR PETE 2	AKKIHBBAL_66 KIKKERI_66 KRPET_66	3:35	3:46	0:10	LINE FAULT
498	9-Oct-20	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	18:06	18:12	0:05	LINE FAULT
499	9-Oct-20	MYSURU	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	0:30	0:38	0:08	LINE FAULT
500	9-Oct-20	TUMKUR	66	BANUVALLI- HONNALLI	BANUVALLI_66	21:10	21:17	0:07	MAIN SUPPLY FAILURE
501	9-Oct-20	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	20:37	20:50	0:13	LINE FAULT
502	9-Oct-20	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	21:21	21:25	0:04	LINE FAULT
503	9-Oct-20	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	22:32	23:22	0:50	LINE FAULT
504	9-Oct-20	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	17:51	18:12	0:21	LINE FAULT
505	9-Oct-20	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL EHT_66	21:09	21:42	0:33	LINE FAULT
506	9-Oct-20	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	5:44	5:55	0:11	LINE FAULT
507	9-Oct-20	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	10:22	10:29	0:07	LINE FAULT
508	9-Oct-20	TUMKUR	66	KATTIGE- RENEW WIND IPP	RENEW WIND ENERGY_IPP_66	21:16	22:22	1:05	MAIN SUPPLY FAILURE
509	9-Oct-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	21:05	21:25	0:19	LINE FAULT
510	9-Oct-20	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	21:05	21:23	0:17	LINE FAULT
511	9-Oct-20	TUMKUR	66	MADHUGIRI 220kv- SIRA 2	SIRA_66,GULIGENAHALLI_66,	10:44	11:00	0:15	LINE FAULT
512	9-Oct-20	TUMKUR	66	MAYAKONDA- DAVANAGERE SRS 220KV	MAYAKONDA_66	17:00	17:38	0:38	LINE FAULT
513	9-Oct-20	TUMKUR	66	MAYAKONDA- DAVANAGERE SRS 220KV	MAYAKONDA_66	20:58	21:15	0:17	LINE FAULT
514	9-Oct-20	TUMKUR	66	MAYAKONDA- DAVANAGERE SRS 220KV	MAYAKONDA_66	22:22	23:50	1:27	LINE FAULT
515	9-Oct-20	TUMKUR	66	NAYAKANAHATTI66- HIREMALLANHOLE	NAYAKANAHATTI_66	5:27	5:42	0:15	LINE FAULT
516	9-Oct-20	TUMKUR	66	SOKKE-JAGLUR	JAGLUR	22:50	22:59	0:09	LINE FAULT
517	9-Oct-20	TUMKUR	66	TR-1	AMRUTHUR_66	12:01	12:26	0:25	LINE CLEAR AVAILED
518	9-Oct-20	TUMKUR	66	TR-1	PANDARAHALLI_66	11:19	16:06	4:46	LINE CLEAR AVAILED
519	9-Oct-20	TUMKUR	66	TR-2	HANAGAL_66	17:51	17:56	0:05	TRANSFORMER FAULT
520	9-Oct-20	TUMKUR	66	TR-2	HONNUDIKE_66	10:57	11:52	0:55	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
521	9-Oct-20	TUMKUR	66	TR-2	LINGADAHALLI_66(SHIMOGA)	11:05	11:26	0:20	LINE CLEAR AVAILED
522	9-Oct-20	TUMKUR	66	TR-2	LINGADAHALLI_66(SHIMOGA)	17:35	19:01	1:26	LINE CLEAR AVAILED
523	9-Oct-20	TUMKUR	66	VENKATAPURA- IMAMI_SOLAR_IPP	IMAMI_SOLAR_IPP	13:57	14:56	0:58	LINE FAULT
524	9-Oct-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT
525	9-Oct-20	TUMKUR	110	TR-2	MAYASANDRA_110	11:38(09.10.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
526	9-Oct-20	TUMKUR	110	TR-2	KBCROSS_220	10:54	12:28	1:34	LINE CLEAR AVAILED
527	9-Oct-20	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE SRS_220	10:11	15:06	4:54	LINE FAULT
528	9-Oct-20	TUMKUR	220	NITTUR 220kV- ARASIKERE	NITTUR_220	15:44	15:48	0:04	LINE FAULT
529	9-Oct-20	TUMKUR	220	NITTUR 220kV- NELAMANGALA	NITTUR_220	12:59	14:51	1:51	LINE CLEAR AVAILED
530	10-Oct-20	BAGALKOT	66	66/33KV,HV3	HARIHAR HOSPET_66	23:50 (09.10.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
531	10-Oct-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
532	10-Oct-20	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL_110	14:14 (16.09.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
533	10-Oct-20	BAGALKOT	110	BAGEWADI-MAMADAPUR1	STATION NOT AFFECTED MAMADAPUR(B)_110	4:58	5:20	0:22	LINE FAULT
534	10-Oct-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN: LINE CLEAR AVAILED
535	10-Oct-20	BAGALKOT	110	CHIKKODI220-ANKALI	ANKALI_110	23:12 (10.10.2020)			LINE OPEN : LINE FAULT
536	10-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN: LINE CLEAR AVAILED
537	10-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
538	10-Oct-20	BAGALKOT	110	GOPPANAKOPPA-NARGUND	STATION NOT AFFECTED NARGUND_110	16:22 (10.10.2020)			LINE OPEN : LINE FAULT
539	10-Oct-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
540	10-Oct-20	BAGALKOT	110	HIDAKAL-ITNAL	ITNAL_110	10:05	10:20	0:15	HAND TRIPPED
541	10-Oct-20	BAGALKOT	110	KAVALLWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	15:34 (13.09.2020)			LINE OPEN: LINE CLEAR AVAILED
542	10-Oct-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
543	10-Oct-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN: LINE CLEAR AVAILED
544	10-Oct-20	BAGALKOT	110	MAHALINGAPUR220-HIDIKAL/ITNAL	STATION NOT AFFECTED MAHALINGAPUR_220	7:50 (08.10.2020)	13:10 10.10.2020	53:20hrs	LINE CHARGED
545	10-Oct-20	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	16:28 (16.09.2020)			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
546	10-Oct-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN: LINE CLEAR AVAILED
547	10-Oct-20	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	13:46 (10.10.2020)			LINE OPEN: LINE CLEAR AVAILED
548	10-Oct-20	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	13:47 (10.10.2020)			LINE OPEN: LINE CLEAR AVAILED
549	10-Oct-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN : LINE FAULT
550	10-Oct-20	GULBARGA	110	HV1	HANUMANAL_110	23:50(10.10.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
551	10-Oct-20	GULBARGA	110	HV1	RAJESHWAR_110	09:27	09:29	00:02	TRANSFORMER FAULT
552	10-Oct-20	GULBARGA	110	HV1	KOLHAR_110	13:08	13:13	00:05	TRANSFORMER FAULT
553	10-Oct-20	GULBARGA	110	HV2	HANUMANAL_110	23:15(10.10.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
554	10-Oct-20	GULBARGA	110	KUSHTAGI-KANAKAGIRI	KANAKAGIRI_110,GANADAL_1 10	22:35(10.10.2020)			LINE OPEN : LINE FAULT
555	10-Oct-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN: LINE CLEAR AVAILED
556	10-Oct-20	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATTI 110	02:40	02:50	00:10	LINE FAULT
557	10-Oct-20	GULBARGA	110	RAICHUR-SHAHAPUR1	DEODURGA_110,GABUR_110	05:11	05:18	00:07	LINE FAULT
558	10-Oct-20	GULBARGA	110	RAICHUR-SINDHANOOR1	VALKAMDINNI_110,SIRWAR_ 110	01:45	02:00	00:15	LINE FAULT
559	10-Oct-20	GULBARGA	110	RAICHUR-SINDHANOOR1	VALKAMDINNI_110,SIRWAR_ 110	19:55	20:08	00:13	LINE FAULT
560	10-Oct-20	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110	19:54	20:01	00:07	LINE FAULT
561	10-Oct-20	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	12:25	15:05	02:40	LINE CLEAR AVAILED
562	10-Oct-20	GULBARGA	110	SEDAM-GURUMITAKAL	GURUMITKAL_110,KONKAL_1 10	19:02	19:16	00:14	LINE FAULT
563	10-Oct-20	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,ASKI_110,HU NSAGI_110,UGAR SUGAR_IPP	03:49	04:01	00:12	LINE FAULT
564	10-Oct-20	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,ASKI_110,HU NSAGI_110,UGAR SUGAR_IPP	04:07	04:21	00:14	LINE FAULT
565	10-Oct-20	GULBARGA	110	SINDHANOOR-RAICHUR2	MASKI_110,MUDDAPUR_110	12:50(25.9.2020)			LINE OPEN: LINE CLEAR AVAILED
566	10-Oct-20	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	02:15	02:30	00:15	MAIN SUPPLY FAILURE
567	10-Oct-20	GULBARGA	220	HUMNABAD-KAPNOOR1	HUMNABAD_220	22:37(11.10.2020)			LINE OPEN: LINE CLEAR AVAILED
568	10-Oct-20	GULBARGA	220	KUSHTAGI-LINGAPUR	KUSHTAGI_220	22:35(10.10.2020)			LINE OPEN : LINE FAULT
569	10-Oct-20	GULBARGA	220	KUSHTAGI-SUZLON WIND2_IPP	KUSHTAGI_220	22:35(10.10.2020)			LINE OPEN : LINE FAULT
570	10-Oct-20	GULBARGA	220	LINGAPUR-BTPS	LINGAPUR_220	13:27	16:37	03:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
571	10-Oct-20	GULBARGA	220	LINGASUGUR-RTPS2	LINGASUGUR_220	23:11	23:46	00:35	LINE FAULT
572	10-Oct-20	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	12:48	13:08	00:20	LINE FAULT
573	10-Oct-20	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	23:16(10.10.2020)			LINE OPEN: LINE CLEAR AVAILED
574	10-Oct-20	GULBARGA	400	JINDAL-BPS4	BPS_400	12:11(9.10.2020)			LINE OPEN : LINE FAULT
575	10-Oct-20	GULBARGA	400	JINDAL-GUTTUR	GUTTUR_400	2:20(10.10.2020)			LINE OPEN : LINE FAULT
576	10-Oct-20	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTYHALLI_66	15:28	16:15	00:47	LINE CLEAR AVAILED
577	10-Oct-20	HASSAN	66	HV2	BAGUR_66	15:34	16:25	00:51	LINE CLEAR AVAILED
578	10-Oct-20	HASSAN	66	HV2	KANDLI_66	15:02	15:13	00:11	TRANSFORMER FAULT
579	10-Oct-20	HASSAN	66	HV2	KANDLI_66	19:50	19:55	00:05	TRANSFORMER FAULT
580	10-Oct-20	HASSAN	66	KIADB H-RAMESWARNAGAR	KIADB_66	06:20	06:27	00:07	LINE FAULT
581	10-Oct-20	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	12:35	16:40	04:05	MAIN SUPPLY FAILURE
582	10-Oct-20	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	12:36	13:10	00:34	LINE FAULT
583	10-Oct-20	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	15:05	16:37	01:32	LINE CLEAR AVAILED
584	10-Oct-20	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	14:32	15:44	01:12	LINE FAULT
585	10-Oct-20	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	15:08	15:41	00:33	MAIN SUPPLY FAILURE
586	10-Oct-20	HASSAN	110	HV2	ESSUR_110	04:40	10:50	06:10	TRANSFORMER FAULT
587	10-Oct-20	HASSAN	110	JOG-NK1	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
588	10-Oct-20	HASSAN	110	JOG-NK2	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
589	10-Oct-20	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	14:32	15:43	01:11	LINE FAULT
590	10-Oct-20	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	15:03	15:40	00:37	LINE FAULT
591	10-Oct-20	HASSAN	220	HASSN22-Shomoga	HASSAN_220	13:11	14:15	01:04	LINE FAULT
592	10-Oct-20	HASSAN	220	KEMAR-UPCL1	KEMAR_220	09:52	14:53	05:01	LINE CLEAR AVAILED
593	10-Oct-20	HASSAN	220	MRSSHM-CHMLR	MRSMSG_220	12:30	12:56	00:26	LINE FAULT
594	10-Oct-20	HASSAN	220	SHRAVTY-SIRISI 1	sharavathy_gen	10:55	13:46	02:51	LINE CLEAR AVAILED
595	10-Oct-20	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	23:30 (9.10.2020)	13:47 (10.10.2020)	14:16 hrs	LINE CHARGED
596	10-Oct-20	HASSAN	220	UPCL-KEMAR1	upcl_gen	09:53	14:53	05:00	NFBC ISSUED
597	10-Oct-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:08 (10.10.2020)			LINE OPEN: LINE CLEAR AVAILED
598	10-Oct-20	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATION EFFECTED	11:39	11:47	0:08	LINE FAULT
599	10-Oct-20	MYSURU	66	DR PETE-MADHUVANAHALLI	SANTHEMARAHALLI_66	14:59	15:10	0:10	LINE FAULT
600	10-Oct-20	MYSURU	66	G UKKADA-SR PATNA	SRIRANGAPATNA_66	6:10	6:20	0:10	LINE FAULT
601	10-Oct-20	MYSURU	66	HANNUR-KOTHANUR	NO STATION EFFECTED	14:15	14:30	0:15	LINE FAULT
602	10-Oct-20	MYSURU	66	HANNUR-KOTHANUR	NO STATION EFFECTED	11:29	12:49	1:20	LINE CLEAR AVAILED
603	10-Oct-20	MYSURU	66	HANNUR-MADHUVANAHALLI 1	BANDALLI_66 COWDALLI_66 HANNUR_66 MARTAHALLI_66 RAMAPURA_MYS_66	14:11	14:19	0:07	LINE FAULT
604	10-Oct-20	MYSURU	66	HANNUR-MADHUVANAHALLI 2	NO STATION EFFECTED	11:29	12:04	0:35	LINE CLEAR AVAILED
605	10-Oct-20	MYSURU	66	HANNUR-MADHUVANAHALLI 2	NO STATION EFFECTED	12:29	14:40	2:11	LINE CLEAR AVAILED
606	10-Oct-20	MYSURU	66	HV1	KUSHALANAGARA_66	10:04	17:08	7:04	LINE CLEAR AVAILED
607	10-Oct-20	MYSURU	66	HV1	SATHEGALA_66	10:41	18:24	7:42	LINE CLEAR AVAILED
608	10-Oct-20	MYSURU	66	HV3	KUSHALANAGARA_66	11:40	16:52	5:12	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
609	10-Oct-20	MYSURU	66	HV4	KUSHALANAGARA_66	11:40	16:52	5:12	LINE CLEAR AVAILED
610	10-Oct-20	MYSURU	66	KOLLEGALA-SATHEGALA	NO STATION EFFECTED	12:35	15:43	3:08	NFBC ISSUED
611	10-Oct-20	MYSURU	66	KUNTHUR-DR PETE	JANNUR_66 MUGUR_66 THAYURU_66 TNARASIPURA_66 SANTHEMARAHALLI_66	14:59	15:09	0:10	LINE FAULT
612	10-Oct-20	MYSURU	66	KUSHALNAGARA 220-BETTADHAPURA	BETTADHAPURA_66 KITTUR_66 RAVANDUR_66	4:35	4:47	0:12	LINE FAULT
613	10-Oct-20	MYSURU	66	KUSHALNAGARA 220-BETTADHAPURA	NO STATION EFFECTED	11:30	17:11	5:41	LINE CLEAR AVAILED
614	10-Oct-20	MYSURU	66	KUSHALNAGARA 220-BYLUKUPPE	NO STATION EFFECTED	11:27	17:05	5:37	LINE CLEAR AVAILED
615	10-Oct-20	MYSURU	66	KUSHALNAGARA 220-EDCL	NO STATION EFFECTED	11:40	16:49	5:09	LINE CLEAR AVAILED
616	10-Oct-20	MYSURU	66	KUSHALNAGARA 220-MERCERA-1	MADIKERI_66	10:46	17:07	6:20	LINE CLEAR AVAILED
617	10-Oct-20	MYSURU	66	KUSHALNAGARA 220-MYSORE-1	NO STATION EFFECTED	11:30	17:11	5:41	LINE CLEAR AVAILED
618	10-Oct-20	MYSURU	66	KUSHALNAGARA 220-PERIPATNA-1	NO STATION EFFECTED	11:27	17:05	5:37	LINE CLEAR AVAILED
619	10-Oct-20	MYSURU	66	KUSHALNAGARA 220-RAMANTHAPURA1	NO STATION EFFECTED	11:18	16:58	5:40	LINE CLEAR AVAILED
620	10-Oct-20	MYSURU	66	KUSHALNAGARA 220-SUNTIKOPPA	SUNTIKOPPA_66	10:46	17:07	6:21	LINE CLEAR AVAILED
621	10-Oct-20	MYSURU	66	PARINAMIPURA-TALKADU	CHANDALLI_66 THALAKADU_66	7:40	7:46	0:06	LINE FAULT
622	10-Oct-20	MYSURU	66	VAJMANGALA-KADAKOLA 2	NO STATION EFFECTED	6:06	6:12	0:06	LINE FAULT
623	10-Oct-20	MYSURU	220	HV1	KUSHALNAGARA_220	11:41	16:43	5:02	LINE CLEAR AVAILED
624	10-Oct-20	MYSURU	220	HV2	KUSHALNAGARA_220	11:33	16:43	5:10	LINE CLEAR AVAILED
625	10-Oct-20	MYSURU	220	KUSHALNAGARA 220-BASTIPURA 1	NO STATION EFFECTED	11:56	16:33	4:37	LINE CLEAR AVAILED
626	10-Oct-20	MYSURU	220	KUSHALNAGARA 220-BASTIPURA 2	NO STATION EFFECTED	11:39	12:30	0:51	LINE FAULT
627	10-Oct-20	MYSURU	220	KUSHALNAGARA 220-BASTIPURA 2	NO STATION EFFECTED	12:30	16:33	4:03	LINE CLEAR AVAILED
628	10-Oct-20	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	0:11	2:58	2:47	LINE FAULT
629	10-Oct-20	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	8:53	13:22	4:28	LINE FAULT
630	10-Oct-20	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	11:02	11:12	0:09	LINE FAULT
631	10-Oct-20	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	12:19	12:31	0:11	LINE FAULT
632	10-Oct-20	TUMKUR	66	KUNDUR- SUZLON	SUZLON_IPP_66	11:01	11:35	0:34	MAIN SUPPLY FAILURE
633	10-Oct-20	TUMKUR	66	MADHUGIRI 220KV- KORATAGERE 2	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	11:25	11:46	0:21	LINE FAULT
634	10-Oct-20	TUMKUR	66	TR-1	MYLANAHALLI_66	3:28	3:39	0:10	LINE CLEAR AVAILED
635	10-Oct-20	TUMKUR	66	TR-1	MYLANAHALLI_66	2:33	2:41	0:07	LINE CLEAR AVAILED
636	10-Oct-20	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	2:14	10:02	7:47	TRANSFORMER FAULT
637	10-Oct-20	TUMKUR	110	HONNAVALI 110-ADAN SOLAR_66	ADAN SOLAR_IPP_66	7:50	8:19	0:28	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
638	10-Oct-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT
639	10-Oct-20	TUMKUR	110	TR-2	MAYASANDRA_110	23:38(09.10.2020)	16:23(10.10.20)	16:45hrs	LINE CHARGED
640	10-Oct-20	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	9:54	20:09	10:14	LINE FAULT
641	10-Oct-20	TUMKUR	220	PAVAGADA220-MADHUGIRI 2	PAVAGADA_220	4:00	4:57	0:57	LINE FAULT
642	10-Oct-20	TUMKUR	220	PAVAGADA66-MADHUGIRI	PAVAGADA_66	3:00	5:29	2:29	LINE FAULT
643	11-Oct-20	BAGALKOT	66	66/33KV,HV3	HARIHAR HOSPET_66	23:50 (09.10.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
644	11-Oct-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
645	11-Oct-20	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL_110	14:14 (16.09.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
646	11-Oct-20	BAGALKOT	110	110/11KV,HV1	GUTTAL_110	11:06	11:16	0:10	TRANSFORMER FAULT
647	11-Oct-20	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	14:10	14:50	0:40	LINE CLEAR AVAILED
648	11-Oct-20	BAGALKOT	110	110/11KV,HV2	ACHANUR_110	20:56	22:04	1:08	TRANSFORMER FAULT
649	11-Oct-20	BAGALKOT	110	BAGEWADI-MAMADAPUR1	STATION NOT AFFECTED MAMADAPUR(B)_110	2:05	2:26	0:21	LINE FAULT
650	11-Oct-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN: LINE CLEAR AVAILED
651	11-Oct-20	BAGALKOT	110	CHIKKODI220-ANKALI	ANKALI_110	23:12 (10.10.2020)	0:35 (11.10.2020)	1:23hrs	LINE CHARGED
652	11-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (31.08.2020)			LINE OPEN: LINE CLEAR AVAILED
653	11-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
654	11-Oct-20	BAGALKOT	110	GOPPANAKOPPA-NARGUND	STATION NOT AFFECTED NARGUND_110	16:22 (10.10.2020)	11:55 (11.10.2020)	19:33hrs	LINE CHARGED
655	11-Oct-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
656	11-Oct-20	BAGALKOT	110	KAVALLWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	15:34 (13.09.2020)			LINE OPEN: LINE CLEAR AVAILED
657	11-Oct-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
658	11-Oct-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN: LINE CLEAR AVAILED
659	11-Oct-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	STATION NOT AFFECTED BAGALKOT_220	21:05 (11.10.2020)			LOAD CURTAILMENT
660	11-Oct-20	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	16:28 (16.09.2020)			LINE OPEN: LINE CLEAR AVAILED
661	11-Oct-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN: LINE CLEAR AVAILED
662	11-Oct-20	BAGALKOT	220	MAHALINGAPUR-ATHANI	STATION NOT AFFECTED MAHALINGAPUR_220	20:00	22:32	2:32	LINE FAULT
663	11-Oct-20	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	13:46 (10.10.2020)			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
664	11-Oct-20	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	13:47 (10.10.2020)			LINE OPEN: LINE CLEAR AVAILED
665	11-Oct-20	BAGALKOT	220	VAJRAMATTI-BAGALKOT1	STATION NOT AFFECTED VAJRAMATTI_220	19:45 (11.10.2020)			LINE OPEN : LINE FAULT
666	11-Oct-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN : LINE FAULT
667	11-Oct-20	GULBARGA	66	HV1	ITTAGGI_220	06:01	06:05	00:04	TRANSFORMER FAULT
668	11-Oct-20	GULBARGA	66	ITTAGGI-HIREHADAGALLI1	HIREHADAGALLI_66,GIRIYAPU RA_66,MAGALA_66,SOVENAH ALLI_66,TUNGBABHADRA_IPP	12:06	12:25	00:19	LINE FAULT
669	11-Oct-20	GULBARGA	110	HUMNABAD-MANEKHALI	MANEKHALI_110	17:54	18:07	00:13	LINE FAULT
670	11-Oct-20	GULBARGA	110	HV1	HANUMANAL_110	23:50(10.10.2020)	0:20(11.10.20 20)	0:30hrs	TRANSFORMER CHARGED
671	11-Oct-20	GULBARGA	110	HV1	HANUMASAGAR_110	21:30	23:59	02:29	TRANSFORMER FAULT
672	11-Oct-20	GULBARGA	110	HV2	HANUMANAL_110	23:15(10.10.2020)	0:20(11.10.20 20)	1:05hrs	TRANSFORMER CHARGED
673	11-Oct-20	GULBARGA	110	HV2	DEODURGA_110	12:45	13:04	00:19	TRANSFORMER FAULT
674	11-Oct-20	GULBARGA	110	HV2	DEODURGA_110	13:30	13:50	00:20	TRANSFORMER FAULT
675	11-Oct-20	GULBARGA	110	HV2	SINDHANOOR_110	03:49	03:55	00:06	TRANSFORMER FAULT
676	11-Oct-20	GULBARGA	110	KUSHTAGI-KANAKAGIRI	KANAKAGIRI_110,GANADAL_1 10	22:35(10.10.2020)	0:30(11.10.20 20)	1:55 HRS	LINE CHARGED
677	11-Oct-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN: LINE CLEAR AVAILED
678	11-Oct-20	GULBARGA	110	RAICHUR-SHAHAPUR1	DEODURGA_110,GABUR_110	05:49	06:21	00:32	LINE FAULT
679	11-Oct-20	GULBARGA	110	RAICHUR-SHAHAPUR1	DEODURGA_110,GABUR_110	06:28	06:51	00:23	LINE FAULT
680	11-Oct-20	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	06:01	06:21	00:20	LINE FAULT
681	11-Oct-20	GULBARGA	110	RAICHUR-SINDHANOOR1	VALKAMDINNI_110,SIRWAR_ 110	00:40	00:53	00:13	LINE FAULT
682	11-Oct-20	GULBARGA	110	RAICHUR-SINDHANOOR1	VALKAMDINNI_110,SIRWAR_ 110	18:10	18:14	00:04	LINE FAULT
683	11-Oct-20	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110,KORWAR TEMPLE_110	11:50	21:46	09:56	LINE FAULT
684	11-Oct-20	GULBARGA	110	SEDAM-KURKUNTA	KURUKUNTA_110	12:47	17:42	04:55	LINE FAULT
685	11-Oct-20	GULBARGA	110	SEDAM-VICTASAGAR CEMENTS_IPP	VICTASAGAR CEMENTS_IPP	06:57	07:10	00:13	LINE FAULT
686	11-Oct-20	GULBARGA	110	SINDHANOOR-RAICHUR2	MASKI_110,MUDDAPUR_110	12:50(25.9.2020)			LINE OPEN: LINE CLEAR AVAILED
687	11-Oct-20	GULBARGA	220	HUMNABAD-KAPNOOR1	HUMNABAD_220	22:37(11.10.2020)	7:34(11.10.20 20)	9:00 HRS	LINE CHARGED
688	11-Oct-20	GULBARGA	220	KUSHTAGI-LINGAPUR	KUSHTAGI_220	22:35(10.10.2020)	0:01(11.10.20 20)	1:26 HRS	LINE CHARGED
689	11-Oct-20	GULBARGA	220	KUSHTAGI-SUZLON WIND2_IPP	KUSHTAGI_220	22:35(10.10.2020)			LINE OPEN : LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
690	11-Oct-20	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	23:16(10.10.2020)	8:23(11.10.2020)	9:07 HRS	LINE CHARGED
691	11-Oct-20	GULBARGA	400	JINDAL-BPS4	BPS_400	12:11(9.10.2020)			LINE OPEN : LINE FAULT
692	11-Oct-20	GULBARGA	400	JINDAL-GUTTUR	GUTTUR_400	2:20(10.10.2020)			LINE OPEN : LINE FAULT
693	11-Oct-20	HASSAN	66	CHANNAR-SHETTIHALLY	CHANNARAYAPATNA_66	03:36	03:48	00:12	LINE FAULT
694	11-Oct-20	HASSAN	66	HNPURA-RAMNATHPURA	HNPURA_66	10:39	12:08	01:29	LINE CLEAR AVAILED
695	11-Oct-20	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	10:40	12:14	01:34	LINE CLEAR AVAILED
696	11-Oct-20	HASSAN	66	HV1	HNPURA_66	10:39	12:09	01:30	LINE CLEAR AVAILED
697	11-Oct-20	HASSAN	66	HV2	HNPURA_66	10:39	12:09	01:30	LINE CLEAR AVAILED
698	11-Oct-20	HASSAN	66	HV2	KANDLI_66	09:25	09:31	00:06	TRANSFORMER FAULT
699	11-Oct-20	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	10:29	10:37	00:08	LINE FAULT
700	11-Oct-20	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	10:30	11:15	00:45	LINE CLEAR AVAILED
701	11-Oct-20	HASSAN	110	JOG-NK1	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
702	11-Oct-20	HASSAN	110	JOG-NK2	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
703	11-Oct-20	HASSAN	110	NANDIKU-BELMAN	NANDIKUR_110	05:38	06:04	00:26	LINE FAULT
704	11-Oct-20	HASSAN	110	NANDIKU-MULKY	NANDIKUR_110	05:38	06:01	00:23	LINE FAULT
705	11-Oct-20	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	13:21	18:59	05:38	LINE FAULT
706	11-Oct-20	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	10:22	16:40	06:18	LINE CLEAR AVAILED
707	11-Oct-20	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	10:22	16:41	06:19	LINE CLEAR AVAILED
708	11-Oct-20	HASSAN	220	MRSSHM-STRP1	MRSMG_220	10:22	16:39	06:17	LINE CLEAR AVAILED
709	11-Oct-20	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	10:23	16:42	06:19	LINE CLEAR AVAILED
710	11-Oct-20	MYSURU	66	CR NAGARA-HONNALLY	HONNALLY_MYS_66 ATTIGULIPURA_66	6:27	6:42	0:15	LINE FAULT
711	11-Oct-20	MYSURU	66	HALAGUR-TK HALLI	NO STATION EFFECTED	10:29	14:50	4:21	LINE CLEAR AVAILED
712	11-Oct-20	MYSURU	66	HV1	METAGALLY_66	10:25	16:47	6:22	LINE CLEAR AVAILED
713	11-Oct-20	MYSURU	66	HV1	SATHEGALA_66	11:35	18:54	7:18	LINE CLEAR AVAILED
714	11-Oct-20	MYSURU	66	HV2	SATHEGALA_66	15:01	16:50	1:49	LINE CLEAR AVAILED
715	11-Oct-20	MYSURU	66	HV2	SATHEGALA_66	18:03	18:32	0:29	LINE CLEAR AVAILED
716	11-Oct-20	MYSURU	66	K HONNALGERE-IGLOOR	K HONNALGERE_66	11:28	14:55	3:27	MAIN SUPPLY FAILURE
717	11-Oct-20	MYSURU	66	KM DODDI-TK HALLI	KIADBMANDYA_66 KMDODDI_66 KOLKARANADODDI_66 MADDUR_66 SOMANAHALLI_66 TUMBEEKERE_66	11:39	14:41	3:02	LINE CLEAR AVAILED
718	11-Oct-20	MYSURU	66	KOLLEGALA-MADHUVANAHALLI	NO STATION EFFECTED	12:32	12:37	0:05	LINE FAULT
719	11-Oct-20	MYSURU	66	KOLLEGALA-SATHEGALA	SATHEGALA_66	6:37	6:56	0:18	LINE FAULT
720	11-Oct-20	MYSURU	66	KOLLEGALA-SATHEGALA	SATHEGALA_66	15:29	19:06	3:37	NFBC ISSUED
721	11-Oct-20	MYSURU	66	KUSHALNAGARA 220-RAMANTHAPURA 1	ALUR SIDDAPURA_66 KANAGAL_66	1:58	2:06	0:08	LINE FAULT
722	11-Oct-20	MYSURU	66	MADHUVANAHALLI-KOLLEGALA 1	NO STATION EFFECTED	12:33	12:37	0:03	LINE FAULT
723	11-Oct-20	MYSURU	66	SATHEGALA-BPCL	NO STATION EFFECTED	15:01	19:08	4:07	LINE CLEAR AVAILED
724	11-Oct-20	MYSURU	66	SATHEGALA-HEBBANI	SATHEGALA_66	15:01	16:50	1:48	LINE CLEAR AVAILED
725	11-Oct-20	MYSURU	66	SATHEGALA-HEBBANI	SATHEGALA_66	18:03	18:32	0:29	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
726	11-Oct-20	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	15:07	15:16	0:08	LINE FAULT
727	11-Oct-20	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66,BASAVAPATNA_66	14:07	14:18	0:11	LINE FAULT
728	11-Oct-20	TUMKUR	66	MADHUGIRI 220kv-PULAMAGATTA	PULAMG_66	18:10	18:55	0:44	LINE FAULT
729	11-Oct-20	TUMKUR	66	PAVAGADA-NAGALAMADIKE	NAGALMADIKE_66	12:20	12:26	0:06	LINE FAULT
730	11-Oct-20	TUMKUR	66	TR-1	HANAGAL_66	11:42	12:13	0:30	LINE CLEAR AVAILED
731	11-Oct-20	TUMKUR	66	TR-1	LINGDHALLI_66(SHYLAPURA)	16:17	17:40	1:23	LINE CLEAR AVAILED
732	11-Oct-20	TUMKUR	66	TR-1	MYLANAHALLI_66	7:50	8:01	0:11	TRANSFORMER FAULT
733	11-Oct-20	TUMKUR	66	TR-1	PAVAGADA_220	13:07	13:12	0:05	TRANSFORMER FAULT
734	11-Oct-20	TUMKUR	66	TR-1	PAVAGADA_220	16:31	16:35	0:03	TRANSFORMER FAULT
735	11-Oct-20	TUMKUR	66	TR-2	BENNEHALLI_66	13:32	14:56	1:24	LINE CLEAR AVAILED
736	11-Oct-20	TUMKUR	66	TR-2	HARIHAR_66	6:44	9:41	2:57	TRANSFORMER FAULT
737	11-Oct-20	TUMKUR	110	HONNAVALLI 110-ADAN SOLAR_66	ADAN SOLAR_IPP_66	10:31	18:19	7:47	LINE CLEAR AVAILED
738	11-Oct-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT
739	11-Oct-20	TUMKUR	220	NITTUR 220kv- NELAMANGALA	NITTUR_220	10:25	14:14	3:49	LINE CLEAR AVAILED
740	12-Oct-20	BAGALKOT	66	66/33KV,HV3	HARIHAR HOSPET_66	23:50 (09.10.2020)	11:59 (12.10.2020)	12:09 hrs	TRANSFORMER CHARGED
741	12-Oct-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
742	12-Oct-20	BAGALKOT	110	110/11KV, HV1	SIDAPUR_110	12:36	12:43	00:07	LINE CLEAR AVAILED
743	12-Oct-20	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL_110	14:14 (16.09.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
744	12-Oct-20	BAGALKOT	110	110/11KV,HV2	BEDI_110	16:33	17:31	00:58	LINE CLEAR AVAILED
745	12-Oct-20	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	14:51	15:59	01:08	LINE CLEAR AVAILED
746	12-Oct-20	BAGALKOT	110	110/11KV,HV2	HIDIKAL DAM_110	14:30	15:19	00:49	LINE CLEAR AVAILED
747	12-Oct-20	BAGALKOT	110	110/11KV,HV4	KERUR_110	15:11	15:18	00:07	LINE CLEAR AVAILED
748	12-Oct-20	BAGALKOT	110	110/11KV,HV4	KERUR_110	15:34	15:40	00:06	LINE CLEAR AVAILED
749	12-Oct-20	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	20:44 (12.10.2020)			LOAD CURTAILMENT
750	12-Oct-20	BAGALKOT	110	ATHANI220-AIGALI	AIGALI_110	20:38	20:52	00:14	LINE FAULT
751	12-Oct-20	BAGALKOT	110	BAGEWADI220 1-MAMADAPUR	MAMADAPUR_110	12:35	12:50	00:15	LINE FAULT
752	12-Oct-20	BAGALKOT	110	BAGEWADI-MAMADAPUR1	MAMADAPUR(B)_110	18:18	19:35	01:17	LINE FAULT
753	12-Oct-20	BAGALKOT	110	BAGEWADI-MAMADAPUR2	MAMADAPUR(B)_110	18:18	19:35	01:17	LINE FAULT
754	12-Oct-20	BAGALKOT	110	BELGAUM220-KANABARGI LAYOUT	KANABARGI LAYOUT_110	03:34	03:39	00:05	LINE FAULT
755	12-Oct-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN: LINE CLEAR AVAILED
756	12-Oct-20	BAGALKOT	110	CHIKKODI220-ANKALI	ANKALI_110	02:35	03:00	00:25	LINE FAULT
757	12-Oct-20	BAGALKOT	110	CHIKKODI220-ANKALI	ANKALI_110	21:39	21:50	00:11	LINE FAULT
758	12-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	19:05 (04.10.2020)			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
759	12-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
760	12-Oct-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
761	12-Oct-20	BAGALKOT	110	JAMBAGI-HALKI(MUDHOL)	STATION NOT AFFECTED HALKI_110	19:12	19:30	00:18	LINE FAULT
762	12-Oct-20	BAGALKOT	110	JAMBAGI-HALKI(MUDHOL)	STATION NOT AFFECTED HALKI_110	23:40	23:50	00:10	LINE FAULT
763	12-Oct-20	BAGALKOT	110	KANABARGI LAYOUT- NEHARUNAGAR(BELGAUM110)	STATION NOT AFFECTED KANABARGI LAYOUT_110	03:35	14:59	11:24	LINE FAULT
764	12-Oct-20	BAGALKOT	110	KAVALLWADA(AMBEWADI)- KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.10.2020)			LINE OPEN: LINE CLEAR AVAILED
765	12-Oct-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
766	12-Oct-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN: LINE CLEAR AVAILED
767	12-Oct-20	BAGALKOT	110	MAMADAPUR-BELGAUM SUGARS	BELGAUM SUGARS IPP_110	18:18	20:13	01:55	LINE FAULT
768	12-Oct-20	BAGALKOT	110	MAMADAPUR-SHIRBUR	SHIRBUR_110	15:53	16:46	00:53	LINE CLEAR AVAILED
769	12-Oct-20	BAGALKOT	110	NAVALGUND-NOKAR SOLAR	NBTL(NOKAR SOLAR IPP)_110	18:34	20:03	01:29	LINE CLEAR AVAILED
770	12-Oct-20	BAGALKOT	110	VAJRAMATTI220-JAMBAGI	STATION NOT AFFECTED JAMBAGI_110	23:40	23:50	00:10	LINE FAULT
771	12-Oct-20	BAGALKOT	220	220/110KV,HV1	BAGALKOT_220	11:29 (12.10.2020)			LINE OPEN: LINE CLEAR AVAILED
772	12-Oct-20	BAGALKOT	220	220/110KV,HV3	BAGALKOT_220,NEER BUDIHAL_110,KALADAGI_110	05:05	05:22	00:17	TRANSFORMER FAULT
773	12-Oct-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	BAGALKOT_220	21:05 (11.10.2020)	12:18 (12.10.2020)	15:13 hrs	LINE CHARGED
774	12-Oct-20	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	16:28 (16.09.2020)			LINE OPEN: LINE CLEAR AVAILED
775	12-Oct-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN: LINE CLEAR AVAILED
776	12-Oct-20	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	20:49 (12.10.2020)			LOAD CURTAILMENT
777	12-Oct-20	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	20:49 (12.10.2020)			LOAD CURTAILMENT
778	12-Oct-20	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	13:46 (10.10.2020)	13:03 (12.10.2020)	23:17 hrs	LINE CHARGED
779	12-Oct-20	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	13:19 (12.10.2020)			LINE OPEN: LINE CLEAR AVAILED
780	12-Oct-20	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	13:47 (10.10.2020)	13:03 (12.10.2020)	23:16 hrs	LINE CHARGED
781	12-Oct-20	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	13:20 (12.10.2020)			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
782	12-Oct-20	BAGALKOT	220	VAJRAMATTI-BAGALKOT1	VAJRAMATTI_220	19:45 (11.10.2020)	12:19 (12.10.2020)	16:34 hrs	LINE CHARGED
783	12-Oct-20	BENGALURU	66	66kV	VIKAS TECH PARK 220 - PRIMAL PROJECT	12:44	12:50	00:05	MAIN SUPPLY FAILURE
784	12-Oct-20	BENGALURU	66	66kV	VIKAS TECH PARK 220 - GLOBAL TECH PARK	12:44	12:50	00:05	MAIN SUPPLY FAILURE
785	12-Oct-20	BENGALURU	66	66kV	VIKAS TECH PARK 220 - RMZ	12:44	12:50	00:05	MAIN SUPPLY FAILURE
786	12-Oct-20	BENGALURU	66	66kV	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	12:44	12:50	00:05	MAIN SUPPLY FAILURE
787	12-Oct-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN : LINE FAULT
788	12-Oct-20	BENGALURU	66	BIDADI 220 - BOSCH (EHT)	BOSCH (EHT)	05:55	06:43	00:48	LINE CLEAR AVAILED
789	12-Oct-20	BENGALURU	66	BIDADI 220 - EPIPL (EHT)	EPIPL (EHT)	05:55	06:43	00:48	LINE CLEAR AVAILED
790	12-Oct-20	BENGALURU	66	BIDADI 220 - HEJJALA	HEJJALA	05:55	06:50	00:55	LINE CLEAR AVAILED
791	12-Oct-20	BENGALURU	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPANAHALLI	05:55	06:43	00:48	LINE FAULT
792	12-Oct-20	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	10:30	10:40	00:10	LINE CLEAR AVAILED
793	12-Oct-20	BENGALURU	66	ISRO LAYOUT - SUBRAMANYAPURA 220	ISRO LAYOUT	06:02	06:22	00:20	MAIN SUPPLY FAILURE
794	12-Oct-20	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	12:44	12:59	00:14	MAIN SUPPLY FAILURE
795	12-Oct-20	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	12:44	12:52	00:07	MAIN SUPPLY FAILURE
796	12-Oct-20	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	12:44	12:52	00:08	MAIN SUPPLY FAILURE
797	12-Oct-20	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	06:02	06:57	00:55	LINE FAULT
798	12-Oct-20	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	12:44	12:49	00:05	LINE CLEAR AVAILED
799	12-Oct-20	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	12:44	12:49	00:05	LINE CLEAR AVAILED
800	12-Oct-20	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	12:44	12:49	00:05	LINE CLEAR AVAILED
801	12-Oct-20	BENGALURU	220	HV1	BIDADI 220	05:55	08:04	02:09	TRANSFORMER FAULT
802	12-Oct-20	BENGALURU	220	HV1	SARJAPURA 220	12:45	12:50	00:05	MAIN SUPPLY FAILURE
803	12-Oct-20	BENGALURU	220	HV2	BIDADI 220	05:55	06:42	00:47	TRANSFORMER FAULT
804	12-Oct-20	BENGALURU	220	HV2	SARJAPURA 220	12:46	12:58	00:11	MAIN SUPPLY FAILURE
805	12-Oct-20	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	12:44	12:46	00:01	LINE FAULT
806	12-Oct-20	BENGALURU	220	VIKAS TECH PARK - SARJAPURA 220	VIKAS TECH PARK	12:44	12:49	00:05	MAIN SUPPLY FAILURE
807	12-Oct-20	GULBARGA	66	HV1	CHORNOOR_66	14:10	14:25	00:15	TRANSFORMER FAULT
808	12-Oct-20	GULBARGA	66	HV1	HANASI_66	16:16	16:30	00:14	LINE CLEAR AVAILED
809	12-Oct-20	GULBARGA	66	HV1	HANASI_66	16:35	17:00	00:25	LINE CLEAR AVAILED
810	12-Oct-20	GULBARGA	66	HV1	HANASI_66	17:05	17:10	00:05	LINE CLEAR AVAILED
811	12-Oct-20	GULBARGA	66	HV1	HANASI_66	17:25	17:30	00:05	LINE CLEAR AVAILED
812	12-Oct-20	GULBARGA	66	ITTAGI-HIREHADAGALI1	HIREHADAGALLI_66	06:12	06:22	00:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
813	12-Oct-20	GULBARGA	66	ITTAGI-HIREHADAGALI1	HIREHADAGALLI_66	09:10	09:30	00:20	LINE FAULT
814	12-Oct-20	GULBARGA	66	KUDLIGI-HANASI	HANASI_66	16:25	16:30	00:05	LINE CLEAR AVAILED
815	12-Oct-20	GULBARGA	66	KUDLIGI-HANASI	HANASI_66	16:35	17:00	00:25	LINE CLEAR AVAILED
816	12-Oct-20	GULBARGA	66	KUDLIGI-HANASI	HANASI_66	17:10	17:15	00:05	LINE CLEAR AVAILED
817	12-Oct-20	GULBARGA	110	GULBARGASOUTH-GULBARGAUNIVERSITY	GULBARGAUNIVERSITY_110	10:10(10.10.2020)			LINE OPEN : LINE FAULT
818	12-Oct-20	GULBARGA	110	GURUMITKAL-SEDAM	GURUMITKAL_110	22:00	22:05	00:05	LINE CLEAR AVAILED
819	12-Oct-20	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110,MGS SK IPP,BSSK IPP	05:48	05:56	00:08	LINE FAULT
820	12-Oct-20	GULBARGA	110	HV1	KOLHAR_110	18:15	18:30	00:15	TRANSFORMER FAULT
821	12-Oct-20	GULBARGA	110	HV2	SINDHNOOR_110	09:50	10:00	00:10	TRANSFORMER FAULT
822	12-Oct-20	GULBARGA	110	HV2	HATTI_110	20:36	20:40	00:04	TRANSFORMER FAULT
823	12-Oct-20	GULBARGA	110	HV2	HATTI_110	20:48	20:50	00:02	TRANSFORMER FAULT
824	12-Oct-20	GULBARGA	110	HV2	HATTI_110	22:14	22:17	00:03	TRANSFORMER FAULT
825	12-Oct-20	GULBARGA	110	KONKAL-GURUMITKAL	GURUMITKAL_110,KONKAL_110	12:05	12:35	00:30	LINE FAULT
826	12-Oct-20	GULBARGA	110	KUSHTAGI-YELBURGA	YELBURGA_110	12:15	12:30	00:15	LINE FAULT
827	12-Oct-20	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	01:48	01:58	00:10	LINE FAULT
828	12-Oct-20	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	03:11	03:18	00:07	LINE FAULT
829	12-Oct-20	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	05:41	05:44	00:03	LINE FAULT
830	12-Oct-20	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110	04:58	05:08	00:10	LINE FAULT
831	12-Oct-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN: LINE CLEAR AVAILED
832	12-Oct-20	GULBARGA	110	RAICHUR-SINDHANOOR1	VALKAMDINNI_110,SIRWAR_110	00:13	00:21	00:08	LINE FAULT
833	12-Oct-20	GULBARGA	110	RAICHUR-SINDHANOOR1	VALKAMDINNI_110,SIRWAR_110	02:07	02:25	00:18	LINE FAULT
834	12-Oct-20	GULBARGA	110	RAICHUR-SINDHANOOR1	VALKAMDINNI_110,SIRWAR_110	03:57	04:20	00:23	LINE FAULT
835	12-Oct-20	GULBARGA	110	RAICHUR-SINDHANOOR1	VALKAMDINNI_110,SIRWAR_110	05:40	06:09	00:29	LINE FAULT
836	12-Oct-20	GULBARGA	110	RAICHUR-SINDHANOOR1	VALKAMDINNI_110,SIRWAR_110	06:29	06:35	00:06	LINE FAULT
837	12-Oct-20	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110,KORWAR TEMPLE_110	14:32	15:30	00:58	LINE FAULT
838	12-Oct-20	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110,KORWAR TEMPLE_110	15:30	16:05	00:35	LINE FAULT
839	12-Oct-20	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110,KORWAR TEMPLE_110	16:17	17:12	00:55	LINE FAULT
840	12-Oct-20	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITKAL_110	12:40(12.10.20)			LINE OPEN: LINE CLEAR AVAILED
841	12-Oct-20	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITKAL_110	05:36	05:52	00:16	LINE FAULT
842	12-Oct-20	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITKAL_110	12:07	12:40	00:33	LINE FAULT
843	12-Oct-20	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,ASKI_110,HU NSAGI_110,UGAR SUGAR_IPP	03:36	03:47	00:11	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
844	12-Oct-20	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,ASKI_110,HU NSAGI_110,UGAR SUGAR_IPP	05:10	05:19	00:09	LINE FAULT
845	12-Oct-20	GULBARGA	110	SINDHANOOR-RAICHUR2	MASKI_110,MUDDAPUR_110	12:50(25.9.2020)			LINE OPEN: LINE CLEAR AVAILED
846	12-Oct-20	GULBARGA	110	SINDHNOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110, YERADONA_110,SRERAMNAG AR_110,MALLAPURA_110	13:20	13:38	00:18	LINE FAULT
847	12-Oct-20	GULBARGA	110	SINDHNOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110, YERADONA_110,SRERAMNAG AR_110,MALLAPURA_110	17:50	18:05	00:15	LINE FAULT
848	12-Oct-20	GULBARGA	110	SINDHNOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110, YERADONA_110,SRERAMNAG AR_110,MALLAPURA_110	22:06	23:38	01:32	LINE FAULT
849	12-Oct-20	GULBARGA	110	SINDHNOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110, YERADONA_110,SRERAMNAG AR_110,MALLAPURA_110	23:28	23:38	00:10	LINE FAULT
850	12-Oct-20	GULBARGA	110	SINDHNOOR-SINDHNOOR1	SINDHNOOR_110	13:20	13:38	00:18	LINE FAULT
851	12-Oct-20	GULBARGA	110	SINDHNOOR-SUZLON1_IPP	SINDHNOOR_220	13:20	13:38	00:18	LINE FAULT
852	12-Oct-20	GULBARGA	220	HV1	SEDAM_220	10:50(12.10.20)			TRANSFORMER OPEN: LINE CLEAR AVAILED
853	12-Oct-20	GULBARGA	220	HV1	SINDHNOOR_220	13:20	14:25	01:05	TRANSFORMER FAULT
854	12-Oct-20	GULBARGA	220	KUSHTAGI-SUZLON WIND2_IPP	KUSHTAGI_220	22:35(10.10.2020)			LINE OPEN : LINE FAULT
855	12-Oct-20	GULBARGA	220	LINGASUGUR-RTPS2	LINGASUGUR_220	04:10	04:11	00:01	LINE FAULT
856	12-Oct-20	GULBARGA	220	RTPS-LINGSUGUR	LINGSUGUR_220	04:08	04:10	00:02	LINE FAULT
857	12-Oct-20	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	21:06(12.10.2020)			LINE OPEN: LINE CLEAR AVAILED
858	12-Oct-20	GULBARGA	400	JINDAL-BPS4	BPS_400	12:11(9.10.2020)	16:27(12.10.2 020)	76:16HRS	NFBC ISSUED
859	12-Oct-20	GULBARGA	400	JINDAL-GUTTUR	GUTTUR_400	2:20(10.10.2020)			LINE OPEN : LINE FAULT
860	12-Oct-20	HASSAN	66	BANDISH-ADANI	BANDISHETTYHALLI_66	22:02	22:52	00:50	LINE FAULT
861	12-Oct-20	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	16:24	18:54	02:30	LINE CLEAR AVAILED
862	12-Oct-20	HASSAN	66	HV4	BALEHONNUR_66	13:20	13:46	00:26	TRANSFORMER FAULT
863	12-Oct-20	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	10:44	10:52	00:08	LINE CLEAR AVAILED
864	12-Oct-20	HASSAN	110	HV1	ARASIKERE_220	11:39	11:59	00:20	TRANSFORMER FAULT
865	12-Oct-20	HASSAN	110	HV1	GANDASI_110	13:40	13:45	00:05	LINE CLEAR AVAILED
866	12-Oct-20	HASSAN	110	HV1	PUTTUR_110	09:46	13:41	03:55	LINE CLEAR AVAILED
867	12-Oct-20	HASSAN	110	HV2	BIRUR_110	14:33	14:50	00:17	TRANSFORMER FAULT
868	12-Oct-20	HASSAN	110	HV2	GANDASI_110	13:40	13:45	00:05	LINE CLEAR AVAILED
869	12-Oct-20	HASSAN	110	JOG-NK1	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
870	12-Oct-20	HASSAN	110	JOG-NK2	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
871	12-Oct-20	HASSAN	110	LV1	ARASIKERE_220	20:43	20:55	00:12	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
872	12-Oct-20	HASSAN	110	LV2	MRSMG_220	15:33 (12.10.2020)			LINE OPEN: LINE CLEAR AVAILED
873	12-Oct-20	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	09:04	16:15	07:11	LINE CLEAR AVAILED
874	12-Oct-20	HASSAN	110	MRSSHM-SS1	MRSMG_220	11:07	11:08	00:01	HAND TRIPPED
875	12-Oct-20	HASSAN	110	MRSSHM-SS2	MRSMG_220	11:06	11:07	00:01	HAND TRIPPED
876	12-Oct-20	HASSAN	220	HV1	ARASIKERE_220	20:43	20:55	00:12	TRANSFORMER FAULT
877	12-Oct-20	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMG_220	12:03	13:16	01:13	LINE CLEAR AVAILED
878	12-Oct-20	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	12:03	13:16	01:13	LINE CLEAR AVAILED
879	12-Oct-20	HASSAN	220	SHHRAVTY-SHIMOGA3	sharavathy_gen	12:03	13:16	01:13	LINE CLEAR AVAILED
880	12-Oct-20	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	12:03	13:16	01:13	LINE CLEAR AVAILED
881	12-Oct-20	HASSAN	220	SHRAVTY-TALAGUPPA1	sharavathy_gen	07:49	14:39	06:50	LINE FAULT
882	12-Oct-20	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	07:49	14:39	06:50	LINE FAULT
883	12-Oct-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:08 (10.10.2020)			LINE OPEN: LINE CLEAR AVAILED
884	12-Oct-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:06 (9.10.2020)	6:19 (12.10.2020)	57:12 hrs	LINE CHARGED
885	12-Oct-20	MYSURU	66	HAMPAPURA-KADAKOLA	HAMPAPURA(K)_66	13:17	13:40	00:22	LINE FAULT
886	12-Oct-20	MYSURU	66	HV1	BGNAGARA_66	15:30	16:38	01:08	LINE CLEAR AVAILED
887	12-Oct-20	MYSURU	66	HV1	SATHEGALA_66	10:32	15:02	04:29	LINE CLEAR AVAILED
888	12-Oct-20	MYSURU	66	HV2	SATHEGALA_66	10:32	12:25	01:52	LINE CLEAR AVAILED
889	12-Oct-20	MYSURU	66	KABHALLY-CLEAN SOLAR	NO STATION EFFECTED	18:27	19:53	01:26	LINE CLEAR AVAILED
890	12-Oct-20	MYSURU	66	SATHEGALA-BPCL	NO STATION EFFECTED	10:33	14:15	03:42	LINE CLEAR AVAILED
891	12-Oct-20	MYSURU	66	SATHEGALA-HEBBANI	SATHEGALA_66	10:33	12:24	01:51	LINE CLEAR AVAILED
892	12-Oct-20	MYSURU	66	SATHEGALA-KOLLEGALA	SATHEGALA_66	10:30	12:25	01:55	LINE CLEAR AVAILED
893	12-Oct-20	MYSURU	66	THANDYA-NANJANGUDU	NO STATION EFFECTED	14:22	17:45	03:22	LINE CLEAR AVAILED
894	12-Oct-20	MYSURU	220	KUSHALNAGARA-BASTIPURA 2	NO STATION EFFECTED	11:44	15:12	03:28	LINE FAULT
895	12-Oct-20	TUMKUR	66	CHITRADURGA 220KV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66 ,CHITRAHALLI_66	09:59	10:29	00:29	LINE CLEAR AVAILED
896	12-Oct-20	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	06:48	06:51	00:03	LINE FAULT
897	12-Oct-20	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL EHT_66	12:07	12:17	00:10	LINE FAULT
898	12-Oct-20	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_6 6	13:51	13:58	00:07	LINE FAULT
899	12-Oct-20	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	15:16	15:24	00:08	LINE FAULT
900	12-Oct-20	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIR I_66, BASAVAPATNA_66	15:09	15:18	00:09	LINE FAULT
901	12-Oct-20	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	06:05	06:43	00:37	LINE FAULT
902	12-Oct-20	TUMKUR	66	KUNDUR- SUZLON_IPP_66	SUZLON_IPP_66	13:52	14:29	00:37	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
903	12-Oct-20	TUMKUR	66	MADHUGIRI 220kv- PULAMAGATTA	PULAMG_66	10:19	16:36	06:17	LINE CLEAR AVAILED
904	12-Oct-20	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,R AMAGIRI_66	09:46	10:37	00:50	LINE CLEAR AVAILED
905	12-Oct-20	TUMKUR	66	TR-1	BANUVALLI_66	11:01	11:26	00:25	LINE CLEAR AVAILED
906	12-Oct-20	TUMKUR	66	TR-1	MAVINAKATTE_66	12:56	13:05	00:09	TRANSFORMER FAULT
907	12-Oct-20	TUMKUR	66	TR-1	PANDARAHALLI_66	14:03	15:41	01:38	LINE CLEAR AVAILED
908	12-Oct-20	TUMKUR	66	TR-2	BELLAVI_66	09:30	10:42	01:11	LINE CLEAR AVAILED
909	12-Oct-20	TUMKUR	66	TR-2	HONNUDIKE_66	15:12	15:38	00:25	LINE CLEAR AVAILED
910	12-Oct-20	TUMKUR	66	TR-2	HOSADURGA_66	13:59	14:26	00:27	LINE CLEAR AVAILED
911	12-Oct-20	TUMKUR	66	TR-2	MANGALWADA_66	22:27	22:31	00:03	TRANSFORMER FAULT
912	12-Oct-20	TUMKUR	66	TURUVANUR66-CHITRADURGA	TURUVANUR_66	11:20	11:56	00:35	HAND TRIPPED
913	12-Oct-20	TUMKUR	66	TURUVANUR66-JAGALUR	JAGALUR_66,BIDARKERE_66,S OKKE_66	10:44	11:55	01:11	LINE CLEAR AVAILED
914	12-Oct-20	TUMKUR	110	KB CROSS 220kv- MAYASANDRA	MAYASANDRA_110,TALKERE_ 110	16:39	17:03	00:24	LINE FAULT
915	12-Oct-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT
916	12-Oct-20	TUMKUR	110	TR-2	SHETYKERE_110	09:00	09:30	00:30	LINE CLEAR AVAILED
917	12-Oct-20	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	12:47	13:21	00:33	HAND TRIPPED
918	12-Oct-20	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	09:38	09:52	00:14	LINE FAULT