

INDUSTRIAL BRAIN	Calibration Report	Doc ID: Calibration_Report_V204
	Effective: 2023-01-01	Rev: 1.0

Instrument Calibration Report

Asset: Valve V-204 (Positioner) **Date:** 2023-06-20 **Technician:** Maria Gonzalez

Procedure: Stroked valve from 0% to 100%. **Results:** - 0% signal -> 0% travel (PASS) - 50% signal -> 48% travel (FAIL - adjusted to 50%) - 100% signal -> 100% travel (PASS)

Valve positioner calibrated successfully.

Prepared By / Technician

Approved By / Supervisor