

INDUSTRIAL BRAIN	Standard Operating Procedure	Doc ID: SOP-02_Lockout_Tagout
	Effective: 2023-01-01	Rev: 1.0

SAFETY NOTICE: Ensure all Lockout/Tagout procedures are followed before commencing work.

Standard Operating Procedure: SOP-02

Title: Lockout/Tagout (LOTO) Safety Protocol **Last Updated:** 2023-01-15 **Author:** Safety Department

1. Scope

Mandatory for all mechanical and electrical maintenance on active machinery.

2. Requirements

- Engineer must identify all energy sources (Electrical, Pneumatic, Hydraulic).
- Apply personal lock to the primary breaker.
- Verify zero energy state before proceeding.

Prepared By / Technician

Approved By / Supervisor