

INDUSTRIAL BRAIN	Standard Operating Procedure	Doc ID: SOP-03_Vibration_Analysis
	Effective: 2023-01-01	Rev: 1.0

SAFETY NOTICE: Ensure all Lockout/Tagout procedures are followed before commencing work.

Standard Operating Procedure: SOP-03

Title: Vibration Analysis Standards Last Updated: 2023-01-15 Author: Alex Chen

1. Thresholds for Rotating Machinery

- **Normal:** < 0.15 in/s
- **Warning (Alert):** 0.15 - 0.25 in/s
- **Critical (Danger):** > 0.25 in/s

If vibration exceeds the Critical threshold, the asset MUST be shut down immediately to prevent structural damage.

Prepared By / Technician

Approved By / Supervisor