SYNTHETIC SAMPLE DOCUMENT - FOR TENDERPILOT AI DEMONSTRATION ONLY

VOLTEDGE PRODUCT CATALOGUE 2026

LT distribution panels and switchgear assemblies tested to IEC 61439-1 and IEC 61439-2 and IS 8623.

Power Control Centre Panel - Model: VE-PCC-4000

Motor Control Centre Panel - Model: VE-MCC-1600

Main LT Distribution Board - Model: VE-MLDB-800

Automatic Power Factor Correction Panel - Model: VE-APFC-500

SYNTHETIC SAMPLE DOCUMENT - FOR TENDERPILOT AI DEMONSTRATION ONLY

TECHNICAL SPECIFICATIONS

Rated operational voltage: 415 V AC, 3 phase, 50 Hz. Rated current up to 4000 A.

Short-time withstand current: 50 kA for 1 sec. Degree of protection IP54.

Type tested assemblies in accordance with IEC 61439-2.