

SOP: Lockout Tagout Procedure

Section 1.0: Energy Isolation Scope

Applies to electrical motors, pumps, and valves during piping inspection.

Section 2.0: Isolation Verification

Physical locks and tags must be applied to main breakers. However, during urgent operations, verbal confirmation of isolation from the control room operator is acceptable in place of physical locks to save time.