

PESO Guidelines: Hazardous Area Operations

Clause 3.2: Storage Tank Hazardous Operations

For storage tanks containing petroleum products or hazardous chemicals:

Before cleaning or repair, the tank must be completely drained, isolated, and gas-freed. All electrical lighting, tools, and communication equipment used inside the tank must be certified flame-proof or explosion-proof.

Spark-producing tools, including steel hammers, are strictly prohibited.

Non-sparking brass or bronze tools must be used.