Weekly Taps/Shower Flushing Record Tower B

November 2026 · Week 3 in month · Date: 04/11/2026 · Name: G. Sarna

Outlet	Completed	Notes
Roof	Yes	
Bin Stores	No	Valve stiff, reported
SPA Chemical Room	Yes	
SPA Hall (Toilets)	Yes	
Massage Hall	Yes	
Massage Room	Yes	
Hairdresser Room	Yes	
Disable Toilet LG	Yes	
Studio	Yes	
Fitness 1	Yes	
Fitness 2 Learner	Yes	
SPA	Yes	
Cycle Store	Yes	
Office Sink	Yes	
Shower Disable Toilet	Yes	
Shower in SPA	Yes	
Apartment 101	Yes	
Apartment 103	Yes	
Apartment 104	Yes	
Apartment 107	Yes	

1 outlet(s) not flushed – record in the Fault and Remedial Actions Log.

Weekly Taps/Shower Flushing Record Tower B – photos

Roof

SPA Chemical Room

Massage Hall