Company Name	KLECET	Project Title	End plate
Group/Team Name	Civil	Subtitle	
Designer	Deepak	Job Number	123456
Date	05 /06 /2016	Method	Limit State Design (No Earthquake Load)

Design Conclusion	
Endplate	Pass
Endplate	
Connection Properties	
Connection	
Connection Title	Flexible Endplate
Connection Type	Shear Connection
Connection Category	
Connectivity	Column flange-Beam web
Beam Connection	Welded
Column Connection	Bolted
Loading (Factored Load)	
Shear Force (kN)	160
Components	
Column Section	ISSC 250
Material	Fe 410
Beam Section	ISMB 400
Material	Fe 410
Hole	STD
Plate Section	300X200X10
Thickness (mm)	10
Width (mm)	200
Depth (mm)	300
Hole	STD
Weld	
Type	Double Fillet
Size (mm)	10
Bolts	
Type	HSFG
Grade	8.8
Diameter (mm)	20
Bolt Numbers	4
Columns (Vertical Lines)	2
Bolts Per Column	2
Gauge (mm)	0
Pitch (mm)	226
End Distance (mm)	37
Edge Distance (mm)	37
Assembly	
Column-Beam Clearance (mm)	10

Created with

Company Name	KLECET	Project Title	End plate
Group/Team Name	Civil	Subtitle	
Designer	Deepak	Job Number	123456

Date 05 /06 /2016 Method Limit State Design (No Earthquake Load)

Design Check

Check	Required	Provided	Remark
Bolt shear capacity (kN)		V_{dsb} = ((800.0*0.6126*20*20)/(√3*1.25*1000) = 52.694 [cl. 10.3.3]	
Bolt bearing capacity (kN)		V_{dpb} = (2.5*0.508*20*10.0*410)/(1.25*1000) = 83.312 [cl. 10.3.4]	
Bolt capacity (kN)		Min (52.694, 83.312) = 52.694	**Pass**
Critical bolt shear (kN)	≤ 52.694	45.797	**Pass**
No. of bolts		4	
No.of column(s)	≤ 2	2	
No. of bolts per column per side of end plate		2	
Bolt pitch (mm)	≥ 2.5*20 = 50, ≤ Min(32*8.9, 300) = 285 [cl. 10.2.2]	226	**Pass**
Bolt gauge (mm)	≥ 2.5*20 = 50, ≤ Min(32*8.9, 300) = 285 [cl. 10.2.2]	0	
End distance (mm)	≥ 1.7*22.0 = 37.4, ≤ 12*8.9 = 106.8 [cl. 10.2.4]	37	**Pass**
Edge distance (mm)	≥ 1.7*22.0 = 37.4, ≤ 12*8.9 = 106.8 [cl. 10.2.4]	37	**Pass**
Block shear capacity (kN)	≥ 160	V_{db} = 323 [cl. 6.4.1]	
Plate thickness (mm)	≥ 8	10	**Pass**
Plate height (mm)	≥ 0.6*400.0=240.0, ≤ 400.0-16.0-14.0-16.0-14.0- 10=330.0 [cl. 10.2.4, Insdag Detailing Manual, 2002]	300	**Pass**
Plate Width (mm)	≥ 174, ≤ 250.0	200	**Pass**
Effective weld length (mm)		300-2*10 = 280	
Weld strength (kN/mm)	0.286	f_v =(0.7*10*410)/(√3*1.25*1000) = 1.326 [cl. 10.5.7]	**Pass**

Created with

Company Name KLECET Project Title End plate
Group/Team Name Civil Subtitle
Designer Deepak Job Number 123456
Date 05 /06 /2016 Method Limit State Design (No Earthquake Load)

Views



Created with

Company Name	KLECET	Project Title	End plate
Group/Team Name	Civil	Subtitle	
Designer	Deepak	Job Number	123456
Date	05 /06 /2016	Metdod	Limit State Design (No Earthquake Load)

Additional Comments