Company Name	**iit-m**	**Project Title**	**endplate3**
Group/Team Name		**Subtitle**	
Designer	**satish**	**Job Number**	
Date	**04 /06 /2016**	**Method**	**Limit State Design (No Earthquake Load)**

Design Conclusion	
Endplate	**Pass**
Endplate	
Connection Properties	
Connection	
Connection Title	Flexible Endplate
Connection Type	Shear Connection
Connection Category	
Connectivity	Column flange-Beam web
Beam Connection	Welded
Column Connection	Bolted
Loading (Factored Load)	
Shear Force (kN)	160
Components	
Column Section	ISSC 250
Material	Fe 410
Beam Section	ISMB 400
Material	Fe 410
Hole	STD
Plate Section	240X188X10
Thickness (mm)	10
Width (mm)	188
Depth (mm)	240
Hole	STD
Weld	
Type	Double Fillet
Size (mm)	8
Bolts	
Type	HSFG
Grade	8.8
Diameter (mm)	24
Bolt Numbers	6
Columns (Vertical Lines)	2
Bolts Per Column	3

Gauge (mm)	0
Pitch (mm)	60
End Distance (mm)	60
Edge Distance (mm)	44
Assembly	
Column-Beam Clearance (mm)	10

Company Name	iit-m	Project Title	endplate3
Group/Team Name		Subtitle	
Designer	satish	Job Number	
Date	04 /06 /2016	Method	Limit State Design (No Earthquake Load)

Design Check			
Check	**Required**	**Provided**	**Remark**
Bolt shear capacity (kN)		V_{dsb} = ((800.0*0.6126*24*24)/(√3*1.25*1000) = 75.88 [cl. 10.3.3]	
Bolt bearing capacity (kN)		V_{dpb} = (2.5*0.519*24*10.0*410)/(1.25*1000) = 102.139 [cl. 10.3.4]	
Bolt capacity (kN)		Min (75.88, 102.139) = 75.88	**Pass**
Critical bolt shear (kN)	≤ 75.88	42.274	**Pass**
No. of bolts		6	
No.of column(s)	≤ 2	2	
No. of bolts per column per side of end plate		3	
Bolt pitch (mm)	≥ 2.5*24 = 60, ≤ Min(32*8.9, 300) = 285 [cl. 10.2.2]	60	**Pass**
Bolt gauge (mm)	≥ 2.5*24 = 60, ≤ Min(32*8.9, 300) = 285 [cl. 10.2.2]	0	
End distance (mm)	≥ 1.7*26.0 = 44.2, ≤ 12*8.9 = 106.8 [cl. 10.2.4]	60	**Pass**
Edge distance (mm)	≥ 1.7*26.0 = 44.2, ≤ 12*8.9 = 106.8 [cl. 10.2.4]	44	**Pass**
Block shear capacity (kN)	≥ 160	V_{db} = 219 [cl. 6.4.1]	
Plate thickness (mm)	≥ 8	10	**Pass**
Plate height (mm)	≥ 0.6*400.0=240.0, ≤ 400.0-16.0-14.0-16.0-14.0-10=330.0 [cl. 10.2.4, Insdag Detailing Manual, 2002]	240	**Pass**

Plate Width (mm)	≥ 188, ≤ 250.0	188	**Pass**
Effective weld length (mm)		240-2*8 = 224	
Weld strength (kN/mm)	0.357	f_v =(0.7*8*410)/(√3*1.25*1000) = 1.06 [cl. 10.5.7]	**Pass**

Company Name	iit-m	Project Title	endplate3
Group/Team Name		Subtitle	
Designer	satish	Job Number	
Date	04 /06 /2016	Method	Limit State Design (No Earthquake Load)

Views



Company Name	iit-m	Project Title	endplate3
Group/Team Name		Subtitle	
Designer	satish	Job Number	
Date	04 /06 /2016	Metdod	Limit State Design (No Earthquake Load)

Additional Comments	