

OQMS SGD 034

Issue No.	:	05
Date of Issue	:	19-May-2014
Revision No.	:	01
Date of Revision	:	30-Aug-2014
Page	:	1 of 19

Table of Content

Tabl	le of Content
1	General2
2	Material2
3	Branch – off –Kits included:
4	Requirement7
5	Marking7
6	Packing
7	Categorization of the Aerial Closures
8	Compliance Sheet:
9	Compliance Sheet for Heat Shrinkable Closures – 4 Pages
10	Compliance Sheet for Mechanical Closures – 3 Pages
11	Field Test Report for Heat Shrinkable Closures – 2 Pages
12	Filed Test Report for Mechanical Closures – 2 Pages



OQMS SGD 034

Issue No.	:	05
Date of Issue	:	19-May-2014
Revision No.	:	01
Date of Revision	:	30-Aug-2014
Page	:	2 of 19

1 General

This specification covers the splice closure which is an enclosure or a device covering the spliced conductors in a cable joint and restore the integrity of the cable sheaths at the cable joint.

With the closure, outer surface of the ends of the cable sheath which are to be joined are covered.

The splice closure shall be suitable for closing polyethylene sheathed underground or aerial cables with straight or branch joints.

There are two types of splice closures:

- 1.1.1 heat-shrinkable type
- 1.1.2 re-enterable mechanical type

1.2 Heat-shrinkable Closure

The heat-shrinkable closure is a sheet made of special polymer which shrinked when wrapped around the cable splice and applied heat. It forms a water tight permanent closure not re-opernable.

1.3 Mechanical Closure

The mechanical closures are re-openable for modifications or maintenance purposes. Normally they are in split sleeves. Nuts and Bolts or clips are employed as fastners. Gaskets are used in case of water tight closures. Also free breathin type closures available which allows ventilation to a certain degree inside the splice closure to prevent water condensation. Mainly these are two types of installation methods.

- **1.3.1** In-line
- **1.3.2** Dome type (Sleeve 31 BPO standard) Dome type is mountable on poles, walls or inside manholes. Suitable for capacity cables.

2 Material

2.1 Material used for the closure shall be of polymer specially formulated to resist ultra – violet radiation and adverse effects of surrounding environment



OQMS SGD 034

Issue No.	:	05
Date of Issue	:	19-May-2014
Revision No.	:	01
Date of Revision	:	30-Aug-2014
Page	:	3 of 19

- 2.2 The material of the closure shall be compatible with the material of the cable sheath and the other material used in outside plant in order to prevent corrosion or other electro/chemical reactions.
- 2.3 All metal parts used shall be of high quality and rust proof.
- 2.4 Any adhesive used for the closure shall posses long lasting qualities without deterioration under extreme humid and temperature conditions, shall be impervious to moisture and resistant to mould growth throughout its life time. The peel strength of the adhesive shall be indicated. The adhesive shall ensure a water tight seal.
- 2.5 The splice closure system shall be able to withstand stresses imposed into the joint.
- 2.6 It shall also provide electrical continuity of the shield across the joint and shall have a current carrying capacity of a 4mm diameter (6 AWG) copper conductor.
- 2.7 The material for the shield connector for the shield continuity shall be preferably made of Tin-plated Brass. The connector shall be capable of carrying 1200 amperes for 10 seconds or 1000 amperes for 20 seconds.

The heat shrinkable joint closure kit shall contain the following basic components.

- 2.7.1 A wrap around heat shrinkable closure.
- 2.7.2 A flexible stainless steel closure channel with under clip.
- 2.7.3 Non corrosive metalic support canister.
- 2.7.4 Branch- off- kits.
- 2.7.5 Cable shield continuity hardware.
- 2.7.6 PVC tapes, cleaning materials, etc
- 2.7.7 Any other components relevant for the joint

The mechanical joint closure kit shall contain the following basic components

- 2.7.8 End caps for single entry /multiple entry for cables.
- 2.7.9 Split sleeve closure body with stainless steel clips, nuts and bolts etc.
- 2.7.10 PVC tapes, cleaning material etc.
- 2.7.11 Cable shield continuity hardware.
- 2.7.12 Sealing gaskets or any other required material for the same.
- 2.7.13 Installation instructions in English Language.
- 2.7.14 Any other components relevant for the joint.

3 Branch – off –Kits included:

Basically it is identified that the Branch – Off- Kit supplied with the closures need the following items to be included.



OQMS SGD 034

Issue No.	:	05
Date of Issue	:	19-May-2014
Revision No.	:	01
Date of Revision	:	30-Aug-2014
Page	:	4 of 19

Accessories required for Branch off Kits (BOKT)

No	Item	Small	Medium	Large
1.	Branching Clip	01	01	01
2.	Cleaning Tissue	02	03	03
3.	Cellophanes Tape Roll	02	02	02
4.	Silica Gel Desiccant	02	02	02
5.	Measurement Scale	01	01	01
6.	Earth wire Accessory	01	01	01
7.	Adhesive Aluminum Foil	02	02	02
8.	Adhesive PVC Tape	01	01	02
9.	Aluminium Tape	01	01	01
10.	Americ Strip	02	02	02
11.	Tie Wrap/Binding Strip	01	01	01
12.	Instruction leaflet in English	Yes	Yes	Yes
	language			



3.1 Mechanical Properties

Heat Shrinkable complete closure joint shall comply with the following tests



OQMS SGD 034

Issue No.	:	05
Date of Issue	:	19-May-2014
Revision No.	:	01
Date of Revision	:	30-Aug-2014
Page	:	5 of 19
1		

a) Tightness Test

Immerce in water at 23°C for 15 minutes at 40 Kpa test pressure. There should be no sign of air leakage from the complete closure joint.

b) Impact Test

A steel ball of 1Kg shall drop from a 2m height at 45oC for a direct impact on the surface of the closure.

Shall pass the tightness test as per 1.1.4.a) above

c) Static Load

Apply a load of 200N/cm² perpendicular to the closure surface at 45°C. Repeat the same at the diagonally opposite surface.

Shall pass the tightness test as per 1.1.4.a) above

d) Axial Tension

Tensile load at 50% of the yield strength of the cable for 15minutes at 45°C. Shall pass the tightness test as per 1.1.4.a) above

e) Bending

Clamping distance 10x cable diameter from closure edge (min:250mm) for 500N max force, for 45 degree bend or 300 mm displacement for two complete flexure cycles at 45°C per cable.

Shall pass the tightness test as 1.1.4.a) above

f) Torsion

Clamping distance 10x cable diameter from closure edge for 50 Nm torsion or 90 degree max rotation for 2 complete torsion cycles per cable at 45oC.

g) Vibration

 $10~\rm{Hz}$ sinusoidal vibration with 6mm amplitude (Peak to Peak) at a clamping $10~\rm{x}$ cable diameter (min 250mm) from closure edge for 240 hours at 45oC

h) Temperature Cycling



OQMS SGD 034

Issue No.	:	05
Date of Issue	:	19-May-2014
Revision No.	:	01
Date of Revision	:	30-Aug-2014
Page	:	6 of 19
1		

Temperature cycles from –40oC to 60oC with 8 hours duration for 10 cycles.

i) Heat resistance for jointers torch

Apply the tip of yellow flame of the jointer,s torch on the same spot of the sleeve for 10 seconds.

Shall pass the tightness test as per 1.1.4.a) above

j) Split propagation

Sleeve installed on substrate of maximum application diameter with perpendicular edge cut of 5mm length, the cut shall not propagate the split with the application of heat.

Compound filled complete mechanical closure joint shall comply with the following test series.

- Water soaked for 3 days at room temperature.
- Temperature cycling from –40°C to 60° C with 8 hourly cycle for 10 cycles.
- Re-enter the closure, remove all compound and re-encapsulate the closure with new compound.
- Temperature cycles from -40°C to 60°C with 8 hourly cycles for 10 cycles.
- Water soaked for 6 hours at 60°C.
- Apply tensile force at 50% of the yield strength of the cable for 15 minutes at 45°C.
- Water soaked for 3 days at ambient temperature, after being subjected to above series of tests the closure shall not show any deterioration. The insulation resistance of the connectors in the closure shall be more than 5000M Ω @ 500V DC.

3.2 Chemical reaction

The complete closure both mechanical /heat shrinkable shall be soaked in the following chemical for 24 hours.

a) 0.1N Sulphuric acid.



OQMS SGD 034

Issue No.	:	05
Date of Issue	:	19-May-2014
Revision No.	:	01
Date of Revision	:	30-Aug-2014
Page	:	7 of 19
1		

- b) 0.1N Sodiumhydroxide.
- c) 5% Sodium chloride,95% water by weight.
- d) 0.1N Sodium carbonate.
- e) Commercial fuel oil.

After each of the 24 –hour chemical soak, the closure shall not show any sign of damage or decay and the insulation resistance of the connections in the closure shall stay above 5,000 M Ω @ 500V DC.

4 Requirement

The closure carton shall be durable and properly labelled.

5 Marking

5.1 On the closure carton:

- 5.1.1 the manufacturer's name,
- 5.1.2 the Month and Year of manufacture,
- 5.1.3 expiry date,
- 5.1.4 splice closure designation, and
- 5.1.5 the cable pair sizes for which the kit to be used.
- 5.2 On the outer surface of the sleeve following shall be printed /engraved /embossed clearly and firmly to remain visible after installation(after heating the closure in the case of heat shrinkable closures).
 - 5.2.1 SLT Logo. The valid current logo shall be collected from the SLT Procurement Division by the Supplier in case of material supply.
 - 5.2.2 Manufacturer's Name,
 - 5.2.3 Month and year of Manufacture
 - 5.2.4 Expiry Date

6 Packing

- a) The splice closure shall be supplied in cartons in kit form containing all the requisite accessories, together with the installation instruction in simple and clear English.
- b) A list of contents in the kit shall be included in every unit.



OQMS SGD 034

Issue No.	:	05
Date of Issue	:	19-May-2014
Revision No.	:	01
Date of Revision	:	30-Aug-2014
Page	:	8 of 19

7 Categorization of the Aerial Closures

The following table shows the Minimum and the Maximum sizes for each category.

	Dia.	0.4	mm	0.5	mm	0.61	mm	0.9 r	nm
Pairs		Min	Max	Min	Max	Min	Max	Min	Max
2	20	90	225	90	250	150	250	150	275
3	30	90	225	90	250	180	250	180	275
5	50	200	300	200	300	200	300	200	350
8	30	200	300	200	300	200	325	200	300
1	00	275	450	275	450	300	480	400	480
1.	50	300	480	300	480	400	480	400	500
2	00	400	580	400	580	500	600	500	600

Category 1 : = 20 - 50 pairs : 0.4 - 0.6mm

1 Category 2 : = 80 - 100 pairs : 0.4 - 0.6 mm

2 Category3 : = 150 – 200 pairs : 0.4 – 0.6 mm

3 Category 4 : = 20 – 50 pairs : 0.9mm

4 Category 5 : = 80 - 200 pairs : 0.9mm

8 Compliance Sheet:

See Next Page.

- 9 Compliance Sheet for Heat Shrinkable Closures 4 Pages
- 10 Compliance Sheet for Mechanical Closures 3 Pages
- 11 Field Test Report for Heat Shrinkable Closures 2 Pages
- 12 Filed Test Report for Mechanical Closures 2 Pages



OQMS SGD 034

:	05
:	19-May-2014
:	01
:	30-Aug-2014
:	9 of 19
	: : : : : : : : : : : : : : : : : : : :

Field Test Report For Heat Shrinkable Closures

(In this format item no. 1 shall be filled after 6 months (for samples) / when you cut or open the closure)

Sample Description:	Manhole/ Hand Hole
Area Installed	No
Sample No	Date Installed

No	Test P	arameter	SLT Specification	Complied/ Not	Remarks
1.	Closure	1.1 Material	Fibre Reinforced laminated Material		
	G20212001	CARROCCAVIAL	Compatible with cable sheath		
		1.2 Adhesive	Long lasting under extreme humid &		10
			Temperature conditions		
			Moisture Resistant		0
			Resistant to moss growth		
		1.3 Seal	Water Tight Seal		
		1.4 Continuity	To the second se		-
		across the joint	Yes	1	
2.	Closure Kit	2.1 A wrap			4
	shall contain	around heat			
	01200030000040	shrinkable	Yes		
		closure			
		2.2 A flexible			1
		stainless steel	Leading Co.		
		closure channel	Yes		
		with under clip			
		2.3 Non		+	+
		corrosive	1000		
		metallic support	Yes		
		canister			
		2.4 Branching	-	1	-
		clips	Yes		
		2.5 Cable shield			
		CONTRACTOR STREET			
		continuity hardware (Earth			
			Yes		
		Wire Accessory)			
		2 6 4 11	-	1	
		2.6 Adhesive	Yes		
		PVC Tapes		-	-
		2.7 Cleaning	Yes		
		Tissues	(200)		
		2.8 Cellophane	Yes		
		Tape roll			
		2.9 Silica Gel	Yes		
		Desiccant	***		
		2.10Adhesive	Yes		
		Aluminium Foil	160		
		2.11 Adhesive		i	1
	Continued to	Aluminium Tape	Yes		
	next page				

Test Done	By:
(Signature	& Date)



OQMS SGD 034

:	05
:	19-May-2014
:	01
:	30-Aug-2014
:	10 of 19
	: : : : : : : : : : : : : : : : : : : :

Field Test Report For Heat Shrinkable Closures

Sample Description: Area Installed Sample No				Manhole/ Hand Hole No	
				Date Installed	
No	Test P	arameter	SLT Specification	Complied/ Not	Remarks
_	Closure Kit	2.12 Americ strip			

	Closure Kit shall contain Continued	2.12 Americ strip	Yes		
		2.13 Tie Wrap	Yes		
		2.14 Installation details in English	Yes		
		2.15 Any other components relevant for the joint (mention)	Yes		
3	Other	Closure Carton	Durable		
	Requirements		Labeled with 1. Manufacturer's Name 2. Month & Year of Manufacture 3. Splice closure Designation 4. Expiry date		
4	Marking (This	On the Outer	1. SLT Logo	** :1	8
	needs to be visible after	surface of the sleeve shall be	Month & Year of Manufacture		
	heating)	printed/ engraved/	Expiry Date		
		embossed	Name of Manufacturer		
		embossed	Name of Manufacturer		A. I.
	Overall Comme	ents (Write)			
	Recommended	/ Not			

Overall Comments (Write)	
Recommended/ Not	
Signature of Officer Tested	Date
Employee No	

Test Done By:.....(Signature & Date)

Page 2 of 2



OQMS SGD 034

Issue No.	:	05
Date of Issue	:	19-May-2014
Revision No.	:	01
Date of Revision	:	30-Aug-2014
Page	:	11 of 19

Compliance Sheet For Heat Shrinkable Closures

Samp	le Description:				
Samp	le No			Date	45
No	Test P	arameter	SLT Specification	Complied/ Not	Remarks
5.	Other Requirements	Closure Carton	Durable Labeled with 1. Manufacturer's Name 2. Year of Manufacture 3. Splice closure		
6.	Marking	On the Outer	Designation Cable pair sizes for which kit to be used SLT Logo Year of		
		sleeve shall be printed/ engraved/	Manufacture 3. Manufacturer's name		
7.	Packaging	Shall be supplied in cartons in kit form containing all the accessories together with installation instructions in simple and clear instructions	Yes		

Note 1: Tests

1.1. Tightness Test

Immerce in water at 23°C for 15 minutes at 40 Kpa test pressure. There should be no sign of air leakage from the complete closure joint.

1.2. Impact Test

A steel ball of 1Kg shall drop from a 2m height at 45° C for a direct impact on the surface of the closure. Shall pass the tightness test as per 1.1

1.3. Static Load

Apply a load of 200N/cm2 perpendicular to the closure surface at 45°C. Repeat the same at the diagonally opposite surface.

Shall pass the tightness test as per 1.1

Test Done	Ву:
(Signature	& Date)



OQMS SGD 034

Issue No.	:	05
Date of Issue	:	19-May-2014
Revision No.	:	01
Date of Revision	:	30-Aug-2014
Page	:	12 of 19

Compliance	Sheet	For Heat	Shrinkable	Closures
------------	-------	----------	------------	----------

78	. F			1 .55	
ple No				Date	
	Test Parameter		SLT Specification	Complied/ Not	Remarks
	171718 1911111		trength of the cable for 15minute or 1.1	es at 45°C	**************************************
	1.5. Bend	ing			
	(일이 아이트) 아프 (이 경기)		neter from closure edge (min:250 mplete flexure cycles at 45°C pe	35	, for 45 degree bend
	Shall pass the tigh	tness test as pe	r 1.1		
	1.6. Torsi	on			
			neter from closure edge for 50 N at 45°C.	m torsion or 90 degree m	ax rotation for 2
complete torsion cycles per cable at 45°C. 1.7. Vibration 10 Hz sinusoidal vibration with 6mm amplitude (Peak to Peak) at a clamping 10 x cable diameter (min 250mm closure edge for 240 hours at 45°C 1.8. Temperature Cycling Temperature cycles from -40°C to 60°C with 8 hours duration for 10 cycles. 1.9. Heat resistance for jointers torch Apply the tip of yellow flame of the jointer,s torch on the same spot of the sleeve for 10 seconds. Shall pass the tightness test as per 1.1 1.10. Split propagation Sleeve installed on substrate of maximum application diameter with perpendicular edge cut of 5mm length, shall not propagate the split with the application of heat.			conds.		
Vo	te 2: Chemical			olatin Gradi — escologico de escola A	138990
	a. b. c. d.	0.1N Sulphuri 0.1N Sodiumh	nydroxide. nloride ,95% water by weight. carbonate.	the following chemical f	or 24 hours.
	Overall Comment	s (Write)			
	Recommended/ N	lot			
	Signature of Offic			Date	

(Signature & Date)

Page 4 of 4



Sample Description:

Specification for OSP Material Splice Closure

OQMS SGD 034

:	05
:	19-May-2014
:	01
:	30-Aug-2014
:	13 of 19
	: : : : : : : : : : : : : : : : : : : :

Compliance Sheet For Mechanical Closures

nple No			Date	Ĭ.
		8	45	150
o Test	Parameter	SLT Specification	Complied/ Not	Remarks
1	1.1 Material	Fibre Reinforced laminated Material Compatible with cable sheath		
	1.2 Connector	Capable of carrying 1200A for 10 seconds or 1000A for 20 seconds	0	
Closure	1.3 Adhesive	Long lasting under extreme humid & Temperature conditions		
		Moisture Resistant		40
		Resistant to moss growth		17
	1.4 Seal	Water Tight Seal	5	
	1.5 Continuity across the joint	Yes		
2 Closure Ki shall contai		Yes		
	2.2 Split sleeve with stainless steel clips, stainless steel bolts, nuts etc	Yes		
	2.3 Filling compound	Yes		
	2.4 Sealing gaskets or any other required for the same	Yes		
	2.5 Cable shield continuity hardware	Yes		
	2.6 PVC Tapes, Cleaning Materials, etc	Yes		
	2.7 Installation details in English Language	Yes		8
	2.8 Any other components			

Test Done	Ву:
(Signature	& Date)

relevant for the joint (mention)



Sample Description:

Specification for OSP Material Splice Closure

OQMS SGD 034

Issue No.	:	05
Date of Issue	:	19-May-2014
Revision No.	:	01
Date of Revision	:	30-Aug-2014
Page	:	14 of 19

Compliance Sheet For Mechanical Closures

		(1)			
Samp	ole No	<u></u>		Date	
No	Test P	arameter	SLT Specification	Complied/ Not	Remarks
3.	Tests	Water soaked for 3 days at room temperature			
		Temperature cycling from - 40°C to 60°C with 8 hourly cycle for 10 cycles	Closure shall not show any deterioration.		
		Re-enter the closure, remove all compound and re-encapsulate the closure with new compound			
		Temperature cycling from -40°C to 60°C with 8 hourly cycle for 10 cycles			
		Water soaked for 6 hrs at 60°C	b. Insulation resistance of the connectors in the closure shall be $>5000M\Omega$		
		Apply tensile force at 50% of the yield strength of the cable for 15 minutes at 45°C			
4.	Chemical Reaction (See note 1)	After 24hr chemical soak	No sign of damage - Supportive certificates shall be supplied by the supplier		
			Insulation resistance of the connections shall be $>$ 5000M Ω		



OQMS SGD 034

Issue No.	:	05
Date of Issue	:	19-May-2014
Revision No.	:	01
Date of Revision	:	30-Aug-2014
Page	:	15 of 19

Compliance Sheet For M	lechanical Closures
------------------------	---------------------

ol	e Description:).			
ample No				Date	
o	Test P	arameter	SLT Specification	Complied/ Not	Remarks
	Other Requirements	Closure Carton	Durable Labeled with 1. Manufacturer's Name 2. Year of Manufacture 3. Splice closure Designation 4. Cable pair sizes for which kit to be used		
	Marking	On the Outer surface of the sleeve shall be printed/ engraved/	SLT Logo Year of Manufacture Manufacturer's name		
n, i	Packaging	Shall be supplied in cartons in kit form containing all the accessories together with installation instructions in simple and clear instructions	Yes		
No		omplete heat shrin a. 0.1N Sulphuric b. 0.1N Sodiumhy	droxide. oride ,95% water by weight. orbonate.	he following chemical fo	or 24 hours.
	Overall Comme	ents (Write)			
	Recommended	/ Not			
		ficer Tested/ Suppl		Date	
t D	one By:				

(Signature & Date)

Page 3 of 3



OQMS SGD 034

Issue No.	:	05
Date of Issue	:	19-May-2014
Revision No.	:	01
Date of Revision	:	30-Aug-2014
Page	:	16 of 19

Field Test Report For Heat Shrinkable Closures

Sample Description:					
Sample	- 11-			Date	ř
Sample	e NO			Date	
No	Test P	arameter	SLT Specification	Complied/ Not	Remarks
1		1.1 Material	Fibre Reinforced laminated Material		
- 24			Compatible with cable sheath		
	Closure	1.2 Adhesive	Long lasting under extreme humid & Temperature conditions		
			Moisture Resistant		
			Resistant to moss growth	Ī	
		1.3 Seal	Water Tight Seal	į.	ř.
		1.4 Continuity across the joint	Yes		
2	Closure Kit shall contain	2.1 A wrap around heat shrinkable closure	Yes		
		2.2 A flexible stainless steel closure channel with under clip	Yes		
		2.3 Non corrosive metallic support canister	Yes		
		2.4 Branch off clips	Yes		
		2.5 Cable shield continuity hardware	Yes	c	
		2.6 PVC Tapes, Cleaning Materials, etc	Yes		
		2.7 Installation details in English Language	Yes		
		2.8 Any other components relevant for the joint (mention)	Yes		

Test Done	Ву:
(Signature	& Date)



OQMS SGD 034

Î		
Issue No.	:	05
Date of Issue	:	19-May-2014
Revision No.	:	01
Date of Revision	:	30-Aug-2014
Page	:	17 of 19

Field Test Report For Heat Shrinkable Closures

Samp	le Description:				
Sample No					
No	Test P	arameter	SLT Specification	Complied/ Not	Remarks
3	Other Requirements	Closure Carton	Durable Labeled with 1. Manufacturer's Name 2. Year of Manufacture 3. Splice closure Designation 4. Cable pair sizes for which kit to be used		
4	Marking	On the Outer surface of the sleeve shall be printed/ engraved/	SLT Logo Year of Manufacture Manufacturer's name	<u>.</u>	
7.	Packaging	Shall be supplied in cartons in kit form containing all the accessories together with installation instructions in simple and clear instructions	10000000		
	Overall Comme	ents (Write)			
	Recommended/ Not				57 25
		ficer Tested/ Suppl		Date	

(Signature & Date)

Test Done By:....

Standardization committee for OSP Materials

Page 2 of 2



OQMS SGD 034

Issue No.	:	05
Date of Issue	:	19-May-2014
Revision No.	:	01
Date of Revision	:	30-Aug-2014
Page	:	18 of 19

Field Test Report For Mechanical Closures

Sampl	e Description:				
ampl	e No			Date	=
No	Test P	arameter	SLT Specification	Complied/ Not	Remarks
		1.1 Material	Fibre Reinforced laminated Material		
	Closure	1.2 Adhesive	Compatible with cable sheath Long lasting under extreme humid & Temperature conditions	0	
			Moisture Resistant		
			Resistant to moss growth		
		1.3 Seal	Water Tight Seal		1
		1.4 Continuity across the joint	Yes		
	Closure Kit shall contain	2.1 End caps for single entry/ Multiple entry for cables	Yes		
		2.2 Split sleeve with stainless steel clips, stainless steel bolts, nuts etc	Yes		
		2.3 Filling compound	Yes		
		2.4 Sealing gaskets or any other required for the same	Yes		
		2.5 Cable shield continuity hardware	Yes		
		2.6 PVC Tapes, Cleaning Materials, etc	Yes		
		2.7 Installation details in English Language	Yes		
		2.8 Any other components relevant for the joint (mention)	Yes		

Test Done By:.....(Signature & Date)



OQMS SGD 034

:	05
:	19-May-2014
:	01
:	30-Aug-2014
:	19 of 19
	: : : : : : : : : : : : : : : : : : : :

Field Test Report For Mechanical Closures

Other Requirements Closure Carton Durable Labeled with 1. Manufacturer's Name 2. Year of Manufacture 3. Splice closure Designation 4. Cable pair sizes for which kit to be used Marking On the Outer surface of the sleeve shall be printed/ engraved/ Packaging Shall be supplied in cartons in kit form containing all the accessories together with installation instructions in simple and clear	No	Test P	arameter	SLT Specification	Complied/ Not	Remarks
Marking On the Outer surface of the sleeve shall be printed/ and print		Other		Durable Labeled with 1. Manufacturer's Name 2. Year of Manufacture 3. Splice closure Designation	Compiled/ Not	Remark
Packaging Shall be supplied in cartons in kit form containing all the accessories together with installation instructions in simple and clear		Marking	surface of the sleeve shall be printed/	which kit to be used 1. SLT Logo 2. Year of Manufacture 3. Manufacturer's		
instructions		Packaging	Shall be supplied in cartons in kit form containing all the accessories together with installation instructions in			

Test Done By:......(Signature & Date)