



THE MAINTENANCE TEAM

4015 Shopton Rd - Suite 400  
Charlotte, NC 28217  
704-319-8326

**Invoice 40361**

Invoice Date 10/28/21

Due Date 11/27/21

Customer 12556

Oct 28 2021

**Bill To:** Woodcrest Akers, LLC  
P O Box 100068  
Fort Worth, TX 76185-0068

**Service Location:** Woodcrest Akers, LLC  
Akers Shopping Center  
1329-1497 E. Franklin Blvd  
Gastonia, NC 28054

**Work Order:** 36087

**Work Performed:** 1495 E. Franklin Blvd. - OLLIE'S - PERFORM SUITE INSPECTION AS FOLLOWS:  
HVAC - USE PM INSPECTION REPORT.

AC #3 Trane Model # YSC120A3EMA2HD; Serial # 611100380L. 2006 Model

Please access any issues. If a repair is needed in order to assess the unit, please email the office for authorization.

10/18/21 - Checked thermostat for unit #3. Changed to correct time. Checked unit up on roof and found disconnect shut-off. Checked through system and found second stage compressor unplugged. Checked and found bad windings. Turned disconnect back on and found no power to unit. Could not find breaker panel in back. Checked above ceiling and traced out electrical lines to outside cubby hole. Checked breaker panel and breaker was tripped, reset. Rechecked power on unit. Turned disconnect back on and ran system through heat. Checked inducer motor, burner assembly and heat exchanger for proper operations in heat. Checked first stage cooling for proper operations. Checked pressures and temps and compressor amps. Checked blower motor and condenser fan motor amps and all wiring and components for proper operations. Checked filters and belts. Job complete.

**Price Method:** Time and Materials

| Line #                      | Date of Service | Description          | P. O. Number | Quantity | UM | Unit Price | Price UM | Price Total | Tax Amount | Total  |
|-----------------------------|-----------------|----------------------|--------------|----------|----|------------|----------|-------------|------------|--------|
| 1 - Labor                   |                 |                      |              |          |    |            |          |             |            |        |
| 1                           | 10/18/21        | Labor - HVAC-Labor   |              | 4.25     |    | 105.00     |          | 446.25      | 31.24      | 477.49 |
| <b>Cost Type 1 Subtotal</b> |                 |                      |              |          |    |            |          | 446.25      | 31.24      | 477.49 |
| 3 - Other                   |                 |                      |              |          |    |            |          |             |            |        |
| 3                           | 10/18/21        | Other - Mobilization |              | 1.00     |    | 20.00      |          | 20.00       | 1.40       | 21.40  |
| <b>Cost Type 3 Subtotal</b> |                 |                      |              |          |    |            |          | 20.00       | 1.40       | 21.40  |
|                             |                 |                      |              |          |    |            |          | 466.25      | 32.64      | 498.89 |
| <b>Subtotal</b>             |                 |                      |              |          |    |            |          |             |            | 466.25 |
| <b>Tax</b>                  |                 |                      |              |          |    |            |          |             |            | 32.64  |
| <b>Total</b>                |                 |                      |              |          |    |            |          |             |            | 498.89 |