



THE MAINTENANCE TEAM

4015 Shopton Rd - Suite 400
Charlotte, NC 28217
704-319-8326

Invoice 41407

Invoice Date 12/16/21
Due Date 01/15/22
Customer 12556

DEC 16 2021

Bill To: Woodcrest Akers, LLC
P O Box 100068
Fort Worth, TX 76185-0068

Service Location: Woodcrest Akers, LLC
Akers Shopping Center
1329-1497 E. Franklin Blvd
Gastonia, NC 28054

Work Order: 36777

Work Performed: Ollie's - The 10 ton RTU that serves the front area above the check out desk needs ductwork replaced due to being smashed and falling apart. Ductwork isn't big enough to support the 4000 CFM airflow and will need to be increased. Existing ductwork is 16 inch flex and will need to be increased to 20 inch to move enough air for system performance. Also the concentric supply duct is so tight against the roof deck that it will not accomodate the upsized flex and will need a return grill added in ceiling (2'x4' return) to keep the concentric duct for the supply as there is room to attach new ductwork. Any store goods will need to be moved from the area that will have the ductwork replaced.

THIS QUOTE IS GOOD FOR FORTY-EIGHT HOURS.

ALL WORK TO BE PERFORMED DURING NORMAL BUSINESS HOURS.

11/30/21 THRU 12/6/21 - Picked up materials. Removed old ductwork. Installed new ductwork and new return box. Installed new flex and collars. Cleaned up job. Installed new return box in ceiling. Job is complete.
Quoted \$3,850.93

Price Method: Flat Price

Line #	Description	Price Total	Tax Amount	Total
1 - Labor				
FP	Flat Price	1,665.00	116.55	1,781.55
Cost Type 1 Subtotal		1,665.00	116.55	1,781.55
2 - Material				
FP	Flat Price	1,934.00	135.38	2,069.38
Cost Type 2 Subtotal		1,934.00	135.38	2,069.38
		3,599.00	251.93	3,850.93
Subtotal				3,599.00
Tax				251.93
Total				3,850.93