OSHA PSM 1910.119 / API RP 75 SHIFT HANDOVER REPORT

Central Processing Facility Train 1 (V-101 Separator & K-101 Compressor)

Report Ref: SHR-924B6FAA-202610242229 | Incident: INC-924B6FAA | Generated: 2026-10-24 22:29:46

Outgoing Shift Lead:	Lead Console Operator	**Incoming Shift Lead:**	Incoming Shift Lead
Operational Status:	**ACTIVE INCIDENT / ABNORMAL**	**Supervisory Mode:**	Level-2 Advisory (Zero DCS Write)

1. Executive Summary & Live DCS Telemetry

Process conditions monitored under Level-2 Supervisory advisory envelope:

Instrument Tag	Current Reading	Operating Envelope	Alarm State
ASV_101_POS	0.00 %	0.0 % (Closed)	**NORMAL**
DPIT-101	0.01 bar	0.010 - 0.050 bar	**NORMAL**
FT-101	25238.30 Sm3/h	50,000 - 80,000 Sm3/h	**NORMAL**
LT-101	50.03 %	40.0 - 65.0 %	**NORMAL**
LT-102	24.60 %	40.0 - 65.0 %	**NORMAL**
LT-103	5.00 %	5.0 - 20.0 %	**NORMAL**
PCV_101_POS	8.00 %	30.0 - 70.0 %	**NORMAL**
PT-101	93.23 barg	28.0 - 34.0 barg	**TRIP (HIGH-HIGH)**
PT-102	92.53 barg	27.0 - 33.0 barg	**TRIP (HIGH-HIGH)**
PT-103	223.75 barg	70.0 - 80.0 barg	**TRIP (HIGH-HIGH)**
VT-101	1.80 mm/s	0.50 - 3.80 mm/s	**NORMAL**

2. Diagnosed Root Causes & Bayesian Posterior Beliefs

Nominal steady-state operation. No active root causes.

3. Actions Executed & Active Remediation Sequence

No corrective actions executed during this shift.

4. Field Verification Checks (Completed vs. Pending for Incoming Crew)

No field checks completed yet during this shift.

All field verification checks cleared for this operational state.

5. Grounded Technical References (SOPs & HAZOP Safeguards)

[SOP-V101 Section 1]: Section 1. High Pressure Abatement & PCV-101 Malfunction Response

Excerpt: - **Normal Operating Pressure:** 30.0 barg to 33.0 barg - **High Pressure Alarm (PAH-101):** 34.0 barg...

[HAZOP-SEP Node 1]: Node 1. High Pressure in Separator V-101 (Parameter: Pressure / High)

Excerpt: - **Deviation:** MORE Pressure (Vessel overpressure > 34.0 barg) - **Direct Causes:**...

6. Formal Shift Handover Sign-off & Regulatory Endorsement

OUTGOING SHIFT OPERATOR

Name / Role: Lead Console Operator

Signature: _____

Timestamp: 2026-10-24 22:29:46

INCOMING SHIFT SUPERVISOR

Name / Role: Incoming Shift Lead

Signature: _____

Timestamp: _____-_____-_____ ____:____