OSHA PSM 1910.119 / API RP 75 SHIFT HANDOVER REPORT

Central Processing Facility Train 1 (V-101 Separator & K-101 Compressor)

Report Ref: SHR-F955AE48-202610242208 | Incident: INC-F955AE48 | Generated: 2026-10-24 22:08:14

Outgoing Shift Lead:	Lead Console Operator	**Incoming Shift Lead:**	Incoming Shift Lead
Operational Status:	**ACTIVE INCIDENT / ABNORMAL**	**Supervisory Mode:**	Level-2 Advisory (Zero DCS Write)

1. Executive Summary & Live DCS Telemetry

Process conditions monitored under Level-2 Supervisory advisory envelope:

Instrument Tag	Current Reading	Operating Envelope	Alarm State
DPIT-101	0.10 bar	0.010 - 0.050 bar	**TRIP (HIGH-HIGH)**
FT-101	90000.00 Sm3/h	50,000 - 80,000 Sm3/h	**HIGH ALARM**
LT-101	50.09 %	40.0 - 65.0 %	**NORMAL**
LT-102	12.80 %	40.0 - 65.0 %	**NORMAL**
LT-103	5.00 %	5.0 - 20.0 %	**NORMAL**
PT-101	30.00 barg	28.0 - 34.0 barg	**NORMAL**
PT-102	29.30 barg	27.0 - 33.0 barg	**NORMAL**
PT-103	72.00 barg	70.0 - 80.0 barg	**NORMAL**
VT-101	2.30 mm/s	0.50 - 3.80 mm/s	**NORMAL**

Active Symptoms: SYM_LOW_INTERFACE

2. Diagnosed Root Causes & Bayesian Posterior Beliefs

1. Emulsion Rag Layer & LT-102 Drift (H05) - 61.3% confidence

2. Wellhead Transient Slug Influx (H06) - 20.8% confidence

3. Separator Foaming & Demister Carryover (H03) - 8.9% confidence

3. Actions Executed & Active Remediation Sequence

No corrective actions executed during this shift.

4. Field Verification Checks (Completed vs. Pending for Incoming Crew)

No field checks completed yet during this shift.

Pending Checks for Incoming Shift Lead:

- [ ] CHK_04_THIEF_SAMPLE_EMULSION: Take Manual Thief Sample from V-101 Interface Try-Cocks
  Target: V-101 | Priority: 1 | Mandatory Verification

5. Grounded Technical References (SOPs & HAZOP Safeguards)

[SOP-V101 Section 3]: Section 3. Emulsion Layer & Oil-Water Interface Control

Excerpt: - **Target Interface Level (LT-102):** 50% - **Interface Range (Clean separation):** 40% - 60%...

[SOP-V101 Section 2]: Section 2. Demister Fouling, Carryover & Foaming Mitigation

Excerpt: - **Normal Clean Demister DP (DPIT-101):** 0.015 - 0.035 bar - **Fouling Warning Threshold:** > 0.050 bar...

6. Formal Shift Handover Sign-off & Regulatory Endorsement

OUTGOING SHIFT OPERATOR

Name / Role: Lead Console Operator

Signature: _____

Timestamp: 2026-10-24 22:08:14

INCOMING SHIFT SUPERVISOR

Name / Role: Incoming Shift Lead

Signature: _____

Timestamp: _____-_____-_____ ____:____