Hangzhou dwelling · summers 2025–2026

External shading
Reduce daytime heat

Night ventilation
Discharge heat at night

Combined (S3) versus baseline (S0)

No air conditioning

Mean indoor temperature
Lower by 1.85–2.12°C

Overheating degree-hours
(above 28°C): −17.5–17.7%

Best single measure:
night ventilation

Cooling held at 26°C

Ideal sensible demand
Lower by 6.44–7.01%

Best single measure:
external shading

Shade by day; open on cooler nights
(outdoors at least 1°C below indoors).