ECOllateral: mid-semester project review


CSCI 4150 A2 | Shaun, Troy, Scott | Evidence snapshot: October 7, 2026

Problem and current scope

How could proposed development change an area's seasonal water reserves and watershed conditions? Intended users are municipal planners, environmental researchers, and utilities. The current prototype estimates one pressure: on-site cooling consumption. It accepts IT MW, cooling type, HUC8 or coordinates, and month; it returns MGD, physical limits, a prediction range, warnings, and permit quotations. Regional supply/reserves, other demands, returns, ecological flows, and a validated stress target remain to be built.

Facility targets and research river data are generated examples. A two-day observed download checks parsing and units, not forecast accuracy. Fictional permits check location rules, not legal compliance. The historical suite had 51 passing tests; the saved API example returns HTTP 200. `predicted_collateral_stress_mgd` means on-site consumption.

Current system map



The number path uses six features: facility MW, dry/wet-bulb temperatures, river flow, PDSI, and season. Separate RF/XGBoost models learn cooling use; heat rules bound predictions and retain raw values. The permit path represents section text as TF-IDF word vectors, ranks them with FAISS, checks HUC or coordinate scope, and returns original quotations. Both paths meet in the API response. This is component evidence, not regional validation.

E1: model comparison

Train on 1,600 generated rows per cooling type across six years, seed 42. Keep complete dates together: oldest 60% train, next 20% select and calibrate, newest 20% test. The imputer learns only from training rows. Choose by calibration RMSE; compare bounded predictions on 333 test rows per type.

Cooling type	RF test MAE (MGD)	XGB test MAE (MGD)	Selected model
Cooling tower	0.004890	0.003668	XGBoost
Direct evaporative	0.003842	0.003191	XGBoost
Dry air-cooled	0.000000	0.000000	RandomForest, tied

Selected tower/direct R^2 values are 0.99808/0.99728. Both exceed $R^2 > 0.80$ and MAE < 0.05 MGD on synthetic targets. Dry cooling has a constant zero target, so R^2 is undefined. Keep XGBoost and RF for comparison; test measured consumption at unseen facilities next. Evidence: `../evidence/regression-comparison.csv`, `../evidence/benchmark.json`; implementation: `src/models/regression.py`.

E2: missing drought readings

Use 365 synthetic dates, including 121 with PDSI <= -2. Remove 10%, 25%, or 40% of observed drought readings with 50 seeded repeats. Both filling methods receive identical masks. Spatial filling tries nearest same-day donors; linear filling uses elapsed time. The fitted model stays fixed. Report variance and empirical 5th/95th percentile change bands; these are sensitivity measures, not accuracy intervals.

Missing rate	Spatial variance (MGD2)	Linear variance (MGD2)	Within +/-0.05 MGD
10%	3.29e-9	6.00e-9	100%, both
25%	6.31e-9	2.21e-8	100%, both
40%	9.05e-9	4.09e-8	100%, both

Similar generated stations make the main study easy. A separate diagnostic adds 100 MGD to donors: with 40% gaps and 20 repeats, spatial tolerance coverage is 60.33% and linear 98.60%. It uses `prediction = 0.01 * streamflow`, not the fitted model. Both fail the stricter requirement that every drought-date central 90% band stay within tolerance. Modify the tests to include biased donors, long gaps, and shared outages. Linear filling uses later readings; live forecasting needs a causal method. Groundwater filling stays in meters and needs an independently measured relationship before it can represent flow. Evidence: `../evidence/missingness-summary.csv`, `../evidence/biased-donor-diagnostic.csv`, `../evidence/missingness-sensitivity.png`, `../evidence/missingness-band90.png`, `../evidence/groundwater-reconstruction.csv`.

E3 and E4: physical and location safeguards

E3 forces model outputs of -1 and 1,000,000 MGD for a 40 MW, 30/20 C dry/wet-bulb case. Bounds are 0-0.446484 MGD; outputs move to the limits and carry `constraint_violation`. These are injected faults, not observed model errors. Keep raw/adjusted values and warnings. PUE 1.2, utilization 1.0, and heat-removal choices are adjustable assumptions, not universal ASHRAE limits. Evidence: `../evidence/constraint-failure-cases.json`; implementation: `src/rules/thermodynamic.py`, `src/models/regression.py`.

E4 uses normalized TF-IDF single words/word pairs and FAISS inner-product ranking, then location eligibility before top-k. Four fictional cases return `local-huc` for a matching HUC, nothing for a wrong HUC, nothing for a coordinate-only permit with HUC-only input, and `coordinate-only` for supplied matching coordinates. Exact

excerpts, offsets, and section IDs survive reload. Keep these checks; review real permits and measure retrieval precision/recall next. A quotation is context for a person, not a compliance decision. Evidence: `../evidence/retrieval-cases.json`; implementation: `src/grounding/store.py`.

E5: prediction-range coverage

Selected model	Test R2	Target coverage	Actual coverage
Cooling tower XGB	0.99808	90%	88.29% (294/333)
Direct evaporative XGB	0.99728	90%	87.99% (293/333)

Both results miss observed coverage >=90%. The samples are synthetic and finite; no significance test was run. R^2 is fit, not confidence. Reusing the middle date group for model selection and range sizing can bias calibration, and time dependence weakens exchangeability. Use separate selection, calibration, and test sets; report counts, range width, clipping, and coverage by cooling type, drought, time, and unseen facility. Dry cooling has 100% coverage and zero width, so it is excluded from this comparison.

The saved 40 MW tower example returns about 0.204339 MGD with a citation and synthetic/ historical-input warnings. Evidence: `../evidence/interval-coverage.csv`, `../evidence/forecast-request.json`, `../evidence/forecast.json`, `../evidence/benchmark.json`.

Decisions and next question

Decision	Evidence	What it means
Adopt models and physical limits	E1, E3	Keep the successful synthetic comparison and separate number checks
Adopt word search plus location	E4	Keep sources and eligible quotations; test real permits next
Modify missing-data and range tests	E2, E5	Test biased/shared outages, live filling, and separate calibration
Reject R2-as-confidence and town-stress claims	E1, E5, output scope	Explain fit, range coverage, and on-site consumption separately
Defer neural and generative LLM models	No comparison run	Focus first on measured water use and checked sources

Can measured area conditions and development demand support a seasonal assessment of reserves and watershed stress in an unseen area? First verify boundaries and station matches, collect measured demand/supply/returns and ecological baselines, define the regional target, and test unseen areas/facilities. Success criteria include physical bounds/warnings, controlled API errors, held-out error/coverage goals, missing-data tolerance and band checks, and no geographically ineligible quotations. Field thresholds still need team/instructor review. Neural/LLM, dense-embedding, heatwave, and 2015-2022 recharge studies are planned, not completed comparisons. Exact class studio links still need confirmation; the implemented AI connections are rules, supervised trees, word vectors, interpolation, and uncertainty testing.

Sources, team, and course readiness

The observed parsing example used USGS-01646500 (HUC8 02070008), NOAA GSOD 72403093738, and climate division 4401 on July 1-2, 2024. The division match is unverified. The synthetic API scenario uses HUC 02070010. Public endpoints and rights references are in `../../data-contracts.md`; new permit/third-party rights need checking. No surveys, IRB approval, or instructor scraping approval are claimed.

Shaun leads code/integration and separate calibration (slides 1-3); Troy supports data, station/area checks, drought/groundwater interpretation, and document grounding (4-5); Scott supports evaluation, failure analysis, regional evidence, diagrams, and rehearsal (6). Supporting roles are assignments; members must confirm their completed contributions.

The package includes the dossier, map, evidence/decision table, editable slides/PDF, four-minute talk/Q&A, team statements, and all 21 checkoff items. Confirm October 20/23 assignment, Submitty deadline, instructor/TA repository access, office hours, rehearsal, and studio references. No submission, message, booking, or access change has occurred. Repository: https://github.com/ScottLiu12/ECOllateral; remote access and pushed state are unverified. `../evidence/manifest.json` describes implementation `125aa40`; current code is refactored. File schemas and engineering choices are in `../../data-contracts.md` and `../../implementation-notes.md`; recorded results are in `../../validation-results.md`.