



RFI # 002

Date: 10/17/2022

REQUEST FOR INFORMATION

Instructions

This RFI form is a mechanism in which a bidding Subcontractor can request information from DR Horton, Central Valley Division regarding a project that is out for bid. Please complete the form and submit to the responsible Purchasing agent on the Invitation to Bid. The RFI response will be communicated via email to all applicable trade Subcontractors.

PROJECT NAME: Santa Fe Trails

To: PFS Engineering
Attn: Terri Frizzell
Phone:
Email: tfrizzell@pfseng.net

From: CVC
Contact: Scott MacFarlane
Phone: (916) 500-2938
Email: smacfarlane@concretevalue.com

QUESTION OR COMMENT

Plan Set Date: Plan #: Page #

Subject (please select all that apply):

<input type="checkbox"/>	Architectural
<input checked="" type="checkbox"/>	Structural
<input type="checkbox"/>	Mechanical
<input type="checkbox"/>	Title 24

<input type="checkbox"/>	Electrical
<input type="checkbox"/>	Plumbing
<input type="checkbox"/>	Landscaping
<input type="checkbox"/>	Solar

<input type="checkbox"/>	Color Schemes
<input type="checkbox"/>	Standard Features
<input type="checkbox"/>	Scope of Work

Question:

Currently the plans show the living slab has #3 @ 24" OCEW.

CVC proposes 2 lbs/cy of Fibermesh 300 ilo the #3 rebar @ 24" OCEW. Please Advise.

BUILDER RESPONSE

Response:

The Fibermesh substitution is acceptable.

Revised Bid Document Needed?

Yes

☐

No

☐

Patrick Modesitt 10/17/2022

Signature (DR Horton Representative)