

RFI # 1Date: 5/18/2022

REQUEST FOR INFORMATION

Instructions

This RFI form is a mechanism in which a bidding Subcontractor can request information from DR Horton, Central Valley Division regarding a project that is out for bid. Please complete the form and submit to the responsible Purchasing agent on the Invitation to Bid. The RFI response will be communicated via email to all applicable trade Subcontractors.

PROJECT NAME: Canterbury Heights

To: PFS Engineering
Attn: Terri Frizzell
Phone: _____
Email: tfrizzell@pfseng.net

From: CVC
Contact: Brett Fortney
Phone: (916) 500-2938
Email: bfortney@concretevalue.com

QUESTION OR COMMENT

Plan Set Date: _____ Plan #: _____ Page # _____

Subject (please select all that apply):

☐ Architectural
☒ Structural
☐ Mechanical
☐ Title 24

☐ Electrical
☐ Plumbing
☐ Landscaping
☐ Solar

☐ Color Schemes
☐ Standard Features
☐ Scope of Work

Question:

Currently the plans show the living and garage slabs have #3 @ 18" OCEW.

CVC proposes 2 lbs/cy of Fibermesh 300 ilo the #3 rebar @ 18" OCEW. Please Advise.

BUILDER RESPONSE

Response:

It is acceptable to use Fibermesh 300 in the conventional concrete slab in place of the #3 rebars at 18"O.C. specified. The substitution amount shall be 2lbs. of Fibermesh 300 per cubic yard.

Revised Bid Document Needed?

Yes ☐No ☐_____
Signature (DR Horton Representative)

This signature has been
applied electronically.

05/19/2022