

RFI # 2Date: 5/18/2022**REQUEST FOR INFORMATION****Instructions**

This RFI form is a mechanism in which a bidding Subcontractor can request information from DR Horton, Central Valley Division regarding a project that is out for bid. Please complete the form and submit to the responsible Purchasing agent on the Invitation to Bid. The RFI response will be communicated via email to all applicable trade Subcontractors.

PROJECT NAME: Canterbury Heights

To: PFS Engineering
Attn: Terri Frizzell
Phone: _____
Email: tfrizzell@pfseng.net

From: CVC
Contact: Scott MacFarlane
Phone: 916 549 8012
Email: smacfarlane24@concretevalue.com

QUESTION OR COMMENT

Plan Set Date: _____ Plan #: _____ Page # _____

Subject (please select all that apply):

<input type="checkbox"/>	Architectural
<input checked="" type="checkbox"/>	Structural
<input type="checkbox"/>	Mechanical
<input type="checkbox"/>	Title 24

<input type="checkbox"/>	Electrical
<input type="checkbox"/>	Plumbing
<input type="checkbox"/>	Landscaping
<input type="checkbox"/>	Solar

<input type="checkbox"/>	Color Schemes
<input type="checkbox"/>	Standard Features
<input type="checkbox"/>	Scope of Work

Question:

Currently the garage slabs have 2 lbs/cy of Fibermesh 300 approved. CVC would like to eliminate reinforcing in the garages.

May we eliminate reinforcement in the garages? Please Advise.

BUILDER RESPONSE**Response:**

It is acceptable to remove the reinforcing from the garage slabs.



Revised Bid Document Needed?

Yes ☐No ☐

Signature (DR H)

This signature has been
applied electronically.

November 16, 2022