

PFS Consulting

1750 Howe Ave. Suite 640
Sacramento, CA 95825

(916) 978-2875 ph
(916) 978-2876 fax

November 16, 2022

D.R. Horton
Attn: Nikoll Morales
419 W. Murray Ave.
Visalia, CA 93291

**RE: Garage Slab Rebar RFI Letter – All Plans
Santa Fe Trail (Job #22026)**

To whom it may concern:

This letter is to verify that for the above project, the following issue has been addressed by this office.

- It is acceptable to remove the #3 bars at 24" O.C. that is specified in keynote 1A from the garage slab.

Please contact this office for any further questions regarding this matter.



This signature has been
applied electronically.

Patrick Modesitt, P.E.

November 16, 2022