PFS Consulting

1750 Howe Ave. Suite 640 Sacramento, CA 95825

(916) 978-2875 ph (916) 978-2876 fax

August 8, 2022

D.R. Horton Attn: Nikoll Morales 419 W. Murray Ave. Visalia, CA 93291

RE: Fiber Mesh RFI Letter – All Plans Eagle Cove(PFS Consulting Job #21006)

To whom it may concern:

This letter is to verify that for the above project, the following issue has been addressed by this office.

• It is acceptable to use Fibermesh 300 in the conventional concrete slab in place of the #3 rebars at 24" O.C. specified on the plans in keynotes 1 and 1A. The substitution amount shall be 2 lbs of Fibermesh 300 per cubic yard.

Please contact this office for any further questions regarding this matter.



Patrick Modesitt, P.E.

August 8, 2022