

Consultee Comments for Planning Application 25/01315/FUL

Application Summary

Application Number: 25/01315/FUL

Address: Land Adjacent 3 Brickfield Cottages East Cowes Road East Cowes Isle Of Wight PO32 6NH

Proposal: Proposed detached dwelling and garage

Case Officer: Hayley Byrne

Consultee Details

Name: Mr Jerry Willis

Address: IOW Council (Seaclose Office), Fairlee Road, Newport, Isle Of Wight PO30 2QS

Email: Not Available

On Behalf Of: Tree Officer

Comments

It is seen that the impact on high amenity tree by this development could be less than the previous consented development. However, the tree protection plan would not be sufficient to protect the trees in this development. This because the RPA of T9 is not completely protected and no information has been provided as to how the porcelain tiles will be installed within it as shown in plans. It is also noted the position of T9 may not accurately plotted as explained on the plans and as such the extent of exposed RPA could be greater.

In the previous plans the current garage within the crown spread of the adjacent tree was to be retained and now will be replaced within the RPA of the adjacent tree and the fencing is not adequate in this instance.

As such it is advised if permission is to be given the following condition should address these factors and detail how the site will be managed during the construction given the limited space and how such things as drainage, services etc will be addressed given the limited consideration the tree report gives such matters.

Arboricultural Method statement (including fencing and demolition)

No development shall take place until an Arboreal Method Statement has been submitted to and agreed in writing by the local planning authority detailing how the potential impact to the trees will be minimised during demolition and construction works, including details of protective tree fencing to be installed for the duration of construction works. The agreed method statement will then be adhered to throughout the development of the site.

Reason: This condition is a pre-commencement condition to prevent damage to trees during

construction and to ensure that the high amenity tree(s) to be retained is adequately protected from damage to health and stability throughout the construction period in the interests of the amenity in compliance with Policy DM12 (Landscape, Seascape, Biodiversity and Geodiversity) of the Island Plan Core Strategy.