

Tewkesbury Borough Council
Council Offices
Gloucester Road
Tewkesbury
Gloucestershire
GL20 5TT

Highways Development
Management
Economy Environment and
Infrastructure
Shire Hall
Westgate Street
Gloucester
GL1 2TG

10 December 2025
Your ref: 25/00855/FUL
Ask for: Mark Sweet

Dear Chloe Buckingham

**TOWN AND COUNTRY PLANNING ACT 1990
(DEVELOPMENT MANAGEMENT PROCEDURE) (ENGLAND) ORDER 2015
ARTICLE 18 CONSULTATION WITH HIGHWAY AUTHORITY**

PROPOSAL: Erection of a detached single storey 3-bedroom self-build dwelling and construction of a detached single storey car port with access driveway and vehicular parking
LOCATION: 124 Cheltenham Road Bishops Cleeve Cheltenham Gloucestershire GL52 8LZ
APPLICANT: Mr James Edwards

Gloucestershire County Council, the Highway Authority acting in its role as Statutory Consultee has undertaken a full assessment of this planning application. Based on the appraisal of the development proposals the Highways Development Management Manager on behalf of the County Council, under Article 18 of the Town and Country Planning (Development Management Procedure)(England) Order, 2015 has no objection subject to condition.

The site plan shows the existing access retained with mature hedges which would restrict width for a shared access and visibility. In accordance with MfGS a minimum access it should be a minimum of 4.1 metres wide for both the existing and proposed dwelling with 2 metre pedestrian visibility splays from the driveway edges along the footway back edge from 2 metres within the site access.

The Design and Access Statement mentions the previous application and only forward visibility, however the Highways Authority stated that emerging pedestrian visibility and shared access width be provided which is sought by condition in the absence of revised plans to widen the existing access and remove obstructive hedge boundaries.

Vehicle visibility is sufficient.

Tel: 01452 427604
Email: mark.sweet@gloucestershire.gov.uk

EV charging is annotated north of site parking on the plan which would be required to meet updated Building Regulations and therefore a condition is not necessary.

Cycle parking is illustrated on plan adjacent to car parking and near the front entrance with details recommended to be secured via condition.

Waste storage is beyond recommended distances for occupants, however this not considered to impact on highway users significantly.

The Highway Authority has undertaken a robust assessment of the planning application. Based on the analysis of the information submitted the Highway Authority concludes that there would not be an unacceptable impact on Highway Safety or a severe impact on congestion. There are no justifiable grounds on which an objection could be maintained.

The Highway Authority therefore submits a response of no objection subject to the following conditions.

CONDITIONS:

Access;

Notwithstanding the submitted plans the shared access shall be widened to a minimum of 4.1 metres to allow two-way estate car passing for the proposed and existing dwellings with extended vehicle footway crossover. Bound hardstanding within 5 metres of the footway back edge and drainage retained on site.

Reason: To ensure safe and suitable access for site and highway users in accordance with INF1 of the Local Plan Core Strategy, PD 0.1 and 0.4 of the Local Transport Plan or policy Paragraph 115 and 117 of NPPF.

Provision of Pedestrian Visibility Splays

The Development hereby approved shall not be brought into use until pedestrian visibility splays of 2m x 2m measured perpendicularly back from the back of footway shall be provided on both sides of the access. These splays shall thereafter be permanently kept free of all obstructions to visibility over 0.6m in height above the adjoining ground level.

Reason: To ensure motorists have clear and unrestricted views of approaching pedestrians when pulling out onto the adopted highway, in the interest of highway safety.

Bicycle Parking

The Development hereby approved shall not be occupied until sheltered, secure and accessible parking for 2 adult bicycles parking has been provided in general accordance with HPD09 Rev A. The storage area shall be maintained for this purpose thereafter.

REASON: To promote sustainable travel and healthy communities according to INF1 of the Core Strategy and NPPF paragraph 112.

Informatives;

Tel: 01452 42 7604

Email: mark.sweet@gloucestershire.gov.uk

Alterations to Vehicular Access

The Local Highway Authority has no objection to the above subject to the applicant obtaining a section 184 licence. The construction of a new access will require the extension of a verge and/or footway crossing from the carriageway under the Highways Act 1980 - Section 184 and the Applicant is required to obtain the permission of Gloucestershire Highways on 08000 Infor514 514 or highways@gloucestershire.gov.uk before commencing any works on the highway. Full Details can be found at www.gloucestershire.gov.uk .

No Drainage to Discharge to Highway

Drainage arrangements shall be provided to ensure that surface water from the driveway and/or vehicular turning area does not discharge onto the public highway. No drainage or effluent from the proposed development shall be allowed to discharge into any highway drain or over any part of the public highway.

Protection of Visibility Splays

The applicant's attention is drawn to the need to ensure that the provision of the visibility splay(s) required by this consent is safeguarded in any sale of the application site or part(s) thereof.