
PRE-APPLICATION ADVICE

Date: 27 August 2025

Applicant: Paul Stack Planning

Location: Land adjacent to 3 Brickfield Cottages, East Cowes Road, PO32 6NH

Proposal: Detached dwelling

History

Pre-application advice issued on the 21 December 2020 in respect of a proposed 2/3 bedroom detached dwelling. Visibility splays of 2.4m by 200.0m recommended, as well as set back of gates and on-site turning facilities.

Pre-application advice issued on the 11 January 2021 in respect of a proposed 2/3 bedroom detached dwelling. Visibility splays of 2.4m by 200.0m recommended, as well as set back of gates and on-site turning facilities.

In respect of planning application 21/02386/FUL - *removal of caravan; Proposed dwelling*, this Office did originally raise an objection on the grounds that *the proposed development would generate an increase in vehicular traffic entering and leaving the public highway through an existing vehicle access that is limited in respect to gate setback and junction visibility to the detriment of highway safety and would add unduly to the hazards of highway users and would therefore be contrary to Policy DM2 (Design Quality for New Development) and DM17 (Sustainable Travel) of the Isle of Wight Core Strategy.*

This Office has previously agreed that speeds are more reflective of a 50mph environment due to the alignment of the carriageway and Y distances of 147m were accepted. A 5m set back for gates was also accepted.

It was accepted that whilst *'the access still fails to fully comply with the required visibility standards when considering the scale of development (a single 2 bedroomed dwelling) and the existing layout it is seen to offer highway safety gain so that this office can support this application on grounds of betterment.'*

3# planning conditions were recommended:

SIGHT LINES


The development / dwelling hereby approved shall not be occupied / brought into use until sight lines have been provided in accordance with the visibility splays shown on the approved plan PL02-003 Rev. C, dated January 2022. Nothing that may cause an obstruction to visibility when taken at a height of 1.0m above the adjacent carriageway / public highway shall at any time be placed or be permitted to remain within that visibility splay.

Reason: In the interests of highway safety and to comply with policy DM2 (Design Quality for New Development) of the Island Plan Core Strategy.

VEHICULAR ACCESS

The development / dwelling hereby approved shall not be occupied / brought into use until the means of vehicular access thereto has been constructed and drained in accordance with details to be submitted and approved in writing by the Local Planning Authority based on the layout as detailed on drawing number PL02-003 Rev. C, dated January 2022.

Reason: In the interests of highway safety and to comply with policy DM2 (Design Quality for New Development) of the Island Plan Core Strategy.



Plan no. PL02-003 Rev. C

SET BACK OF GATES

Notwithstanding the provisions of the Town and Country Planning (General Permitted Development) (England) Order 2015 (or any Order revoking and re-enacting that Order with or without modification), no gates shall be erected other than those expressly authorised by this permission/other than gates that are set back a minimum distance of 5.0 metres from the edge of the carriageway of the adjoining highway and open into the site only.

Reason: In the interests of highway safety and to comply with policy DM2 (Design Quality for New Development) of the Island Plan Core Strategy.

Planning permission was granted on the 8 August 2022 with 12# conditions attached, including:

Condition 5


The dwelling hereby approved shall not be brought into use until sight lines have been provided in accordance with the visibility splays shown on the approved plan PL02-003 Rev. D, dated May 2022. Nothing that may cause an obstruction to visibility when taken at a height of 1.0m above the adjacent carriageway / public highway shall at any time be placed or be permitted to remain within that visibility splay.

Reason: In the interests of highway safety and to comply with policy DM2 (Design Quality for New Development) of the Island Plan Core Strategy.

Condition 6.

The dwelling hereby approved shall not be brought into use until the means of vehicular access thereto has been constructed and drained in accordance with details to be submitted and approved in writing by the Local Planning Authority based on the layout as detailed on drawing number PL02-003 Rev. D, dated May 2022.

Reason: In the interests of highway safety and to comply with policy DM2 (Design Quality for New Development) of the Island Plan Core Strategy.



Plan PL02-003 Rev. D

Condition 7.

Notwithstanding the provisions of the Town and Country Planning (General Permitted Development) (England) Order 2015 (or any Order revoking and re-enacting that Order with or without modification), no gates shall be erected other than those expressly authorised by this permission/other than gates that are set back a minimum distance of 5.0 metres from the edge of the carriageway of the adjoining highway and open into the site only.

Reason: In the interests of highway safety and to comply with policy DM2 (Design Quality for New Development) of the Island Plan Core Strategy

It is noted that Condition 1 requires the development to commence within 3 years from the 8 August 2022 and it is assumed by this Office that the permission is no longer extant.

Current Proposal

Taking into account the history of the site referred to earlier, an 85%ile speed of 50mph has been previously agreed which should result in a Y distance requirement of 149m based on a reaction time of 2 seconds and a deceleration rate of 2.45m/s^2 . Since the previous planning permission still carries some weight and there have been no changes to planning policy or material consideration, a 147m Y distance to the north-east of the proposed access is still considered acceptable.

The weight to be attributed to the previous planning permission also relates to the agreed Y distance to the south-west and a Y distance of 28.5m is considered acceptable. The X distance should be 2.0m and the gates set back at least 5.0m from the carriageway edge.

Please note the highway advice contained within this report is based purely on a desk based assessment of the information submitted to Island Roads for consideration on the 27 August 2025. The comments contained within this report are without prejudice to the outcome of any future planning applications made in relation to this site. Planning permission is not guaranteed to be forthcoming based on this advice.

Island Roads act on behalf of the Isle of Wight Council as a highway consultee for the purpose of the planning process. You are therefore advised to liaise with the Isle of Wight Council Planning Department at Seaclose Offices, Fairlee Road, Newport, Isle of Wight (tel 01983 821000) to ascertain what form of planning consent and obligations are required in association with your proposal.
