



TESTING & CONSULTANCY CELL
Providing Technical Services Since 1979
GURU NANAK DEV ENGINEERING COLLEGE
An Autonomous College u/s[2(f)and 12(B)] of UGC Act 1956
NBA Accredited,Punjab Govt.Aided Status ISO-9001-2008 Certified
Gill Park,Gill Road,Ludhiana-141006 Ph.0161-2491193
Website:<http://tcc.gndec.ac.in> E-mail:tcc@gndec.ac.in

NO.GNDEC/TCC/R/---

Dated:28-2-2015

To

M/s S.S.B. Enterprises,
B-08, Sai Kunj, New Palam Vihar, Part-3,
Gurgaon,

Sub: Test Report of Concrete cubes.(Cilo Foundation,Hopper,Collumn at United Breweries Limited C-60,Focal Point,
Ludhiana

Ref: Your Letter No. Nil dated 27.01.2015

The result of concrete cubes sent by you tested on 29.10.11 are as under.

S.No.	Description	Cube Dated	Mix	Comp.StrengthMpa
1	cube	12.19.2014	M25	18.75
2	cube	29.10.10	M25	24.69
3	cube	28.1.12	M25	22.22
4	cube	2.2.12	M25	22.67
5	cube	12.2.12	M25	23.42
6	cube	24.2.13	M25	20.00

Condition:

1. This test report refers only to the samples submitted for the test.
2. test shall not be used for any sales promotions or advertiements without permission.
3. report is not to be used for legal purpose & will not be produced in the Court of Law

(Co-ordinator)

Dean Testing & Consultancy