

JOB REQUEST

PILIPINAS KAO, INC.

REQUESTING DEPARTMENT

REQUESTING DEPARTMENT	: <u>Logistics</u>	DATE ISSUED	: <u>6-Nov-14</u>
EQUIPMENT TAG NUMBER	: <u>G-253</u>	REQUESTED BY	: <u>ADome</u>
EQUIPMENT DESCRIPTION	: <u>T232 iso-loading pump</u>	SUPERVISOR	: <u>E. Canillo</u>
LOCATION	: <u>STY</u>	SECTION MANAGER	: <u>RDSantos</u>
EXPECTED TIME FINISHED	: <u>7-Nov-14</u>		


BRIEF DESCRIPTION OF REQUEST: (Please use another sheet for drawings, illustration, measures)

Safety Patrol Finding: E1027087 (Detached steam trap discharge line, also some damaged installation)

Please provide steam "by-pass" since currently, only steam trap is installed. Also, please repair insulation.

(Note: This was already initially coordinated with Carlo)

LKG 14 - 137



PRODUCTION ENGINEERING DEPARTMENT

JOB CLASSIFICATION:	<input type="checkbox"/> Maintenance	DATE RECEIVED	: _____
<input type="checkbox"/> MECHANICAL	<input type="checkbox"/> New Installation/ revision	JOB REQUEST NO.	: _____
<input type="checkbox"/> PIPING	<input type="checkbox"/> CIVIL	ENG'R.-IN-CHARGE	: _____
<input type="checkbox"/> ELECTRICAL	<input type="checkbox"/> INSTRUMENTATION	CONTRACTOR	: _____

REMARKS:

FOR NEW INSTALLATION/ REVISION ONLY:

ESTIMATED COST	: _____
ENGINEER-IN-CHARGE	: _____
APPROVED BY	: _____
	Requesting Department Manager

JUSTIFICATION:

MAINTENANCE CONTRACTOR

WORK PERFORMED: (Use separate sheet if necessary)	RECEIVED BY	: _____
TROUBLE:	DATE RECEIVED	: _____
	DATE STARTED	: _____
	DATE FINISHED	: _____
CAUSE(S):	PERFORMED BY	: _____
ACTIONS TAKEN:	JOB STATUS VERIFICATION:	
	ENG'R.-IN-CHARGE	: _____
	REQUESTING DEPT.	: _____
	REMARKS	: _____