

Daily PM and Inspection Checklist

Based on CMS Form 2786R (07/2018) — 2012 Life Safety Code (Healthcare)

Table of Contents

1. Introduction
 2. Daily Tasks
 3. Compliance References
 4. Notes and Guidance
 5. Follow-Up Actions
 6. Summary Section
 7. Document Revision History
-

Introduction

This checklist is designed to ensure the safety and compliance of healthcare facilities with the 2012 Life Safety Code (Healthcare). It covers daily, monthly, quarterly, and annual tasks related to construction/renovation areas, means of egress, exit signs, emergency lighting, corridor and smoke barrier doors, hazardous areas, soiled linen and trash containers, portable fire extinguishers, alcohol-based hand rub dispensers, oxygen cylinder storage, portable space heaters, smoking compliance, fire alarm and sprinkler system status, combustible decorations, and physical environment.

Daily Tasks

- Construction / Renovation Areas — Means of Egress (K791) ★ *REQUIRED DAILY*
- Means of Egress — Full Facility Walk (K211)
- Exit Signs and Emergency Lighting (K293, K291)
- Corridor and Smoke Barrier Doors — Full Facility (K223, K363, K374)
- Hazardous Areas — Doors and Conditions (K321)
- Soiled Linen and Trash Containers (K754)
- Portable Fire Extinguishers — Visual Inspection (K355)
- Alcohol Based Hand Rub Dispensers — ABHR (K325)
- Oxygen Cylinder Storage — Visual Check (K923, K906)
- Portable Space Heaters (K781)
- Smoking Compliance (K741)
- Fire Alarm and Sprinkler System Status (K346, K354)
- Combustible Decorations — Visual Check (K753, K751)
- Physical Environment — Daily Check (§483.90)

Compliance References

- 18.7.9, 19.7.9, 4.6.10, 7.1.10.1, NFPA 241
- 18.2.1, 19.2.1, 7.1.10.1
- 19.2.10.1, 18.2.10.1 | 18.2.9.1, 19.2.9.1
- 18.2.2.2.7–2.2.2.8, 19.2.2.2.7–2.2.2.8 | 19.3.6.3, 18.3.6.3 | 19.3.7.6, 18.3.7.6

- 19.3.2.1, 19.3.5.9 (Existing) | 18.3.2.1 (New)
- 18.7.5.7, 19.7.5.7
- 18.3.5.12, 19.3.5.12, NFPA 10
- 18.3.2.6, 19.3.2.6
- 11.3.1–11.3.4, 11.6.5 | 5.1.3.2, 5.1.3.3 (NFPA 99)
- 18.7.8, 19.7.8
- 18.7.4, 19.7.4
- 9.6.1.6 (Fire Alarm) | 9.7.5, 15.5.2 NFPA 25 (Sprinkler)
- 18.7.5.6, 19.7.5.6 | 18.7.5.1, 19.7.5.1
- 42 CFR §483.90(g), §483.90(i), §483.10(i)

Notes and Guidance

- Provide examples or guidance in the "Notes" column for common issues or observations.
- Include specific details to help inspectors identify and address potential problems.

Follow-Up Actions

Task #	Description	Follow-Up Action Required	Assigned To	Target Date
1				
2				

Summary Section

Total Deficiencies Found: _____

Immediate Corrective Actions Taken: ☐ Yes ☐ No ☐ N/A

Work Orders Submitted: ☐ Yes ☐ No WO#(s): _____

Items Requiring Follow-Up: ☐ Yes ☐ No

#	K-Tag	Location / Description	Action Required	Assigned To	Target Date
1					
2					

Document Revision History

Revision	Date	Description of Changes	Updated By
1.0	2026-05-18	Initial draft with updates.	

1. Construction / Renovation Areas — Means of Egress (K791) ★

REQUIRED DAILY

Reference: 18.7.9, 19.7.9, 4.6.10, 7.1.10.1, NFPA 241

This is the only item in CMS 2786R explicitly required to be inspected daily.

#	Construction / Renovation Area	Egress Path Clear	Signage in Place	Barriers Intact	Notes
1.1	Location: _____	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
1.2	Location: _____	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
1.3	Location: _____	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	

☐ No active construction / renovation today — N/A

⚠ Any means of egress in a construction or renovation area must be **instantly usable in an emergency**. Deficiencies must be corrected before leaving the area.

2. Means of Egress — Full Facility Walk (K211)

Reference: 18.2.1, 19.2.1, 7.1.10.1

Walk every corridor, stairwell, and exit discharge path on each occupied floor.

Floor / Area	Corridors Clear	Stairwells Clear	Exit Discharge Clear	Notes
Floor: _____	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
Floor: _____	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
Floor: _____	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
Basement / Mechanical	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	

3. Exit Signs and Emergency Lighting (K293, K291)

Reference: 19.2.10.1, 18.2.10.1 | 18.2.9.1, 19.2.9.1

Floor / Area	Exit Signs Lit	Directional Signs Lit	Emerg. Lighting Operational	Notes
Floor: _____	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
Floor: _____	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
Floor: _____	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
Stairwells	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
Mechanical / Basement	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	

Total failed exit signs: _____

Total failed emergency lighting units: _____

Work order(s) submitted: ☐ Yes ☐ No WO#: _____

4. Corridor and Smoke Barrier Doors — Full Facility (K223, K363, K374)

Reference: 18.2.2.2.7–2.2.2.8, 19.2.2.2.7–2.2.2.8 | 19.3.6.3, 18.3.6.3 | 19.3.7.6, 18.3.7.6

Floor / Area	No Propped Corridor Doors	Smoke Barrier Doors Functional	Stairwell / Exit Doors Latching	Notes
Floor: _____	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
Floor: _____	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
Floor: _____	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
Basement / Mechanical	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	

Doors found propped open: _____

Doors with damaged hardware / closers: _____

5. Hazardous Areas — Doors and Conditions (K321)

Reference: 19.3.2.1, 19.3.5.9 (Existing) | 18.3.2.1 (New)

Hazardous Area	Location	Door Closed & Latching	No Overflow / Obstruction	Notes
Boiler / Mechanical Room		☐ Yes ☐ No	☐ Yes ☐ No	
Laundry (> 100 sq ft)		☐ Yes ☐ No	☐ Yes ☐ No	
Soiled Linen Room		☐ Yes ☐ No	☐ Yes ☐ No	
Trash Collection Room		☐ Yes ☐ No	☐ Yes ☐ No	
Combustible Storage		☐ Yes ☐ No	☐ Yes ☐ No	
Paint / Maintenance Shop		☐ Yes ☐ No	☐ Yes ☐ No	
Other: _____		☐ Yes ☐ No	☐ Yes ☐ No	

6. Soiled Linen and Trash Containers (K754)

Reference: 18.7.5.7, 19.7.5.7

#	Task	Pass	Fail	N/A	Notes
6.1	No individual container exceeds 32-gallon capacity in corridors or patient areas				
6.2	Total capacity does not exceed 32 gallons within any 64 sq ft area				

#	Task	Pass	Fail	N/A	Notes
6.3	Mobile containers >32 gallons stored in protected room when unattended				
6.4	Recycling containers, if present, are ≤96 gallons and properly labeled				

7. Portable Fire Extinguishers — Visual Inspection (K355)

Reference: 18.3.5.12, 19.3.5.12, NFPA 10

Floor / Area	All Extinguishers Present & Mounted	Seals / Tamper Indicators Intact	Pressure in Operable Range	Last Annual Tag Current	Notes
Floor: _____	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
Floor: _____	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
Floor: _____	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
Mechanical / Kitchen	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	

Extinguishers found missing or discharged: _____

Replaced / reordered: ☐ Yes ☐ No

8. Alcohol Based Hand Rub Dispensers — ABHR (K325)

Reference: 18.3.2.6, 19.3.2.6

#	Task	Pass	Fail	N/A	Notes
8.1	No dispenser installed within 1 inch of ignition source (light switch, outlet)				
8.2	No dispenser installed over carpeted floors in unsprinklered areas				
8.3	Aggregate in any single smoke compartment does not exceed 10 gallons / 1,135 oz aerosol				
8.4	Individual dispensers do not exceed 0.32 gal fluid or 18 oz Level 1 aerosol				
8.5	Minimum 4-foot horizontal spacing between dispensers maintained				

9. Oxygen Cylinder Storage — Visual Check (K923, K906)

Reference: 11.3.1–11.3.4, 11.6.5 | 5.1.3.2, 5.1.3.3 (NFPA 99)

#	Task	Pass	Fail	N/A	Notes
9.1	Cylinders stored upright and secured (chained / strapped)				
9.2	Full and empty cylinders are segregated and labeled				
9.3	No flammable materials stored with oxygen cylinders				
9.4	Valve protection caps in place on cylinders not in use				
9.5	Cylinders not stored in tightly closed spaces without ventilation				
9.6	"NO SMOKING / OXIDIZING GAS" signage posted at cylinder storage rooms				
9.7	Aggregate of cylinders in patient care area $\leq$ 300 cubic feet (if not in enclosed storage)				

10. Portable Space Heaters (K781)

Reference: 18.7.8, 19.7.8

Floor / Area	No Prohibited Space Heaters Found	Notes
Patient Care Areas	☐ Pass ☐ Fail	
Sleeping Rooms	☐ Pass ☐ Fail	
Staff / Employee Areas (check element temp $\leq$ 212°F if present)	☐ Pass ☐ Fail	

11. Smoking Compliance (K741)

Reference: 18.7.4, 19.7.4

#	Task	Pass	Fail	N/A	Notes
11.1	No smoking in oxygen storage or use areas				
11.2	No smoking in flammable/combustible storage areas				
11.3	"No Smoking" signs posted at all major entrances and required areas				
11.4	Metal self-closing butt receptacles available in designated smoking areas				

12. Fire Alarm and Sprinkler System Status (K346, K354)

Reference: 9.6.1.6 (Fire Alarm) | 9.7.5, 15.5.2 NFPA 25 (Sprinkler)

System	Status	If Impaired — Duration	Fire Watch Active	AHJ Notified
Fire Alarm	☐ In Service ☐ Impaired		☐ Yes ☐ No ☐ N/A	☐ Yes ☐ No ☐ N/A
Sprinkler	☐ In Service ☐ Impaired		☐ Yes ☐ No ☐ N/A	☐ Yes ☐ No ☐ N/A

⚠ Fire Alarm out >4 hrs / Sprinkler out >10 hrs in a 24-hour period requires AHJ notification AND evacuation or approved fire watch.

13. Combustible Decorations — Visual Check (K753, K751)

Reference: 18.7.5.6, 19.7.5.6 | 18.7.5.1, 19.7.5.1

#	Task	Pass	Fail	N/A	Notes
13.1	No excessive combustible decorations on walls, ceilings, or non-fire-rated doors				
13.2	Cubicle curtains intact, hanging properly, and not bunched				
13.3	No unapproved fabric, film, or paper decorations in corridors or exits				

14. Physical Environment — Daily Check (\$483.90)

Reference: 42 CFR §483.90(g), §483.90(i), §483.10(i)

#	Task	Pass	Fail	N/A	Notes
14.1	Resident call system — test from at least 2 patient room bedsides (§483.90(g))				
14.2	Resident call system — test from at least 2 toilet / bathing facilities (§483.90(g))				
14.3	Corridor handrails present and firmly secured on both sides of all corridors (§483.90(i)(3))				
14.4	Adequate lighting operational in all corridors, patient rooms, and common areas (§483.10(i)(5))				
14.5	Facility temperature within comfortable and safe range — 71–81°F in patient areas (§483.10(i)(6))				
14.6	No evidence of pest or rodent activity in patient care areas, dining, or food storage (§483.90(i)(4))				
14.7	Dining and activity areas well-lighted, ventilated, and free of obstruction to use (§483.90(h))				

#	Task	Pass	Fail	N/A	Notes
14.8	No visible unsafe condition with mechanical, electrical, or patient care equipment in occupied areas (§483.90(d)(2))				

Temperature Reading(s): _____ °F (Location: _____)

Updates for Emergency Preparedness

- **Communication Plan Check:** Ensure that all communication devices (e.g., phones, radios) are operational and ready for emergency use. *(Not specifically required by CMS, but recommended as a best practice.)*

Summary / Sign-Off

Total Deficiencies Found: _____

Immediate Corrective Actions Taken: ☐ Yes ☐ No ☐ N/A

Work Orders Submitted: ☐ Yes ☐ No WO#(s): _____

Items Requiring Follow-Up: ☐ Yes ☐ No

#	K-Tag	Location / Description	Action Required	Assigned To	Target Date
1					
2					

Inspector Signature: _____ Date: _____

Supervisor / Director Signature: _____ Date: _____

Quick Reference — Inspection Frequency Summary

Frequency	Key Requirement	K-Tag
Each Shift	Egress clear, exit signs lit, doors not propped, O ₂ safety, fire watch if needed, resident call spot check, handrails, temperature	K211, K291, K293, K223, K346, K354, K925, §483.90
Daily	Full facility walk + construction area egress (only explicitly daily item) + resident call system, handrails, lighting, temp, pest check	K791 + all above, §483.90
Monthly	Elevator Firefighter's Service, Generator load test, LIM test, full resident call system test, pest control verification	K531, K918, K914, §483.90
Quarterly	Fire drills (each shift, each quarter), physical environment walk, bed rail/frame inspection, smoke alarm battery check	K712, §483.90, §483.25(n)
Annually	Fire alarm test, sprinkler inspection, door assembly inspection, fire extinguisher service, physical environment compliance	K345, K353, K761, K355, §483.90

Frequency	Key Requirement	K-Tag
	review	

Form based on CMS-2786R (07/2018). Retain completed checklists as part of the facility maintenance record.