

Quarterly PM and Inspection Checklist

Based on CMS Form 2786R (07/2018) — 2012 Life Safety Code (Healthcare)

Table of Contents

1. Introduction
 2. Quarterly Tasks
 3. Compliance References
 4. Notes and Guidance
 5. Summary Section
 6. Document Revision History
-

Notes and Guidance

- Provide examples or guidance in the "Notes" column for common issues or observations.
 - Include specific details to help inspectors identify and address potential problems.
-

Follow-Up Actions

Task #	Description	Follow-Up Action Required	Assigned To	Target Date
1				
2				

Summary Section

Total Deficiencies Found: _____

Immediate Corrective Actions Taken: ☐ Yes ☐ No ☐ N/A

Work Orders Submitted: ☐ Yes ☐ No WO#(s): _____

Items Requiring Follow-Up: ☐ Yes ☐ No

#	K-Tag	Location / Description	Action Required	Assigned To	Target Date
1					
2					

Document Revision History

Revision	Date	Description of Changes	Updated By
1.0	2026-05-18	Initial draft with updates.	

1. Fire Drills (K712) ★ *REQUIRED QUARTERLY — EACH SHIFT*

Reference: 18.7.1.4 through 18.7.1.7, 19.7.1.4 through 19.7.1.7

Fire drills must be conducted at least once per quarter on each shift, at expected and unexpected times, under varying conditions.

Drill 1 — Day Shift

Field	Details
Date	
Time	
Shift	Day (7a–3p)
Drill Type	☐ Expected ☐ Unexpected
Conditions Simulated	
Alarm Signal Transmitted	☐ Yes ☐ No
All Staff Participated	☐ Yes ☐ No
Staff Familiar with RACE/PASS Procedures	☐ Yes ☐ No
Evacuation / Relocation Plan Followed (K711)	☐ Yes ☐ No
Deficiencies Noted	
Drill Conducted By	
Supervisor Signature	

Drill 2 — Evening Shift

Field	Details
Date	
Time	
Shift	Evening (3p–11p)
Drill Type	☐ Expected ☐ Unexpected
Conditions Simulated	
Alarm Signal Transmitted	☐ Yes ☐ No
All Staff Participated	☐ Yes ☐ No
Staff Familiar with RACE/PASS Procedures	☐ Yes ☐ No
Evacuation / Relocation Plan Followed (K711)	☐ Yes ☐ No
Deficiencies Noted	

Field	Details
Drill Conducted By	
Supervisor Signature	

Drill 3 — Night Shift

Field	Details
Date	
Time	
Shift	Night (11p–7a)
Drill Type	☐ Expected ☐ Unexpected
Conditions Simulated	
Coded Announcement Used in Lieu of Audible Alarm (9 PM–6 AM)	☐ Yes ☐ No ☐ N/A
All Staff Participated	☐ Yes ☐ No
Staff Familiar with RACE/PASS Procedures	☐ Yes ☐ No
Evacuation / Relocation Plan Followed (K711)	☐ Yes ☐ No
Deficiencies Noted	
Drill Conducted By	
Supervisor Signature	

Notes:

- Drills must include **transmission of a fire alarm signal** and simulation of emergency fire conditions.
- Night shift drills (9 PM–6 AM) may use a **coded announcement** instead of audible alarms.
- Drill records must be retained and available for survey.

2. Sprinkler System — Waterflow and Supervisory Alarm Device Testing (K353, K352)

Reference: 9.7.5, 9.7.7, 9.7.8 (LSC) | NFPA 25, Chapters 5 and 13

NFPA 25 requires waterflow alarm devices and supervisory signal devices to be tested **quarterly**.

2A. Waterflow Alarm Devices

#	Device Location / Zone	Activated	Alarm Received at Panel	Alarm Transmitted to Central Station	Pass / Fail	Technician
1		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No		
2		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No		
3		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No		
4		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No		

2B. Supervisory Signal Devices (Valve Tamper Switches)

#	Valve / Device Location	Signal Received at Panel	Alarm Transmitted to Central Station	Pass / Fail	Technician
1		☐ Yes ☐ No	☐ Yes ☐ No		
2		☐ Yes ☐ No	☐ Yes ☐ No		
3		☐ Yes ☐ No	☐ Yes ☐ No		
4		☐ Yes ☐ No	☐ Yes ☐ No		

Testing Contractor / Technician:

Test Date:

Records Maintained On-Site: ☐ Yes ☐ No

3. Fire Alarm System — Quarterly Testing (K345)

Reference: 9.6.1.3, 9.6.1.5 | NFPA 72 (National Fire Alarm and Signaling Code)

NFPA 72 requires certain initiating devices, notification appliances, and supervisory devices to be tested quarterly.

3A. Manual Pull Stations (K342) — Annual Requirement (*Confirm annual test is on schedule*)

⚠ Per NFPA 72 Table 14.4.2.2, manual pull stations (manual fire alarm boxes) are tested **annually**, not quarterly. Use this section to confirm the annual test is on track and has not been missed.

#	Task	Complete	Notes
1	Annual pull station test is scheduled and on track for this year	☐ Yes ☐ No	Scheduled date: _____
2	Pull station test records from prior year are on file	☐ Yes ☐ No	

#	Task	Complete	Notes
3	Any pull stations found defective during drills or daily rounds have been reported for repair	☐ Yes ☐ No ☐ N/A	

3B. Notification Appliances — Visual / Functional Verification (K343)

#	Location / Zone	Audible Horn/Strobe Activates	Visual (Strobe) Activates	Pass / Fail
1		☐ Yes ☐ No	☐ Yes ☐ No	
2		☐ Yes ☐ No	☐ Yes ☐ No	
3		☐ Yes ☐ No	☐ Yes ☐ No	

3C. Fire Alarm Control Functions (K344)

#	Control Function	Activates on Alarm	Pass / Fail	Notes
1	HVAC shutdown — smoke compartment _____	☐ Yes ☐ No		
2	Magnetic door hold-opens release — floor _____	☐ Yes ☐ No		
3	Elevator recall (Phase I)	☐ Yes ☐ No		
4	Smoke damper(s) — zone _____	☐ Yes ☐ No		
5	Other: _____	☐ Yes ☐ No		

Testing Contractor / Technician:

Test Date:

Records Maintained On-Site: ☐ Yes ☐ No

4. Emergency Generator — Quarterly Review of Monthly Test Records (K918)

Reference: 6.4.4 (NFPA 99) | NFPA 110

Monthly load tests are required 12×/year in 20–40 day intervals. The quarterly PM confirms all three monthly tests this quarter were completed and documented.

Month	Test Date	Duration (min)	Load Transfer Confirmed	10-sec Start Met	Logged By	Pass / Fail
Month 1 of quarter			☐ Yes ☐ No	☐ Yes ☐ No		
Month 2 of quarter			☐ Yes ☐ No	☐ Yes ☐ No		
Month 3 of quarter			☐ Yes ☐ No	☐ Yes ☐ No		

All 3 monthly load tests completed this quarter: ☐ Yes ☐ No

Maximum interval between tests exceeded 40 days: ☐ Yes ☐ No

5. Evacuation and Relocation Plan — Staff Training Review (K711, K712)

Reference: 18.7.1.1–18.7.1.3, 18.7.2.1.2, 18.7.2.2–2.3 | 19.7.1.1–19.7.1.3, 19.7.2.1.2, 19.7.2.2–2.3

#	Task	Complete	Notes
5.1	Written evacuation and relocation plan is current and up to date	☐ Yes ☐ No	
5.2	Copy of plan available with telephone operator or security	☐ Yes ☐ No	
5.3	All employees have been briefed on their duties under the plan this quarter	☐ Yes ☐ No	
5.4	Plan addresses RACE response required of staff (Rescue, Alarm, Contain, Extinguish/Evacuate)	☐ Yes ☐ No	
5.5	Plan includes use of fire alarm system, containment, evacuation routes, and relocation areas	☐ Yes ☐ No	
5.6	Training records on file for this quarter	☐ Yes ☐ No	

Date of Last Plan Review / Update:

New Employees Trained This Quarter: _____

6. Portable Fire Extinguishers — Quarterly Inspection (K355)

Reference: 18.3.5.12, 19.3.5.12 | NFPA 10

NFPA 10 requires a documented inspection at least every 30 days; quarterly PM documents a thorough documented walkthrough with corrective action tracking.

Location	Unit Type / Size	Pressure OK	Seal Intact	Tag / Date Current	Accessible	Pass / Fail
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	

Location	Unit Type / Size	Pressure OK	Seal Intact	Tag / Date Current	Accessible	Pass / Fail
		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	

Total units inspected: Units requiring service/replacement:

7. Smoking Regulations — Quarterly Compliance Review (K741)

Reference: 18.7.4, 19.7.4

#	Task	Complete	Notes
7.1	Facility smoking policy is current and posted	☐ Yes ☐ No	
7.2	"No Smoking" signs at all major entrances	☐ Yes ☐ No	
7.3	All designated smoking areas have noncombustible ashtrays	☐ Yes ☐ No	
7.4	Metal self-closing containers available in all smoking areas	☐ Yes ☐ No	
7.5	Staff trained on smoking policy this quarter	☐ Yes ☐ No	

8. Construction, Repair, and Improvement Operations — Quarterly Review (K791)

Reference: 18.7.9, 19.7.9, 4.6.10, NFPA 241

#	Task	Complete	Notes
8.1	All active construction / renovation projects have ILSM (Interim Life Safety Measures) documented	☐ Yes ☐ No ☐ N/A	
8.2	Daily egress inspection logs for construction areas are on file	☐ Yes ☐ No ☐ N/A	
8.3	Construction areas comply with NFPA 241	☐ Yes ☐ No ☐ N/A	
8.4	Hot work permits current for any active welding/cutting/brazing	☐ Yes ☐ No ☐ N/A	

Active Construction Projects This Quarter:

Project Description	Location	Start Date	ILSM in Place	Daily Logs on File
			☐ Yes ☐ No	☐ Yes ☐ No
			☐ Yes ☐ No	☐ Yes ☐ No

9. Physical Environment — Quarterly Compliance Walk (\$483.90)

Reference: 42 CFR §483.90(a)(5), §483.90(d), §483.90(e), §483.90(g), §483.90(h), §483.90(i) | §483.25(n) | §483.10(i)

#	Task	Pass	Fail	N/A	Notes
9.1	Corridor handrails — full facility inspection; firmly secured, no loose mounts, present on both sides (§483.90(i)(3))				
9.2	Resident call system — full facility test from bedside and toilet/bathing facility in each room (§483.90(g))				
9.3	Bed frames, mattresses, and bed rails — comprehensive inspection for entrapment hazards, structural damage, and manufacturer compatibility (§483.90(d)(3), §483.25(n))				
9.4	Battery-operated smoke alarms in resident sleeping rooms and common areas — test and battery check per manufacturer recommendations (§483.90(a)(5))				
9.5	Pest control — quarterly evidence review; confirm no pest or rodent activity; verify service records are current (§483.90(i)(4))				
9.6	Temperature — facility thermostats functional; 71–81°F maintained in all patient areas (§483.10(i)(6))				
9.7	Outside windows — present in all resident sleeping rooms; sill height ≤36" in buildings certified after 7/5/2016 (§483.90(e)(1)(vi)–(vii))				
9.8	Emergency water supply procedures — written procedures available and staff are aware of steps to take during water supply loss (§483.90(i)(1))				
9.9	Ventilation — adequate outside ventilation present via windows, mechanical ventilation, or combination (§483.90(i)(2))				
9.10	Dining and activity rooms — well-lighted, well-ventilated, adequately furnished, and sufficient space for all activities (§483.90(h))				
9.11	Mechanical, electrical, and patient care equipment — maintained in safe operating condition; no outstanding unsafe conditions (§483.90(d)(2))				
9.12	Preventive maintenance completion review — overdue high-risk PM tasks tracked with corrective action plan (§483.90(d)(2))				

Bed rail / entrapment deficiencies found: _____ **Work order(s) submitted:** ☐ Yes ☐ No WO#: _____

Smoke alarm batteries replaced this quarter: ☐ Yes ☐ No ☐ N/A

Updates for Emergency Preparedness

Drill and Exercise Review

Conduct a review of recent emergency drills and exercises to ensure compliance with the training and testing program. Evaluate the following criteria:

Criterion	Pass	Fail	N/A	Findings	Corrective Action / Follow- Up	Reviewer Signature	Date
Deficiencies noted	☐	☐	☐				
Staff participation rates	☐	☐	☐				
Timeliness/effectiveness	☐	☐	☐				
Equipment/supply issues	☐	☐	☐				
Lessons learned documented	☐	☐	☐				

Summary / Sign-Off

All three shift fire drills completed: ☐ Yes ☐ No

All waterflow / supervisory alarm tests completed: ☐ Yes ☐ No

All monthly generator tests confirmed on file: ☐ Yes ☐ No

Total Deficiencies Found: _____

Work Orders / Corrective Actions Submitted: ☐ Yes ☐ No WO#(s): _____

#	K-Tag	System / Area	Deficiency Description	Corrective Action	Assigned To	Due Date
1						
2						
3						
4						

Inspector Signature: _____ **Date:** _____

Department Director Signature: _____ **Date:** _____

Safety Officer / EOC Chair Signature: _____ **Date:** _____

Inspection Frequency Reference

Frequency	Key Items	K-Tag
Each Shift	Egress clear, exit signs, propped doors, O ₂ safety, fire watch status	K211, K291, K293, K223, K346, K354, K925

Frequency	Key Items	K-Tag
Daily	Full facility walk, construction area egress, extinguisher visual, O ₂ cylinder storage	K791, K355, K923
Weekly	Generator inspection, sprinkler gauges/valves, fire pump churn, FACP status, medical gas	K918, K353, K352, K345
Monthly	Generator load test (30 min), elevator firefighter's service, LIM test	K918, K531, K914
Quarterly	Fire drills (all 3 shifts) , waterflow/supervisory alarm test, fire alarm device test, evacuation plan review, physical environment walk, bed rail inspection, smoke alarm batteries	K712, K353, K345, K711, \$483.90, \$483.25(n)
Annually	Fire alarm full test, sprinkler full test, door assembly inspection, extinguisher service, emergency lighting 90-min test	K345, K353, K761, K355, K291

Form based on CMS-2786R (07/2018) and NFPA 10, 25, 72, 99, 110, 241. Retain completed checklists as part of the facility maintenance record.