

Shift PM and Inspection Checklist

Based on CMS Form 2786R (07/2018) — 2012 Life Safety Code (Healthcare)

Table of Contents

1. Introduction
 2. Shift-Specific Tasks
 3. Compliance References
 4. Notes and Guidance
 5. Follow-Up Actions
 6. Summary Section
-

Introduction

This checklist is designed to ensure compliance with the 2012 Life Safety Code (Healthcare) and to support the facility's emergency preparedness and response efforts. It is used to document the status of various safety elements and to identify any deficiencies that need to be addressed.

Shift-Specific Tasks

- Clearly specify tasks required for each shift (e.g., morning, evening, night).
 - Include a table or list for quick reference.
-

Notes and Guidance

- Provide examples or guidance in the "Notes" column for common issues or observations.
 - Include specific details to help inspectors identify and address potential problems.
-

Follow-Up Actions

Task #	Description	Follow-Up Action Required	Assigned To	Target Date
1				
2				

Compliance References

Reference: 18.2.1, 19.2.1, 7.1.10.1

#	Location	Clear	Obstructed	N/A	Notes
1.1	Corridor — Unit / Floor: _____				

#	Location	Clear	Obstructed	N/A	Notes
1.2	Corridor — Unit / Floor: _____				
1.3	Corridor — Unit / Floor: _____				
1.4	Exit stairwell doors — accessible and unobstructed				
1.5	Exit discharge path to exterior — clear				
1.6	No equipment, carts, or furnishings blocking corridor width				
⚠ Corridors must be continuously maintained free of all obstructions. Remove any items blocking egress immediately.					

Reference: 19.2.10.1, 18.2.10.1 (Exit Signs) | 18.2.9.1, 19.2.9.1 (Emergency Lighting)

#	Task	Pass	Fail	N/A	Notes
2.1	All exit signs illuminated (continuously lit)				
2.2	Directional exit signs illuminated				
2.3	Emergency lighting fixtures appear operational (no dark units)				
2.4	No exit signs blocked or obstructed from view				

Reference: 18.2.2.2.7, 19.2.2.2.7 (Self-Closing) | 19.3.6.3, 18.3.6.3 (Corridor Doors) | 19.3.7.6, 18.3.7.6 (Smoke Barrier Doors)

#	Task	Pass	Fail	N/A	Notes
3.1	No corridor doors propped open (unless held by approved magnetic hold-open device)				
3.2	Smoke barrier cross-corridor doors close and latch properly				
3.3	Stairwell and exit enclosure doors closed and not propped				
3.4	Hazardous area doors (boiler room, storage, soiled linen, etc.) closed and self-latching				
3.5	No roller latches on corridor or hazardous area doors				
3.6	No visible damage to door frames, hardware, or closers				

Reference: 19.3.2.1, 19.3.5.9 (Existing) | 18.3.2.1 (New)

Area	Door Closed / Self-Latching	No Storage Overflow	Notes
Boiler / Mechanical Room			
Soiled Linen Room			

Area	Door Closed / Self-Latching	No Storage Overflow	Notes
Trash / Waste Collection Room			
Combustible Storage Room(s)			
Repair / Maintenance Shop			
Other: _____			

Reference: 18.7.5.7, 19.7.5.7

#	Task	Pass	Fail	N/A	Notes
5.1	No individual container exceeds 32-gallon capacity				
5.2	Total container capacity does not exceed 32 gallons within any 64 sq ft area				
5.3	Mobile containers >32 gallons are in a protected hazardous area room when unattended				
5.4	Containers are not overflowing into corridors or egress paths				

Reference: 18.3.2.6, 19.3.2.6

#	Task	Pass	Fail	N/A	Notes
6.1	No dispenser installed within 1 inch of an ignition source				
6.2	Individual dispenser capacity does not exceed 0.32 gallons (0.53 gal in suites)				
6.3	Corridor width is at least 6 feet where dispensers are mounted				
6.4	Dispensers over carpeted floors are in sprinklered smoke compartments				
6.5	ABHR is protected against inappropriate access (locked/secured as required)				

Reference: 18.7.8, 19.7.8

#	Task	Pass	Fail	N/A	Notes
7.1	No portable space heaters found in patient care areas				
7.2	Any heater in nonsleeping staff/employee areas has heating elements $\leq$ 212°F (100°C)				

⚠ Portable space heaters are prohibited in all patient care, sleeping, and treatment areas.

Reference: 18.7.4, 19.7.4

#	Task	Pass	Fail	N/A	Notes
8.1	No smoking observed in oxygen storage/use areas				
8.2	No smoking observed in flammable/combustible storage areas				
8.3	No smoking observed by patients classified as "not responsible" without direct supervision				
8.4	"No Smoking" signage posted at all required locations				
8.5	Noncombustible ashtrays available in any designated smoking areas				

Reference: 11.5.1.1, TIA 12-6 (NFPA 99)

#	Task	Pass	Fail	N/A	Notes
9.1	Smoking materials removed from patients receiving respiratory therapy / oxygen				
9.2	No ignition sources within 1 foot of nasal cannula site of intentional expulsion (outside room)				
9.3	No ignition sources within 15 feet of oxygen delivery inside patient room				
9.4	No solid fuel-burning appliances in oxygen administration areas				

Reference: 9.6.1.6 (Fire Alarm) | 9.7.5, 15.5.2 NFPA 25 (Sprinkler)

#	Task	Pass	Fail	N/A	Notes
10.1	Fire alarm system is in service (no active impairments)				
10.2	Sprinkler system is in service (no active impairments)				

⚠ **Fire Alarm out of service > 4 hours in 24-hour period:** Notify authority having jurisdiction AND evacuate or implement approved fire watch.

⚠ **Sprinkler system out of service > 10 hours in 24-hour period:** Evacuate affected area or implement approved fire watch until restored.

If impairment exists, document below:

System	Impairment Start Time	Area(s) Affected	Fire Watch Initiated	AHJ Notified
			☐ Yes ☐ No	☐ Yes ☐ No

Reference: 18.7.5.6, 19.7.5.6 | 18.7.5.1, 19.7.5.1 | 18.7.5.2, 19.7.5.2

#	Task	Pass	Fail	N/A	Notes
11.1	No excessive combustible decorations on walls, ceilings, or doors				

#	Task	Pass	Fail	N/A	Notes
11.2	Cubicle curtains appear intact and undamaged (no large holes or tears)				
11.3	No unapproved or non-flame-retardant decorations present				

Reference: 42 CFR §483.90(g), §483.90(i)(3), §483.10(i)(5–6)

#	Task	Pass	Fail	N/A	Notes
12.1	Resident call system — spot check from at least 1 patient room bedside per unit (§483.90(g))				
12.2	Resident call system — spot check from at least 1 toilet / bathing facility per unit (§483.90(g))				
12.3	Corridor handrails present and firmly secured on both sides during egress walk (§483.90(i)(3))				
12.4	Adequate lighting operational in corridors, patient rooms, and common areas (§483.10(i)(5))				
12.5	Facility temperature within comfortable and safe range — 71–81°F for facilities certified after 10/1/1990 (§483.10(i)(6))				
12.6	No visible unsafe condition with mechanical, electrical, or patient care equipment in inspected areas (§483.90(d)(2))				

Temperature Reading(s): _____ °F (Location: _____)

Updates for Emergency Preparedness

Incident Command Readiness

Ensure the following items are reviewed and documented for each shift:

Shift (Date/Time)	Item	Result (Pass/Fail/N/A)	Verifier (Name)	Notes (Findings/Issues)	Follow- Up / Action Required
	Incident command contact list is current and accessible	☐ Pass ☐ Fail ☐ N/A			
	Command post location(s) are identified and confirmed	☐ Pass ☐ Fail ☐ N/A			

Shift (Date/Time)	Item	Result (Pass/Fail/N/A)	Verifier (Name)	Notes (Findings/Issues)	Follow- Up / Action Required
	Communication equipment (radios, phones, backup power) is available and functioning	☐ Pass ☐ Fail ☐ N/A			
	Assigned personnel and escalation/backup roles are on duty or reachable	☐ Pass ☐ Fail ☐ N/A			
	Access to incident documentation and notification procedures is validated	☐ Pass ☐ Fail ☐ N/A			

Summary / Sign-Off

Emergency Preparedness Completed: ☐ Yes ☐ No ☐ N/A

Deficiencies Found: ☐ Yes ☐ No

Immediate Actions Taken: ☐ Yes ☐ No ☐ N/A

#	K-Tag	Location / Description	Action Taken	Resolved By	Time
1					
2					
3					

Shift Staff Signature: _____ **Time:** _____

Charge Nurse / Supervisor Signature: _____ **Time:** _____

Form based on CMS-2786R (07/2018). Retain completed checklists as part of the facility safety record.