

Weekly PM and Inspection Checklist

Based on CMS Form 2786R (07/2018) — 2012 Life Safety Code (Healthcare)

Table of Contents

1. Introduction
 2. Weekly Tasks
 3. Compliance References
 4. Notes and Guidance
 5. Follow-Up Actions
 6. Summary Section
 7. Document Revision History
-

Introduction

This checklist is designed to help facility staff and inspectors perform regular, systematic inspections and maintenance of critical safety systems. It covers generator, fire protection, medical gas, HVAC, and other essential systems, ensuring compliance with CMS and NFPA standards.

Weekly Tasks

The following tasks must be performed weekly to maintain safety and compliance.

Compliance References

- **Generator / Essential Electric System — Weekly Inspection (K918)**
 - Reference: 6.4.4, 6.5.4, 6.6.4 (NFPA 99) | NFPA 110
 - **Generator sets must be inspected weekly per NFPA 110.**
- **Automatic Sprinkler System — Weekly Gauge and Valve Inspection (K353, K352)**
 - Reference: 9.7.5, 9.7.7, 9.7.8 (LSC) | NFPA 25 (Standard for the Inspection, Testing, and Maintaining of Water-Based Fire Protection Systems)
 - NFPA 25 requires wet-pipe system gauges and control valves be inspected **weekly** (or monthly if electronically supervised).
- **Fire Pump — Weekly Inspection / Churn Test (K353)**
 - Reference: NFPA 25, Chapter 8
 - Electric-drive fire pumps: **weekly churn test**. Diesel-drive fire pumps: **weekly 30-minute run**.
 - *(Mark N/A if no fire pump is installed)*
- **Standpipe System — Weekly Gauge Check (K353)**
 - Reference: NFPA 25, Chapter 6
 - *(Mark N/A if no standpipe system is installed)*
- **Fire Alarm Control Panel — Weekly Status Review (K341, K344, K345)**
 - Reference: 18.3.4.1, 19.3.4.1 | 9.6.1.3, 9.6.1.5 | NFPA 72
- **Medical Gas System — Weekly Visual Check (K907, K909)**
 - Reference: 5.1.14.2.1, 5.1.15 | 5.1.11.1, 5.1.11.2 (NFPA 99)
- **HVAC — Weekly Visual Check (K521, K522)**

- Reference: 18.5.2.1, 19.5.2.1, 9.2
- **Portable Fire Extinguishers — Weekly Visual (K355)**
 - Reference: 18.3.5.12, 19.3.5.12 | NFPA 10
- **Means of Egress — Weekly Comprehensive Walk (K211, K791)**
 - Reference: 18.2.1, 19.2.1 | 18.7.9, 19.7.9
- **Physical Environment — Weekly Walk (\$483.90)**
 - Reference: 42 CFR §483.90(d)(2–3), §483.90(g), §483.90(h), §483.90(i) | §483.25(n) | §483.10(i)
- **Kitchen and Food-Service Equipment — Weekly PM Check**
 - Reference: 42 CFR §483.90(d)(2), §483.90(h); NFPA 96 | Facility preventive maintenance and sanitation program

Notes and Guidance

- Provide examples or guidance in the "Notes" column for common issues or observations.
- Include specific details to help inspectors identify and address potential problems.

Follow-Up Actions

Task #	Description	Follow-Up Action Required	Assigned To	Target Date
1				
2				

Weekly Tasks

1. Generator / Essential Electric System — Weekly Inspection (K918)  *REQUIRED WEEKLY*

Reference: 6.4.4, 6.5.4, 6.6.4 (NFPA 99) | NFPA 110
Generator sets must be inspected weekly per NFPA 110.

#	Task	Pass	Fail	N/A	Notes
1.1	Inspect generator for fluid leaks (oil, coolant, fuel)				
1.2	Check engine oil level				
1.3	Check coolant level				
1.4	Check fuel level / fuel supply				
1.5	Inspect battery condition and connections (no corrosion)				
1.6	Check battery charger / trickle charge indicator				
1.7	Inspect air cleaner / intake (no obstructions)				
1.8	Inspect exhaust system for visible damage or leaks				
1.9	Check generator room — free of combustibles and obstructions				

#	Task	Pass	Fail	N/A	Notes
1.10	Confirm remote EES alarm annunciator is operational (K916)				
1.11	Check control panel for fault codes or alarm indicators				
1.12	Verify day tank / sub-base fuel tank level (if applicable)				
1.13	Confirm transfer switch(es) — no alarms or faults indicated				
1.14	Record inspection findings in written log				

Generator ID / Location:**Engine Hours (if metered):** _____ **Oil Pressure (if gauged):** _____ PSI**Coolant Temp (if gauged):** _____ °F **Battery Voltage:** _____ V**Fuel Level:** _____ %**Days since last load test:** _____*(Load test required 12×/year in 20–40 day intervals — see Monthly PM)***2. Automatic Sprinkler System — Weekly Gauge and Valve Inspection (K353, K352)**

Reference: 9.7.5, 9.7.7, 9.7.8 (LSC) | NFPA 25 (Standard for the Inspection, Testing, and Maintaining of Water-Based Fire Protection Systems)

NFPA 25 requires wet-pipe system gauges and control valves be inspected **weekly** (or monthly if electronically supervised).

#	Task	Pass	Fail	N/A	Reading / Notes
2.1	System water pressure gauge(s) — normal operating range				PSI: _____
2.2	Air pressure gauge (dry/pre-action systems) — normal range				PSI: _____
2.3	All control valves are in the fully open position				
2.4	Control valve tamper switches — no alarms or supervisory signals (K352)				
2.5	No active sprinkler supervisory alarm signals at the fire alarm control panel				
2.6	No visible sprinkler heads damaged, painted, or obstructed				
2.7	Sprinkler riser room — no leaks, room temperature above 40°F				Temp: _____ °F
2.8	Hydraulic nameplate present and legible at each riser				

Riser Location(s):

3. Fire Pump — Weekly Inspection / Churn Test (K353)

Reference: NFPA 25, Chapter 8

Electric-drive fire pumps: **weekly churn test**. Diesel-drive fire pumps: **weekly 30-minute run**.

(Mark N/A if no fire pump is installed)

#	Task	Pass	Fail	N/A	Reading / Notes
3.1	Start fire pump — automatic or manual start				
3.2	Electric pump: run for minimum 10 minutes at churn (no-flow)				
3.3	Diesel pump: run for minimum 30 minutes				
3.4	Check packing gland — slight drip acceptable, no excessive leakage				Drip rate: ___/min
3.5	Suction and discharge pressure gauges — within normal range				Suction: ___ PSI / Discharge: ___ PSI
3.6	Pump room temperature above 40°F				Temp: _____ °F
3.7	Diesel fuel level (if diesel pump)				Level: _____ %
3.8	Battery condition — diesel pump start batteries (if applicable)				
3.9	No unusual noises, vibrations, or leaks during operation				
3.10	Record test in fire pump log				

Fire Pump ID / Location:

4. Standpipe System — Weekly Gauge Check (K353)

Reference: NFPA 25, Chapter 6

(Mark N/A if no standpipe system is installed)

Standpipe Location / Floor	Pressure Gauge Reading	Normal Range	Pass / Fail
	___ PSI		
	___ PSI		
	___ PSI		

5. Fire Alarm Control Panel — Weekly Status Review (K341, K344, K345)

Reference: 18.3.4.1, 19.3.4.1 | 9.6.1.3, 9.6.1.5 | NFPA 72

#	Task	Pass	Fail	N/A	Notes
5.1	Fire alarm control panel — normal status (no active alarms or troubles)				
5.2	No active trouble signals on panel				
5.3	No active supervisory signals on panel				
5.4	Primary power (AC) indicator lit				
5.5	No zones in bypass or disabled status				
5.6	Printer / event log current and functioning (if installed)				
5.7	Confirm notification to central station is active (if applicable)				

FACP Location:

Any Open Troubles / Zones Bypassed: ☐ Yes ☐ No — If yes, describe: _____

6. Medical Gas System — Weekly Visual Check (K907, K909)

Reference: 5.1.14.2.1, 5.1.15 | 5.1.11.1, 5.1.11.2 (NFPA 99)

#	Task	Pass	Fail	N/A	Notes
6.1	Area/master alarm panels — no active alarms (gas pressure or vacuum)				
6.2	Bulk oxygen / liquid oxygen system — no frost, leaks, or alarms				
6.3	Medical gas cylinder storage — cylinders secured, full/empty segregated				
6.4	Gas piping labels visible and legible at required intervals (K909)				
6.5	Zone valve boxes — accessible, not blocked				
6.6	Vacuum system — adequate vacuum pressure at zone valve indicators				

Bulk O₂ Level: _____ % **Medical Air System Status:** ☐ Normal ☐ Alarm

7. HVAC — Weekly Visual Check (K521, K522)

Reference: 18.5.2.1, 19.5.2.1, 9.2

#	Task	Pass	Fail	N/A	Notes
7.1	No visible damage to HVAC supply/return grilles in patient care corridors				
7.2	No combustibles stored against or near heating equipment				

#	Task	Pass	Fail	N/A	Notes
7.3	Mechanical room HVAC equipment — no visible leaks or alarm indicators				
7.4	Any suspended unit heaters: not obstructed, safety shutoff intact (K523)				

8. Portable Fire Extinguishers — Weekly Visual (K355)

Reference: 18.3.5.12, 19.3.5.12 | NFPA 10

Floor / Area	All Units Present & Mounted	Seals Intact	Pressure Gauge in Green	Obstruction-Free Access	Notes
Floor: _____	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
Floor: _____	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
Floor: _____	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
Kitchen / Mechanical	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	

Units missing or discharged: _____ Work order submitted: ☐ Yes WO#: _____

9. Means of Egress — Weekly Comprehensive Walk (K211, K791)

Reference: 18.2.1, 19.2.1 | 18.7.9, 19.7.9

Area	Egress Clear	Signage Correct	Lighting OK	Door Hardware OK	Notes
Floor _____ corridors	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
Floor _____ corridors	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
All stairwells	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
Exterior discharge paths	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	
Construction areas (if any)	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	

10. Physical Environment — Weekly Walk (§483.90)

Reference: 42 CFR §483.90(d)(2–3), §483.90(g), §483.90(h), §483.90(i) | §483.25(n) | §483.10(i)

#	Task	Pass	Fail	N/A	Notes
10.1	Corridor handrails — facility-wide inspection; firmly secured, no loose mounts or damage, present on both sides (§483.90(i)(3))				
10.2	Resident call system — complete floor-by-floor check; call from bedside and bathroom in each unit (§483.90(g))				
10.3	Adequate lighting in all resident rooms, corridors, and common areas — no burned-out fixtures reported (§483.10(i)(5))				
10.4	HVAC supply/return grilles — unobstructed and functional; no unusual odors indicating ventilation failure (§483.90(i)(2))				
10.5	Pest control — no evidence of active pest or rodent activity facility-wide (§483.90(i)(4))				
10.6	Mechanical, electrical, and patient-care equipment — no visible damage, fluid leaks, or unsafe conditions (§483.90(d)(2))				
10.7	Bed rails, frames, and mattresses — spot check for entrapment gaps, structural damage, or loose hardware (§483.90(d)(3), §483.25(n))				
10.8	Dining and activity rooms — well-lighted, ventilated, adequately furnished, and sufficient space maintained (§483.90(h))				
10.9	Bathroom grab bars — firmly secured, no loose mounts or damage, and available in resident-use bathing/toilet areas (§483.90(i)(3))				

Handrail deficiencies found: _____ **Call system failures found:** _____

Work order(s) submitted: ☐ Yes ☐ No WO#: _____

11. Kitchen and Food-Service Equipment — Weekly PM Check

Reference: 42 CFR §483.90(d)(2), §483.90(h); NFPA 96 | Facility preventive maintenance and sanitation program

#	Task	Pass	Fail	N/A	Notes
11.1	Cooking equipment, hot holding equipment, and prep equipment — clean, intact, and operating normally				
11.2	Hood exterior, fan housing, and visible grease accumulation — cleaned or scheduled for service per NFPA 96 guidance				
11.3	Grease traps / grease management devices — inspected and serviced per facility schedule				
11.4	Refrigerators, freezers, and reach-ins — temperatures within safe range and log maintained				

#	Task	Pass	Fail	N/A	Notes
11.5	Door gaskets, seals, latches, and hinges on food-service equipment — intact and functional				
11.6	Kitchen exhaust and make-up air components — no abnormal noise, vibration, or airflow loss; inspect per NFPA 96 guidance				
11.7	Any failed food-service equipment reported for repair and removed from service if needed				

Updates for Emergency Preparedness

- **Emergency Equipment Inspection:** Confirm Sections 1 (Generator / Essential Electric System inspection — K918) and 8 (Portable Fire Extinguishers visual inspection — K355) have been completed and are up to date.
- **Staff Training Review:** Confirm that staff are aware of their roles in the incident command structure. *(Not specifically required by CMS, but recommended as a best practice.)*

Summary / Sign-Off

Total Deficiencies Found: _____

Immediate Corrective Actions Taken: ☐ Yes ☐ No ☐ N/A

Work Orders Submitted: ☐ Yes ☐ No WO#(s): _____

Items Requiring Follow-Up: ☐ Yes ☐ No

#	K-Tag	Location / Description	Action Required	Assigned To	Target Date
1					
2					

Document Revision History

Revision	Date	Description of Changes	Updated By
1.0	2026-05-18	Initial draft with updates.	