


- NOTES:
1. REFER TO SHEET E-0040 FOR THE LUMINAIRE SCHEDULE.
  2. LIGHTING AND FIXTURES ONLY ARE SHOWN ON THE DRAWINGS. NO CHANGE TO EXISTING LIGHTING LAYOUTS IN ROOMS, OFFICES, CORRIDORS, GENERAL AREAS AND STORES. AREAS SHADDED IN BLUE.
  3. ONLY LIGHT FIXTURES AND CIRCUITS SHOWN ON THE DRAWINGS ARE TO BE UPGRADED AS PART OF THIS SCOPE OF WORKS.
  4. REFER TO ELECTRICAL SPECIFICATION FOR THE EXTENT OF SCOPE.
  5. ALL INSTALLATION IS TO BE CARRIED OUT IN ACCORDANCE WITH: AS/NZS 3000:2007 AND AS/NZS 3003:2018
  6. DO NOT SCALE OF DRAWINGS. CO-ORDINATE ALL LOCATIONS AND ELEVATIONS WITH ARCHITECTS DRAWINGS WHERE PROVIDED.
  7. LIGHT SWITCHES SHALL BE HORIZONTALLY ALIGNED WITH DOOR HANDLES AT 900 - 1200 MM ABOVE FINISHED FLOOR LEVEL UNLESS INDICATED OTHERWISE ON THE ELECTRICAL SERVICES DRAWINGS OR AS ADVISED BY THE ARCHITECT.
  8. LIGHTING IN PATIENT ROOMS TO BE CENTRALLY CONTROLLED AT ROOM ENTRANCE, WITH EACH MEDICAL SERVICES PANEL HAVING AN OVERRIDE SWITCH FOR THE LOCAL LIGHT.
  9. SUBMIT AS-BUILTS, COC/ESC AND O&M MANUAL FOR THE INSTALLATION.
  10. INSPECT EXISTING CABLES ON LIGHTING CIRCUITS WHICH LIGHTS ARE BEING UPGRADED. REPLACE FAULTING OR DAMAGED CABLES.
  11. REUSE EXISTING LIGHT CIRCUITS AND CONFIRM CIRCUIT BREAKER RATINGS ARE CORRECT.
  12. INSTALL NEW LIGHTING CIRCUITS WHERE REQUIRED.



REVISION	AMENDMENT	APP	DATE
A	DEVELOPED DESIGN	B.J.L	07/10/2022
B	FOR PRICING / CONSENT	B.J.L	02/12/2022

DETAILED DESIGN

Hamilton Office - Private Bag 3057 - 464 7 838 9344



Hamilton Office  
+64 7 838 9344

Private Bag 3057  
Hamilton 3240  
New Zealand

SCALE	ORIGINAL SIZE
1: 50 @ A1	A1
DRAWN B. LEY	DESIGNED B. LEY
DRAWING VERIFIED D. SINGH	APPROVED K. MCLAREN
DESIGN VERIFIED D. SINGH	APPROVED DATE 02/12/2022

PROJECT  
LDHB  
CORNER ARAWA STREET, PUKEROA ROAD,  
ROTORUA  
LDHB BIRTHING UNIT UPGRADES

TITLE  
LIGHTING LAYOUT 01

OPUS PROJECT NO.	SUITABILITY
2-82236.00	
PROJ-ORG VOL-1/1 TYPE	SHEET NO.
	E-0100
	REVISION
	B

ELECTRICAL SERVICES

DB6S ESSENTIAL AND NON-ESSENTIAL

