

Test Verification of Conformity

On the basis of the referenced test report(s), sample(s) of the below product have been found to comply with the harmonized standards and Directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product.

Once all product relevant  mark directives are verified in compliance, the manufacturer may indicate compliance by signing a Declaration of Performance(DoP) themselves and applying the mark to product identical to the test sample(s) if the product complies with all relevant CE mark Directives requirements.

Applicant Name & Address:	Zhejiang Terasun Air Duct Co., Ltd. (Maren) Chongren Industrial Clustering Area, Shengzhou, 312473, China
Product Description: Ratings & Principle Characteristics:	Fiber Cement Board Reaction to fire: A1 Bending strength: Class 1 Weather resistance: Category A Dimension tolerance: Level 1 12mm thickness sheets
Models: Brand Name: Relevant Standards/ Specifications/Directives: Verification Issuing Office:	TERASUN EN 12467:2012 Construction Products Regulation (CPR) No.305/2011 Intertek Testing Services Ltd., Shanghai Plant 7, No 6958 Daye Road, Fengxian District, Shanghai
Date of Tests: Test Report Number(s):	From August 27, 2015 to December 1, 2015 160222001SHF-BP-1 and 960/45/204 A-1 issued by NB 2137

This verification is part of the full test report(s) and should be read in conjunction with them.

Signature:



Name:

Sun Sun

Position:

Manager

Date:

February 23, 2016



This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.