

ERA 5 calibration to Elexon power

S. Gomez¹

¹School of Mathematics, University of Edinburgh

2026-06-04

Table of contents I

- 1 Overview
- 2 Model performance assessment
- 3 Performance under different regimes
- 4 Time series of data and generic PC estimate
- 5 Appendix

Overview

Updates

New

- Error diagnostics
- Spatiotemporal model for calibration

Ongoing

- Model validation
 - Out-of-sample in time
 - Out-of-sample in space
- Consistency under aggregation
- Low wind events


Model performance assessment

Assessment framework

- Run models on a sample of days
- Performance metrics:
 - RMSE
 - MAE
 - Bias
- Evaluate performance at WF level
- Error under aggregation
 - GB level
 - Onshore / offshore
 - By regime
 - By hour

Sampled days for performance assessment

Daily generation time series for sampled days



Model portfolio


- Wind farm level models:
 - Generic Power Curve (ERA5 + generic PC estimate)
 - Quantile Mapping
 - Linear model
 - Spatiotemporal model
- Linear model at Great Britain (GB) level

Performance under different regimes


Low wind speed

Hyperparameters


Density of Hyperparameters



Estimated spatial field - median




Estimated spatial field - standard deviation



Effect of wind speed and power regime


Wind speed effect

Estimated effect for wind




Power regime effect

Estimated effect for power_correction




Power estimates

Power estimates Time Series 2020-08-14



Power estimates sampled wind farms


Power estimates Time Series 2020-08-14




Medium wind speed

Hyperparameters


Density of Hyperparameters



Estimated spatial field - median




Estimated spatial field - standard deviation



Effect of wind speed and power regime


Wind speed effect

Estimated effect for wind




Power regime effect

Estimated effect for power_correction




Power estimates

Power estimates Time Series 2024-04-17




Power estimates sampled wind farms




High wind speed

Hyperparameters


Density of Hyperparameters



Estimated spatial field - median




Estimated spatial field - standard deviation




Effect of wind speed and power regime

Wind speed effect




Power regime effect

Estimated effect for power_correction




Power estimates

Power estimates Time Series 2024-04-12



Power estimates sampled wind farms




August 10th, 2024

Error metrics

Metrics at wind farm level

model	RMSE	MAE	Bias
Generic PC	0.305	0.206	1.69e-01
QM	0.235	0.153	1.14e-04
GB LM	0.211	0.146	2.42e-02
Linear model	0.198	0.144	-3.25e-15

Error distribution by model




Error metrics aggregated

Metrics at GB level

model	RMSE	MAE	Bias
Generic PC	0.225	0.207	2.07e-01
QM	0.073	0.058	5.33e-02
GB LM	0.037	0.030	2.32e-02
Linear model	0.028	0.023	7.19e-03

Error distribution by model




Technology type

Metrics by technology type

tech_typ	model	RMSE	MAE	Bias
Wind Offshore	Generic PC	0.350	0.253	2.34e-01
Wind Offshore	QM	0.253	0.160	8.46e-02
Wind Offshore	GB LM	0.215	0.149	-2.19e-03
Wind Offshore	Linear model	0.193	0.143	-2.21e-14
Wind Onshore	Generic PC	0.287	0.189	1.46e-01
Wind Onshore	QM	0.228	0.150	-3.05e-02
Wind Onshore	GB LM	0.210	0.144	3.37e-02
Wind Onshore	Linear model	0.200	0.144	3.61e-15

Technology type

Error distribution by technology type




Regime


Metrics by regime

p_group3	model	RMSE	MAE	Bias
low	Generic PC	0.157	0.078	4.60e-02
low	QM	0.124	0.054	-1.31e-02
low	Linear model	0.120	0.076	5.47e-03
low	GB LM	0.116	0.063	7.60e-03
mid	Generic PC	0.281	0.194	1.48e-01
mid	QM	0.209	0.140	-1.84e-02
mid	GB LM	0.188	0.131	1.99e-02
mid	Linear model	0.177	0.127	5.26e-03
high	Generic PC	0.388	0.298	2.68e-01
high	QM	0.303	0.228	2.70e-02
high	GB LM	0.270	0.213	3.88e-02
high	Linear model	0.250	0.204	-8.70e-03

Regime



Hour of the day




Elevation

Metrics by regime

elevation_g4	model	RMSE	MAE	Bias
[-100,-5]	Generic PC	0.353	0.257	2.37e-01
[-100,-5]	QM	0.256	0.163	8.64e-02
[-100,-5]	GB LM	0.217	0.151	-1.74e-03
[-100,-5]	Linear model	0.194	0.144	-3.74e-03
(-5,212]	Generic PC	0.330	0.227	1.97e-01
(-5,212]	QM	0.234	0.154	2.20e-02
(-5,212]	GB LM	0.228	0.162	6.81e-02
(-5,212]	Linear model	0.214	0.160	-4.95e-03
(212,342]	Generic PC	0.292	0.199	1.71e-01
(212,342]	QM	0.212	0.143	-1.44e-02
(212,342]	GB LM	0.202	0.141	5.18e-02
(212,342]	Linear model	0.192	0.138	2.27e-02
(342,725]	QM	0.236	0.152	-9.77e-02
(342,725]	Generic PC	0.227	0.139	6.93e-02
(342,725]	GB LM	0.194	0.128	-2.06e-02
(342,725]	Linear model	0.191	0.134	-1.35e-02

Elevation




Distance to coast

Metrics by distance to coast

dist_coast_g4	model	RMSE	MAE	Bias
[0.382,11.5]	Generic PC	0.335	0.237	2.06e-01
[0.382,11.5]	QM	0.233	0.150	4.77e-02
[0.382,11.5]	GB LM	0.217	0.153	6.84e-02
[0.382,11.5]	Linear model	0.199	0.149	1.66e-02
(11.5,20.4]	Generic PC	0.297	0.217	1.86e-01
(11.5,20.4]	QM	0.210	0.147	8.37e-03
(11.5,20.4]	GB LM	0.197	0.146	7.72e-03
(11.5,20.4]	Linear model	0.189	0.145	-1.45e-02
(20.4,32.4]	Generic PC	0.311	0.208	1.79e-01
(20.4,32.4]	QM	0.237	0.149	1.14e-02
(20.4,32.4]	GB LM	0.205	0.138	2.92e-02
(20.4,32.4]	Linear model	0.198	0.136	1.30e-02
(32.4,212]	Generic PC	0.274	0.162	1.06e-01
(32.4,212]	QM	0.258	0.166	-6.78e-02
(32.4,212]	GB LM	0.224	0.146	-9.56e-03
(32.4,212]	Linear model	0.205	0.147	-1.52e-02

Distance to coast




Spatiotemporal calibration model

Model overview


$$\mathbb{E}(p_{it}^{\text{calib}}) = \alpha + \beta_k + \beta_m + \beta_h + s_p(\hat{p}_{it}) + s_w(w_{it}) + u_{it}, \quad (1)$$

- Calibrated power: corrected output at site i , time t .
- α : intercept.
- Fixed effects $\beta_k, \beta_m, \beta_h$: location/season/time structure.
- ERA5 correction s_p : bias adjustment of ERA5 + generic PC estimate.
- Wind effect s_w : nonlinear wind–power correction.
- Spatiotemporal effect u_{it} : Spatial component + AR1 error.

Estimated spatial field




Standard deviation of the spatial field



Random Effects


Correction by wind speed

Estimated effect for wind




Correction by power regime

Estimated effect for power_correction



Hyperparameters

Density of Hyperparameters




Comparison scores

model	RMSE	MAE	Bias
Generic PC	0.213	0.153	1.02e-01
QM	0.154	0.108	-2.50e-04
Linear model	0.137	0.101	-1.15e-17
Spatio-temporal model	0.094	0.065	8.57e-11

Scores by Offshore / Onshore


tech_typ	model	RMSE	MAE	Bias
Wind Offshore	Generic PC	0.240	0.161	1.44e-01
Wind Offshore	QM	0.142	0.087	4.60e-02
Wind Offshore	Linear model	0.112	0.077	4.33e-16
Wind Offshore	Spatio-temporal model	0.065	0.040	-3.78e-03
Wind Onshore	Generic PC	0.204	0.151	8.77e-02
Wind Onshore	QM	0.159	0.114	-1.58e-02
Wind Onshore	Linear model	0.144	0.109	-1.61e-16
Wind Onshore	Spatio-temporal model	0.101	0.073	1.27e-03

Estimates by hour




Errors by hour

Power estimates Time Series 2025-08-10




Model Mesh

Mesh used for spatial calibration model




Mesh assessment



Time series of data and generic PC estimate


ERA5 data and generic PC estimate

ERA5 + Generic PC Time Series 2025-08-10




Observed data

Observed power Time Series 2025-08-10




Error of generic PC estimate



ERA5 wind speed

Wind speed at wind farm locations


Wind Speed Time Series 2025-08-10



— capacity weighted avg. — simple avg.

Observed generation


Observed power Time Series 2025-08-10




— capacity weighted avg. — simple avg.

Same day previous year

Estimated spatial field




Standard deviation of the spatial field



Random Effects


Correction by wind speed

Estimated effect for wind




Correction by power regime

Estimated effect for power_correction



Hyperparameters

Density of Hyperparameters



Comparison scores


model	RMSE	MAE	Bias
Generic PC	0.385	0.299	2.50e-01
QM	0.314	0.239	-1.23e-04
Linear model	0.251	0.199	3.38e-17
Spatio-temporal model	0.170	0.125	1.08e-09

Scores by Offshore / Onshore

tech_typ	model	RMSE	MAE	Bias
Wind Offshore	Generic PC	0.449	0.369	3.61e-01
Wind Offshore	QM	0.341	0.236	1.47e-01
Wind Offshore	Linear model	0.211	0.162	7.09e-17
Wind Offshore	Spatio-temporal model	0.098	0.072	-4.90e-04
Wind Onshore	Generic PC	0.361	0.276	2.13e-01
Wind Onshore	QM	0.305	0.240	-4.88e-02
Wind Onshore	Linear model	0.263	0.211	2.16e-17
Wind Onshore	Spatio-temporal model	0.187	0.143	1.62e-04


Estimates by hour

Power estimates Time Series 2024-08-10




Errors by hour

Power estimates Time Series 2024-08-10




Model Mesh

Mesh used for spatial calibration model




Mesh assessment



Time series of data and generic PC estimate


ERA5 data and generic PC estimate

ERA5 + Generic PC Time Series 2024-08-10




Observed data

Observed power Time Series 2024-08-10




Error of generic PC estimate



ERA5 wind speed

Wind speed at wind farm locations


Wind Speed Time Series 2024-08-10



— capacity weighted avg. — simple avg.

Observed generation

Observed power Time Series 2024-08-10



— capacity weighted avg. — simple avg.

Appendix


Project Goal

Project Goal


- Correct ERA5 wind power biases using observed generation data.
- Reduce error metrics (RMSE/MAE/bias).
- Ensure spatially consistent estimates that generalise out-of-sample.
- Capture low-wind events: frequency, duration, and spatial extent.

Spatial correlation

Correlation for Elexon generation



Correlation for error after calibration




Calibration of generic power curve estimate

GB level aggregation

- Nearest ERA5 grid for wind speed
- Vertical interpolation using a power law
- Generic Power Curve (onshore, offshore)
- Normalised power aggregated at GB level

$$p_{\text{tot},t} = \sum_i p_{it} / \sum_i C_i$$


- Hourly resolution
- Potential generation (ex curtailment)



Linear model

- Using step AIC criteria selection:
 - k : Type (offshore / onshore)
 - m : month, h : hour
 - w_t : wind speed

$$p_t^{calib} = \alpha_{k,m,h} + \beta_{k,m} \hat{p}_t + \sum_{j=1}^3 \phi_j w_t^3$$




Autoregressive error

- Using step AIC criteria selection:
 - k : Type (offshore / onshore)
 - m : month, h : hour
 - w_t : wind speed
 - u_t : AR1

$$p_t^{calib} = \alpha_0 + \sum \alpha_e + \beta_k \hat{p}_t + f_w(w_t) + u_t$$

where α_0 is the intercept, the α_e $e \in k, m, h$ represent random effects (cyclic for month and hour), β_k is a random slope, f_w is smooth effect (RW2).




Hierarchical Bayesian model

- Turning multiplicative corrections into smooth functions

$$p_t^{calib} = \alpha + \beta_k + \beta_m + \beta_h + s_p(p_t) + s_w(w_t)$$

where β_k , β_m , β_h are random effects and s_p and s_w are smooth functions




Quantile Mapping

- Quantile mapping aims to replicate observed distribution

$$p_t^{calib} = F_{obs}(F_{mod}^{-1}(p_t))$$

where F_{mod} and F_{obs} are the CDF of the power estimate and observed values



Comparison scores

model	RMSE	MAE	Bias
Generic PC	0.200	0.164	1.63e-01
AR inlabru	0.092	0.077	3.16e-04
AR1	0.075	0.062	8.57e-05
QM	0.075	0.054	-2.60e-05
Linear	0.052	0.038	1.39e-19
Linear inlabru	0.049	0.036	-2.61e-10

Power curve modelling

Power curve modelling

Components

- Power curve estimate from data
- Probability of zero generation
- Penalisation to make power curve resemble manufacturer's PC

Using a three-likelihood approach for power curve estimation:

- **1st likelihood:** Observed power is modelled as a smooth function of wind speed
- **2nd likelihood:** Zero inflated component
- **3rd likelihood** Penalisation towards a generic PC

Power model overview

- 1 $\pi_{it} = \pi(w, i) = \Pr(P_{it} = 0)$ depends of wind speed and location

$$L^{(0)}(\theta^0 | \mathbf{p}, \mathbf{w}, \mathbf{i}) = \prod_t [\pi_i(w_{it}, i)^{\mathbb{1}(P_{it}=0)} \times (1 - \pi_i(w_{it}, i))^{\mathbb{1}(P_{it}>0)}]$$

- 2 Generation when $P_{it} > 0$ also depends on wind speed / location. Learned as a smooth function from data: $s^{\text{pc}}(w, i) \in (0, 1)$

$$s^{\text{pc}}(w_{it}, i) = \mathbb{E}(P_{it} | P_{it} > 0, w_{it}, i) = \mu_{it}^+ \\ L^{(\beta)}(\theta^{\text{pc}} | \mathbf{p}, \mathbf{w}, \mathbf{i}) = \prod_{t: P_{it} > 0} \text{Beta}(P_{it} | \mu_{it}^+, \phi),$$

where θ^0 and θ^{pc} represents the parameters of the smooth functions, $\pi(w, i)$ and s^{pc} , and ϕ the precision of the Beta distribution.

Penalisation component

- 3 Finally, we penalise s^{pc} to be close to our generic power curve estimate, $\hat{P}\hat{C}_i(w)$: $d_{it} = |\hat{P}\hat{C}_i(w_{it}) - s^{\text{pc}}(w_{it}, i)|$ should be small.
- Or maximise the negative of $\tau_{\text{ps}} \sum d_{it}^2$ for a certain penalisation parameter τ_{ps} .
- Adding that penalty term is similar to assume $d_{it} \sim N(0, 1/\tau_{\text{ps}}^{-1})$

$$\max_{\theta} \quad l^{(0)}(\theta) + l^{(\beta)}(\theta) - \tau_{\text{ps}} \sum_{i,t} d_{it}^2$$

where $\theta = (\theta^0, \theta^{\text{pc}}, \tau_{\text{ps}})$ represents the parameters of both likelihoods, plus the penalisation parameter.

Power curve model equations

Model is a Zero Inflated Beta (ZIB) with penalisation component:

Zero-probability model (Bernoulli)

$$\eta_{it}^{(0)} = \alpha_{\text{zero}} + f_{\text{zero}}(w_{it}, i),$$

$$Z_{it} \mid \eta_{it}^{(0)} \sim \text{Bernoulli}(\pi_{it}), \quad \pi_{it} = \frac{1}{1 + \exp\left\{-\eta_{it}^{(0)}\right\}},$$

Positive-output model (Beta)

$$\eta_{it}^{(\beta)} = \alpha_{\text{pc}} + f_{\text{pc}}(w_{it}, i),$$

$$P_{it}^{\text{obs}} \mid \eta_{it}^{(\beta)} \sim \text{Beta}(\mu_{it}^+, \phi), \quad \mu_{it}^+ = \frac{1}{1 + \exp\left\{-\eta_{it}^{(\beta)}\right\}},$$

Pseudo-likelihood model (Gaussian)

$$\hat{P}C_i(w_{it}) \mid \eta_{it}^{(\beta)} \sim \mathcal{N}\left(\eta_{it}^{(\beta)}, \tau_{\text{ps}}^{-1}\right), \quad \tau_{\text{ps}} = \text{precision or penalisation}.$$

Details on smooth components

- The smooth components $f_{\text{zero}}(w, i)$ $f_{\text{pc}}(w, i)$ is modelled as a 1D SPDE over wind speed with a uniform correlation matrix across locations $i = 1, \dots, I$.

$$f(w, i) = \sum_{k=1}^I \beta_i \psi_k(w),$$

where $\psi_k(w)$ are basis functions defined over wind speed and β_i are coefficients. The correlation structure of $f(w, i)$ assumes a Matern covariance function: Let w_s, w_h represent two wind speed values in location i , and $d = |w_s - w_t|$ their distance, then:

$$\begin{aligned} \text{Cor}(d) &= \text{Cor}(f(w_s, i), f(w_t, i)) \\ &= \frac{1}{2^{\nu-1} \Gamma(\nu)} (\kappa d)^\nu K_\nu(\kappa d), \quad \alpha = \nu + d/2, \end{aligned}$$

Details on smooth components

- Additionally a uniform correlation matrix is assumed across locations $j, k \in \{1, \dots, I\}$. That is:

$$\text{Cor}(f(w, j), f(w, k)) = \rho, \quad j \neq k$$

which helps to pool information across locations, benefiting locations with less data.

Power estimate

This leads to the following power estimate at time t and location i :


$$\hat{P}_{it} = \begin{cases} 0, & \text{with probability } \pi_{it}, \\ \mu_{it}^+, & \text{with probability } 1 - \pi_{it}. \end{cases}$$

Which leads to the expected power estimate:

$$E[P_{it}|w_{it}, i] = (1 - \pi_{it}) \times \mu_{it}^+$$


Power curve model estimates

- Starting models with
 - 1Y of data (2024)
 - 25 wind farms
 - Hourly data
 - Excluding outages listed in REMIT




Power curve model estimates

Power curve estimate



Probability of zero generation




Alternative versions

- Beta model with RW2 power curve (B-RW2)
- Beta model with 1D SPDE power curve (B-SPDE)
- ZIB model with 1D SPDE power curve (ZIB-SPDE)
- ZIB model with 1D SPDE power curve penalised (ZIB-SPDE-P)

Zero Inflated models better capture low wind power regions.


Power curve estimates under different models



ZIB model vs observed data

- Power curve modelling highly improves the calibration
- ZIB models deal better with the tail regions
- Penalised version actually pulls estimate toward Generic PC
- We could pull estimate instead to a 5 parameter curve estimate

Power curve models vs observed data



Error metrics

Error metrics calculated on 30% of the sampled wind farms data.

model	RMSE	MAE	Bias
Generic PC	0.2188	0.1583	0.1469
B-RW2	0.0995	0.0723	0.0191
B-SPDE	0.0994	0.0722	0.0190
ZIB-SPDE	0.0976	0.0691	0.0103
ZIB-SPDE-P	0.1016	0.0694	0.0269


Pooling data for cut-off estimation

- Not enough data to estimate at wind farm level
- Even using all 5 years of data (2019-2024), only a few farms show cut-off behaviour

Pooling data at high wind speeds


wind speed	prop. $P=0$	prop. $P \leq 0.02$	n obs.
[0,15]	0.22	0.23	3292
(15,20]	0.13	0.14	7062
(20,25]	0.11	0.13	5266
(25,30]	0.43	0.48	670
(30,Inf]	0.76	0.79	63

Tail behaviour of power curve




Model to estimate cut-off by wind speed

Hyperparameters of the cut-off model



Probability of zero generation at high wind speeds




Power Curve fitting

Classic parametric shape

The five-parameter formula (Lydia et.al, 2013):

$$P(u) = D + \frac{A - D}{(1 + (u/C)^B)^G}$$

where: A and D are the upper and lower asymptotes, C controls the inflection point, B is related to the slope at inflection point, and G controls the asymmetry.




Parametric shape for cut-off

Adding extra parameters we can model the decay after cut-off:

$$P(u) = D + \frac{A - D}{(1 + (u/C_1)^{B_1})^G (1 + (u/C_2)^{B_2})^G}$$

where: A and D are the upper and lower asymptotes, C_1 is the first inflection point, C_2 is related to the cut-off, B_1 is related to the slope at inflection point, B_2 to the slope during cut-off, and G controls the asymmetry.

7 parameters power curve




Parametric fit for Scottish wind farms

- We can fit the parametric shape using `optim`
- As long as there is a reasonable amount of points showing the cut-off `optim` can converge

Estimates from data

par	estimate
A	0.92
B1	-9.74
C1	10.06
D	0.02
G	0.43
B2	35.64
C2	24.92

Data and power curve estimate



Next Steps

- Spatiotemporal calibration model
- Non-stationary covariance model
- Comparison against benchmarks

Data sources

Wind speed

- ERA5 at wind farms
 - Hourly data
 - Spatial resolution $0.25^{\circ} \times 0.25^{\circ}$
 - 10m and 100m heights

Wind power

- Elexon BMU data (since 2019)
 - Half hourly data
 - Generation, curtailment, potential, capacity
 - Outage data (REMIT)
- REPD database
 - Location, turbine height, capacity

Previous research

Power curve modelling

Binning method

$$P_i = \frac{1}{n_i} \sum_{j=1}^{n_i} P_{ij}$$

where: P_{ij} is the j th power observation in bin i and n_i no. of observations in bin i

Logistic

$$P(u) = a \frac{1 + m \exp(-u/\tau)}{1 + n \exp(-u/\tau)}$$

where a represents the upper asymptote, n, m shape the lower asymptote, and τ controls the transition.

Power curve modelling

5 parameter curve

$$P(u) = D + \frac{A - D}{(1 + (u/C)^B)^G}$$


where: A and D are the upper and lower asymptotes, C is the inflection point, B the slope at inflection point, and G controls the asymmetry.

Reanalysis data to quantify extreme wind power statistics

D. Cannon, D. Brayshaw, et. al (2015)

- MERRA wind speed validated with MIDAS
- Vertical interpolation with a logarithmic change
- Calibrated power curves based on manufacturers PC
- Use that to analyse extreme low and high levels, and ramps


ΔCF comparison



Balancing energy

H. Thornton, D. Brayshaw (2020) analyse the relationship between weather, energy demand, and wind power.

- ERA Interim wind speed
- Cubic power curve with air density correction
- CF compared with GB average from other studies
- Seasonal effects on Demand and




Analysis of extreme wind droughts

Panit Potisomporn, C. Vogel (2024) perform a extreme value analysis of wind droughts in GB.

- Use ERA5 wind speeds calibrated to MIDAS with QM
- Build a ML algorithm that learns how to extrapolate wind speed from 10m to hub height
- Use a 5 parameter logistic function to model power curve
- Model energy losses with factors by type.


CF calibration




ERA5 + generic power curve error analysis

Error by Onshore / Offshore

Errors by observed power




Error density




Errors through time

Error by hour



Error by month



Challenges in spatial wind calibration

Challenges in spatial wind calibration


- Non-stationarity
 - (space) spatially varying coefficients
 - (wind direction) anisotropy
 - (time) regimes / storms and other weather events
- Physically informed model
 - Regularisation / penalisation
- Data dimensionality reduction
 - Aggregate time dimension (day)

Non-stationarity approaches found in the literature


Regression with PDE regularisation

- Tomasetto et al.(2024) model anisotropy through a physics informed regression model
- Including physical knowledge through a PDE regularisation term

Anisotropic non-stationary diffusion



Sea Surface Temperature (SST)




Explanatory variables in the covariance

- Ingebrigtsen, Lindgren, and Steinsland (2014)
- Regression on ranke and precision parameters of spatial term

$$\log \tau(\mathbf{s}) = b_0^{(\tau)}(\mathbf{s}) + \sum_{k=1}^p b_k^{(\tau)}(\mathbf{s}) \theta_k, \quad (2)$$

$$\log \kappa(\mathbf{s}) = b_0^{(\kappa)}(\mathbf{s}) + \sum_{k=1}^p b_k^{(\kappa)}(\mathbf{s}) \theta_k. \quad (3)$$


Field and correlation at two points





Variables relevant to non-stationarity in wind

- Wind dynamics are non-stationary in space and time
- Weather regimes, storms, other events
- Circulation patterns (NAO, AO, EA, SCAN)
- NAO + leads to higher wind speeds UK and more variability



North Atlantic Oscillation (NAO) *500-hPa Height Anomalies*





Circulation patterns and wind power





Circulation patterns and wind power



Circulation patterns and error in wind power estimates



Circulation patterns and error in wind power estimates



References

- Cannon, D. J., D. J. Brayshaw, J. Methven, P. J. Coker, and D. Lenaghan. 2015. "Using Reanalysis Data to Quantify Extreme Wind Power Generation Statistics: A 33 Year Case Study in Great Britain." *Renewable Energy* 75 (March): 767–78. <https://centaur.reading.ac.uk/38448/>.
- Potisomporn, P. 2024. "Spatiotemporal Variability of Extreme Low Wind Power Events in Great Britain - ORA - Oxford University Research Archive." [Http://purl.org/dc/dcmitype/Text](http://purl.org/dc/dcmitype/Text).
<https://ora.ox.ac.uk/objects/uuid:de37bee2-1813-42e5-a69c-9b15f038d096>.
- Thornton, Hazel E. 2020. "Atmospheric Circulation, Seasonal Predictability and Britain's Energy System." PhD thesis, University of Reading.
<https://doi.org/10.48683/1926.00095832>.