

BRIHANMUMBAI MUNICIPAL CORPORATION
MUMBAI FIRE BRIGADE.

Sub: Provisional Fire Safety Approval from Fire Safety Point of View i.e. Fire Protection & Fire Fighting Requirements for the proposed Construction of Low-Rise Commercial cum Residential Building (redevelopment of existing building) on land bearing Old CTS No. 194A, New CTS No.194/A/16/1/A (Pt.) of village Ghatkopar Plot No. 28, of B. Nath Pai Nagar, at Vidya Bhawan Marg, Ghatkopar (East), Mumbai-400077.

Ref: Online Submission by Licensed Surveyor, Mr. Ashish Bhatt under File No. P-29345/2026/(194A/16/1/A (pt.))/N Ward/GHATKOPAR-CFO/1/New.

Name Of Applicant/Owner:

Mr. Devesh Rajendra. Gupta,

of M/s. Ayaansh Buildcon LLP C.A to Owner,

This is a proposal for the construction of a Low-rise Residential cum Commercial building having basement (-04.50 mtrs.) + Ground floor + 1st floor commercial + 2nd to 8th upper residential floors with a total height of 31.95 mtrs. From general ground level up to terrace level, and proposed automated mechanized car parking tower on North East corner of the building with total height of 31.95 mtrs. from ground level to the top of car parking tower with a separate MS staircase of 00.90 mtrs. and 1.00 mtrs. Wide platform with Railing, as shown on the plan.

THE FLOOR-WISE USERS OF THE BUILDING ARE AS UNDER.

Floors	Users
Basement (-04.50 mtrs.)	Pump room + U.G. Tank.
Ground Floor	Entrance lobby + 03 nos. of shops + 02 Nos. of meter rooms + fire control room + stack & surface car parking.
1 st floor	04 nos. of offices + society office + fitness center
2 nd to 8 th floors	03 nos. of Residential flats on each floor.
Terrace floor	Open to the sky (Treated as refuge area)

STAIRCASE & LIFTS:

THE DETAILS OF THE STAIRCASE OF THE BUILDING ARE AS UNDER:

Staircase description	Width of staircase	Nos. of staircase	Type
Leading from basement to terrace floor (diverted at ground floor).	1.50 mtrs	01 no.	Enclosed
Leading from ground to 1 st floor. (for offices)	1.50 mtrs	01 no.	Open

The proposed staircase is enclosed type and is externally located & adequately ventilated to outside air, as shown on the plan.

THE LIFTS PROVIDED ARE AS UNDER:

Lifts Type	Profile	Nos. of lifts
Passenger lift	Leading from ground to terrace floor	01 no.
Fire lift	Leading from ground to terrace floor	01 no.
Passenger lift	Leading from ground to 1 st floor	01 no.
The lift lobby & common corridor at each floor level is directly ventilated to outside air as shown on the plan.		

The site abuts on 13.40 mtrs wide Existing Road on the South side, as shown on the plans.

The side open spaces all around the building are as under:

Sides	Open space from building line to plot boundary
North	01.50 mtrs. to 03.14 mtrs.
South	04.57 mtrs. To 05.18 mtrs. + 13.40 mtrs wide Existing Road
East	01.50 mtrs. To 03.64 mtrs.
West	03.62 mtrs to 03.86 mtrs.

REFUGE AREA: -

The height of the building is less than 32.00 mtrs. i.e. 31.95 meters., Hence, terrace of the building will be treated as refuge area as per DCPR 2034.

The proposal has been considered favorably in view of the facts that:

- As applied by the Architect proposal falls under Regn. **33(7)(B)** of DCPR-2034.
- The plot abuts on 13.40 mtrs wide Existing Road on the South, as shown on the plans.
- That, in-built fixed firefighting systems such as wet riser cum downcomer systems, fire alarm systems, fire detection systems, water spray projection systems, automatic sprinkler systems & public address systems, etc. were stipulated to do the compliance. The installations shall be done by Govt. Approved Licensed agency as per prevailing norms. The certificate to that effect shall be obtained from Govt. Approved Licensed agency before applying for compliance remarks to this department.
- It is recommended that electrical cables in electrical conduit/shaft shall be of low smoke hazard type & fire resistant. All the electrical installations, electrical wiring, etc. shall be as per the prevailing electricity Act & Rule. The certificate to that effect from the Govt. Approved Licensed electrician shall be obtained before applying for compliance remarks to this department.
- Recommended to provide an automatic sprinkler system in each shop, each office, society office, fitness center, the lift lobby/common corridor on each floor level of the building.

- vi) Recommended to provide an automatic smoke detection system in each shop, each office, society office, fitness center, and pump room of the building.
- vii) During the construction stage and before the final occupation party shall comply with additional requirement stipulated by the Mumbai Fire Brigade Officer, if any.

In view of the above, as far as this department is concerned; provisional fire safety approval/clearance, stipulating fire-protection & fire-fighting safety requirements for the proposed construction of the Low-rise Residential cum Commercial building having basement (-04.50 mtrs.) + Ground floor + 1st floor commercial + 2nd to 8th upper residential floors with a total height of 31.95 mtrs. From general ground level up to terrace level, and proposed automated mechanized car parking tower on North East corner of the building with total height of 31.95 mtrs. from ground level to the top of car parking tower with a separate MS staircase of 00.90 mtrs. and 1.00 mtrs. Wide platform with Railing, as shown on the plan, signed in token of approval, subject to satisfactory compliance of the following requirements;

1. ACCESS: -

- i) There shall be no compound wall on the roadside i.e. South side, However, removable bollards with chain link/sliding gates may be provided.
- ii) The roads shall be kept free from obstruction and encroachment.
- iii) There shall not be any of the trees obstructing the maneuvering of fire appliances.

2. COURTYARDS: -

- a. The available courtyards on all the sides of the building shall be paved suitably to bear the load of fire engines weighing up to 48 M. tons with a point load of 10 kg/sq cm.
- b. All the courtyards shall be in one plane.
- c. No structure of any type shall be permitted in courtyards of the building.

3. STAIRCASE: -

- a. The flight width of the staircase shall be maintained as shown in the enclosed plans.
- b. The flight width of each staircase shall not be less than 01.50 mtrs. Throughout its height.
- c. Externally located staircases adequately ventilated to the outside air.
- d. Openable sashes or R.C.C. grills with clear openings of not less than 0.5 sq. mtrs. Per landing on the external wall of the staircase shall be provided.
- e. No combustible material shall be kept or stored in the staircase/passage.

Terrace Staircase Door Manners:

The terrace door shall be provided in the following manners:

- a) The top half portion of the door shall be provided with louvers.
- b) The latch-lock shall be installed from the terrace side at a height of not more than 1 meter.

- c) The glass front of 6-inch diameter with the breakable glass shall be provided just above the latch lock to open the latch in case of an emergency by breaking the glass.
- d) The door shall either be fitted with magnetic lock connected to console & detection system or shall be synchronized with fire detection and alarm system.

4. ELECTRIC CABLE DUCT AND ELECTRIC METER ROOM:

- i) The electric cable duct shall be exclusively used for electric cables and should not open in the staircase enclosure.
- ii) Inspection doors for the duct shall have two hours' fire resistance.
- iii) Electric cables shall not pass through the staircase enclosure and shall be taken in a concealed manner.
- iv) Electric cables shall be sealed at each floor level with non-combustible materials such as vermiculite concrete. No storage of any kind shall be done in the electric duct.
- v) Electric wiring/ cable shall be non-toxic, non-flammable, low smoke hazard having copper core for the entire building with provision of ELCB/MCB.
- vi) An electric meter room shall be provided at the location marked on the plan. They shall be adequately ventilated.
- vii) An automatic smoke detection system shall be installed in the electric meter room & entire electrical duct on each floor of each wing.
- viii) The electrical bus bar system shall be preferred to electric cables.

5. LIFT:

A. PASSENGER LIFT:

- a) Walls enclosing the lift shaft shall have a fire resistance of not less than two hours.
- b) Shafts shall have permanent vents of not less than 0.2 Sq. Mtrs. in a clear area immediately under the machine room.
- c) Landing doors and lift car doors of the lift shall be of steel shuttered with fire resistance of one hour. No collapsible shutter shall be permitted.
- d) One of the lifts shall be converted into a "fire lift" and shall be as per specifications laid down under the regulations a toggle switch shall be provided to this lift for the use of Firemen.
- e) Thresholds of non-combustible material shall be provided at the entrance of each landing door.

B. FIRE LIFT:

- i) To enable fire services personnel to reach the upper floors with the minimum delay, one lift shall be provided and shall be available for the exclusive use of the firemen in an emergency.
- ii) The electric supply shall be on a separate service from electric supply mains in a building and the cables run in a route safe from fire, that is, within the lift shaft. Light & fans in the elevators having wooden paneling or sheet steel construction shall be operated on 24 volt supply.
- iii) Fire lift should be provided with a ceiling hatch for use in case of emergency. So that when the car gets stuck up, it shall be easily openable.
- iv) In case of failure of normal electric supply, it shall automatically change over to an alternate supply. For apartment houses, this changeover of supply could be done through a manually operated changeover switch.

Alternatively, the lift shall be so wired that in case of power failure, it comes down at the ground level and comes to a standstill with the door open.

- v) The operation of the fire lift should be by a simple toggle or two-button switch situated in the glass-fronted box adjacent to the lift at the entrance level. When the switch is on, landing call points will become inoperative and the lift will be on car control only or on a priority control device. When the switch is off, the lift will return to normal working. So this lift can be used by the occupants in normal times.
- vi) The words 'Fire lift' shall be conspicuously displayed in fluorescent paint on the lift landing doors at each floor level.
- vii) The speed of the fire lift shall be such that it can reach the top floor from ground level within one minute.
- viii) Fire lift shall be constructed as per prevailing Indian & International standards.

6. AUTOMATED MECHANIZED CAR PARKING TOWER:

- i) All the structural steel members of the mechanized car parking block i.e. columns, beams shall be protected with the fire resisting / retardant materials and methods as stipulated under relevant I.S. specification. A certificate to that effect that the fire resistance protection has been provided as above shall be furnished from the chartered Structural Engineer.
- ii) The cars shall be separated by perfect partition of 4.50 mm thick steel pallets between two cars to prevent spread of fire from one level to next level.
- iii) The mechanized car-parking block has door at the bottom and covered opening at the top to create natural drafts, to prevent spreading of fire.
- iii) The electrical cables used internally shall be fire retardant, and heat resistant of 105 degree centigrade.
- iv) Emergency Stop switch shall be installed inside the auto parking system, at the top of the tower, near the driving unit, outside the tower on operation panel & on the main control panel for activation in case of any emergency, for the power cut off to the main motor and all operations to stop.
- v) Stopper shall be installed on each pallet for the maximum position to which the car can be driven onto the pallet.
- vi) Blue and Red display lamps indicating whether system is ready to accept the car shall be installed at the entry point of the car. When the red lamp is on, car should not enter into the tower.
- vii) Automatic water spray projector system conforming to the standard laid down by T.A.C. and relevant I.S. specification shall be provided with sprinkler heads at each level below each pallet on engine side.
- viii) Fire detectors (Heat) shall be installed below each pallet to detect any increased temperature beyond 80 degrees centigrade Control Panel on the ground floor.
- ix) A Wet -riser of internal dia. of 10 cm. G.I. 'C' Class pipe shall be provided on external platform with staircase on alternate car cage level with single hydrant outlet and connected to the fire service outlet on the external face of the building directly fronting the courtyards shall be provided to connect the mobile pump of the fire service to the wet riser.

- x) Separate M.S. staircase of 01.00 mtrs. width having 01.00 mtrs. wide platform with Railing on shall be provided at alternate car parking level.
- xi) The car engine shall be shut off at ground level before parking at higher level.
- xii) Only trained operator certified by company installing car towers shall operate car parking.
- xiii) The proposed car parking tower & building shall be segregated by 04 hrs. fire resistance wall.

7. STACK CAR PARKING:

- i) Structural design: The SA-FAMCP shall be constructed of structural steel construction.
- ii) Vertical deck separation for SA-FAMCP having multi-car parking levels, vertical separation between upper & lower decks by using non-perforated & non-combustible materials. (Structural steel plate) shall be provided. This is to minimize direct impingement of flame to the car in the upper deck & also to prevent dripping of any possible leaking fuel to the lower deck.
- iii) Stack car parking shall be protected with an automatic sprinkler system covering each car.
- iv) Elements of the stacked car parking structure shall have 01-hour fire resistance.

8. ENTRANCE DOORS & KITCHEN DOORS (if provided):

The flat & office entrance, Rolling shutter of the shop, and Kitchen door (if provided) shall be of a solid core having a fire resistance of not less than one hour (solid wood of 45 mm thickness.)

9. BASEMENT (-04.50 mtrs.):

- a) The basement shall be used for designated purposes only as shown in the plan.
- b) The basement shall be provided with natural ventilation through the ventilators, and open cutouts as shown in the plan.
- c) The staircases of the basement shall be of enclosed type and entry to basement areas shall be through two two-hour fire resistance self-closing doors provided in the enclosed wall of the staircase and through smoke check / cut-off lobby.
- d) Suitable signage shall be provided in the pit showing exit directions, ways to exits, etc.
- e) The staircase and lift lobby shall be illuminated by inverter-operated exit signs with IP 54 enclosure. Luminance of the signage shall be such that they are visible from a distance of 12 to 16 meters.

10. FALSE CEILING: (if provided):

- i) False ceiling if provided in the building shall be of noncombustible material.
- ii) Similarly, the suspenders of the false ceiling shall be of no combustible materials.

11. MATERIALS FOR INTERIOR DECORATION/FURNISHING:

The use of materials that are combustible in nature and may spread toxic fumes/gases should not be used for interior decoration/furnishing, etc.

12. FIRE-FIGHTING REQUIREMENTS: -

A) UNDERGROUND STATIC WATER STORAGE TANK

A common underground water storage tank of capacity 75,000 liters shall be provided at the location marked on the plan, as per the design specified in the rules with a baffle wall and fire brigade collecting breaching. The layout shall be approved by the H.E.'s department prior to erection. The tanks shall be connected to the wet riser & sprinkler system.

B) OVERHEAD WATER STORAGE TANK: -

An overhead water storage tank of 30,000 liters capacity shall be provided at the terrace level. The design & layout shall be got approved from the H.E.'s department prior to erection. The tank shall be connected to the downcomer system through a booster pump through a non-return valve & gate valve.

C) WET RISER CUM DOWN COMER:

Wet Riser cum Down comer of G.I. 'C' class of 15 cm. dia. shall be provided in the lift lobby as shown on the plan with double hydrant outlet and hose reel on each floor in such a way as not to deduct the width of the corridor as shown on the plan. Pressure-reducing discs or orifices shall be provided at a lower level so as not to exceed the pressure of 5.5 kg / sq. cm.

D) FIRE SERVICE INLET:

- i) A fire service inlet on the external face of the building near the tank directly fronting the courtyards shall be provided to connect the mobile pump of the fire service independently to (a) The wet riser cum down comer & (b) Sprinkler system. (c) water spray projector system.
- ii) Breeching connection inlet shall be provided to refill U.G. Tank

E) AUTOMATIC SPRINKLERS SYSTEM:

An automatic sprinkler system shall be provided in each shop, each office, fitness center, society office, and in the lift lobby on each floor and the same shall be connected to the wet riser. The automatic sprinkler system shall be installed as per the standard laid down by T.A.C. and relevant I.S. specifications.

F) AUTOMATIC SMOKE DETECTION SYSTEM:

An automatic smoke detection system shall be provided in each shop, each office, society office, fitness center service area & lift lobby on each floor, and lift machine room and the same should be connected to the main console panel on the ground floor level as per IS specification.

G) WATER SPRAY PROJECTOR SYSTEM:

A water spray projector system shall be provided for the entire car parking tower with sprinkler heads at each level below each pallet on the engine side as per the standard laid down as per relevant I.S. specifications.

H) FIRE PUMP, SPRINKLER PUMP, JOCKEY PUMP & BOOSTER PUMP:

- a. Wet riser shall be connected to a fire pump at the ground level of 1800 liters/min capacity giving a pressure of not less than 3.2 kgs / sq.cms. At the topmost.
- b. Booster pump of capacity of 900 liters/min. Having a pressure of not less than 3.2 kgs./sq.cms. At the hydrant outlets, the wet riser shall be provided at the terrace level of the building.
- c. Sprinkler pump of suitable capacity along with a jockey pump shall be provided for an automatic sprinkler system.
- d. Electric supply (normal) to these pumps shall be on an independent circuit.
- e. Only surface-mounted pump or vertical turbine pump shall be installed for the fire-fighting system. Submersible pumps are not permitted.
- f. Firefighting panel shall be provided at ground level at an easily accessible/noticeable place.
- g. Two-way switches for the booster pump shall be provided at the terrace level as well as on the ground floor.

I) EXTERNAL HYDRANTS:

Courtyard hydrants on the ground shall be provided at a distance of 30.00 mtrs. Each around the building within the confines of the site of the downcomer system. A hose box with two hoses & branch shall be kept on the ground floor.

J) PORTABLE FIRE EXTINGUISHERS: -

- i. Dry Chemical Powder (A.B.C.) type fire extinguishers of 06 kgs. Capacity each having a B.I.S. certification mark & 02 buckets filled with dry, clean sand shall be kept at the service area.
- ii. One dry chemical powder type fire extinguisher of 06kgs. Capacity having a B.I.S. certification mark shall be kept on each floor level at prominent places, in the fitness center, society office, & each shop & office.
- iii. Dry Chemical Powder (A.B.C.) type fire extinguishers each of 06 kgs. Capacity having a B.I.S. certification mark shall be kept at the car parking area for every 100 sq. mtrs. Area.
- iv. **ELECTRICAL VEHICLE CHARGING POINT: (if provided)**
 - a) If electrical charging point proposed for charging of electrical vehicles, it same shall be provided at ground only.
 - b) For the EV Charging stations/ points the Fire safety advisory/ guidelines issued u/No. FB/H/1035 dated 18/10/2022 shall be complied with.
 - c) AVD (Aqueous Vermiculite Dispersion) Extinguishers of minimum 09 liters capacity & 06 Nos. of F-500 (Encapsulation agent) shall be provided near charging point & also designated area of electrical vehicle parking.
 - d) Security officer & staff shall be trained to handle the AVD Extinguishers OR F-500 (Encapsulation agent).
 - e) Additionally, Water curtain system shall be provided appropriately around the EV charging stations/points to protect other vehicles in the vicinity.
 - f) Certificate from Chief Electrical Inspector, PWD shall be obtained for the same before applying for compliance certificate of this department.

K) GUIDELINES FOR DESIGN, CONSTRUCTION TESTING, CERTIFICATION, MANAGEMENT ETC. FOR ALL EV CHARGING POINTS/ STATIONS:

- a) All the EVC points / stations shall be designed, installed, tested, certified, Inspected and connected in accordance with provisions as per prevailing Electricity Act & Rules, guidelines etc. issued by Central Electricity Authority, BIS & all the other competent Govt. authorities.
- b) The charging device i.e. charger shall be certified by a nationally recognized testing laboratory such as National Accreditation Board for Testing & Calibration Laboratory NABL.
- c) Use of EVSE integrated with IOT based safety devices can be insisted upon in Consultation of Electrical authorities at this stage.

L) FIRE ALARM SYSTEM: -

The building shall be provided with a manual fire alarm system with a main control panel at the ground floor level and pill-boxes and hooters at each upper floor level. The layout of a fire alarm system shall be in accordance with I.S. specifications.

M) PUBLIC ADDRESS SYSTEM:

The building shall be provided with a public address system in common areas with the main control panel on the ground floor.

N) FIRE DRILLS / EVACUATION DRILLS:

Fire Drills and evacuation drills shall be conducted regularly in consultation with the Mumbai Fire Brigade and a log of the same shall be maintained.

O) SIGNAGES:

Self-glowing/fluorescent exit signs in green color shall be provided showing the means of escape.

P) TRAINED OCCUPIERS/TRAINED SECURITY STAFF:

Occupiers of the building /Security staff shall be trained in Fire prevention and extinguishing fire in the initial stage, supervision on Maintenance of fixed fire-fighting systems & portable extinguishers, Mock evacuation drills, etc.

Q) FIRE AND LIFE SAFETY AUDITS:-

- (a) If applicable as per Section 45-A.(1) (a) Fire and Life Safety Audit shall be carried out by the owner, or where the owner is not traceable, the occupier of a building, for all the occupancies mentioned in sub-section (1) of section 45 by licensed "Fire and Life Safety Auditor" and such Fire and Life Safety Audit shall be carried out within a period of one year from the date of commencement of Maharashtra Fire Prevention and Life Safety Measures (Amendment) Act, 2023 and thereafter, once in every two years.
- (b) The owner or occupier, as the case may be, shall furnish to the Director or Chief Fire Officer or the nominated officer, a certificate in the prescribed form issued by a licensed Fire and Life Safety Auditor regarding the evaluation of the fire prevention and life safety measures in his such building or part thereof, as required by or under the provisions of this Act or rules made thereunder.

Explanation. -For the purposes of the Act, the expression “Fire and Life Safety Audit” means the evaluation of fire prevention and life safety measures required as per prevalent Acts or rules or National Building Code of India in force.

Periodic “Fire and Life safety Audits” conducted by third party auditor shall be done and the recommendations reported by them shall be complied with accordingly.

13. REFUGE AREA: -

The terrace floor of the building shall be treated as a refuge area & shall conform to;

- a. The entrance door to the refuge area shall be painted or fixed with a sign painted in luminous paint as **“Refuge Area In Case Of Emergency”**.
- b. An adequate drinking water facility shall be provided in the refuge area.
- c. Adequate emergency lighting facility connected to the electric circuit of the staircase, corridor/passage lighting, etc. shall be provided.
- d. The top half portion of the doors shall be provided with louvers.
- e. The latch-lock shall be installed from the terrace side at a height of not more than 01.00 mtr.
- f. The glass front of 6-inch diameter with the breakable glass shall be provided just above the latch lock, so as to open the latch in case of an emergency by breaking the glass.

14. OTHER N.O.C. / PERMISSIONS:

- i. Necessary permissions / N.O.C. for licensable trade activity u/s. 390 / 394 of M.M.C. Act., addition / alteration, interior work, loft etc. shall be obtained from competent Municipal Authorities.
- ii. Any addition or alterations in utility services, escape route shall be strictly done with prior permission & sanction of C.F.O. & other competent concerned authorities.

15. ELEVATION FEATURE, (If Provided):

The Elevation Feature / Treatment shall be given as per the B.M.C guidelines, D.C.P.R. 2034 & Circular u/r. no. Ch. Eng./D.P./110/Gen. dated 30/01/2020.

16. ELECTRICAL AUDIT:

Electrical authority audits of entire building shall be done periodically under the supervision of competent licensed electrical contractor to prevent electric fire in premises in future.

Scrutiny Fees: -

LS has certified the gross built up area as **2760.00 sq. mtrs.** the party has paid scrutiny fees of **Rs. 27,330/-** vide Online Receipt no 5/3/2026/64475 dated 05/3/2026 (Demand Note No: CHE/BP/196653/26).

Fire & Emergency Service Fees: -

The Architect has certified the height of the building as 31.95 mtrs. & total built-up area **2760.00 sq. mtrs.** for the said Low rise residential cum commercial building & as per schedule II of section 11(1) of Maharashtra fire prevention & life safety measure act 2006, & Maharashtra fire prevention & life safety measure Act amended 2023 and as per BRC No.78 dated

15/03/2024, has paid the Fire and Emergency Service Fee Rs. 2,73,270/- vide online receipt no: 5/3/2026/64475 dated 05/3/2026 (Demand Note No: CHE/BP/196653/26).

However, **E.E. B.P.(E.S.)** is requested to verify the total built-up area and inform this department, if the same is found to be more for the purpose of levying additional Scrutiny fees, if required.

Note:

- i) The Fire-Fighting installation shall be carried out by Govt. of Maharashtra-approved Licensing Agency.
- ii) The width of the Abutting Road & Open spaces is mentioned in the plans as submitted by the Architect attached herewith & these parameters shall be certified by the licensed surveyor.
- iii) E.E.B.P.(E.S.) shall examine the proposal in context with the relevant Regulations of D.C.P.R. -2034.
- iv) The Schematic Drawings / Plans of the Automatic sprinkler system, Automatic smoke detection system, Down comer system, Public address system, and Manual fire alarm system shall be submitted to the C.F.O. dept.
- v) The area, size, etc. for the Sprinkler system, Detection system, Fire alarm system, Down comer system, public address system, Electrical duct, etc. to be verified & examined by M.E.P. Consultant.
- vi) Separate necessary permission for any licensable activity shall be obtained from concerned authorities of B.M.C./C.F.O's Department, till then shall not be allowed to use.
- vii) There shall be no tree located in the compulsory open spaces or in the access way near the Entrance gates.
- viii) This recommendation letter is issued only from the Fire Protection & Fire-Fighting requirements point of view on behalf of the online application from the Architect. If any matter pertaining to authenticity or legality shall be cleared by the concerned Owner/Occupier/Developer/LS etc.
- ix) The plans approved along with this approval are issued from a Fire Risk & Life Safety point of view only. Approval of these plans does not mean in any way allowing construction of the building. It is LS/Developers responsibility to take necessary prior approval from all concerned competent authorities for the proposed construction of the building.
- x) As per Section 3 of the Maharashtra Fire Prevention & Life Safety Measures Act. 2006, it is the liability of the Owner / Occupier to provide the Fixed Fire-Fighting installations & which shall be maintained in good working order & in efficient condition all the time, in accordance with the provisions of the Maharashtra Fire Prevention & Life Safety Measures Act. or the Rules.
- xi) This approval is issued without prejudice to legal matters pending in the court of law, if any.

VINOD
DATTARAM
MAYEKAR
MAYEKAR

Digitally signed by
VINOD DATTARAM
MAYEKAR
Date: 2026.04.22
18:55:04 +05'30'

Div. Fire Officer
(Scrutinized and primary approval by)

Chief Fire Officer
(Approved by)

Copy To: 1) **E.E. B.P.(E.S.)**
2) **Licensed Surveyor, Mr. Ashish Bhatt.**

