

BRIHANMUMBAI MUNICIPAL CORPORATION
MUMBAI FIRE BRIGADE

Sub:Provisional Fire Safety Approval for the Proposed Redevelopment of Existing building known “Swavalamban Building” low-rise residential building on CTS No.785, 785/1 to 785/6 of village Malad-North, Mamledar wadi, 6th Cross Road, situated in P/N Ward, Malad (West), Mumbai.

Ref:Online submission from Shri. Mehul Jitendra Kanakia, Architect, Under file No.: P-23852/2024/(785 And Other)/P/NWard/MALAD-P/N-CFO/1/New.

NAME OF THE APPLICANT/OWNER,

SHRI- Nitin Vasudev Bhandarkar, partner of M/s. Prime Group LLP.

This is a proposal for redevelopment of a Existing low-rise residential building having Ground floor on stilt + 1st to 9th upper residential floor with a total height of 31.95 mtrs measured from general ground level to terrace level as shown on the plan.

FLOOR WISE USERS OF THE BUILDING WHICH ARE AS FOLLOWS:

Floor level	Users
Ground floor	Entrance lobby + stack car parking + Cantilever car parking + Electric Meter Room + Drivers W.C.
1 st to 9 th floor	03 Nos. of Residential Flats on each floor.
Terrace	Open to sky (Treated as refuge area)

THE DETAILS OF STAIRCASES:

No. of staircase	Type of staircase	Width	From – to
01 No.	Open type	01.50 mtrs.	Leading from ground to terrace level.
The staircase are externally located & adequately ventilated to outside air as shown on the plan.			

THE DETAILS OF LIFT:

No. of lifts	Type of lifts	Profile
02 Nos. of lifts	Passenger lifts	Each leading from ground floor to terrace floor level.
One passenger lift shall be converted into fire lift. The lift lobby/common corridor at each floor level is ventilated to outside air as shown on the plans.		

THE OPEN SPACES:

The plot abuts on 09.15 Mtrs. wide Road No. 6 on East side of the building as shown on the plan

Sides	From Building line to Plot boundary at Ground Level.
North	03.60mtrs to 03.74mtrs.
South	04.38mtrs to 04.50mtrs.
East	03.55mtrs to 03.68mtrs. + 09.15 Mtrs. wide Road No. 6
West	04.57 to 04.73mtrs.

Terrace floor of the building is treated as refuge area as such building height is less than 32 mtrs.

➤ **The proposal has been considered favorably in view of the facts that;**

1. The plot abuts on 09.15 Mtrs. Road No.6 on East side of the building as shown on the plan.
2. Recommended to provide automatic sprinkler system in entire car parking area covering each car parking level floor.
3. Recommended to provide automatic smoke detection system in Meter room & in Lift Machine Room.
4. During construction stage and before the final occupation party shall comply additional requirement stipulated by Mumbai Fire Brigade Officer, if any.

In view of above, as far as this department is concerned, these provisional fire safety approvals are issued for the proposal for the construction of a low-rise residential building having Ground floor on stilt + 1st to 9th upper residential floor with a total height of 31.95 mtrs measured from general ground level to terrace level as shown on the plan, signed in token of approval subject to compliance of the following requirements stipulated by this Department:-

1. ACCESS:

- i) All access & fire tender access should be free of encumbrances.
- ii) There shall be no compound wall on road side of the building. However, removable bollard chain link may be permitted.

2. COURTYARDS:

- i) The entire available courtyards on all the sides of the building shall be paved suitably to bear the load of fire engines weighing up to 58 m. tones each with a point load of 10 Kgs. per sq.cms.
- ii) The courtyards shall be kept free from obstruction at all times.
- iii) No structure of any kind shall be permitted in courtyards of the building.

3. STAIRCASE:

- i) The layout of the staircase shall be open type as shown in the plan throughout its height and shall be approached (gained) at each floor level.
- ii) The flight width of the staircase shall not be less than 01.50 mtrs. Throughout its height.

- iii) Permanent vent at the top equal to 5% of the cross-sectional area of the staircase shall be provided.
- iv) Openable sashes or R.C.C. grills with clear opening of not less than 0.5 sq. mtrs. per landing on the external wall of the staircase shall be provided.
- v) Nothing shall be kept or stored in staircase / corridor / passage.

The terrace door shall be provided in the following manner.

- A. The top of portion of the doors shall be provided with louvers.
- B. The single latch lock shall be installed from the terrace side at the height of not more than one mtrs.
- C. The glass front of 6-inch diameter with the breakable glass shall be provided just above the single latch lock, so as to open the latch in case of an emergency by breaking glass.

4. CORRIDOR / LIFT LOBBY:

- i) Corridor / lift lobby at each floor level shall be naturally ventilated.
- ii) The common corridor / lift lobby at each floor level shall be kept free from obstructions at all times.
- iii) Proper signage for way to staircase, escape routes, staircase, floor nos. etc. shall be provided at each floor of building.

5. ELECTRIC CABLE CONDUIT & ELECTRIC METER PANEL:-

- i. Electric cable conduit shall be exclusively used for electric cables & should not open in staircase enclosure.
- ii. Electric cable conduit shall be sealed at each floor level with non-combustible materials such as vermiculite concrete. No storage of any kind shall be done in electric shaft.
- iii. Electric wiring/ cable shall be non-toxic, non-flammable, low smoke hazard having copper core / fire resistance for the entire building with provision of E.L.C.B. / M.C.B.
- iv. Electric meter panel shall be provided at location marked on the plans with electric emergency switch at the ground floor level. It shall be adequately ventilated & easily accessible.
- v. Electric wiring shall be having copper core having the fire resistance and low smoke hazard cables for the entire bldg., with the provision of E.L.C.B / M.C.B.
- vi. Low & medium voltage wiring running in shaft & in false ceiling should run in separate conduits.
- vii. Water mains, telephone lines, intercom lines, gas pipes or any other service line should not be laid in the duct for electrical cables; use of bus bar / solid rising mains instead of cables is preferred.
- viii. Separate circuits for firefighting pumps, lifts, staircases & corridor lighting shall be provided directly from the main switch gear panel and these circuits shall be laid in separate conduit pipes, so that fuse in one circuit will not affect the others. Such circuits shall be protected at origin by an automatic circuit breaker with its no-volt coil removed.

- ix. Master switches controlling essential service circuits shall be clearly labelled & provide in the lobby for emergency operation.

6. ESCAPE ROUTE LIGHTINGS:

- i) The staircase and corridor lighting shall be on separate circuits and shall be independently connected so that they could be operated by one switch installation on the ground floor easily accessible to firefighting staff at any time irrespective of the position of the individual control of the light points, if any.

7. ENTRANCE DOORS & EXIT / ENTRANCE STAIRCASE:

- i) Entrance door of each occupancy and each room shall be of solid core having fire resistance of not less than one hour.

8. FALSE CEILING (if provided):

False ceiling if provided in the building shall be of non-combustible material. Similarly, the suspenders of the false ceiling shall be of no combustible materials.

9. MATERIALS FOR INTERIOR DECORATION/FURNISHING:

The use of materials which are combustible in nature and may spread toxic fume/gases should not be used for interior decoration/furnishing.

10. STACK CAR PARKING :-

- i) Structural design shall be of structural steel construction.
ii) Vertical deck separation multi-car parking level, vertical separation between the upper & lower decks shall be of non-perforated and non-combustible materials. Structural steel plate shall be provided. This is to minimize direct impingement of flame to the car in the upper deck and also to prevent dripping of any possible leaking fuel to the lower deck.
iii) Elements of the stacked car parking structure shall have 1 hr. fire resistance.
iv) Each car parking deck shall have 1 hr. fire resistance.
v) Parking area shall be accessible by trained staff when carrying out the maintenance work.
vi) The parking system is to be ceased during the maintenance operation.
vii) Stack car parking shall be provided with automatic sprinkler system covering each car parking level.

11. LIFT:

A. PASSENGER LIFT:

- a. Walls enclosing lift shaft shall have a fire resistance of not less than 02 hour.
b. Shafts shall have permanent vent of not less than 0.2 sq. mtrs in clear area immediately under the machine room.
c. One of the passenger lift shall be converted into fire lift as per norms.
d. Landing doors and lift car doors of the lifts shall be of steel shuttered with fire resistance of one hour. No collapsible shutter shall be permitted.
e. Threshold of non-combustible material shall be provided at the entrance of each landing door.

B. FIRE LIFT :

- i) To enable fire services personnel to reach the upper floors with minimum delay, one or more of the lifts shall be so designed as to be available for the exclusive use of such personnel in an emergency and be directly accessible to every dwelling/lettable floor space of each floor.
- ii) The lift shall have a floor area of not less than 1.4 sq. m. with a minimum dimension of 1.12 m. It shall have a loading capacity of not less than 545 kg. (8 persons lift) with automatic closing doors.
- iii) The shaft for the fire lift in a lift bank shall be separated from each other by a brick masonry or R.C.C. wall of fire resistance of not less than two hours. Lift car doors shall have fire resistance of not less than one hour.
- iv) There shall be an alternate electric supply from a generator of an adequate capacity apart from the electric supply in the building and the cables shall run in a route safe from fire, i.e. within the lift shaft. In case of failure of normal electric supply, it shall automatically trip over to alternate supply. For apartment buildings, this change over of supply could be done through a manually operated change-over switch.
- v) The operation of a fire lift shall be by a simple toggle or two button switch situated in a glass fronted box adjacent to the lift at the entrance level. When the switch is on, landing call-points will become inoperative and the lift will be on care control only or on priority control device. When the switch is off, the lift will return to normal working. This lift can be used by the occupants in normal times.
- vi) The words 'FIRE LIFT' shall be conspicuously displayed in fluorescent paint on the lift landing doors at each floor level.
- vii) Collapsible gates shall not be permitted for lifts; the lifts shall have solid doors with fire resistance of at least one hour.
- viii) The speed of the fire lift shall be such that it can reach the top floor from ground level within one minute.
- ix) Fire lift shall be constructed as per prevailing Indian & International standard.

12. FIRE FIGHTING REQUIREMENTS:**A. OVERHEAD WATER STORAGE TANK:**

A tank of 30,000 liters capacity shall be provided on the staircase of the building as shown on the plan. The design shall be got approved from H.E.s department prior to erection. The tank shall be connected to the wet riser through booster pump through a non-return valve and gate valve.

B. DOWN COMER SYSTEM:

A Down comer having internal diameter of 10 cms. of G.I. C class pipe shall be provided with single hydrant out let & hose reel on each floor, as shown on plan. Pressure reducing discs or orifices shall be provided at lower level so as not to exceed the pressure of 3.2 Kgs/sq.cm. The Down comer shall be connected to automatic sprinkler system.

C. AUTOMATIC SPRINKLERS SYSTEM:

Car parking area covering each car at stilt on ground floor, cantilever car parking shall be protected with Automatic sprinkler system as per standards laid down by T.A.C. or relevant I.S. specifications. Automatic

sprinkler system shall be clubbed with down comer system.

D) BOOSTER PUMP:

A booster pump of capacity of 900 lit/min & giving pressure of not less than 3.2 Kgs/sq.cm. at the topmost hydrant outlet shall be connected to down comer. A two way starting switch shall be provided at ground & at terrace level. The booster pump shall be surface mounted. (Submersible pump shall not be permitted).

E) EXTERNAL HYDRANTS:

Courtyard hydrants shall be provided within the confines of the site of the wet riser on ground floor for every 30.00 mtrs. distance around the building.

F) FIRE SERVICE INLET:-

A fire service inlet on the external face of the building near the tank directly fronting the courtyards shall be provided to connect the mobile pump of the fire service to the down comer.

G) DEDICATED BASE LIFTING PUMP FOR OVERHEAD FIRE WATER TANK

Dedicated base lifting pump of capacity 900ltrs/min. having a pressure of not less than 3.2 kgs. / sq.cms. at top most hydrant shall be provided to ensure that overhead water storage tank shall remain filled at all time.

H) HOSE & HOSE BOXES:

Hose Box, with two hoses of 15mts. length of 63mm dia along with branch shall be provided near wet riser landing valve on ground floor as well as alternate floor level.

I) FIRE-FIGHTING REQUIREMENTS AT THE CONSTRUCTION STAGE OF BUILDING:

- a) Following fire protection arrangement shall be provided & same shall be maintained in good working condition at all the times.
- b) Dry riser of minimum 15 cm diameter pipe with hydrant outlets on the floor constructed with fire service inlet to boost the water in the dry riser & maintenance should be in accordance with good practice.
- c) Drums of 200 ltrs capacity filled with water & two fire buckets shall be kept of each floor for every 100 sq. mtrs area.
- d) Water storage tank of minimum 20,000 ltrs capacity shall be kept at site ready to use in case of emergency, which may be used for other construction purpose also.

J) FIRE ALARM SYSTEM:-

The building shall be provided with manual fire alarm system with main control panel at ground floor level and pill-boxes and hooters at each upper floor level. The layout of fire alarm system shall be in accordance with I.S. specification.

K) ALTERNATE SOURCE OF POWER SUPPLY:

An alternate source of LV/HV supply from a separate substation OR from a D.G. set with appropriate changeover switch shall be provided for fire lift, fire pump, booster pump, sprinkler pump, jockey pump, staircase and corridor lighting circuits, detection and fire alarm system. It shall be housed in separate cabin.

L) PORTABLE FIRE EXTINGUISHERS:

- i. One dry chemical powder (ABC type) fire extinguisher of 9 kgs. capacity having B.I.S. certification mark and two buckets filled with dry clean sand shall be kept in electric meter panel & lift machine room.
- ii. One dry chemical powder (ABC type) fire extinguisher of 9 kgs. capacity having B.I.S. certification mark shall be kept in Society Office and at car parking area at prominent place.
- iii. One dry chemical powder (ABC type) fire extinguisher of 9 kgs. capacity having B.I.S. certification mark and two buckets filled with dry clean sand shall be kept on ground.

M) Electrical Vehicle Charging Point: - (IF PROVIDED)

- a. If electrical charging point proposed for charging of electrical vehicles, it same shall be provided at ground floor only.
- b. AVD (Aqueous Vermiculite Dispersion) Extinguishers of minimum 09 liters capacity or F-500 (Encapsulation agent) fire extinguishers of 09 kgs. Capacity shall be provided near charging point & also designated area of electrical vehicle parking.
- c. Security guards shall be trained to handle the AVD Extinguishers or F500 (Encapsulation agent) fire extinguishers.

N) AUTOMATIC SMOKE DETECTION SYSTEM:

Automatic smoke detection system shall be installed system in electric meter room & in lift machine room of the building

O) PANEL BOARD OF FIRE-FIGHTING SYSTEM:

Fire alarm system, Public address system, Alternate supply, etc. panels shall be installed on ground floor at the location shown in the plans & which shall be manned 24 hours.

P) SIGNAGES:

- i. Self-Glowing / Fluorescent exit signs in 'Green' color shall be provided in passage area of the building showing the direction of Escapes / Staircase / Exits etc.
- ii. All the exit routs shall be marked with fluorescent/radium painted & exits signs at strategic locations.

Q) TRAINED FIRE STAFF/SECURITY GUARDS:

The trained fire staff / Security guards having basic knowledge of

firefighting & fix firefighting installation shall be posted in the building.

R) PANEL BOARD OF FIRE-FIGHTING SYSTEM:

Fire alarm system, smoke detection system, etc. panels shall be installed on ground floor.

S) FIRE DRILLS / EVACUATION DRILLS:

Fire Drills and evacuation drills shall be conducted regularly and log of the same shall be maintained.

13. REFUGE AREA:

Terrace floor as a refuge floor:

The necessary facilities such as emergency lighting, drinking water etc. shall be provided. The access door/s from the enclosed staircase/s to the terrace floor shall have louvers at top half portion of the door. The entrance doors to the terrace shall be painted or fixed with sign painted in luminous paint mentioning "REFUGE AREA".

14. ELEVATION FEATURES:

Elevation treatment shall be of non-combustible materials and it should not obstruct firefighting activities. Elevation features for entire building shall be as per circular issued by Hon. M.C Under No. CHE/DP/110/GEN/2019-20 Dated 2019-20.

SCRUTINY FEES: -

Architect vide his letter dated 25/10/2024 has certified the gross built up area as 2624.54 sq. mtrs. the party has paid scrutiny fees of Rs. 25,000/- vide Online challan no. CHE/BP/173363/25 dated 19/06/2025 and receipt no. 19/06/2025/48327.

FIRE AND EMERGENCY SERVICE FEES: -

Architect has certified height of the building as 31.95 mtrs. & total built up area 2624.54 sq. mtrs. for the said Low rise residential building & as per schedule II of section 11(1) of Maharashtra fire prevention & life safety measure act 2006, and circular from Directorate of Maharashtra fire & Emergency service vide no. मअस-2023-59/895 dated 02/06/2023, the party has paid Fire & Emergency Service Fee of Rs. 1,44,580/- vide Online challan no. CHE/BP/173363/25 dated 19/06/2025 and receipt no. 19/06/2025/48327 and Rs. 7611/- vide challan no. CHE/CFO/174387/25 & receipt No. 25/6/2025/48709.

However, E.E.B.P.(W.S.) is requested to verify the gross built up area and inform this department if the same is found to be more for levying the additional scrutiny fees if any.

Note for the Architect/ E.E.B.P.(W.S.).

1. The fire-fighting installation shall be carried out by Govt. of Maharashtra approved Licensing Agency

2. The width of abutting road & open spaces is mentioned in plans as submitted by the Architect attached herewith and these parameters shall be certified by the Architect.
3. E.E.B.P.(W.S.) shall verify the proposal in context with the relevant Regulations of DCPR-2034.
4. The schematic drawings/plans of automatic sprinkler system, automatic smoke detection system, wet riser system, public address system, manual fire alarm system shall be got approved from CFO.
5. The area, size, etc. for the sprinkler system, detection system, fire alarm system, wet riser system, public address system, Fire duct, electrical duct etc. to be verified & examined by MEP Consultant.
6. Separate necessary permission for any licensable activity shall be obtained from concerned authorities of MCGM/CFO's department, till then shall not be allowed to use.
7. There shall be no any tree located in the compulsory open spaces or in the access way near the Entrance gates.
8. This recommendation letter is issued only from Fire Protection & Fire-Fighting requirements point of view on behalf of the application from Architect. If any matter pertaining to authenticity or legality shall be cleared by concerned Owner/Occupier/Developer/Architect, etc
9. The plans approved along with this approval are issued from Fire Risk & Life Safety point of view only. Approval of these plans does not mean in any way of allowing construction of the building. It is Architect/Developers responsibility to take necessary prior approval from all concerned competent authorities for the proposed construction of the building
10. As per section 3 of Maharashtra Fire Prevention and Life Safety Measures Act 2006, it is the liability of Owner/Occupier to provide the Fire Protection measures & Fixed Fire Fighting Safety system installations and shall be maintained in good working order & in efficient condition all the time, in accordance with the provisions of Maharashtra Fire Prevention and Life Safety Measures Act or the rules.
11. This approval is issued without prejudice to legal matters pending in court of law, if any.

SURENDRA
KRISHNA SAWANT

Digitally signed by SURENDRA
KRISHNA SAWANT
Date: 2025.06.27 13:30:42 +05'30'

**Asst. Div. Fire Officer
(Scrutinized & Approved by)**

COPY TO:

E.E.B.P.(W.S.)

Shri. Mehul Jitendra Kanakia, Architect