Published in IET Generation, Transmission & Distribution Received on 4th October 2013 Revised on 22nd May 2014 Accepted on 20th June 2014 doi: 10.1049/iet-gtd.2014.0228



ISSN 1751-8687

Constrained spectral clustering-based methodology for intentional controlled islanding of large-scale power systems

Jairo Quirós-Tortós¹, Rubén Sánchez-García², Jacek Brodzki², Janusz Bialek³, Vladimir Terzija¹

¹School of Electrical & Electronic Engineering, University of Manchester, Manchester, M13 9PL, UK

Abstract: Intentional controlled islanding is an effective corrective approach to minimise the impact of cascading outages leading to large-area blackouts. This study proposes a novel methodology, based on 'constrained spectral clustering', that is computationally very efficient and determines an islanding solution with minimal power flow disruption, while ensuring that each island contains only coherent generators. The proposed methodology also enables operators to constrain any branch, which must not be disconnected, to be excluded from the islanding solution. The methodology is tested using the dynamic models of the IEEE 39- and IEEE 118-bus test systems. Time-domain simulation results for different contingencies are used to demonstrate the effectiveness of the proposed methodology to minimise the impact of cascading outages leading to large-area blackouts. In addition, a realistically sized system (a reduced model of the Great Britain network with 815 buses) is used to evaluate the efficiency and accuracy of the methodology in large-scale networks. These simulations demonstrate that the author's methodology is more efficient, in a factor of approximately 10, and more accurate than another existing approach for minimal power flow disruption.

1 Introduction

Interconnected power systems are prone to cascading outages leading to large-area blackouts, and intentional controlled islanding (ICI) has been proposed as an effective corrective control action [1, 2]. ICI is an adaptive control strategy for systems under emergency and *in extremis* states [1–5]. After a severe contingency, ICI intentionally separates the bulk network into several self-sustaining electrically isolated islands. This adaptive control strategy is aimed to be used as a last resort only after instabilities have been detected, but before the system becomes uncontrollable [1, 2].

The ICI problem can be modelled as a constrained combinatorial optimisation problem and its complexity increases exponentially with the size of the system [6–11]. Hence, determining an islanding solution in real-time, that is, quickly enough to ensure effective islanding within a limited timeframe, is an extremely complex analytical and practical problem [12, 13].

The ICI methods aim to determine in real-time (a few seconds in practice [12]) a set of branches that must be disconnected across the network to create stable and sustainable islands [5–13]. When determining this set of lines, multiple constraints, such as generator coherency, load-generation balance, thermal limits, voltage and transient stability, should be considered. Since including all of these in

the ICI problem may result in a very complex problem that could not be solvable in a limited timeframe, only a subset of constraints can be considered [13]. The exclusion of some constraints and the inherent characteristics of the system mean that additional corrective measures [1–5] are necessary to ensure that each island retains its stability and security margins in the post-islanding stage [5–13].

Among the aforementioned constraints, the generator coherency constraint, which is used as a practical substitution of the true transient stability constraint, is crucial for the success of the controlled separation, as it enhances the transient stability of the islands [8, 9, 14]. Hence, current approaches for ICI aim to split the system such that each island contains only coherent generator [5–13].

The existing ICI methods can be classified according to the objective function used. Two major classes are: (a) minimal power imbalance, for example, [5–11], and (b) minimal power flow disruption, for example, [12, 13, 15]. While methods for the former minimise the load-generation imbalance within the islands, approaches for the latter minimise the change of the power flow pattern following system islanding.

Even though these approaches result in different islanding solutions, they both can be described as searching problems on graphs, which are generally 'NP-hard' [16], and therefore there is no general 'polynomial time' algorithm to

²Mathematical Sciences, University of Southampton, Southampton SO17 1BJ, UK

³School of Engineering and Computing Sciences, Durham University, Durham, DH1 3LE, UK E-mail: jairo.quirostortos@manchester.ac.uk

find the optimal solution [17]. Hence, to rapidly determine an islanding solution, computationally more efficient algorithms that approximate the optimal solution must be used instead [8–10].

In particular, solutions with minimal power flow disruption can be achieved using efficient graph theoretic techniques such as 'spectral clustering' [18]. This technique uses the eigenvalues and eigenvectors of a matrix associated with a graph that represents the power system to determine splitting solutions within 'polynomial time' [18]. Spectral clustering is used in [12] to determine islanding solutions with minimal power flow disruption. Even though this method is computationally efficient, it does not include the generator coherency constraint in the ICI problem. Failure to consider this vital constraint restricts the use of this approach [13].

More recently, a spectral clustering controlled islanding (SCCI) algorithm has been proposed in [13]. The SCCI algorithm minimises the power flow disruption, while ensuring that each island contains only coherent generators. However, an islanding solution can only be directly determined when the number of islands is two, that is, the SCCI algorithm only finds a solution for the 'bisection case'. This issue is resolved by applying 'recursive bisection' [13]. Nevertheless, 'recursive bisection' is a computationally demanding technique that requires the repeated 'eigendecomposition' of a matrix associated with the graph. Recursive bisection can also affect the quality of the islanding solution [18–22].

This paper proposes a novel methodology, based on constrained spectral clustering, that is computationally more efficient. Our methodology directly determines an islanding solution with minimal power flow disruption for any given number of islands, while ensuring that each island contains only coherent generators. In addition, it enables operators to constrain any branch to be excluded from the solution. The methodology solves an associated 'eigenproblem' only once, even when multiple islands (larger than two) are to be created, and avoids iterative algorithms (e.g. *k*-means [18]). These advantages significantly improve the computational efficiency and the quality of the solution, particularly when dealing with large-scale systems.

We test our methodology using dynamic models of the IEEE 39- and IEEE 118-bus test systems. Time-domain simulation results are used to demonstrate the effectiveness of the methodology to minimise the impact of cascading outages leading to large-area blackouts. We also used a reduced Great Britain network with 815 nodes to demonstrate that our approach is computationally very efficient and determines, in all our simulations, a 'good islanding solution', meaning a solution with small power flow disruption relative to the size of the islands.

This paper is organised as follows. Section 2 presents the background material on spectral graph clustering, and introduces the ICI problem considered in this paper. Section 3 presents the proposed ICI methodology, and in Section 4, we study its effectiveness in preventing cascading outages leading to large-area blackouts. Finally, Section 5 discusses the main strengths and limitations of the new ICI methodology, and Section 6 summarises the conclusions drawn from this study.

2 Spectral graph clustering and ICI

This section presents the background of spectral graph clustering. Spectral clustering is a computationally efficient graph theoretic technique that can partition systems using the eigenvalues and eigenvectors of a matrix associated with the graph that represents the power system [18]. This section also explains the ICI problem for minimal power flow disruption, considering the generator coherency constraint, and introduces a quality index to measure the performance of our methodology.

2.1 Spectral graph clustering

2.1.1 Graph theory fundamentals: A power system with n buses and m generators can be represented as a weighted and undirected graph $G = (V, E, \omega)$. The elements $v_i \in V$, i = 1, 2, ..., n, and $e_{ij} \in E \subset V \times V$, i, j = 1, 2, ..., n, denote the nodes and edges of G, respectively. The sets V and E represent the buses and branches of the system, respectively. Owing to the nature of power systems, G can be assumed to be simple, that is, no multiple edges and no loops exist.

The number $w_{ij} = \omega(e_{ij})$, i, j = 1, 2, ..., n, represents the weight factor associated with the edge $e_{ij} \in E$ (active power flow). To accommodate network losses, the value of w_{ij} is calculated as follows

$$w_{ij} = w_{ji} = \begin{cases} \frac{|P_{ij}| + |P_{ji}|}{2} & \text{if } e_{ij} \in E\\ 0 & \text{otherwise} \end{cases}$$
 (1)

where P_{ij} and P_{ji} represent the active power flow in the branch from bus i to j, and from j to i, respectively.

We define the subset $V_{\rm GN} \subset V$ of generation-nodes, with elements $v_i^{\rm GN} \in V_{\rm GN}$, to represent the m generation-buses of the system. Therefore the subset $V_{\rm LD} = V \backslash V_{\rm GN}$ of load-nodes (where \ denotes the set-theoretic difference and defines $V_{\rm LD}$ as the set of nodes in V that do not appear in $V_{\rm GN}$), with elements $v_i^{\rm LD} \in V_{\rm LD}$, is defined to represent the n-m load-buses. For example, Fig. 1 shows the graph representation of the IEEE 39-bus system. The black and the grey dots are the generation- and the load-nodes, respectively. We explain the subgraphs shown in Fig. 1 in more detail in Section 4.1.

2.1.2 Graph Laplacian matrices: Laplacian matrices are used in graph theory to describe and study graphs [18]. There are two main types of Laplacian matrices: the 'unnormalised' Laplacian matrix L and the 'normalised' Laplacian matrix L_N . These matrices are used in this paper to represent the active power flow in the branches of the system.

The 'unnormalised' Laplacian matrix L (used in [13]) of G is the $n \times n$ matrix computed as follows [18]

$$[\boldsymbol{L}]_{ij} = \begin{cases} d_i & \text{if } i = j \\ -w_{ij} & \text{if } i \neq j \text{ and } e_{ij} \in \boldsymbol{E} \\ 0 & \text{otherwise} \end{cases}$$
 (2)

where d_i is the weighted degree of the node v_i , which is defined as the total weight of the edges connected to that node [18]

$$d_i = \sum_{j=1}^n w_{ij} \tag{3}$$

The matrix L can be written as L = D - W, where D is a diagonal matrix with non-zero entries d_i , and W is the weighted adjacency matrix of G, that is, the matrix whose ij-entry is w_{ij} .




Fig. 1 Results for the IEEE 39-bus system a Representation of the 'Voronoi' diagrams in the graph b Islanding solution for the case r = 2

The 'normalised' Laplacian matrix of G is the $n \times n$ matrix $L_N = D^{-1/2}LD^{-1/2}$, that is, [18]

$$[\boldsymbol{L}_N]_{ij} = \begin{cases} 1 & \text{if } i = j \\ -w_{ij}/\sqrt{d_i d_j} & \text{if } i \neq j \text{ and } e_{ij} \in \boldsymbol{E} \\ 0 & \text{otherwise} \end{cases}$$
 (4)

The matrix L_N has the advantage of being scale-independent and, in particular, it allows the comparison of graphs with different weights [18–22].

2.1.3 Eigenvalues of the Laplacian matrices: Spectral clustering uses r eigenvectors of either L or L_N to provide geometric coordinates for the nodes $v_i \in V$ in r-dimensional Euclidean space \mathbb{R}^r [18]. This so-called 'spectral embedding' (see Fig. 2 for an example) is then used to cluster the data-points using a clustering algorithm for point clouds in \mathbb{R}^r , such as k-means [18]. We use the normalised Laplacian L_N as a number of studies have shown that it offers superior performance compared with L on weighted networks [18–22]. Hence, we will use the eigenvectors ψ_1 , ψ_2, \ldots, ψ_r , associated with the smallest r eigenvalues 0 = $v_1 \le v_2 \le \cdots \le v_r$ of the matrix L_N [18]. In our methodology, the value of r is the number of islands to be created. This value corresponds to the number of identified coherent groups of generators [4-13], as current practices (e.g. [23, 24]) suggest that the number of islands should be equal to the number of coherent groups obtained after the severe disturbance. Note that, nevertheless, the proposed methodology can determine an islanding solution for any given number of islands.

2.1.4 Spectral embedding: Spectral embedding refers to a representation of G in \mathbb{R}^r using the eigenvectors $\psi_1, \psi_2, ..., \psi_r$ [18]. Ordering these eigenvectors as columns creates a matrix $X \in \mathbb{R}^{n \times r}$ with rows x_i , i = 1, 2, ..., n. Then the vector x_i represents the coordinates of the node $v_i \in V$ in r-dimensional Euclidean space \mathbb{R}^r .

To improve the quality of the solution, the vectors x_i must be normalised to have length one before applying any clustering technique [19, 22]. Thus, we define


$$y_i := \frac{x_i}{||x_i||}, \quad i = 1, 2, ..., n$$
 (5)

The normalisation (5) effectively projects the vectors \mathbf{x}_i to the unit (r-1)-dimensional 'sphere' $\mathbb{S}^{r-1} = \{\mathbf{y}_i \in \mathbb{R}^r \text{ such that } ||\mathbf{y}_i|| = 1\}$ and creates the matrix $\mathbf{Y} \in \mathbb{R}^{n \times r}$ with rows \mathbf{y}_i .

After computing the spectral embedding, the nodes $v_i \in V$ can be seen as data-points x_i in \mathbb{R}^r , or y_i on \mathbb{S}^{r-1} . For example, we plot the vectors x_i in Fig. 2a and the vectors y_i in Fig. 2b for the spectral embedding of the IEEE 39-bus system when r = 2.

2.1.5 Representative data-points (centroids): We define $X_{\rm GN} \subset X$, and equivalently $Y_{\rm GN} \subset Y$, as the subset of data-points representing the m generation-nodes $v_i^{\rm GN} \in V_{\rm GN}$. Observe that $|X_{\rm GN}| = |Y_{\rm GN}| = m$. We call these data-points 'centroids' and denote them by $x_i^{\rm GN}$ and $y_i^{\rm GN}$ in \mathbb{R}^r and on \mathbb{S}^{r-1} , respectively. We explain the function of these centroids in Section 3. The advantages of using centroids are to: (i) satisfy the generator coherency constraint, (ii) accelerate the identification of a solution and (iii) reduce the memory usage by reducing the order of a similarity matrix. For an illustration, Fig. 2 shows the centroids as dots and the remaining data-points (representing load-nodes) as asterisks.

2.1.6 Constrained spectral clustering: Constrained spectral clustering is an extension of spectral clustering which allows two main types of constraints, must-link (ML-) and cannot-link (CL-) constraints, to be used [20, 21]. A ML-constraint between two nodes indicates that the pair of nodes must be clustered together, and a CL-constraint specifies that the pair of nodes cannot be assigned to the same cluster. We will only consider ML-constraints in this paper, to exclude branches that must






Fig. 2 *IEEE 39-bus system* a 2D spectral embedding in Euclidean space \mathbb{R}^2 b Normalised vectors on the unit circle \mathbb{S}^1 The numbers on the diagram correspond to node numbers The dots and the asterisks represent the generation- and load-nodes, respectively

not be disconnected from the islanding solutions, as it is considered that CL-constraints have less relevance for practical implementations.

2.2 Intentional controlled islanding

Fig. 3 presents the general concept of ICI [25, 26], which is associated with the blackout progress [27]. Following a severe disturbance on a healthy system at $t = t_{\rm dist}$ (known as initiating event), the slow degradation of the power system commonly takes place [1, 2]. Although remedial actions (RA) may be implemented to minimise the outage propagation, they may fail to restore the system to a secure state, either because they are not sufficient or they may just not be timely and effectively implemented by operators. This typically causes the system to enter the fast speed cascading outages, triggering the uncontrolled disconnection of system components and causing large-area blackouts [1, 2].

In this context, ICI aims to limit this fast speed cascading outages, by splitting the power system into several stable islands [28]. When the vulnerability analysis indicates the necessity to island at $t = t_{\text{nec,isl}}$ (when RA fail to minimise the impact of the initiating event), an islanding solution must be determined. To avoid any delay in the controlled islanding, it is important that the ICI method is computationally efficient to reduce the computational time [4]. Thus, after a short computational time, denoted as t_{comp} , an islanding solution must be determined to split the power system at the implementation time (t_{imp}), which must be before the system becomes uncontrollable. Post-islanding corrective actions (e.g. fast valving, load shedding etc.) are expected to be undertaken, and stable islanded operation obtained [25].

2.2.1 Generator coherency: Groups of generators can lose synchronism after a severe disturbance [8, 14, 29]. Each of these dynamically coherent groups of generators must be separated into different islands to help the transient stability of the system when determining an islanding solution [12]. Therefore, when the coherent groups of generators, denoted by $V_{\rm GN1}, ..., V_{\rm GNr}$, are identified after a severe disturbance, that is, using approaches such as those described in [24, 29], our methodology will create islands such that each of these contains only coherent generators, as detailed below.

2.2.2 Quality of the islanding solution and objective function: Spectral clustering finds a cutset, that is, a subset of edges $E_S \subset E$ whose removal splits the graph G into r disjoint subgraphs $G_1, ..., G_r$ [18]. Each subgraph corresponds to a node set $V_1, ..., V_r$ such that $V_1 \cup \cdots \cup V_r = V$ and $V_i \cap V_j = \emptyset$ for all $i \neq j$. An islanding solution consists




Fig. 3 Time-line showing the implementation of the methodology [26]

in identifying an appropriate cutset that splits the power system into islands that are represented by the subgraphs $G_1, ..., G_r$.

We need a measure of the quality of an islanding solution (cutset) to evaluate the performance of the methodology. This can be done using the ratio between the 'cut' and the 'volume' of each subgraph (island).

The 'cut' of an island represented by a node set V_k is the sum of the edge-weights between the nodes in V_k and the nodes not in V_k , that is, the sum of the edge-weights linking V_k with its complement V_k [18]

$$\operatorname{cut}(V_k, \bar{V}_k) = \sum_{v_i \in V_k, v_j \in \bar{V}_k} w_{ij}$$
 (6)

The cut measures the connectivity of an island, and in our case, it corresponds to the power flow disruption if the island V_k is disconnected from the rest of the system. We then make this quantity relative to the size of the island, in the following sense.

The 'volume' of an island with node set V_k is the sum of the weighted-degrees of its nodes [18]

$$\operatorname{vol}(V_k) = \sum_{v_i \in V_k} d_i \tag{7}$$

The volume of an island represents the internal power flow of the island plus the cross-boundary flow.

We can then define the quality of an island V_k as one minus the cut relative to its size

$$\phi(V_k) = 1 - \frac{\operatorname{cut}(V_k, \bar{V}_k)}{\operatorname{vol}(V_k)}$$
(8)

The quantity $\phi(V_k)$ ranges from zero to one, and measures the connectivity of an island relative to its volume. For clustering purposes, the greater the value of $\phi(V_k)$, the better the island is considered to be [30]. For example, $\phi(V_k) = 0.98$ represents a poorly connected island (its cross-boundary flow represents 2% of its total internal power flow), and hence a better candidate for islanding than a better connected island with $\phi(V_k) = 0.65$. Hence a large $\phi(V_k)$ represents an island with small power flow disruption and large internal power flow.

We define the overall quality of an islanding solution as the worst (minimum) quality of the islands it creates, that is, $\min_{k=1,2,\dots,r} (\phi(V_k))$. Therefore the clustering objective function is

$$\max_{V_1, \dots, V_r} \min_{k=1, 2, \dots, r} (\phi(V_k))$$
 (9)

that is, finding the r-partition maximising the worst (minimum) quality among its islands.

We require, in addition, that each island contains only coherent generators

$$V_{\text{GN}i} \subset V_i$$
 (10)

that is, the ith island must contain the ith group of coherent generators. This overall formulation (9) and (10) reduces the possibility of overloading the branches in the created islands [14] and increases the probability that the generators in each island will remain in synchronism [12, 13].

Finally, we enable operators to exclude branches from the islanding solutions. To do so, we define a new subset $E_C \subset E$ to represent branches that must not be disconnected, that is,

unavailable lines, lines that are important for the stability of the islands or lines without synchro-check relays (these devices are vital during the restoration process [12]). Excluding these branches amounts to impose the condition $E_C \cap E_S = \emptyset$, that is, to consider only partitions with cutsets E_S not containing any excluded edges from E_C .

With these new sets of constraints, the problem that we attempt to solve can be formulated as finding

$$\min_{V_1,\dots,V_r} \max_{k=1,2,\dots,r} \left(\frac{\operatorname{cut}(V_k, \bar{V}_k)}{\operatorname{vol}(V_k)} \right)$$
subject to
$$V_{\mathrm{GN}i} \subset V_i, \text{ and } E_C \cap E_S = \emptyset$$
(11)

Note that this type of min–max optimisation problems (11) on graphs are related to Laplacian eigenvalues, and this is the key connection between islanding with respect to minimal power flow disruption and spectral clustering [18]. Indeed, finding an optimal solution of (11) is in general NP-hard, and spectral clustering provides an efficient method of finding solutions of a relaxation of (11) [30], that is, it gives approximate solutions in polynomial time (details can be found in [18], and elsewhere in the vast literature of spectral clustering). The approximate and the optimal solution can be related via the so-called 'Cheeger inequality' [22], and this is one of the main theoretical justifications of the spectral clustering methodology [18]. We compare in Section 4.1, the quality of our solution with the quality of the optimal solution that is defined by the theoretical lower bounds of the 'Cheeger inequality' [22].

Proposed islanding methodology

Our methodology aims to minimise the power flow disruption, while satisfying the generator coherency constraint and excluding the constrained branches from the islanding solution, i.e., our objective function is given by (11). As explained above, we use spectral clustering to approximate a solution in polynomial time (a few seconds in all our test cases) of this NP-hard problem. Fig. 4 shows the flowchart of the proposed methodology, which is based on the spectral clustering algorithm of [19]. We identify each step by an S (step) followed by a number and we use in each step the definitions provided in Section 2.1.

Step 1: Build the graph G using the power flow data computed at the moment of islanding ($t_{\text{nec,isl}}$ in Fig. 3).

Step 2: Identify edges $e_{ij} \in E_C$ to be excluded from the cutset, and change their associated weight factor to the largest value in W (i.e. max (W))

for all
$$e_{ij} \in E_{\mathcal{C}}$$
, let $w_{ij}^{'} = w_{ji}^{'} = \max(\mathcal{W})$ (12)

The changes in (12) create a new weighted adjacency matrix W', which is then used to compute the matrix L_N using (4). Step 3: Compute the eigenvectors $\psi_1, \psi_2, ..., \psi_r$ of L_N .

Step 4: Create the matrix $X \in \mathbb{R}^{n \times r}$, and compute the spectral

embedding (see Fig. 2a for an example). Step 5: Define the centroids $x_i^{\text{GN}} \in X_{\text{GN}}$ in \mathbb{R}^r (e.g. the dots in Fig. 2a). The remaining data-points $x_i^{\text{LD}} \in X \setminus X_{\text{GN}}$ (e.g. the asterisks in Fig. 2a) represent the load-nodes of \widetilde{G} .

Step 6: Normalise the vectors $x_i \in X$ using (5) to compute the vectors y_i which form the rows of a matrix $Y \in \mathbb{R}^{n \times r}$. The

Fig. 4 Flowchart of the proposed methodology




Fig. 5 Results for the IEEE 39-bus system without islanding

- a Generator rotor angle
- b Generator speed
- c Voltage magnitudes

17518695, 2015, 1, Downloaded from https://ietrasearch.onlinelibrary.wiley.com/doi/10.1049/iet-gtd.2014.0228 by CochraneChina, Wiley Online Library on [23/07/2024]. See the Terms and Conditions (https://onlinelibrary.wiley.com/terms-and-conditions) on Wiley Online Library for rules of use; OA articles are governed by the applicable Creative Commons. License

Table 1 Results islanding the IEEE 39-bus system into two islands

Cutset	Island no.	Cut, MW	Volume, MW	$\phi(V_k)$, %
$e_{8,9}$, $e_{3,4}$, $e_{16,17}$	1	12	7383	99.84
	2	12	18 605	99.94

vectors y_i represent the nodes $v_i \in V$ as data-points on \mathbb{S}^{r-1} (see Fig. 2b for an example).

Step 7: Define the data-points $y_i^{GN} \in Y_{GN}$ on \mathbb{S}^{r-1} (the dots in Fig. 2b) as the centroids on \mathbb{S}^{r-1} .

Step 8: Compute the distances c_{ij} between the data-points $\mathbf{y}_i^{\text{LD}} \in \mathbf{Y} \backslash \mathbf{Y}_{\text{GN}}$ and the centroids $\mathbf{y}_j^{\text{GN}} \in \mathbf{Y}_{\text{GN}}$ (the asterisks and the dots in Fig. 2b). This creates a similarity matrix $\mathbf{C} := (c_{ij})$. Note that the size of \mathbf{C} is reduced to $(n-m) \times m$, and the advantages of this reduction are discussed in Section 4.4. Step 9: Associate each data-point $\mathbf{y}_i^{\text{LD}} \in \mathbf{Y} \backslash \mathbf{Y}_{\text{GN}}$ with the nearest centroid $\mathbf{y}_j^{\text{GN}} \in \mathbf{Y}_{\text{GN}}$. Mathematically, we identify the minimum value in the *i*th row of \mathbf{C} . Hence each load-node $v_i^{\text{LD}} \in \mathbf{Y}_{\text{LD}}$ is grouped with one and only one generation-node $v_j^{\text{GN}} \in \mathbf{Y}_{\text{GN}}$. For example, we found in Fig. 2b that data-points 28 and 29 are closer to the centroid

marked as 38 than to any other centroid. Thus, the nodes v_{28} , v_{29} are grouped with v_{38} . When each load-node is associated with the closest generation-node, m disjoint subgraphs are obtained (see Fig. 1a). We define each of these subgraphs as the 'domain of the generator for minimal power flow disruption'. This is a special case of a 'Voronoi' diagram [31], which simply assigns each point to its closest centroid. In our methodology, each generator has a different domain and examples of generator domains are illustrated in Fig. 1a and explained in detail in Section 5. Step 10: Create the final clusters (islands) by grouping the domains of the coherent generation-nodes. This ensures that the generator coherency constraint is satisfied. For example, the coherent groups of generators in the IEEE 39 are $V_{\text{GN1}} = \{v_{30}, v_{37}, v_{38}, v_{39}\}$ and $V_{\text{GN2}} = \{v_{31}, v_{32}, v_{33}, v_{34}, v_$ v_{35} , v_{36} (Fig. 5), thus we obtain the islands shown in Fig. 1b.

4 Simulation results

This section presents the simulation results. We use the dynamic models of the IEEE 39- and IEEE 118-bus test systems to demonstrate with time-domain simulations that the methodology can minimise the impact of cascading




Fig. 6 Results for the IEEE 39-bus system with islanding

a Generator rotor angle

b Generator speed

c Voltage magnitudes




Fig. 7 Results for the IEEE 118-bus system without islanding

- a Generator rotor angle
- b Generator speed
- c Voltage magnitudes

outages leading to blackouts. We also use a static model of a reduced Great Britain network with 815 buses to demonstrate the scalability of our methodology and to show that it is computationally more efficient and more accurate, in particular for large-scale networks, than the SCCI algorithm detailed in [13]. All time-domain simulations are performed in DIgSILENT PowerFactory [32], and the methodology has been implemented in MATLAB [33]. The time settings of the protective relays used in the simulations are carefully selected to show the desired oscillation mode, although, in practice, they may be shorter. In addition, instantaneous power flows are used for disconnecting overloaded lines. All times quoted are based upon simulations performed on a PC with 2.33 GHz double core CPU and 2 GB RAM.

4.1 Test case I: IEEE 39-bus system

We use the IEEE 39-bus system to illustrate our methodology in a small network. The data of this system and the controllers (automatic voltage regulators and power system stabilisers only) can be found in [34].

Testing case description: We have increased the base load level by 25%, while maintaining the same power factor. This is done to stress the system and increase the likelihood of instability following a disturbance. This increment has been equally distributed among the generators G2-G7. The output power of the other generators remains the same. We then consider that at time t = 0 s, a three phase-to-ground solid fault occurs near bus 16 at line 16-17, and is cleared after local relays open the faulty line at t = 0.4 s. If no control action is undertaken, it can be observed in Fig. 5a that the system loses synchronism at about 2.8 s. Indeed, the software DIgSILENT PowerFactory [32] indicates out of step (pole slip) at t = 2.85 s. Then, because of the power oscillations and the line overloads caused by the disconnection of line 16-17, multiple lines are disconnected in cascade. Line 13-14 is disconnected at time t = 5.5 s. This then triggers the uncontrolled cascading outages of lines 4-5, 3-4, 5-8 and 6-7 at the times 6.2, 6.7, 7.1 and 7.3 s, respectively. These cascading outages lead to the uncontrolled separation of the system into three islands, which are eventually affected by blackouts. Fig. 5b shows the frequency of the generators. As noticed, the system is




Fig. 8 Single line diagram of the IEEE 118-bus test system and proposed islanding solution

partitioned into three groups, which are not balanced. Finally, Fig 5c illustrates that the voltage magnitudes at the system buses are considerably small, leading to a blackout of the system at about $7 \, \text{s}$.

The loss of synchronism and the frequency of the generators are clear indicators that the system should be split [11]. Here we consider the necessity to partition the system at time t=3 s. In practical implementations, this time depends on the vulnerability analysis performed following severe disturbances. We use our methodology to determine the most suitable islanding solution with respect to the actual power flow in the branches at t=3 s. In the simulations presented for this test case, we assume that any transmission line can be included in the cutset, that is, $E_C=\emptyset$. We exclude transformers from the solution.

Since two coherent groups are identified at t=3 s, we define r=2 and consider the spectral embedding into \mathbb{R}^2 shown in Fig. 2a. We then normalise the vectors \mathbf{x}_i in \mathbb{R}^2 , i=1, 2, ..., 39, so they lie on the unit circle \mathbb{S}^1 shown in Fig. 2b. We then compute the distance between the vectors $\mathbf{y}_i^{\text{LD}} \in \mathbf{Y} \setminus \mathbf{Y}_{\text{GN}}$ (asterisks) and the centroids $\mathbf{y}_i^{\text{GN}} \in \mathbf{Y}_{\text{GN}}$

Table 2 Results islanding the IEEE 118-bus system into two islands

Island no.	Cut, MW	Volume, MW	$\phi(V_k)$, %
1	28	7961	99.65
2	28	10 193	99.73

(dots). We use these distances to build the similarity matrix C, and each load-node $v_i^{\mathrm{LD}} \in V_{\mathrm{LD}}$ is then grouped with the nearest generation-node $v_j^{\mathrm{GN}} \in V_{\mathrm{GN}}$. This preliminary grouping creates the 'domain of each generator for minimal power flow disruption', or Voronoi diagrams, shown in Fig. 1a in different background shades.

Then, as the identified coherent groups of generators shown in Fig. 5 are $V_{\rm GN1} = \{v_{30}, v_{37}, v_{38}, v_{39}\}$ and $V_{\rm GN2} = \{v_{31}, v_{32}, v_{33}, v_{34}, v_{35}, v_{36}\}$, the clusters in Fig. 1a containing coherent generation-nodes are grouped together to determine the islanding solution illustrated in Fig. 1b. Table 1 shows the value of the cut (6), the volume (7) and the value of $\phi(V_k)$ (8) of each island obtained. We conclude that the quality of the islanding solution (the minimum value of $\phi(V_k)$ from all of the islands) is 99.84%.

This solution was obtained in approximately 1.5 ms $(t_{\text{comp}} = 0.0015 \text{ s})$ and thus the corresponding corrective controlled strategy was undertaken at t = 3.0015 s. Fig. 6 presents the dynamic simulation results with islanding. We can see that the blackout has been successfully avoided, and two stable islands are created with frequency at t = 15 s between 0.989 and 1.035 pu, and voltages between 0.895 and 1.09 pu. Indeed, power flows computed in the post-islanding state demonstrate the feasibility of these results. Note that the machines are not equipped with governors. In practical implementations, control measures, such as fast valving, can be applied to decrease the frequency deviations.

We now compare the quality of the islanding solution determined by the proposed methodology, which was found in few milliseconds, with the optimal solution, which

cannot be found in general in polynomial time [18]. The theoretical lower bound (defined by the eigenvalue $v_2/2$ of L_N [22]) establishes that the quality of the optimal solution (defined by the 'Cheeger inequality', see [22] for more details) is bounded to 99.87%, whereas the quality of our approximation was 99.84%.

4.2 Test case II: IEEE 118-bus system

We now test the proposed methodology using the IEEE 118-bus system. The dynamic data of the generators can be found in [11], and they are selected according to the typical generator data in [35]. The generators have also been equipped with governors. The governor model is taken from the Standard Models library in DIgSILENT PowerFactory and is gov_TGOV1.BlkDef, a steam turbine governor [32]. We consider that any line can be included in the cutset E_S , but transformers must be excluded from this.

Testing case description: We consider that at time t = 0 s, a three phase-to-ground fault occurs near bus 25 at line 23–25 and is cleared after local relays open the faulty line at 0.18 s. The swing trajectories obtained are shown in Fig. 7a. It can be seen that within a short time after the fault is cleared, the

generators are divided into two groups: $\{10, 12, 25, 26, 31\}$ and $\{46, 49, 54, 59, 61, 65, 66, 69, 80, 87, 89, 100, 103, 111\}$. As it can be observed in Figs. 7b and c, if the system is not split, the frequency of the generators in the first group considerably increases, the voltage magnitudes in major part of the network are significantly reduced, and, if no control actions are timely undertaken, the system quickly collapses.

In this case, the necessity to split the system is considered to be at 0.38 s. The islanding solution found by our methodology is illustrated in Fig. 8. Table 2 summarises the results of each island; the quality of this islanding solution is 99.65%. This solution was found in approximately 8.1 ms, and hence the islanding was undertaken at 0.3881 s. Fig. 9 shows the dynamic response of the power system in the post-islanding state. These results indicate that our methodology can effectively prevent the blackout. We can also see that two islands are successfully created with frequencies between 0.9987 and 1.0111 pu. Similar to the previous case, we use the power flows in the post-islanding state to check the feasibility of these results. It is important to mention that this test network has not been equipped with voltage regulators; thus, the voltage magnitudes shown




Fig. 9 Results for the IEEE 118-bus system with islanding

- a Generator rotor angle
- b Generator speed
- c Voltage magnitudes

Table 3 Results and comparison using the Great Britain network

No. of islands	Proposed methodology		Existing SCCI algorithm	
	Cut, MW	Quality, %	Cut, MW	Quality, %
2	1869	98.79	1869	98.79
3	1895	98.72	2167	95.06
4	3332	94.73	4204	93.69
5	5333	96.95	6318	95.06

in Fig. 9c are expected to be higher in the scenario where these controllers are used.

4.3 Test case III: reduced Great Britain network

We finally test the proposed methodology using a realistically sized power system, a static model of a reduced Great Britain network with 815 buses. Specifically, we study splitting into r islands for r=2, 3, 4, 5. These static simulations aim to demonstrate the scalability of our methodology, and to compare it with an existing SCCI algorithm [35]. Table 3 shows the total power flow disruption and the quality of each islanding solution, that is, $\min_{k=1,2,\ldots,r} (\phi(V_k))$, using both the proposed methodology and the SCCI algorithm in [13].

The results using our methodology are as good (when r=2) or significantly better (when r=3, 4, 5). It is important to note that our methodology improves the accuracy of the results (measured as the ratio between the total power flow disruption difference and the power flow disruption using the existing technique) in 12.6, 20.7 and 15.6% for the cases with r=3, 4 and 5, respectively.

4.4 Evaluating the computational efficiency of the proposed methodology

We list in Table 4 the computational time of our methodology, and compare it with an implementation of the SCCI algorithm of [13]. Our methodology has the key advantage of solving the associated 'eigenproblem' only once, even when multiple islands are to be created, which considerably accelerates the determination of an islanding solution, particularly when dealing with large-scale power systems, and potentially increases the quality of the islanding solution [18–22].

The runtime of our methodology is dominated by that of the 'eigendecomposition' of a real symmetric $n \times n$ matrix. Therefore, the theoretical computational complexity of our

Table 4 Computational time using both the proposed methodology and the existing SCCI algorithm (average runtime over 1000 instances with the same loading condition)

Test system	Runtime using the proposed methodology, s	Runtime using the existing SCCI algorithm, s
IEEE 39 ² IEEE 118 ² Great Britain-815 ² Great Britain-815 ³ Great Britain-815 ⁴ Great Britain-815 ⁵	0.0014 0.0081 1.1478 1.1638 1.1653 1.1753	0.0141 0.0455 7.3884 9.7664 9.9415 9.9901

The superscript indicates the number of created islands

methodology is approximately $O(n^3)$ [21], although it can be reduced to $O(n^{4/3})$ when utilising a sparse form of L_N [15].

The key message is that our methodology is capable of determining an islanding solution in real-time even for large-scale power systems, as we can see in Table 4. In fact, our methodology reduces by a factor of approximately ten the computational time with respect to the competing SCCI algorithm. Consequently, our methodology can meet the demand of real-time controlled islanding.

5 Discussion

The proposed ICI methodology can effectively prevent cascading outages leading to large-area blackouts by islanding the bulk network across the lines with reduced power flow following a severe disturbance, that is, it can find an islanding solution with minimal power flow disruption. Even though the new approach has significantly improved the voltages at all the system buses for the IEEE 39- and IEEE 118-bus test systems (see Figs. 6 and 9) compared to the uncontrolled separation, additional research is required to include voltage stability constraints in the formulation. This further improvement can help ensure that the power system will successfully operate after islanding actions are undertaken. In addition, post-islanding analyses and simulations are required in practical implementations of the new approach to evaluate its behaviour in these new cases.

The proposed ICI methodology can determine islanding solutions for any given number of islands, while ensuring that each island contains only coherent generators. Even though this approach enhances the transient stability of the islands [12], it cannot consider the location of the fault that has caused the loss of synchronism between the coherent groups of generators. Hence, additional investigations to consider the fault location could further improve the applicability of the new approach.

To enhance the transient stability of the future islands, our approach has followed current practices, and has considered the generator coherency constraint in the formulation. However, further research is required to consider the true transient stability constraint. This remains an open, extensive and exciting area of research.

Finally, the proposed ICI methodology has considered that the number of islands to be created is equal to the number of coherent groups of generators. Although this follows current practices, for example, [23, 24], it would be interesting to further investigate the applicability of the methodology for different number of islands. This is of particular interest as the number of coherent groups is not a necessarily unique solution [19] because of changes in system operating condition and network configuration, and this will have consequences for the islands obtained, and their quality.

6 Conclusions

This paper proposes a novel methodology, based on constrained spectral clustering, that determines an islanding solution for minimal power flow disruption, while ensuring that each island contains only coherent generators. It also enables operators to constrain any branch to be excluded from the islanding solution. The proposed methodology uses the first r eigenvectors of a normalised Laplacian matrix associated with the graph that represents the power flow of the power system, and this approach improves the

quality of the islanding solutions, compared to competing methods that use the unnormalised Laplacian matrix.

The new methodology has the key advantage that it solves the associated 'eigenproblem' only once, even when multiple islands are to be created. As we avoid 'recursive bisection', the methodology considerably accelerates the determination of an islanding solution and simultaneously improves its quality. Furthermore, our methodology defines the vectors representing the generation-nodes as centroids on the unit sphere in Euclidean space, and computes, just once, the distance only between the vectors representing load-nodes and the centroids. This reduces the order of the similarity matrix and avoids the use of iterative approaches. These two features also contribute accelerating the determination of an islanding solution.

The proposed methodology was tested and validated using dynamic models of the IEEE 39- and IEEE 118-bus test systems. Time-domain simulation results are used to demonstrate that our methodology can minimise the impact of cascading outages leading to blackouts. We have also presented static simulations on a reduced Great Britain network with 815 buses to demonstrate the scalability of our methodology, to show that it meets the real-time requirements of islanding methods even for large-scale power systems and to compare it with a competing algorithm. These simulations show that our methodology can be used with practical power systems to determine, in a limited timeframe, a good islanding solution, that is, a solution with small power flow disruption relative to the power in each island, and any given number of islands.

7 Acknowledgments

The authors would like to thank all the anonymous reviewers for their many valuable suggestions during the reviewing process. The first and fifth authors would like to thank the Engineering and Physical Science Research Council (EPSRC) grants EP/E009735/1 in the UK, and the Office of International Affairs and External Cooperation at the University of Costa Rica for their financial support. The second, third and fourth authors would like to acknowledge support by EPSRC grants EP/G059101/1 and EP/G060169/1.

8 References

- 1 Andersson, G., Donalek, P., Farmer, R., et al.: 'Causes of the 2003 major grid blackouts in North America and Europe, and recommended means to improve system dynamic performance', *IEEE Trans. Power Syst.*, 2005, 20, (4), pp. 1922–1928
- 2 Kundur, P., Taylor, C.: 'Blackout experiences and lessons, best practices for system dynamic performance, and the role of new technologies'. IEEE Task Force Report, 2007
- 3 Henner, V.E.: 'A network separation scheme for emergency control', Int. J. Electr. Power Energy Syst., 1980, 2, (2), pp. 109–114
- 4 Adibi, M.M., Kafka, R.J., Maram, S., Mili, L.M.: 'On power system controlled separation', *IEEE Trans. Power Syst.*, 2006, 21, (4), pp. 1894–1902
- 5 You, H., Vittal, V., Yang, Z.: 'Self-healing in power systems: an approach using islanding and rate of frequency decline-based load shedding', *IEEE Trans. Power Syst.*, 2003, 18, (1), pp. 174–181
- 6 Sun, K., Zheng, D., Lu, Q.: 'Splitting strategies for islanding operation of large-scale power systems using OBDD-based methods', *IEEE Trans. Power Syst.*, 2003, 18, (2), pp. 912–923
- 7 Zhao, Q., Zheng, D., Ma, J., Lu, Q.: 'A study of system splitting strategies for island operation of power system: a two-phase method

- based on OBDDs', $\it IEEE$ Trans. Power Syst., 2003, 18, (4), pp. 1556-1565
- 8 You, H., Vittal, V., Wang, X.: 'Slow coherency based islanding', *IEEE Trans. Power Syst.*, 2004, 19, (1), pp. 483–491
- 9 Xu, G., Vittal, V.: 'Slow coherency based cutset determination algorithm for large power systems', *IEEE Trans. Power Syst.*, 2010, **25**, (2), pp. 877–884
- Wang, C., Zhang, B., Hao, Z., et al.: 'A novel real-time searching method for power system splitting boundary', *IEEE Trans. Power Syst.*, 2010, 25, (4), pp. 1902–1909
- 11 Sun, K., Zheng, D., Lu, Q.: 'A simulation study of OBDD-based proper splitting strategies for power systems under consideration of transient stability', *IEEE Trans. Power Syst.*, 2005, 20, (1), pp. 389–399
- 12 Hao, L., Rosenwald, G.W., Jung, J., Liu, C.C.: 'Strategic power infrastructure defense'. Proc. of the IEEE, 2005, 93, (5), pp. 918–933
- 13 Ding, L., Gonzalez-Longatt, F., Wall, P., Terzija, V.: 'Two-step spectral clustering controlled islanding algorithm', *IEEE Trans. Power Syst.*, 2013, 28, (1), pp. 75–84
- 14 Machowski, J., Bialek, J.W., Bumby, J.R.: 'Power system dynamics stability and control' (John Wiley & Sons, West Sussex, 2008)
- Peiravi, A., Ildarabadi, R.: 'Comparison of computational requirements for spectral and kernel k-means bisection of power system', *Aust. J. Basic Appl. Sci.*, 2009, 3, (3), pp. 2366–2388
- 16 Leighton, T., Rao, S.: 'Multicommodity max-flow min-cut theorems and their use in designing approximation algorithms', J. ACM, 1999, 46, (6), pp. 787–832
- 17 Garey, M.R., Johnson, D.S.: 'Computers and intractability: a guide to the theory of NP-completeness' (Freeman, San Francisco, CA, 1979)
- 18 Von Luxburg, U.: 'A tutorial on spectral clustering', Stat. Comput., 2007, 17, (4), pp. 395–416
- 19 Ng, A.Y., Jordan, M.I., Weiss, Y.: 'On spectral clustering: analysis and an algorithm', Adv. Neural Inf. Process. Syst., 2002, 2, pp. 849–856
- 20 Wang, X., Davidson, I.: 'Flexible constrained spectral clustering'. 16th ACM SIGKDD Int. Conf. on Knowledge Discovery and Data Mining (KDD 2010), Washington DC, USA, 2010, pp. 563–572
- Wang, X., Qian, B., Davidson, I.: 'On constrained spectral clustering and its applications', *Data Min. Knowl. Discov.*, 2012, 28, (1), pp. 1–30
- 22 Lee, J.R., Gharan, S.O., Trevisan, L.: 'Multi-way spectral partitioning and higher-order Cheeger inequalities'. 44th Symp. on Theory of Computing, 2012, pp. 1117–1130
- 23 Franco, R., Sena, C., Taranto, G.N., Giusto, A.: 'Using synchrophasors for controlled islanding a prospective application for the Uruguayan power system', *IEEE Trans. Power Syst.*, 2013, 28, (2), pp. 2016–2024
- 24 Ariff, M.A.M., Pal, B.C.: 'Coherency identification in interconnected power system an independent component analysis approach', *IEEE Trans. Power Syst.*, 2013, 28, (2), pp. 1747–1755
- 25 Terzija, V., Wall, P., Quirós-Tortós, J., Norris, S., Bialek, J.: 'Preventing cascading outages by intentional controlled islanding'. IEEE PES General Meeting, Vancouver, 2013
- 26 Quirós-Tortós, J., Panteli, M., Terzija, V., Crossley, P.: 'On evaluating the performance of intentional controlled islanding schemes'. IEEE PES General Meeting, Vancouver, 2013, pp. 1–6
- 27 Pourbeik, P., Kundur, P., Taylor, C.W.: 'The anatomy of a power grid blackout root causes and dynamics of recent major blackouts', *IEEE Power Energy Mag.*, 2006, 4, (5), pp. 22–29
- 28 Quirós-Tortós, J., Terzija, V.: 'Controlled islanding strategy considering power system restoration constraints'. IEEE PES General Meeting, San Diego, 2012, pp. 1–8
- 29 Juarez, C., Messina, A.R., Castellanos, R., Espinosa-Perez, G.: 'Characterization of multi-machine system behavior using a hierarchical trajectory cluster analysis', *IEEE Trans. Power Syst.*, 2011, 26, (3), pp. 972–981
- 30 Sánchez-García, R., Fennelly, M., Norris, S., et al.: 'Hierarchical spectral clustering of power grids', IEEE Trans. Power Syst., 2014, 29, (5), pp. 2229–2237
- 31 Okabe, A., Boots, B., Sugihara, K., Chiu, S.N.: 'Spatial tessellations: concepts and applications of Voronoi diagrams' (John Wiley & Sons, England, 2000, 2nd edn.)
- 32 DIgSILENT PowerFactory, ed. Heinrich-Hertz-Straße, Germany
- 33 MATLAB R2010a: Natick, Massachusetts: The MathWorks Inc., 2010
- 34 IEEE PES PSDPC SCS. (2013, October). Power System Test Cases. Available at: http://www.sel.eesc.usp.br/ieee/
- 35 Anderson, P.M., Fouad, A.A.: 'Power system control and stability' (IEEE Press, New York, 2003, 2nd edn.)