Form 72—fire hydrant and sprinkler system periodic testing and maintenance

This form is to be used for the purposes of maintenance to water based fire safety installations, as required by the Queensland Development Code – Mandatory Part (MP) 6.1, which is a building assessment provision under the *Building Act 1975*, section 30. This form is also to be used in accordance with the 'Fire hydrant and sprinkler system commissioning and periodic maintenance procedure', defined in MP 6.1 as the 'Relevant procedure'. Please note that this form does not comprise all maintenance requirements—this form is only for collecting results for maintenance for some sections of the Australian Standards referred to and in each case, further testing is required.

Part A—Test details

Site name	Shangri-La Hotel - Pierpoint Road Cairns
Site address	Pierpoint Road Shangri-La Hotel - Pierpoint Road Cairns
Contractor	Lewie Fire Protection Pty Ltd

Test details

Test date: 28/04/2026

Time: 09:15 AM

Maintenance test:

no service level ☐

	Annual	5 year
fire hose reel	☐	☐
fire hydrant	☐	☐
fire sprinkler	☑	☐
combined	☐	☐

Part B—Hydrant hydrostatic test PASS ☐ FAIL ☐

Refer to the required pressure specification for periodic testing (as applicable) as per AS2419.1 or AS1851.

Boost pressure	kPa	**Test pressure**	kPa		
Duration of test	mins	**End of test pressure**	kPa	**Loss (if any):**	L/min

Comments:

Part C—Hydrant test equipment/pressure gauges

If using more devices, provide details in the Notes section below or complete another form. The correction factor must be kPa or a percentage.

Flow measuring device	Orifice ☐ Part C not required for orifice testing	Mechanical ☐ Calibrated:	Electro magnetic ☐ Calibrated:

	Device/gauge 1	Device/gauge 2	Device/gauge 3	Device/gauge 4
Serial number				
Date calibrated				
Correction certificate				
65/100/150 mm face				
Digital reader				
Increments (kPa)				

☑ **Please tick if Calibration Certificate attached to Job Number**

Part D—Hydrant system flow test			PASS ☐		FAIL ☐	
This part relates to tests under Section 4 of AS1851. If pressure/flow rates do not meet the fire system design criteria and there are no on-site problems, contact the relevant water service provider to ascertain if there are any problems with the water system network. In the table below, please record the pressure readings obtained during the hydrant system flow test.						
Hydrant 1 location			Hydrant 3 location			
Hydrant 2 location			Hydrant 4 location			
System requirements	L/s at kPa		Static pressure	kPa		
On-site pump set installed		Yes ☐		No ☐		
Pressure zone number:	**Size/flow rate**	**Device/gauge no. (Part C)**	**Hydrant 1 only**	**Hydrants 1 and 2**	**Hydrants 1, 2 and 3**	**Hydrants 1, 2, 3 and 4**
Nozzles	19 mm		kPa	kPa	kPa	kPa
	22 mm		kPa	kPa	kPa	kPa
	25 mm		kPa	kPa	kPa	kPa
Other portable testing devices	L/sec		kPa	kPa	kPa	kPa
	L/sec		kPa	kPa	kPa	kPa
	L/sec		kPa	kPa	kPa	kPa
	L/sec		kPa	kPa	kPa	kPa
	L/sec		kPa	kPa	kPa	kPa
	System achieved: L/sec at kPa					
Comments:						

Part E—Pump appliance booster test		PASS ☐	FAIL ☐
This part relates to sections 10.4 and 10.5 of AS2419.1 and for tests under Section 4 of AS1851. If pressure/flow rates do not meet the fire system design criteria and there are no on-site problems, contact the relevant water service provider to ascertain if there are any problems with the water system network. In the table below, please record the pressure readings obtained during the pump appliance booster test.			
Hydrant locations		Height of highest hydrant above booster	m
System requirements	L/s at kPa	Static pressure	kPa
Pump inlet pressure	kPa	Pump discharge pressure	kPa
Boost pressure		Calculated frictional loss	kPa
Comments:			

Part F—Sprinkler hydrostatic test		**PASS** ☐	**FAIL** ☐
Relevant required pressure specification in AS2118.1, AS2118.4 and AS2118.6.			
Pressure	kPa	Time held	mins
Comments:			

Part G—Sprinkler system flow test				
This section is to be used for sections 4.14 of AS2118.1-1999, 4 of AS2118.6-2012 and 6.2 of AS2118.4-2012 and section 2 of AS1851. Notes: (1) For AS2118.1 and AS2118.6 systems, multiple testing points may be required. (2) For AS2118.4, a simulated running test may be required for systems without a flow measuring device, in which the test involves opening a valve to discharge a volume of water that is accepted as being in excess of the design flow. System test points shall be noted for each different system and its location and descriptor.				
	System specifications (block plan): Ordinary Hazar...		**Test results:** PASS	
Test point 1	Location	Sprinkler valve room		
	Required flow rate	624L/min	Pass ☑ Fail ☐	665L/min
	Required pressure	446kPa	Pass ☑ Fail ☐	605kPa
Test point 2	Location			
	Required flow rate	L/min	Pass ☐ Fail ☐	L/min
	Required pressure	kPa	Pass ☐ Fail ☐	kPa
Running test	Installation gauge pressure:	535kPa		
Comments:				

Part H—Compliance			
Critical defects identified	Yes	☐	Give owner/occupier a critical defect notice
	No	☑	No action required in relation to critical defects at this time
Repairs/corrective actions taken	Yes	☐	Attach details (including action and date taken) as part of Licensee's report
	No	☑	No action required in relation to repairs/corrective actions at this time
System	Pass	☑	
	Fail	☐	

Comments:

Part I—Signature

By signing this Form 72, I confirm that the information contained herein is correct to the best of my knowledge given the information available and that this Form 72 has been completed in accordance with the relevant standards, codes and regulations.

Licensee name	Ronald Kaldenbach	**Licensee signature**	RKJ
Licence no. (QBCC/PIC)	PD23172	**Licensee report no.**	98745

Note: Building owners/occupiers are responsible for ensuring their buildings continuously meet fire safety standards. Where a building owner/occupier becomes aware that their building does not meet the minimum requirements for water pressure required by any standard applicable under the Queensland Development Code Mandatory Part 6.1 (Maintenance of fire safety installations) the building owner/occupier should contact the Queensland Fire and Emergency Service.

Definitions → *"Maintenance test"* means a test that is required under a maintenance standard such as AS1851. *"Running test"* means a two inch waste test installed at the sprinkler control valve on older systems.

Privacy: The information on this form is collected for purposes related to monitoring compliance under the *Plumbing and Drainage Act 2002*, the *Building Act 1975* and the *Building Fire Safety Regulation 2008* ("legislation"). This information may be stored in the department's database and may be used for statistical research, information provision and evaluation of Plumbing Industry Council and state government services. Your personal information may be disclosed to other government agencies, local government authorities and third parties for purposes related to this application. Except for these circumstances, personal information will only be disclosed to third parties with your consent or in accordance with the *Information Privacy Act 2009*.

RTI: The information collected on this form will be retained as required by the *Public Records Act 2002* and other relevant Acts and regulations, and is subject to the Right to Information regime established by the *Right to Information Act 2009*. If you have any further questions regarding your privacy, please email Building Codes Queensland on buildingcodes@qld.gov.au. Published by the Queensland Government July 2014, 41 George Street, Brisbane QLD 4000.