



ASSET RECORD FOR JOB No. 97387

Inspection date: 30/03/2026

Purchase Order:

Customer name: Shangri-La Hotel Cairns

Email: michelle.davis@shangri-la.com

Site name: Shangri-La Hotel - Pierpoint Road Cairns

Site address: Pierpoint Road , Cairns QLD 4870

Contact: Michelle Davis

Asset Register - 04.5 Electric Pumps - AS1851.2012

Asset ID	Building Location	Pump Number	Equipment Number	Site Name and Simpro Number	Location of Pump	Service Level	Date	Pass / Fail
93649	Shangri-la hotel	1	93649	Shangri-la	Basement car park sprinkler valve room	Monthly	30/03/2026	Fail
Test Readings							Result	
Work Order Number							MAR 26 SM MECH (M)	
Site Attendance Record Number							A 106714	
TABLE 3.4.1 MONTHLY ROUTINE SERVICE SCHEDULE - FIRE PUMPSETS ELECTRICAL							2026-03-30	
--- 1.1 Pump areas - (a) CHECK that pump areas are unobstructed, not used for storage and lighting is adequate.							Pass	
--- 1.1 Pump areas - (b) Where pump pressure-relief valves are fitted, CHECK that discharge will not cause flooding or water damage.							Pass	
--- 1.2 Signage and ID plates per AS 2941 (where applicable) - (a) CHECK that each pumpset has a clearly visible warning sign stating 'Danger this Pump Starts Automatically'.							Fail	
--- 1.2 Signage and ID plates per AS 2941 (where applicable) - (b) CHECK that there are readily seen and clearly legible ID plates on each controller, driver (diesel and electric), pumpset (on base plate) and pump (on the pump).							Fail	
--- 1.2 Signage and ID plates per AS 2941 (where applicable) - (c) CHECK each pump controller is labelled 'Fire Pump Controller', has clear operating instructions posted, has all operating components clearly identified, and has all indicating lights clearly labelled.							Pass	
--- 1.3 Pump water supply valves - CHECK that all valves are in the open position or the closed position, as labelled, and secured, where applicable.							Fail	
--- 1.4 Pressure Gauges - CHECK that all pressure gauges are reading within the ranges indicated on the pressure gauge schedule. Record pressure.							Fail	
--- 1.4 Pressure Gauges - CHECK that all pressure gauges are reading within the ranges indicated on the pressure gauge schedule. Record pressure. - Pump Suction (kPa)							660	
--- 1.4 Pressure Gauges - CHECK that all pressure gauges are reading within the ranges indicated on the pressure gauge schedule. Record pressure. - Pump Discharge (kPa)							850	
--- 1.5 Water supply tank (if installed) - Perform routine service in accordance with Section 5.							N/A	
--- 1.6 General inspection - CHECK for any obvious signs of physical damage or deterioration. - Electric							Pass	
--- 1.6 General inspection - CHECK for any obvious signs of physical damage or deterioration. - Jacking							Pass	
--- 1.6 General inspection - CHECK for any obvious signs of physical damage or deterioration. - Jockey							N/A	
--- 1.15 Electric motor driven pumpset— Precautions - Prior to commencing any test function: (a) CHECK all safety guards are in place and secure.							Pass	
--- 1.15 Electric motor driven pumpset— Precautions - Prior to commencing any test function: (b) CHECK enclosure for corrosion and ingress of water, dust or insects.							Pass	
--- 1.16 Pump controller status - CHECK that the main isolating switch is in the ON position and secured in position where facilities are provided and, where fitted, the green power supply lamps are illuminated and that no red warning lamps are on. Ensure all lights are functional by pressing the lamp test button, where fitted.							Pass	
--- 1.17 Pump starting devices - (a) START each pumpset by reducing the applied water pressure to the starting device and run motor continuously for at least 3 minutes.							Pass	
--- 1.17 Pump starting devices - (a) START each pumpset by reducing the applied water pressure to the starting device and run motor continuously for at least 3 minutes. - Record Number of automatic starting devices.							1	
--- 1.17 Pump starting devices - (b) RESTART each pumpset using the manual starting device and run motor continuously for at least 3 minutes.							Pass	
--- 1.17 Pump starting devices - (b) RESTART each pumpset using the manual starting device and run motor continuously for at least 3 minutes. - Record Number of Manual starting devices.							1	
--- 1.17 Pump starting devices - (c) RECORD the starting pressures and the run time at the completion of the test. - Starting pressure (kPa)							550	
--- 1.17 Pump starting devices - (c) RECORD the starting pressures and the run time at the completion of the test. - Total Run time (Minutes)							6 min	
--- 1.18 Run test checks - During and after the running period CHECK: (a) Pump operates at the correct discharge pressures allowing for varying suction conditions. Record suction and discharge pressure.							Pass	



ASSET RECORD FOR JOB No. 97387

Inspection date: 30/03/2026

Purchase Order:

Customer name: Shangri-La Hotel Cairns

Email: michelle.davis@shangri-la.com

Site name: Shangri-La Hotel - Pierpoint Road Cairns

Site address: Pierpoint Road , Cairns QLD 4870

Contact: Michelle Davis

Test Readings	Result
--- 1.18 Run test checks - During and after the running period CHECK: (a) Pump operates at the correct discharge pressures allowing for varying suction conditions. Record suction and discharge pressure. - Pump Suction (kPa)	650
--- 1.18 Run test checks - During and after the running period CHECK: (a) Pump operates at the correct discharge pressures allowing for varying suction conditions. Record suction and discharge pressure. - Pump Discharge (kPa)	1200
--- 1.18 Run test check - During and after the running period CHECK (if applicable): (a) (i) - Pressure Relief Valve operates at the correct pressure. Record PRV pressure. (kPa)	1100
--- 1.18 Run test checks - (b) Pump glands and drain or mechanical seal(s) operate efficiently.	N/A
--- 1.18 Run test checks - (c) Out-of-balance condition or abnormal noises are not evident.	Pass
--- 1.18 Run test checks - (d) Both local and remote 'pump running' alarms and lights operate. - Local.	Pass
--- 1.18 Run test checks - (d) Both local and remote 'pump running' alarms and lights operate. - Remote.	Pass
--- 1.19 Controller batteries - (a) CHECK battery complies with details on identification plate fitted to the enclosure.	N/A
--- 1.19 Controller batteries - (b) CHECK battery for corrosion, physical damage and security.	Pass
--- 1.19 Controller batteries - (c) CHECK battery enclosure for corrosion, and the ingress of water, dust and insects.	Pass
--- 1.19 Controller batteries - (d) CHECK float voltage of the battery and record.	Pass
--- 1.19 Controller batteries - (d) CHECK float voltage of the battery and record. - (Volts)	N/A
--- 1.20 Restoration to operational condition all pumpsets - After completion of testing procedures, RETURN all equipment to the operational condition.	Pass
TABLE 3.4.5.1 MONTHLY ROUTINE SERVICE SCHEDULE - FIRE PUMPSETS - JACKING PUMPSETS	2026-03-30
--- 5.1 Pump areas - (a) CHECK that pump areas are unobstructed, not used for storage and lighting is adequate.	Pass
--- 5.1 Pump areas - (b) Where pump pressure-relief valves are fitted, CHECK that the discharge will not cause flooding or water damage.	Pass
--- 5.1 Pump areas - (c) CHECK for any obvious signs of physical damage or deterioration and that all safety guards are in place and secure.	Fail
--- 5.2 Valves - ENSURE that all valves are in the open position or the closed position, as labelled, and secured where applicable.	Pass
--- 5.3 Water supply tank (where fitted) - CHECK that the water supply tank is full.	N/A
--- 5.4 Pump controller status - CHECK that the main isolating switch is in the on position and secured (where facilities are provided), the green power supply lamps are illuminated and that no red warning lamps are on. Ensure all lights are functional by pressing the lamp test button, where fitted.	Pass
--- 5.5 Pump - (a) VERIFY operation (manual and automatic).	Pass
--- 5.5 Pump - b) RECORD cut-in and cut-out pressures. - CUT IN (kPa)	950
--- 5.5 Pump - b) RECORD cut-in and cut-out pressures. - CUT OUT (kPa)	1150
--- 5.5 Pump - (c) Jacking/Jockey Pump Counter Reading:	118
Have all previously reported defects been rectified	No
Queensland Buildings Only: I hereby acknowledge that the mentioned system above has been routinely serviced in accordance with Australian Standard AS1851-2012 Amendment 1 & AS2293.2 and that the information on this report is true and correct. This record does not infer compliance of all applicable building and fire legislation within the relevant jurisdiction - Queensland Buildings Only - Maintenance complies with QDC, MP6.1:	Yes
Queensland Buildings Only: I hereby acknowledge that the mentioned system above has been routinely serviced in accordance with Australian Standard AS1851-2012 Amendment 1 & AS2293.2 and that the information on this report is true and correct. This record does not infer compliance of all applicable building and fire legislation within the relevant jurisdiction - Queensland Buildings Only - System is in proper working order:	Yes

Notes	
	monthly testing complete
	Previously reported and quote has been approved awaiting material
	Defects as per below-
	-5.1 Jacking pump housing has heavy corrosion. Will monitor
	-Pressure relief valve was not operating. Adjusted valve and is now relieving. Recommended overhaul of pressure relief valve. Dorot 50mm
	Recommend a Circulation relief valve be installed to prevent possible damage to pump in the event of pressure relief failure.



ASSET RECORD FOR JOB No. 97387

Inspection date: 30/03/2026

Purchase Order:

Customer name: Shangri-La Hotel Cairns

Email: michelle.davis@shangri-la.com

Site name: Shangri-La Hotel - Pierpoint Road Cairns

Site address: Pierpoint Road , Cairns QLD 4870

Contact: Michelle Davis

Circulation relief valves on fire pumps are a requirement of AS2941
-Jacking pump 25mm suction valve spindle has broken. Require new valve
-No labels on valves
-No this pump may start automatically sign
-No pump duty details on base of pump
-incorrect installed PRV- wrong side of check valve

Annual defects

1.3 no valve list

1.3 no Pressure schedule

All works above have been carried out in accordance with the relevant Australian Standards, Codes of Practice and the information on this data report is true and correct. This record does not infer compliance with all applicable building and fire safety legislation within the relevant jurisdiction.

Technician (Print Name): Paul Bartlett

Licence No.

Customer (Print Name):

15151897

Technician (Signature):

Customer (Signature):