

Lewie Fire Protection
4 Schmid Street
Garbutt, 4814
Ph: 07 4728 3622 Fax:
ABN 18 146 907 511

Asset Record - Job No. 79184
Shangri-La Hotel - Pierpoint Road Cairns
Pierpoint Road
Cairns QLD 4870

Inspection Date: 29/01/2025
Contact: Michelle Davis
Phone:

Asset Register - 06.1 Passive Fire and Smoke Systems - Fire Resistant Doorsets - AS1851.2012									
Asset ID	Location	Equipment Number	Door Number	Building Number	Door Type	Tag Number	Date	Service	Pass / Fail
96780	Shopping centre nest to hotel lobby	.	1707	.	Sliding door	.	29/01/2025	3 Monthly	Fail
Test Readings	Attendance Record No. (If Applicable):								
Failure Points	2.1 - other - 12.4.3.2								
Notes	Unable to test due to door switch not being accessible/installed.								
96782	Shopping centre to lobby	.	1708	.	Sliding door	.	29/01/2025	3 Monthly	Fail
Test Readings	Attendance Record No. (If Applicable):								
Failure Points	2.1 - other - 12.4.3.2								
Notes	Unable to test due to door switch not being accessible.								

Description Of Work
2 sliding doors within the reception

Comments / Recommendations

All works above have been routinely serviced and maintained in accordance with AS1851.2012 amendment 1 & AS2293.2 and the information on this data report is true and correct. This record does not infer compliance with all applicable building and fire safety legislation within the relevant jurisdiction.

Technician (Print Name): Aaron Nixon



Technician (Signature):

Licence No. 1250392

Customer (Print Name):

Customer (Signature):