

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622 Fax:
 ABN 18 146 907 511

Asset Record - Job No. 83387
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 05/06/2025
Contact: Michelle Davis
Phone:

Asset Register - 02.5 Ansul System - AS3772									
Asset ID	Equipment Number	Type	Make	Manufacture Date	Location	Nitrogen Cartridge Replacement Date	Date	Service	Pass / Fail
99266		Ansul R102-kitchen hood system	ANSUL	2013	Main Kitchen Lvl 1	01/05/2013	05/06/2025	Yearly	Fail
Test Readings	Log Book Entry Number:			Have all previously reported defects been rectified: No					
Failure Points	1.1 Other								
Notes	Pulled through new cable as existing was damaged and frayed. System requires PT of cylinders(4), replacement of ANSULEX, pressure test of regulators, replacement of all blow off Caps(18). Requires access to plenum to clean and replace nozzles. Requires testing of activation to confirm shut down of supply air to kitchen. Require confirmation of nozzle placement and type for each area.								
103786	Backyard Kitchen	ANSUL R-102 system	R102	3 x cylinder 8/2022	Backyard kitchen	01/05/2022	05/06/2025	Yearly	Fail
Test Readings	Log Book Entry Number:			Have all previously reported defects been rectified: No					
Failure Points	1.1 Other								
Notes	Replaced all fusible links. Requires new caps-9 needed verify layout. Requires new discharge hoses x 3								

Description Of Work

Asset ID 99266 - Asset Type 02.5 Ansul System - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2025

Comments / Recommendations

Lewie Fire Protection
4 Schmid Street
Garbutt, 4814
Ph: 07 4728 3622 Fax:
ABN 18 146 907 511

Asset Record - Job No. 83387
Shangri-La Hotel - Pierpoint Road Cairns
Pierpoint Road
Cairns QLD 4870

Inspection Date: 05/06/2025
Contact: Michelle Davis
Phone:

All works above have been routinely serviced and maintained in accordance with AS1851.2012 amendment 1 & AS2293.2 and the information on this data report is true and correct. This record does not infer compliance with all applicable building and fire safety legislation within the relevant jurisdiction.

Technician (Print Name): Aaron Nixon

Licence No.

Customer (Print Name):

1250392

Technician (Signature):



Customer (Signature):