

Lewie Fire Protection
4 Schmid Street
Garbutt, 4814
Ph: 07 4728 3622
ABN 18 146 907 511

Asset Record - Job No. 91600
Shangri-La Hotel - Pierpoint Road Cairns
Pierpoint Road
Cairns QLD 4870

Inspection Date: 27/10/2025
Contact: Michelle Davis
Phone:

Asset Register - 02.5 Ansul System - AS3772									
Asset ID	Equipment Number	Type	Make	Manufacture Date	Location	Nitrogen Cartridge Replacement Date	Date	Service	Pass / Fail
99266	1F Shangri-La Main Kitchen	Ansul R102-kitchen hood system	ANSUL	2025	Main Kitchen Lvl 1	01/05/2025	27/10/2025	6 Monthly	Pass
Test Readings	Log Book Entry Number:			Have all previously reported defects been rectified: Yes					
Notes	All items passed service level.								
	Recommend replacement of manual pull stations to newer model.								
103786	GF The Backyard Kitchen	ANSUL R-102 system	R102	3 x cylinder 8/2022	Backyard kitchen	01/05/2022	27/10/2025	6 Monthly	Pass
Test Readings	Log Book Entry Number:			Have all previously reported defects been rectified: Yes					
Notes	Completed 6 monthly service task no faults to report								

Description Of Work
Asset ID 99266 - Asset Type 02.5 Ansul System - Service Level 6 Monthly - Service Due Date 01/10/2025

Comments / Recommendations

Lewie Fire Protection
4 Schmid Street
Garbutt, 4814
Ph: 07 4728 3622
ABN 18 146 907 511

Asset Record - Job No. 91600
Shangri-La Hotel - Pierpoint Road Cairns
Pierpoint Road
Cairns QLD 4870

Inspection Date: 27/10/2025
Contact: Michelle Davis
Phone:

All works above have been routinely serviced and maintained in accordance with AS1851.2012 amendment 1 & AS2293.2 and the information on this data report is true and correct. This record does not infer compliance with all applicable building and fire safety legislation within the relevant jurisdiction.

Technician (Print Name):	Aaron Nixon	Licence No.	Customer (Print Name):
		1250392	
Technician (Signature):			Customer (Signature):