

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98772
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset Register - 05.2 Portable Hydrants - AS1851.2012 A1									
Asset ID	Location	Equipment Number	Type / Make	LFP Equipment Number	Hydrant Stand Pipe Size	Hydrant Valve Pipe Connection	Date	Service	Pass / Fail
93804	Car park near lifts	83448	MFA	83448	100mm	Roll Grooved on Copper Pipe	13/04/2026	Yearly	Fail
Test Readings	Site Attendance Record Number (If applicable) ::								
Failure Points	0.3 - Other (Non Conformance) - 4.4.3								
Notes	Annual testing completed								
	Requires 100mm around handle. 65mm m&f needed to repair and drain down.								
93805	Car park west wall	83410	MFA	83410	100mm	Roll Grooved on Steel Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93806	Car park Nth wall	83420	MFA	83420	100mm	Roll Grooved on Steel Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93807	Car park Nth east wall	83409	MFA	83409	100mm	Roll Grooved on Steel Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93808	Car park near park 90 in cupboard	83429	MFA	83429	100mm	Roll Grooved on Steel Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93809	Car park cupboard between parks 40 & 101	83439	MFA	83439	100mm	Roll Grooved on Steel Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93810	Ground floor cupboard centre of atrium	83418	MFA	83418	100mm	Roll Grooved on Steel Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93811	Nth entrance to shons	83428	MFA	83428	100mm	Roll Grooved on Steel Pipe	13/04/2026	Yearly	Pass

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98772
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93812	Booster cupboard	83437	MFA FEED HYD	83437	150mm	Threaded on Steel Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93813	Booster cabinet	83417	MFA FEED HYD	83417	150mm	Threaded on Steel Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93814	Booster cabinet	83427	MFA FEED HYD	83427	150mm	Threaded on Steel Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93815	Booster cabinet	83438	MFA FEED HYD	83438	150mm	Threaded on Steel Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93816	Booster cabinet	83406	Sprinkler Booster rear entry MFA	83406	100mm	Roll Grooved on Steel Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93817	Booster cabinet	83416	Sprinkler booster rear entry MFA	83416	100mm	Roll Grooved on Steel Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93818	Booster cabinet	83447	HYD booster rear entry MFA	83447	100mm	Roll Grooved on Steel Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93819	Booster cabinet	83407	HYD booster rear entry MFA	83407	100mm	Roll Grooved on Steel Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93820	Ground floor inside cabinet Nth east	83436	MFA	83436	100mm	Threaded on Steel Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98772
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset Register - 05.2 Portable Hydrants - AS1851.2012 A1									
Asset ID	Location	Equipment Number	Type / Make	LFP Equipment Number	Hydrant Stand Pipe Size	Hydrant Valve Pipe Connection	Date	Service	Pass / Fail
93821	Ground floor outside Nth east entrance in cupboard	83426	MFA	83426	80mm	Threaded on Copper Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93822	Ground floor east entrance outside deck	78319	MFA	78319	100mm	Roll Grooved on Steel Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93823	Ground floor fire exit opposite oiled massage	83425	MFA	83425	100mm	Roll Grooved on Steel Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93824	Staff access to mezzanine	83446	MFA	83446	80mm	Threaded on Copper Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93825	Mezzanine level passage next to HP Accounting	83414	MFA	83414	80mm	Threaded on Copper Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93826	Mezzanine level adjacent fire door	83403	MFA	83403	80mm	Threaded on Copper Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93827	Main entrance to shops from car park	83445	MFA	83445	100mm	Threaded on Steel Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98772
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset Register - 05.2 Portable Hydrants - AS1851.2012 A1									
Asset ID	Location	Equipment Number	Type / Make	LFP Equipment Number	Hydrant Stand Pipe Size	Hydrant Valve Pipe Connection	Date	Service	Pass / Fail
93828	Behind shangri-la reception	83424	MFA	83424	100mm	Threaded on Copper Pipe	13/04/2026	Yearly	Fail
Test Readings	Site Attendance Record Number (If applicable) ::								
Failure Points	0.3 - Other (Non Conformance) - 4.4.3								
Notes	Annual testing completed Requires 100mm clearance around handle Requires 65mm m&f and drain down.								
93829	Level 4 Adjacent room 4007	83600	HYD MFA	83600	80mm	Threaded on Copper Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93830	Level 3 adjacent room 3008	83570	HYD MFA	83570	100mm	Threaded on Copper Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93831	Level 4 adjacent room 4003	83434	HYD MFA	83434	100mm	Roll Grooved on Steel Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93832	Level 3 adjacent room 3003	83423	HYD MFA	83423	100mm	Roll Grooved on Steel Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93833	Level 2 near room 2065	83433	HYD MFA	83433	100mm	Threaded on Copper Pipe	14/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93834	Level 2 opposite room 2083	83443	HYD MFA	83443	100mm	Threaded on Copper Pipe	14/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93835	Level 2 opposite room 2097	83402	HYD MFA	83402	100mm	Threaded on Copper Pipe	14/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98772
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset Register - 05.2 Portable Hydrants - AS1851.2012 A1									
Asset ID	Location	Equipment Number	Type / Make	LFP Equipment Number	Hydrant Stand Pipe Size	Hydrant Valve Pipe Connection	Date	Service	Pass / Fail
93836	Level 2 near room 2107	83412	HYD MFA	83412	100mm	Threaded on Copper Pipe	14/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93837	Roof space top of stair 9	83441	HYD MFA	83441	80mm	Threaded on Copper Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93838	Roof space top of stair 8	83411	HYD MFA	83411	80mm	Threaded on Copper Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93839	Roof space stairs 4	83591	HYD MFA	83591	100mm	Threaded on Copper Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93840	Roof space top of stair 2	83589	HYD MFA	83589	80mm	Threaded on Copper Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93841	Level 2 near room 2001	83519	HYD MFA	83519	100mm	Threaded on Copper Pipe	14/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93842	Level 2 opposite room 2014	83508	HYD MFA	83508	100mm	Threaded on Copper Pipe	14/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93843	Level 2 opposite room 2029	83518	HYD MFA	83518	100mm	Threaded on Copper Pipe	14/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93844	Level 2 opposite room 2044	83530	HYD MFA	83530	100mm	Threaded on Copper Pipe	14/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98772
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Notes	Annual testing completed								
93845	Level 2 opposite room 2056	83502	HYD MFA	83502	100mm	Threaded on Copper Pipe	14/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93846	Level 1 opposite room 1080	83513	HYD MFA	83513	100mm	Threaded on Copper Pipe	14/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93847	Level 1 near room 1062	83503	HYD MFA	83503	100mm	Threaded on Copper Pipe	14/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93848	Level 1 opposite room 1053	83507	HYD MFA	83507	100mm	Threaded on Copper Pipe	14/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93849	Level 1 opposite room 1041	83529	HYD MFA	83529	100mm	Threaded on Copper Pipe	14/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93850	Level 1 opposite room 1026	83528	HYD MFA	83528	100mm	Threaded on Copper Pipe	14/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93851	Level 1 opposite room 1011	83549	HYD MFA	83549	100mm	Threaded on Copper Pipe	14/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93852	Level 1 near 1003	83521	HYD MFA	83521	100mm	Threaded on Copper Pipe	14/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93853	Level 1 near lift near Government office	83539	HYD MFA	83539	100mm	Threaded on Copper Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98772
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset Register - 05.2 Portable Hydrants - AS1851.2012 A1									
Asset ID	Location	Equipment Number	Type / Make	LFP Equipment Number	Hydrant Stand Pipe Size	Hydrant Valve Pipe Connection	Date	Service	Pass / Fail
93854	Level 1 walkway to kitchen from pool	83401	HYD MFA	83401	100mm	Threaded on Copper Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93855	Level 1 opposite room 1088	83516	HYD MFA	83516	100mm	Threaded on Copper Pipe	14/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93856	Mezzanine opposite room 10	83525	HYD SRI	83525	100mm	Roll Grooved on Steel Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93857	Mezzanine opposite room 21	83547	HYD MFA	83547	80mm	Threaded on Copper Pipe	13/04/2026	Yearly	Fail
Test Readings	Site Attendance Record Number (If applicable) ::								
Failure Points	0.3 - Other (Non Conformance) - 4.4.3								
Notes	Annual testing completed								
	Handle requires 100mm clearance Requires 65mm m&f and drain down								
93858	Mezzanine opposite room 28	83523	HYD SRI	83523	100mm	Roll Grooved on Steel Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93859	Mezzanine opposite room 35	83535	HYD SRI	83535	100mm	Roll Grooved on Steel Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93860	Mezzanine next to room 38	83532	HYD MFA	83532	100mm	Roll Grooved on Steel Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93861	Mezzanine nea room 45	83545	HYD MFA	83545	100mm	Roll Grooved on Steel Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								

Lewie Fire Protection

4 Schmid Street
Garbutt, 4814
Ph: 07 4728 3622
ABN 18 146 907 511

Asset Record - Job No. 98772

Shangri-La Hotel - Pierpoint Road Cairns
Pierpoint Road
Cairns QLD 4870

Inspection Date: 14/04/2026

Contact: Michelle Davis

Phone:

Notes	Annual testing completed								
93862	Mezzanine Events area next to stair 5	83593	HYD SRI	83593	100mm	Roll Grooved on Steel Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93863	Mezzanine Trinity room 2 at events	83533	HYD MFA	83533	100mm	Threaded on Copper Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
93864	Mezzanine Adjacent staff lunch room	82990	HYD MFA	82990	80mm	Threaded on Copper Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
102668	Mezzanine level outside stair 8	78320	Old MFA	78320	100mm	Threaded on Copper Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								
139668	Adjacent helipad ground floor deck in cupboard	86115	MFA HYD	86115	80mm	Threaded on Copper Pipe	13/04/2026	Yearly	Pass
Test Readings	Site Attendance Record Number (If applicable) ::								
Notes	Annual testing completed								

Description Of Work

Asset ID 93804 - Asset Type 05.2 Portable Hydrants - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2026
 Asset ID 93805 - Asset Type 05.2 Portable Hydrants - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2026
 Asset ID 93806 - Asset Type 05.2 Portable Hydrants - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2026
 Asset ID 93807 - Asset Type 05.2 Portable Hydrants - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2026
 Asset ID 93808 - Asset Type 05.2 Portable Hydrants - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2026
 Asset ID 93809 - Asset Type 05.2 Portable Hydrants - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2026
 Asset ID 93810 - Asset Type 05.2 Portable Hydrants - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2026
 Asset ID 93811 - Asset Type 05.2 Portable Hydrants - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2026
 Asset ID 93812 - Asset Type 05.2 Portable Hydrants - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2026
 Asset ID 93813 - Asset Type 05.2 Portable Hydrants - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2026
 Asset ID 93814 - Asset Type 05.2 Portable Hydrants - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2026

4 Schmid Street
Garbutt, 4814
Ph: 07 4728 3622
ABN 18 146 907 511

Shangri-La Hotel - Pierpoint Road Cairns
Pierpoint Road
Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

[illegible]

Lewie Fire Protection
4 Schmid Street
Garbutt, 4814
Ph: 07 4728 3622
ABN 18 146 907 511

Asset Record - Job No. 98772
Shangri-La Hotel - Pierpoint Road Cairns
Pierpoint Road
Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset ID 93850 - Asset Type 05.2 Portable Hydrants - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2026
Asset ID 93851 - Asset Type 05.2 Portable Hydrants - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2026
Asset ID 93852 - Asset Type 05.2 Portable Hydrants - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2026
Asset ID 93853 - Asset Type 05.2 Portable Hydrants - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2026
Asset ID 93854 - Asset Type 05.2 Portable Hydrants - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2026
Asset ID 93855 - Asset Type 05.2 Portable Hydrants - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2026
Asset ID 93856 - Asset Type 05.2 Portable Hydrants - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2026
Asset ID 93857 - Asset Type 05.2 Portable Hydrants - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2026
Asset ID 93858 - Asset Type 05.2 Portable Hydrants - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2026
Asset ID 93859 - Asset Type 05.2 Portable Hydrants - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2026
Asset ID 93860 - Asset Type 05.2 Portable Hydrants - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2026
Asset ID 93861 - Asset Type 05.2 Portable Hydrants - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2026
Asset ID 93862 - Asset Type 05.2 Portable Hydrants - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2026
Asset ID 93863 - Asset Type 05.2 Portable Hydrants - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2026
Asset ID 93864 - Asset Type 05.2 Portable Hydrants - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2026
Asset ID 102668 - Asset Type 05.2 Portable Hydrants - Service Level Yearly (Includes 6 Monthly) - Service Due Date 01/04/2026

Comments / Recommendations

All works above have been routinely serviced and maintained in accordance with AS1851.2012 amendment 1 & AS2293.2 and the information on this data report is true and correct. This record does not infer compliance with all applicable building and fire safety legislation within the relevant jurisdiction.

Technician (Print Name): Ronald Kaldenbach

Licence No.

Customer (Print Name):

1229455

Technician (Signature): 

Customer (Signature):