

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset Register - 01.6 Portable Fire Equipment Service Record - AS1851.2012								
Asset ID	Building Location	Extinguishers	Fire Blankets	Hose Reels	NOTES:	Date	Service	Pass / Fail
93646	Entire Site	Yes	Yes	Yes		14/04/2026	Yearly	Fail
Test Readings	Asset Type: Fire Extinguisher, Fire Hose Reel, Fire Blanket		Work Order Number: APR 26 SM PORT A		Site Attendance Record Number:: A 106717			
	Table 10.4.1 6 MONTHLY ROUTINE SERVICE SCHEDULE - FIRE EXTINGUISHERS: 2026-04-14		--- 1.1 Accessibility - CHECK the extinguisher is conspicuous, readily accessible and in its assigned location. All Extinguisher types : Pass		--- 1.2 Anti-tamper device -CHECK that the anti tamper device is intact. All Extinguisher types : Pass			
	--- 1.3 Exterior and operating instructions - CHECK that the extinguisher is clean and the operating instructions are legible. All extinguisher types : Pass		--- 1.4 Servcie tag or label -- CHECK that the service tag or label is firmly attached to the extinguisher. All Extinguisher types : Pass		--- 1.5 External damage - CHECK that the extinguisher , including any attachments, is not damaged (see AS 2337.1) All Extinguisher types : Pass			
	--- 1.6 External corrosion - CHECK that the exterior of the extinguisher is not pitted or otherwise damaged by corrosion (see Clause 10.2.5 and AS 2337.1) All extinguisher types : Pass		--- 1.7 Outlet hose assembly - CHECK that the hose is securely fitted, the nozzle is securely attached and the assembly is free from obstruction, and the hose shows no cracking, or other signs of damage or deterioration. All extinguisher types : Pass		--- 1.8 Pressure Indicator - Where fitted, CHECK that the pressure indicator is legible, and registering within operable range. All extinguisher types : Pass			
	--- 1.9 Contents - WEIGH the extinguisher to determine that it is fully charged. All extinguisher types : Pass		--- 1.10 Signage - CHECK that the location sign is visible. All extinguisher types: Pass		--- 1.11 Support Bracket - CHECK that the appropriate support bracket is securely attached to wall or other suitable feature. All extinguisher types : Fail			
	--- 1.12 Discharge Nozzle - CHECK that the appropriate discharge nozzle is fitted and is not blocked or damaged. All extinguisher types : Pass		--- 1.13 Discharge nozzle and control valve - CHECK that the discharge nozzle is not blocked and that the control valve is functional. All wheeled extinguishers : N/A		--- 1.14 Carriage Assembly - CHECK that the carriage assembly is functional and free form corrosion. All wheeled extinguishers : N/A			
	--- 1.15 Powder- Portable extinguishers - INVERT the extinguisher and ensure that the powder remains free flowing. Powder (stored pressure), powder (gas container) : Pass		--- 1.16 Compressed gas container - DETERMINE that the compressed gas container is the correct type and size, in good condition, fully charged, and subjected to service as per AS 2030.5. All gas container extinguishers : Pass		--- 1.17 Actuating device - DETERMINE where possible and without discharging any contents, that the actuating device is free of corrosion, moves freely and is undamaged. Water(stored pressure),wet chemical, foam(stored pressure),powder(stored pressure), Carbon Dioxide, vaporizing liquid : Pass			
	--- 1.18 Internal components - DETERMINE that the internal discharge tube and strainer (where fitted) provide clear passage and are securely attached. Water (gas container), foam (gas container) : N/A		--- 1.19 Tyres - DETERMINE that pneumatic tyres, where fitted, are pressurised to the recommended pressure. All wheeled extinguishers : N/A		--- 1.20 Wheel - LUBRICATE wheel bearings (where applicable). All wheeled extinguishers : N/A			
	--- 1.21 Mobility - CHECK that the extinguisher moves readily on its wheels by rolling it for a distance of al least 5 meters. All wheeled extinguishers : N/A		Table 10.4.2 AUSTRALIA STANDARD YEARLY ROUTINE SERVICE SCHEDULE - FIRE EXTINGUISHERS: 2026-04-14		--- 2.1 Six-monthly service - COMPLETE all six-monthly activities, as listed in Table 10.4.1: Pass			
	--- 2.2 Operating head or cap - CHECK that the threads on operating head or cap are not damaged, vent(s) is (are) not blocked, and any strainer or expansion device is unobstructed. For heads with no screw thread, determine that security locking device is undamaged and operational. Water (gas container), foam (gas container), water with additive (stored pressure), foam (stored pressure), powder (stored pressure): N/A		--- 2.3 Discharge - CHECK that the extinguisher functions in accordance with the operating instructions and that the discharge is satisfactory. Recharge in accordance with Item 2.8. - (a) Water with additive (stored pressure), foam (stored pressure) : N/A		--- 2.3 Discharge - CHECK that the extinguisher functions in accordance with the operating instructions and that the discharge is satisfactory. Recharge in accordance with Item 2.8. - (b) *Water with corrosion inhibitors or freezing point depressants (stored pressure). (*To be discharged on a three-yearly frequency): N/A			
	--- 2.4 Actuating device - CHECK that the actuating device is free of corrosion, moves freely, and is undamaged; any cutting edge is sharp; and all sealing gaskets are in good condition. Water (gas container),		--- 2.5 Internal components - (a) CHECK that the internal discharge tube, strainer and anti-overfill tube (where fitted) provide clear passage and are securely attached, and that the anti-overfill device		--- 2.5 Internal components - (b) Check that the internal discharge tube, or gas inlet tube or ports, provide clear passage and are correctly installed, and that the powder is free flowing. Powder (gas			

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

foam (gas container), foam (stored pressure), powder (gas container): N/A	is undamaged. Water with additive (stored pressure), foam (stored pressure) : N/A	container): N/A
--- 2.6 Internal condition-Portable extinguishers - CHECK that the interior of the cylinder is clean , is not pitted by corrosion (see AS2337.1), and any internal lining is in good condition. Water (gas container), water with additive (stored pressure), foam (gas container), foam (stored pressure), powder (gas container): N/A	--- 2.7 Internal condition - wheeled extinguishers - CHECK that the interior of the cylinder is clean. Water (gas container), foam (gas container), foam (stored pressure): N/A	--- 2.8 Extinguishing agent replacement - RECHARGE the extinguisher with fresh extinguisher agent in accordance with the manufacturer's instructions. Water with additive (stored pressure), foam (gas container), foam (stored pressure) - Upon completion of recharging stored pressure type extinguishers, perform a leak test as per item 2.10.: N/A
--- 2.9 Seals - CHECK that the operating head or cap seal is in good condition. Water (gas container), water with additive (stored pressure), foam (gas container), foam (stored pressure), powder (gas container): N/A	--- 2.10 Leak detection - CHECK if there are any leaks at the joints and seals that were renewed or disturbed during recharging. Water with additive (stored pressure), foam (stored pressure): N/A	--- 2.11 Fire hazard - CHECK that the fire hazard/risk to be protected has not changed. All extinguisher types : Pass
--- 2.12 Suitability - CHECK that the extinguisher is correct type, class, size and /or rating for the hazard to be protected. All extinguisher types. : Pass	--- 2.13 Obstructions - (a) CHECK that no alterations have been made to the building that may impede access to the extinguisher or increase the travel distances to more than those specified in AS2444 or the approved design. All portable extinguishers : Pass	--- 2.13 Obstructions - (b) CHECK that no alterations have been made to the building that may impede access to , or restrict the movement of the extinguisher. All wheeled extinguishers : Pass
TABL 11.4 SIX-MONTHLY SERVICE SCHEDULE - FIRE BLANKETS: 2026-04-14	--- 1.1 Accessibility - CHECK that the fire blanket is: - (a) Conspicuous.: Pass	--- 1.1 Accessibility - CHECK that the fire blanket is: - (b) In its assigned location.: Pass
--- 1.1 Accessibility - CHECK that the fire blanket is: - (c) Readily accessible.: Pass	--- 1.1 Accessibility - CHECK that the fire blanket is: - (d) Installed in accordance with AS 2444.: Pass	--- 1.2 Signage - CHECK that the location sign is visible and correct.: Pass
--- 1.3 Blanket container - CHECK that the fire blanket container: - (a) Is securely and correctly supported.: Pass	--- 1.3 Blanket container - CHECK that the fire blanket container: - (b) Is clean and free from damage.: Pass	--- 1.3 Blanket container - CHECK that the fire blanket container: - (c) Has clear and legible instructions thereon.: Fail
--- 1.3 Blanket container - CHECK that the fire blanket container: - (d) Has a service record tag/label attached.: Pass	--- 1.4 Fire blanket - REMOVE the fire blanket from the container and check: - (a) For any damage or contamination to the fire blanket (refer also Clause 11.2.4): Pass	--- 1.4 Fire blanket - REMOVE the fire blanket from the container and check: - (b) For unsecured or damaged hand-holding devices.: Pass
--- 1.4 Fire blanket - REMOVE the fire blanket from the container and check: - (c) That the fire blanket is correctly folded. Where the fire blanket conforms to the above, REPACK the blanket into the container as recommended by the manufacturer. NOTE: It is important that fire blankets are always folded in the manner prescribed by the manufacturer in order that they can be removed from the container quickly (see AS/NZS 3504): Pass	TABLE 9.4.1 SIX-MONTHLY SERVICE SCHEDULE FIRE HOSE REELS: 2026-04-14	--- 1.1 Accessibility - CHECK that the hose reel is readily accessible with no obstacles restricting its access. Where a hose reel is installed in a recess or cabinet, CHECK that the clearances around the hose reel comply with the requirements of AS 2441.: Fail
--- 1.2 Signage - Where a location sign is required by AS 2441, CHECK that it is correctly located and visible.: Pass	--- 1.3 Operating instructions - CHECK that the operating instructions are legible.: Pass	--- 1.4 Damage - CHECK for any damage or corrosion of components that could adversely affect the operation of the hose reel.: Fail
--- 1.5 Cabinet - CHECK that any hose reel cabinet is accessible, clear of extraneous materials, clearly and correctly marked and in good repair.: Pass	--- 1.6 Nozzle interlock - CHECK that the nozzle is retained in the nozzle interlock.: Pass	--- 1.7 * Swing arm Where fitted, TEST the swing arm to ensure it operates correctly and allows the hose to be run off in its intended direction.: N/A
--- 1.8 * Unwind With the nozzle closed and stop valve open, TEST that the hose reel can be unwound freely in its intended direction by unwinding at least 5 m of hose.: Pass	--- 1.9 * Leakage With the nozzle closed, pressurize the reel by opening the stop valve. DETERMINE if there are any leaks from the reels waterway, including glands, nozzle, stop valve, hose or any fittings. NOTE: In order to check that there is no leakage of water from any part of the reel waterway, it is recommended that the hose be completely unwound off the reel, so that all parts of the waterway can be examined.: Fail	--- 1.10 * Flow TEST water to ensure it is able to flow through the reel by opening and closing the nozzle.: Pass

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Test Readings	--- 1.11 * Service tag or label CHECK that the service tag or label is firmly attached to the hose reel.: Pass --- 2.1 Six monthly service - COMPLETE all six-monthly service activities, as listed in Table 9.4.1.: Pass --- 2.4 Hose fittings - CHECK that all hose fittings and connections are tight.: Fail --- 2.6 Flow rate - Minimum acceptable flow rates: - (a) 0.33 L/s for reels with 19 mm hose. (15 seconds = 4.95 litres): PASS --- 2.8 Ancillary equipment - CHECK that any foam branch pipe or other equipment is in good repair and maintained in accordance with the manufacturer's instructions.: Pass Have all previously reported defects been rectified: No	* After completing these actions, the nozzle shall be re-installed in the nozzle interlock and the hose depressurized (see Clause 9.2.6): Pass --- 2.2 Anchor points - CHECK that the hose reel is securely mounted and that the anchor points are tight.: Pass --- 2.5 Bearings - CHECK that the hose reel bearings are not damaged or excessively worn.: Pass --- 2.6 Flow rate - Minimum acceptable flow rates: - (b) 0.41 L/s for reels with 25 mm hose. (15 seconds = 6.15 litres): Pass --- 2.9 Fire hazard - CHECK that the hose reel is appropriate protection for the fire hazard/risk.: Pass Queensland Buildings Only: I hereby acknowledge that the mentioned system above has been routinely serviced in accordance with Australian Standard AS1851-2012 Amendment 1 & AS2293.2 and that the information on this report is true and correct. This record does not infer compliance of all applicable building and fire legislation within the relevant jurisdiction - Queensland Buildings Only - Maintenance complies with QDC, MP6.1.: Yes	TABLE 9.4.2 YEARLY SERVICE SCHEDULE FIRE HOSE REELS: 2026-04-14 --- 2.3 Hose guide - CHECK that any hose guide fixed to the hose reel supply pipe is not able to move upwards and cause the hose to jamb.: Pass --- 2.6 Flow rate - With the stop valve and nozzle fully opened, MEASURE the water flow rate from the most disadvantaged hose reel.: Pass --- 2.7 Hose - CHECK hose for kinking, excessive damage or wear, or collapse.: Pass --- 2.10 Obstructions - CHECK that no alterations have been made to the building, which impede access to the hose reel or restrict the running out of the hose, and that the hose can reach the fire hazard/risk in accordance with AS 2441.: Pass Queensland Buildings Only: I hereby acknowledge that the mentioned system above has been routinely serviced in accordance with Australian Standard AS1851-2012 Amendment 1 & AS2293.2 and that the information on this report is true and correct. This record does not infer compliance of all applicable building and fire legislation within the relevant jurisdiction - Queensland Buildings Only - System is in proper working order: Yes
Failure Points	Performed 12 Monthly Testing and Maintenance - Issues Found - Refer to Assets for Defects / Failures and/or Recommendations. - 9.4.2 & 10.4.2 & 11.4.1		
Notes	x22 failure points. See individual assets for effect information		

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
93795	79321	Outside front deck	Left of underground car park ent	36	Wormwald	79321	13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
93796	79313	Underground Carpark	Carpark left side of boom gate as you enter	36m	Quell	79313	13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
93797	79314	Underground carpark	Left of boomgate as you enter carpark		9.0Kg ABE	79314	13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
93798	79315	Underground Carpark	Adj pump room	36m	BFI	79315	13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
93799	79316	Underground Carpark	Inside Pump Room		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
93800	79317	Underground Carpark	West Wall North Of Pump Room	36m	Quell		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
93802	79318	Underground Carpark	North Wall, Back Left Of Carpark	36	Wormwald	79318	13/04/2026	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	0.2 - Other (Non Critical Defect) - 9.4.1								
Notes	Valve handle does not shut off correctly. Requires repair and replacement of handle								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
93899	79325	Ground Floor shopping	Adj Coffee Beach		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
93906	79326	Ground Floor Shopping	Next To Howling Jays Signage Opposite Toilet		4.5Kg ABE		13/04/2026	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	0.4 - Other (Recommendations) - 10.4.1								
Notes	Due For 5 Yearly 06/2026 recommend replacing before next service								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
93909	79333	Ground Floor Shopping	Next To Howlin Jays Signage, Adj Toilets	36m	Chubb		14/04/2026	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.9 - Hose Reel leaking - 9.4.1 Recommendation:								
Notes	Significant leak from the hub. FHR requires replacing NOTE: Signs of excessive use from outdoor shops used to clean, recommend signage reminding people FHR is for emergency use								
93914	79327	Ground Floor Outside	Outside East Entrance, Next To Marinades Resturant	36m	Wormwald		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
93923	79328	Ground Floor Shopping	Next To Cairns Koalas RHS	36m	Quell		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
93935	86721	Ground Floor Outside	Outside Entrance Adj D Finger Wharf And Big Marlin	36m	Fireater	86721	13/04/2026	Yearly	Pass

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Test Readings	Attendance Record Number (if applicable):								
93960	79343	Mezzanine Above Shopping	Mezzanine Down Hallway Next To HP Accounting	36m	Quell		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
93961	79345	Mezzanine Above Shopping	Hallway next to the therapists room beside FHR cupboard		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
93962	79344	Mezzanine Above Shopping	Adj Stairs And Lift Through Brown Double Doors	36M	Quell		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
93963	83435	Mezzanine Above Shopping	Adj Stairs And Lift Through Brown Double Doors		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
93964	79336	Ground Floor Shopping	Pole With Tvs, infront Of Stairs To Carpark		4.5Kg ABE		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
93966	86374	Ground Floor Shopping	Main Entrance At Crossing	36m	Quell		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
93971	79346	Bin Room	Bin Rom Next To Fire Exit Door	36m	Wormald		13/04/2026	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	0.2 - Other (Non Critical Defect) - 9.4.1								
Notes	Base of nozzle leaks under pressure. Requires new nozzle								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
93999	83451	Bin Area	Bin Area Next To Fire Exit Door		2.0Kg ABE DCP		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
93974	79337	Ground Floor Shangri-la	Behind Reception Adj Toilets & Safe deposit Room	36m	FlameStop		13/04/2026	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	0.2 - Other (Non Critical Defect) - 9.4.1			0.3 - Other (Non Conformance) - 9.4.1					
Notes	FHR has been replaced by others 2 months prior to testing. Installation does not comply with AS2441 and old valve is to be removed. See photo attached								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94407	79339	Plant Room Roof	Inside Plant Room Next To Door, Stairs 10. Sth		4.5Kg ABE		13/04/2026	Yearly	Pass

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
			Tower						
Test Readings	Attendance Record Number (if applicable):								
94408	83431	Plant Room Roof	Lift Motor Room, Stairs 10. Sth Tower		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94481	79350	Level 4 South Tower	Adj Fire Stairs & Room 4007,	36M	Quell		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94482	79348	Level 3 South Tower	Level 3 South Tower Adj Lift & Fire Stair		2.0Kg ABE DCP		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94483	83559	Level 3 South Tower	Adj Lift And Fire Stairs	36m	Quell		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94484	83495	Plant Room Top Stairs 7	North Tower		4.5Kg ABE		13/04/2026	Yearly	Pass

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Test Readings	Attendance Record Number (if applicable):								
94485	83444	Plant Room Top Stairs 7	Motor Room Above Plant Room		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94486	83461	Level 4 North Tower	Level 4 Adj Lift & 4003		2.0Kg ABE DCP		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94487	83413	Level 4 North Tower	Adj Lift & Room 4003	36m	Quell		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94488	83471	Level 3 North Tower	Adj Fire Door Exit & Room 3003		2.0Kg ABE DCP		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94489	83481	Level 3 North Tower	Adj Fire door Exit & Room 3003	36m	Quell		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94490	83452	Level 2 North End	Adj Lift & room 2065 In FHR Cupboard		2.0Kg ABE DCP		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94492	83462	Level 2 North End	Adj Lift & Room 2065 In FHR Cupboard	36m	Quell		14/04/2026	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	0.2 - Other (Non Critical Defect) - 9.4.1								
Notes	- leaking from valve when under pressure								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94493	83482	Level 2 Ocean Side	Adj Room 2083 In FHR Cupboard		2.0Kg ABE DCP		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94494	83472	Level 2 Ocean Side	Adj Room 2083 In FHR Cupboard	36m	Quell		14/04/2026	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.9 - Hose Reel leaking - 9.4.1 Recommendation: * Non-Critical: Hose Reel leaking								
Notes	- Severe leak from hub. Requires new FHR								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94495	83492	Level 2 Ocean Side	Adj Room 2097 In FHR Cupboard		2.0Kg ABE DCP		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94496	83453	Level 2 Ocean Side	Adj Room 2097 In FHR Cupboard	36m	Quell		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94497	83463	Level 2 South End	Adj Lift, Near Room 2107		2.0Kg ABE DCP		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94498	83473	Level 2 South End	Adj Lift, Near Room 2107	36m	Quell		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94499	83483	Projection Room	Adj Plant Room Top Of Stairs 11		3.5kg Co2		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94500	83422	Lift Motor Room 5	Between Stairs 11 and Stairs 9 behind Back Wall In Plant		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94501	83493	Plant Room	Top Of Stairs 9 Inside Plant Room		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94502	83474	Plant Room	Top Of Stairs 9 Inside Plant Room	36m	Quell		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94503	83484	Plant Room	Top Of Stair 8 Inside Plant Room		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94504	83494	Plant Room	Top Of Stairs 8, Inside Plant Room	36m	Quell		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94505	83464	Plant Room	Top Of Stairs 6, Inside Plant Room		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94506	83454	Plant Room	Top Of Stair 6, Inside Plant Room	36m	Quell		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94507	83455	Plant Room	Top of Stairs 5 Inside Plant Room		2.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94508	83421	Plant Room	Top Of Stair 5 Inside Plant Room	36	Quell		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94509	83465	Plant Room	Top of Stairs 5 Left Side Of Wall In Plant Room		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94510	83560	Plant Room	Top of Stair 4 inside plant room stand alone extinguisher		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94511	83581	Plant Room	Top of stair 4 inside plant room with FHR and hydrant		2.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94512	83592	Plant room	Top of stair 4	36m	Quell		13/04/2026	Yearly	Fail

Lewie Fire Protection
4 Schmid Street
Garbutt, 4814
Ph: 07 4728 3622
ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
Pierpoint Road
Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number		Date	Service	Pass / Fail
			inside plant room with hydrant and extinguisher							
Test Readings	Attendance Record Number (if applicable):									
Failure Points	0.2 - Other (Non Critical Defect) - 9.4.1									
Notes	Stop valve will not shut water supply off. Requires repair (Spindle)									

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94513	83475	Outdoor rooftop	Top of stair 3 outside		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number		Date	Service	Pass / Fail
94514	83510	Outside rooftop	Top of stair 3 outside	36m	Wormald			13/04/2026	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):									
Failure Points	1.6 - Nozzle not retained in interlock - 9.4.1 Recommendation: * Non-Critical: Nozzle not retained in interlock			2.4 - Hose fittings or connections faulty - 9.4.2 Recommendation: * Non-Critical: Hose fittings or connections faulty				2.7 - Hose exposed to excessive damage or general wear - 9.4.2 Recommendation: * Non-Critical: Hose exposed to excessive damage or general wear		
Notes	- Stop valve severely corroded - Hose is perished - nozzle is seized Requires new FHR and stop valve. Recommend installing canvas cover									

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94515	83485	Plant room	Top of stair 2 in plant room		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94516	83456	Plant room	Top of stair 2 inside plant room next to FHR		2.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94517	83466	Plant room	Top of stair 2 next to extinguisher	36m	Quell		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94518	83520	Lift motor room	Lift motor room adj stair 2		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94519	83476	Plant Room	Near stair 2, next to fire door and hot water room		9.0Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94520	83486	Level 2	adj conference rooms next to kitchen entry in cupboard		2.5Kg ABE		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94521	83501	Level 2	Adj conference rooms, next to	36m	Quell		14/04/2026	Yearly	Pass

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
			kitchen entry in cupboard						
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94522	83496	Level 2 City Side	In Cupboard Adj Room 2003		2.0Kg ABE DCP		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94523	83509	Level 2 City Side	Adj room 2003 in cupboard	36m	Quell		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94524	83457	Level 2 City Side	Adj room 2014 in FHR cupboard		2.0Kg ABE DCP		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94525	83467	Level 2 City Side	Adj room 2014 in FHR cupboard	36m	Quell		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94526	83477	Level 2 City Side	Adj room 2029 in Cupboard		2.5Kg ABE		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94527	83487	Level 2 City Side	Adj room 2029	36m	Quell		14/04/2026	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.1 - Hose reel obstructed or where in a cabinet, reel not in compliance with AS 2441 - 9.4.1 Recommendation: * Non-Critical: Hose reel obstructed or where in a cabinet, reel not in compliance with AS 2441								
Notes	Hose reel does not have minimum 100mm clearance on all sides. Photo attached to asset								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94528	83497	Level 2 North face	Adj room 2044		2.0Kg ABE DCP		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94529	83458	Level 2 North Face	Adj Room 2044	36	Quell		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94530	83478	Level 2 North Face	Adj room 2056		2.5Kg ABE		14/04/2026	Yearly	Pass

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Test Readings	Attendance Record Number (if applicable):		
---------------	---	--	--

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94531	83468	Level 2 North Face	Adj room 2056	36m	Quell		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94532	83488	Outdoor pool area	Adj level 1 entry to pool room 1080 in locked room		3.5kg Co2		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94533	83498	Level 1 Ocean Side	Adj room 1080		4.5Kg ABE		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94534	83459	Level 1 Ocean Side	Adj room 1080	36m	Quell		14/04/2026	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.9 - Hose Reel leaking - 9.4.1 Recommendation: * Non-Critical: Hose Reel leaking			2.4 - Hose fittings or connections faulty - 9.4.2 Recommendation: * Non-Critical: Hose fittings or connections faulty					
Notes	- Significant leak from hub under pressure - plastic nozzle seized and requires replacing								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94535	83469	Level 1 Ocean Side	Adj Elevator Next To Room 1062		2.0Kg ABE DCP		14/04/2026	Yearly	Fail

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Test Readings	Attendance Record Number (if applicable):		
Failure Points	1.11 - Extinguisher support bracket not secure (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher support bracket not secure (all extinguisher types)		
Notes	Bracket has been damaged and requires new 2kg FlameStop bracket		

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94536	83504	Level 1 Ocean Side	Adj Elevator Next to Room 1062	36m	Quell		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94537	83479	Level 1 North Face	Adj Room 1053		2.0Kg ABE DCP		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94538	83506	Level 1 North Face	Adj Room 1053	36m	Quell		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94539	83489	Level 1 City Side	Adj Room 1041		2.0Kg ABE DCP		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94540	83540	Level 1 City Side	Adj Room 1041	36m	BFI		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94541	83499	Level 1 South Face	Adj Room 1026		2.5Kg ABE		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94542	83550	Level 1 South Face	Adj Room 1026	36	Quell		14/04/2026	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.1 - Hose reel obstructed or where in a cabinet, reel not in compliance with AS 2441 - 9.4.1 Recommendation: * Non-Conformance: Hose reel obstructed or where in a cabinet, reel not in compliance with AS 2441 * Non-Critical: Hose reel obstructed or where in a cabinet, reel not in compliance with AS 2441			2.4 - Hose fittings or connections faulty - 9.4.2 Recommendation: * Non-Critical: Hose fittings or connections faulty					
Notes	Hose reel must be 100mm clear from the rim on all sides - Hose reel is 60mm from brick work - Needs to be moved over to be in accordance - plastic nozzle is seized. Requires new nozzle								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94543	83460	Level 1 South Face	Adj Room 1011		2.0Kg ABE DCP		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94544	83470	Level 1 South Face	Adj Room 1011	36m	Quell		14/04/2026	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	0.2 - Other (Non Critical Defect) - 9.4.1			0.3 - Other (Non Conformance) - 9.4.1					
Notes	- FHR has been replaced by others 2 months prior to testing. Installation does not comply with AS2441 and old valve is to be removed. - Mounting bolts missing above valve See photo attached								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94545	83480	Level 1 South Face	Adj Room 1003		2.0Kg ABE DCP		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94546	83511	Level 1 South Face	Adj Room 1003	36m	Quell		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94547	83490	Level 1 South Face	Next to fire door behind sitting area over looking reception		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94548	83500	Level 1 South Face	Next to single lift near government		2.0Kg ABE DCP		13/04/2026	Yearly	Pass

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
			office						
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94549	83442	Level 1 South Face	Next to single lift near government office	36	BFI		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94550	83580	Level 1 Kitchen Entry	Hallway between Kitchen and pool next to FHR		2.0Kg ABE DCP		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94552	83531	Level 1 Kitchen entry	Hallway between kitchen and pool	36m	Wormald		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94553	83517	Level 1 kitchen entry	Next to door leading from pool to kitchen hallway		4.5Kg ABE		13/04/2026	Yearly	Pass

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Test Readings	Attendance Record Number (if applicable):								
94554	83590	Level 1 Ocean side	Adj room 1089		2.0Kg ABE DCP		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94555	83527	Level 1 Ocean Side	Adj Room 1089	36m	FlameStop		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94556	83599	Level 1 Ocean Side	Adj Room 1093		2.0Kg ABE DCP		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94557	83505	Level 1 Ocean side	Adj 1093	36m	Quell		14/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94558	83551	Level 2 Kichen	Next to Maintenance Elevator		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset Register - 01.1 Fire Blankets - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Equip Size Type	LFP Equipment Number	Make	Location	Date	Service	Pass / Fail
94559	83569	Level 2 Kitchen	1.2 x 1.8		Wormald	Adj Chemical Storage & Coolroom	13/04/2026	Yearly	Pass
Test Readings	Log Book Entry Number:								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94560	83579	Level 2 Kitchen	Next To Sinks, Adj Coolroom		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.1 Fire Blankets - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Equip Size Type	LFP Equipment Number	Make	Location	Date	Service	Pass / Fail
94561	83561	Level 1 Kitchen	1.2 x 1.2		FlameStop	Adj Lift, Next To Switchboard	13/04/2026	Yearly	Pass
Test Readings	Log Book Entry Number:								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94562	83552	Level 1 Kitchen	Adj Lift, Next To Switchboard		7.0Lt Wet Chem		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94563	83572	Level 1 Kitchen	Between Fire Door & Ice Machine		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.1 Fire Blankets - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Equip Size Type	LFP Equipment Number	Make	Location	Date	Service	Pass / Fail
94564	86722	Level 1 Kitchen	1.8 x 1.2		Lewie	Next To Fire Door	13/04/2026	Yearly	Pass

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset ID	Equipment Number	Building Number	Equip Size Type	LFP Equipment Number	Make	Location	Date	Service	Pass / Fail
						& Ice Machine			
Test Readings	Log Book Entry Number:								
94565	83522	Level 1 Kitchen	1.8 x 1.2		Firebox	Next To Ansul & Stoves	13/04/2026	Yearly	Pass
Test Readings	Log Book Entry Number:								
94567	86725	Level 1 Kitchen	1.2 x 1.8		Lewie	Adj Deep Fryer & Exhaust Fan Switch	13/04/2026	Yearly	Pass
Test Readings	Log Book Entry Number:								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94569	83541	Level 1 Kitchen	Next To Coolroom, Adj Prep Area		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94571	83537	Level 1 Kitchen	Inside Office, Next to Coolroom		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.1 Fire Blankets - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Equip Size Type	LFP Equipment Number	Make	Location	Date	Service	Pass / Fail
94573	86709	Level 1 Kitchen	1.2 x 1.8		Lewie	Adj Storage Area, Next To Toilets	13/04/2026	Yearly	Pass
Test Readings	Log Book Entry Number:								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94577	83548	Level 1 Kitchen	Adj Toilets, Near Storage Area		2.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94580	83562	Mezzanine Level	Inside Plant Room		4.5Kg ABE		13/04/2026	Yearly	Pass

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
		BOH	Next To Lift						
Test Readings	Attendance Record Number (if applicable):								
94581	83582	Mezzanine Workshop	Workshop office near sign in		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94582	83526	Mezzanine Workshop	Adj Workshop Bench		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94584	83553	Mezzanine BOH	Hallway Next to Workshop Adj Food Storage		2.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94585	83514	Mezzanine BOH	Hallway next to workshop adj food storage	36m	Quell		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94588	83563	Mezzanine level rooms	Adj Room 10		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94589	83573	Mezzanine level rooms	Adj room 10	36m	Chubb		13/04/2026	Yearly	Pass

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Test Readings	Attendance Record Number (if applicable):		
---------------	---	--	--

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94592	79349	Mezzanine level rooms	Hallway adj room 21		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94595	83546	Mezzanine level rooms	Hallway adj room 21	36m	Wormald		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94600	83554	Mezzanine level rooms	Hallway adj room 28		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94602	83512	Mezzanine level rooms	Hallway adj room 28	36m	Chubb		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94611	83564	Mezzanine level rooms	Hallway adj room 35		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94614	83524	Mezzanine level rooms	Hallway adj room 35	36m	Chubb		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94620	83583	Mezzanine level rooms	Hallway adj room 38		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94624	83544	Mezzanine level rooms	Hallway adj room 38	36m	Chubb		13/04/2026	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.9 - Hose Reel leaking - 9.4.1 Recommendation: * Non-Critical: Hose Reel leaking								
Notes	Significant leak from hub. Hose itself seems to be split FHR requires replacing								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94628	83568	Mezzanine level rooms	Next to room 45, infront of fire door		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94630	83536	Mezzanine level	Next to room 45,	36m	Chubb		13/04/2026	Yearly	Pass

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
		rooms	infront of fire door						
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94633	83578	Mezzanine to shopping	Second door on left down hallway next to HP accounting		3.5kg Co2		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94637	83542	Shangrila executive centre	Above pier shopping		3.5kg Co2		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94641	83534	Shangrila Executive centre	Above pier shopping		3.5kg Co2		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94646	83555	shangrila Executive centre	Above pier shopping		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.1 Fire Blankets - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Equip Size Type	LFP Equipment Number	Make	Location	Date	Service	Pass / Fail
94649	83565	Shangrila executive centre	1.2 x 1.8		FireWorld	Above shopping in kitchen	13/04/2026	Yearly	Pass
Test Readings	Log Book Entry Number:								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94479	79340	Level 4	Adj Fire Door Exit & Room 4007, South Tower		2.0Kg ABE DCP		13/04/2026	Yearly	Pass

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Test Readings	Attendance Record Number (if applicable):								
93977	79338	Ground Floor Shangri-la	Behind Reception Adj Toilets & Safe Deposit Room		2.0Kg ABE DCP		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
93949	79334	Mezzanine To Shopping	Mezzanine Adj lift In Staff Only Door	36	Quell		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
93946	79335	Mezzanine Of Shopping	Staff Door To Messanine Adj Lift		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
93938	79330	Ground Floor Shopping	Adj Priceless Gems in Black Cabinet	36m	Quell		13/04/2026	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	0.2 - Other (Non Critical Defect) - 9.4.1			0.3 - Other (Non Conformance) - 9.4.1					
Notes	FHR has been replaced by others 2 months prior to testing. Installation does not comply with AS2441 and old valve is to be removed. See photo attached								
93939	79342	Ground floor Shopping	Inside Fire Exit Opposite Oiled Massage	36m	Dixon		13/04/2026	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.6 - Nozzle not retained in interlock - 9.4.1 Recommendation: * Non-Critical: Nozzle not retained in interlock								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Notes	Annual testing completed Defects - Due to pipe underneath hose reel, hose does not go into interlock Recommend changing to figure 8 which will require new nozzle								
93894	79324	Ground Floor	GF Centre Shopping Adj Himalayan Dreams (Black Cab)	36m	Chubb		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
93888	79332	Underground Carpark	Entrance to stairwell		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
93889	83408	Underground Carpark	Infront Of Door To Stairwell	36m	Wormwald		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
93886	83449	Underground Carpark	Near Lifts	36m	Quell		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
93882	79322	Underground Carpark	Back Wall Behind Carpark 2	36m	Quell		13/04/2026	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	0.2 - Other (Non Critical Defect) - 9.4.1			0.3 - Other (Non Conformance) - 9.4.1					
Notes	FHR has been replaced by others 2 months prior to testing. Installation does not comply with AS2441 and old valve is to be removed. See photo attached								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
93868	79323	Underground Carpark	Between Park 64 & 65 Far Wall Opposite Boom gate		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
93877	79319	Underground Carpark	Mounted On Wall Left Of Carpark 1		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
93875	83450	Underground Carpark	Inside Cupboard between Carpark 40 & 101 (Rear Of Carpark)	36m	FlameStop		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
93873	79320	Underground Carpark	In Cupboard Between Carpark 40 & 101 (Rear Of Park)		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
93871	83430	Underground Carpark	In Cupboard Next to Carpark 90	36m	FlameStop		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
4 Schmid Street
Garbutt, 4814
Ph: 07 4728 3622
ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
Pierpoint Road
Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
93869	83419	Underground Carpark	Far Area Opposite car Park 68		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94660	83543	Mezzanine	Plant room near loading dock		4.5Kg ABE	83543	13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94667	83594	Mezzanine	Main switch room behind plant room		5.0Kg Co2	83594	13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94672	83584	Mezzanine	Main electrical switch room		9.0Kg ABE	83584	13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94678	83574	Mezzanine	Outside PABX Room	36m	BFI	83574	13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94676	83595	Plant room Mezzanine	Next to pabx room, plant room behind loading dock		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94668	83585	Plant room mezzanine level	Behind loading dock next to electrixal substation		2.0Kg ABE DCP		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94664	83575	main plant room on Mezzanine	Behind loading dock and behnd		9.0Kg ABE		13/04/2026	Yearly	Pass

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
			executive centre (main)						
Test Readings	Attendance Record Number (if applicable):								
94739	82951	Mezzanine	Laundry infront of dryers		4.5Kg ABE	82951	13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94695	83588	Mezzanine events area	Outside stair 5 fire door		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94699	83598	Mezzanine events area	Outside of stairs 5 fire door	50m	Quell		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94705	83557	Mezzanine events area	Trinity room 2 next to stairs 4		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94711	83558	Mezzanine events area	Trinity room 2 next to stairs 4	36m	Quell		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94714	83556	Mezzanine events kitchen	Kitchen adj sink and prep bench		4.5Kg ABE		13/04/2026	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	0.4 - Other (Recommendations) - 10.4.1								
Notes	Due For 5 Yearly 06/2026 recommend replacing before next service								
94717	83566	Mezzanine events area kitchen	Kitchen, in store room		3.5kg Co2		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.1 Fire Blankets - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Equip Size Type	LFP Equipment Number	Make	Location	Date	Service	Pass / Fail
94721	83404	Mezzanine events kitchen	1.8 x 1.8		FlameStop	Kitchen adj sink and prep	13/04/2026	Yearly	Pass
Test Readings	Log Book Entry Number:								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94722	83576	Events front entrance	Main entrance door next to pier bar, facing lagoon		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94723	83405	Events main entrance	Events main door next to pier bar, facing lagoon	36m	Wormald		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94732	83567	Mezzanine loading dock	Plant Room 2		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94733	86364	Mezzanine loading dock	Chemical room		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94734	83587	Mezzanine loading dock	FHR cupboard in loading dock		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94735	82968	Mezzanine loading dock	FHR cupboard	36m	Quell		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94736	82969	Mezzanine loading dock	Left side of FHR cupboard		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94737	82970	Mezanine laundry area	Next to service lift		4.5Kg ABE		13/04/2026	Yearly	Fail
Test Readings	Attendance Record Number (if applicable):								
Failure Points	0.4 - Other (Recommendations) - 10.4.1								
Notes	Due For 5 Yearly on 08/2026 recommend replacing before next service								
94740	83000	Mezzanine laundry	Next to chemical storage adj sink		5.0Kg Co2		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
94742	82961	Mezzanine	Adjacent staff lunch room	36	BFI	82961	13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
94743	82999	Mezzanine staff area	Adj staff lunch room		2.0Kg ABE DCP		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94744	82971	Mezzanine behind laundry	Electrical and communications room adj female change		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94741	82978	Mezzanine laundry	Next to chemical storage adj sink		9.0Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94738	82958	Mezzanine loading dock	Adjacent office before hallway		9.0Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94745	82981	Mezzanine horizon club	Kitchen area of horizon club buffet		2.0Kg ABE DCP		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94757	82979	Mezzanine horizon club	Horizon club, backside next to sapphire system		3.5kg Co2		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94758	83586	Pool area Bar	Inside bar area by the pool		2.0Kg ABE DCP		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94759	82960	Ground floor reception	Office behind reception next to printer		4.5Kg ABE		13/04/2026	Yearly	Fail

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Test Readings	Attendance Record Number (if applicable):								
Failure Points	1.5 - Extinguisher or attachments externally damaged (all extinguisher types) - 10.4.1 Recommendation: * Non-Critical defect: Extinguisher or attachments externally damaged (all extinguisher types)								
Notes	Pressure gauge has been damaged. Requires replacing								
94760	83596	Backyard kitchen	Next to coldroom adj fire door		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
94761	82980	Backyard Kitchen	Adj stoves and door to ocean side		7.0Lt Wet Chem		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.1 Fire Blankets - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Equip Size Type	LFP Equipment Number	Make	Location	Date	Service	Pass / Fail
94762	83597	Backyard Kitchen	1.2 x 1.8		FlameStop	Adj stoves and door to ocean side	13/04/2026	Yearly	Fail
Test Readings	Log Book Entry Number:								
Failure Points	0.0 - Other - 11.4								
Notes	Container is faded and requires replacing								
94763	86726	Baxkyard Kitchen	1.2 x 1.8		Lewie	Centre wall adj stoves in kitchen	13/04/2026	Yearly	Pass
Test Readings	Log Book Entry Number:								
102704	86707	Mezzanine workshop	1.2m x 1.2m	86707	FlameStop	Wall before workshop entry at sign in	13/04/2026	Yearly	Pass
Test Readings	Log Book Entry Number:								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
102707	85957	Backyard Kitchen	Adj stoves		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
117491	86375	Bun area	Behind clear curtains		4.5Kg ABE		13/04/2026	Yearly	Pass

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Test Readings	Attendance Record Number (if applicable):		
---------------	---	--	--

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1

Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
117194	86385	Mezzanine above shopping	Eastern emergency exit next to your offices sign	36m	Wormald		13/04/2026	6 Monthly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012

Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
117231	86388	Mezzanine above shopping	Hallway next to the therapists room in FHR cupboard		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
117095	86372	Underground carpark	CP9 Adj underground entry on caged area		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
139634	85955	Basement lift motor room	Near Pay station and stairs to ground		2.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
139700	86867	Outdoor of shopping areas	Switch room near marinades		2.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
139766	86855	mezzanine offices	Mezzanine back area behind conference room hidden away		2.0Kg ABE DCP		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
139767	86876	Mezzanine offices	Mezzanine back area behind conference room		3.5kg Co2		13/04/2026	Yearly	Pass

Lewie Fire Protection
 4 Schmid Street
 Garbutt, 4814
 Ph: 07 4728 3622
 ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
 Pierpoint Road
 Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

Asset Register - 01 Portable and Wheeled Fire Extinguishers - AS1851.2012									
Asset ID	Equipment Number	Building Number	Location	LFP Barcode	Equipment Size Type	LFP Equipment Number	Date	Service	Pass / Fail
			hidden away						
Test Readings	Attendance Record Number (if applicable):								
139768	86900	Mezzanine offices	Mezzanine back area behind conference room hidden away		2.0Kg ABE DCP		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
139769	86877	Mezzanine offices	Mezzanine back area behind conference room hidden away		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
139865	86887	Mezzanine loading dock	Switchroom next to haz chem		9.0Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								
139898	86886	Mezzanine generator room	Behind laundry		4.5Kg ABE		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Asset Register - 01.2 Fire Hose Reels - AS1851.2012 A1									
Asset ID	Equipment Number	Building Number	Location	Hose Length	Make	LFP Equipment Number	Date	Service	Pass / Fail
139667	86302	Shopping outdoor north	Adj helicopter pad	36m	Wormald		13/04/2026	Yearly	Pass
Test Readings	Attendance Record Number (if applicable):								

Description Of Work

Perform **ANNUAL** inspection on all **Portable Fire Safety Equipment** at **Shangri-La Hotel - Pierpoint Road Cairns** for the month of **April 2026**.

Comments / Recommendations

Lewie Fire Protection
4 Schmid Street
Garbutt, 4814
Ph: 07 4728 3622
ABN 18 146 907 511

Asset Record - Job No. 98854
Shangri-La Hotel - Pierpoint Road Cairns
Pierpoint Road
Cairns QLD 4870

Inspection Date: 14/04/2026
Contact: Michelle Davis
Phone:

All works above have been routinely serviced and maintained in accordance with AS1851.2012 amendment 1 & AS2293.2 and the information on this data report is true and correct. This record does not infer compliance with all applicable building and fire safety legislation within the relevant jurisdiction.

Technician (Print Name): Thomas Elliott

Technician (Signature):


Licence No.

Customer (Print Name):

Customer (Signature):